

	LIGHTS	TASK LIGHTS	MISC EQUIP	SPACE HEATING	SPACE COOLING	HEAT REJECT	PUMPS & AUX	VENT FANS	REFRIG DISPLAY	HT PUMP SUPPLEM	DOMEST HOT WTR	EXT USAGE	TOTAL
--	--------	-------------	------------	---------------	---------------	-------------	-------------	-----------	----------------	-----------------	----------------	-----------	-------

NONR ELECTRICITY													
#3 KWH	0.	0.	305158.	0.	0.	0.	0.	0.	0.	0.	0.	0.	305158.
EMI ELECTRICITY													
#2 KWH	311047.	5468.	11246.	2101.	201238.	0.	19058.	181710.	0.	0.	768.	1100.	733736.
ELEV ELECTRICITY													
KWH	0.	0.	6264.	0.	0.	0.	0.	0.	0.	0.	0.	0.	6264.
FUEL NATURAL-GAS													
THERM	0.	0.	0.	10323.	0.	0.	61.	0.	0.	0.	6100.	0.	16484.
NONR NATURAL-GAS													
THERM	0.	0.	104.	0.	0.	0.	0.	0.	0.	0.	0.	0.	104.
DHW- NATURAL-GAS													
THERM	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.

TOTAL ELECTRICITY	1045157. KWH	5.844 KWH /SQFT-YR GROSS-AREA	5.844 KWH /SQFT-YR NET-AREA
TOTAL NATURAL-GAS	16588. THERM	0.093 THERM /SQFT-YR GROSS-AREA	0.093 THERM /SQFT-YR NET-AREA

PERCENT OF HOURS ANY SYSTEM ZONE OUTSIDE OF THROTTLING RANGE = 2.71 #14
 PERCENT OF HOURS ANY PLANT LOAD NOT SATISFIED = 0.00
 HOURS ANY ZONE ABOVE COOLING THROTTLING RANGE = 72
 HOURS ANY ZONE BELOW HEATING THROTTLING RANGE = 165

NOTE: ENERGY IS APPORTIONED HOURLY TO ALL END-USE CATEGORIES.

UTILITY-RATE	RESOURCE	METERS	METERED ENERGY UNITS/YR	TOTAL CHARGE (\$)	VIRTUAL RATE (\$/UNIT)	RATE USED ALL YEAR?
REG-ELEC-TARIFF	ELECTRICITY	EM1 ELEV	214158. KWH	61557.	0.2874	YES
UNREG-ELEC-TARIFF	ELECTRICITY	NONR	42048. KWH	9457.	0.2249	YES
REG-GAS-TARIFF	NATURAL-GAS	FUEL DHW-	6324. THERM	7030.	1.1117	YES
UNREG-GAS-TARIFF	NATURAL-GAS	NONR	719. THERM	799.	#1 1.1117	YES
				=====		
				78843.		

ENERGY COST/GROSS BLDG AREA: 1.76
 ENERGY COST/NET BLDG AREA: 1.76

NUMBER OF SPACES 26 EXTERIOR 18 INTERIOR 8

SPACE	SPACE*FLOOR MULTIPLIER	SPACE TYPE	AZIM	LIGHTS (WATT / SQFT)	PEOPLE	EQUIP (WATT / SQFT)	INFILTRATION METHOD	ACH	AREA (SQFT)	VOLUME (CUFT)
Spaces on floor: B-FLOOR										
B-LOCKER-2	1.0	INT	0.0	0.57	4.3	0.00	AIR-CHANGE	0.00	217.5	2175.0
B-MER	1.0	INT	0.0	0.80	18.6	0.00	AIR-CHANGE	0.00	5570.2	55701.8
B-STORAGE	1.0	INT	0.0	0.80	2.9	0.00	AIR-CHANGE	0.00	882.3	8823.2
B-CORR	1.0	INT	0.0	0.63	1.4	0.00	AIR-CHANGE	0.00	1450.0	14500.0
Spaces on floor: 1-FLOOR										
1-CAFE-1	1.0	EXT	0.0	0.65	258.5	0.12	AIR-CHANGE	0.15	2081.3	20813.2
1-KITCHEN	1.0	INT	0.0	0.99	95.6	5.28	AIR-CHANGE	0.10	1649.4	16494.4
1-CORR	1.0	EXT	0.0	0.63	3.9	0.00	AIR-CHANGE	0.15	3920.8	39208.0
1-CLASS-3	1.0	EXT	0.0	0.72	90.3	0.23	AIR-CHANGE	0.15	2076.4	20764.4
1-OFF-1	1.0	EXT	0.0	0.72	12.6	1.12	AIR-CHANGE	0.15	1259.0	12590.4
1-PLENUM	1.0	EXT	0.0	0.00	0.0	0.00	NO-INFILT.	0.00	11200.0	112000.0
Spaces on floor: 2-FLOOR										
2-LIBRARY	1.0	INT	0.0	1.02	9.7	0.50	AIR-CHANGE	0.15	973.6	9735.6
2-CLASS-3	1.0	EXT	0.0	0.72	93.6	0.23	AIR-CHANGE	0.15	2152.1	21520.8
2-OFF-3	1.0	INT	0.0	0.72	9.9	1.12	AIR-CHANGE	0.15	990.6	9906.4
2-CORR	1.0	EXT	0.0	0.63	3.0	0.00	AIR-CHANGE	0.15	2967.4	29674.2
2-CLASS-4	1.0	EXT	0.0	0.72	57.4	0.23	AIR-CHANGE	0.15	1321.3	13212.6
2-CLASS-5	1.0	EXT	0.0	0.72	56.3	0.23	AIR-CHANGE	0.15	1295.6	12956.4
2-CLASS-1	1.0	EXT	0.0	0.72	84.2	0.23	AIR-CHANGE	0.15	1937.4	19373.6
2-PLENUM	1.0	EXT	0.0	0.00	0.0	0.00	NO-INFILT.	0.00	11200.0	112000.0
Spaces on floor: 3-FLOOR										
3-MULTI-PURPOSE	1.0	INT	0.0	1.58	366.6	0.00	AIR-CHANGE	0.15	4032.2	40322.1
3-CORR	1.0	EXT	0.0	0.63	2.9	0.00	AIR-CHANGE	0.15	2911.6	29116.0
3-CLASS-E	1.0	EXT	0.0	0.72	74.9	0.23	AIR-CHANGE	0.15	1722.6	17226.4
3-CLASS-6	1.0	EXT	0.0	0.72	44.5	0.23	AIR-CHANGE	0.15	1022.4	10223.6
3-CLASS-4	1.0	EXT	0.0	0.72	74.3	0.23	AIR-CHANGE	0.15	1709.2	17092.2
3-CLASS-1	1.0	EXT	0.0	0.72	42.9	0.23	AIR-CHANGE	0.15	985.8	9857.6
3-CLASS-2	1.0	EXT	0.0	0.72	72.7	0.23	AIR-CHANGE	0.15	1672.6	16726.2
3-PLENUM	1.0	EXT	0.0	0.00	0.0	0.00	NO-INFILT.	0.00	11200.0	112000.0
BUILDING TOTALS				1481.2				78401.4		784014.2

#1

#2

#3

NUMBER OF EXTERIOR SURFACES 335

(U-VALUE INCLUDES OUTSIDE FILM; WINDOW INCLUDES FRAME AND CURB, IF DEFINED)

SURFACE	- - - W I N D O W S - - -		- - - - W A L L - - - -		- W A L L + W I N D O W S -		AZIMUTH
	U-VALUE (BTU/HR-SQFT-F)	AREA (SQFT)	U-VALUE (BTU/HR-SQFT-F)	AREA (SQFT)	U-VALUE (BTU/HR-SQFT-F)	AREA (SQFT)	
EW-84 in space: 2-RESOURCE-1	0.425	45.21	0.051	97.79	0.169	143.00	NORTH
EW-122 in space: 2-PLENUM	0.000	0.00	0.051	57.20	0.051	57.20	NORTH
EW-3 in space: 1-CAFE-1	0.425	445.63	0.051	934.37	0.172	1380.00	NORTH
EW-5 in space: 1-KIT-STO	0.000	0.00	0.051	201.00	0.051	201.00	NORTH
EW-7 in space: 1-KIT-SUPPORT	0.000	0.00	0.051	312.00	0.051	312.00	NORTH
EW-10 in space: 1-STAIR-2	0.425	6.46	0.051	131.14	0.068	137.60	NORTH
EW-20 in space: 1-AUDI-SUPPORT	0.000	0.00	0.051	130.20	0.051	130.20	NORTH
EW-28 in space: 1-ELEC-1	0.000	0.00	0.051	772.80	0.051	772.80	NORTH
EW-29 in space: 1-ELEC-1	0.000	0.00	0.051	134.40	0.051	134.40	NORTH
EW-32 in space: 1-GYM	0.000	0.00	0.051	1045.80	0.051	1045.80	NORTH
EW-208 in space: 3-PLENUM	0.000	0.00	0.051	54.00	0.051	54.00	EAST
EW-68 in space: 1-PLENUM	0.000	0.00	0.051	7.80	0.051	7.80	EAST
EW-210 in space: 3-PLENUM	0.000	0.00	0.051	52.80	0.051	52.80	EAST
EW-211 in space: 3-PLENUM	0.000	0.00	0.051	160.40	0.051	160.40	EAST
EW-212 in space: 3-PLENUM	0.000	0.00	0.051	44.00	0.051	44.00	EAST
EW-214 in space: 3-PLENUM	0.000	0.00	0.051	36.40	0.051	36.40	EAST
EW-117 in space: 2-PLENUM	0.000	0.00	0.051	43.20	0.051	43.20	EAST
EW-7763 in space: 4-CONF-2	0.425	32.29	0.051	71.71	0.167	104.00	EAST
EW-72	0.000	0.00	0.051	106.80	0.051	106.80	EAST


Base Case

REPORT- LV-D Details of Exterior Surfaces

WEATHER FILE- NEW YORK LAGUARDI NY

						(CONTINUED)	
EW-273	0.000	0.00	0.051	57.20	0.051	57.20	WEST
in space: 4-PLENUM							
EW-9	0.425	45.21	0.051	96.79	0.170	142.00	WEST
in space: 1-CAFE-2							
EW-61	0.000	0.00	0.051	85.20	0.051	85.20	WEST
in space: 1-PLENUM							
ROOF 22	0.000	0.00	0.037	5370.96	0.037	5370.96	ROOF
in space: 1-AUDI-SUPPORT							
ROOF 23	0.000	0.00	0.037	879.78	0.037	879.78	ROOF
in space: 1-AUDI-SUPPORT							
RF-1	0.000	0.00	0.037	3198.72	0.037	3198.72	ROOF
in space: 1-ELEC-1							
ROOF 39	0.000	0.00	0.037	7268.31	0.037	7268.31	ROOF
in space: 1-GYM							
RF-3	0.000	0.00	0.037	2140.60	0.037	2140.60	ROOF
in space: 1-PLENUM							
RF-4	0.000	0.00	0.037	2394.81	0.037	2394.81	ROOF
in space: 1-PLENUM							
RF-5	0.000	0.00	0.037	152.88	0.037	152.88	ROOF
RF-7	0.000	0.00	0.037	11045.52	0.037	11045.52	ROOF
in space: 4-PLENUM							
RF-8	0.000	0.00	0.037	795.00	0.037	795.00	ROOF
in space: 4-PLENUM							
RF-9	0.000	0.00	0.037	9371.01	0.037	9371.01	ROOF
in space: 4-PLENUM							
UF-1	0.000	0.00	0.070	346.79	0.070	346.79	UNDERGRND
in space: 1-SECURITY							
UF-2	0.000	0.00	0.070	775.75	0.070	775.75	UNDERGRND
in space: 1-LIB-SUPPORT							
UF-3	0.000	0.00	0.070	154.09	0.070	154.09	UNDERGRND
in space: 1-AUDIO							
UF-4	0.000	0.00	0.070	710.15	0.070	710.15	UNDERGRND
in space: 1-STAIR-1							
UF-5	0.000	0.00	0.070	435.43	0.070	435.43	UNDERGRND
in space: 1-VEST-1							
UF-6	0.000	0.00	0.070	7991.64	0.070	7991.64	UNDERGRND
in space: 1-CAFE-1							
UF-7	0.000	0.00	0.070	490.81	0.070	490.81	UNDERGRND
in space: 1-STO-2							
UF-8	0.000	0.00	0.070	152.30	0.070	152.30	UNDERGRND
in space: 1-ELEC-2							
UF-9	0.000	0.00	0.070	641.57	0.070	641.57	UNDERGRND
in space: 1-KIT-STO							


	AVERAGE U-VALUE/WINDOWS (BTU/HR-SQFT-F)	AVERAGE U-VALUE/WALLS (BTU/HR-SQFT-F)	AVERAGE U-VALUE WALLS+WINDOWS (BTU/HR-SQFT-F)	WINDOW AREA (SQFT)	WALL AREA (SQFT)	WINDOW+WALL AREA (SQFT)
NORTH	0.425	0.051	0.188	7737.16	13443.74	21180.90
EAST	0.425	0.051	0.175	5437.97	10915.38	16353.35
SOUTH-EAST	0.000	0.051	0.051	0.00	175.20	175.20
SOUTH	0.425	0.051	0.161	6168.42	14840.48	21008.90
SOUTH-WEST	0.000	0.051	0.051	0.00	54.00	54.00
WEST	0.425	0.051	0.139	3829.83	12470.82	16300.65
#2 → ROOF	0.000	0.037	0.037	0.00	64653.50	64653.50
ALL WALLS	0.425	0.051	0.166	23173.39	51899.62	75072.99
WALLS+ROOFS	0.425	0.043	0.106	23173.39	116553.12	139726.48
UNDERGRND	0.000	0.070	0.070	0.00	75333.49	75333.49
BUILDING	0.425	0.054	0.094	23173.39	191886.61	215059.98



#2



#1



NUMBER OF WINDOWS 132

(Note: u-values include outside air film)

#1

WINDOW NAME	MULTIPLIER	GLASS AREA (SQFT)	GLASS HEIGHT (FT)	GLASS WIDTH (FT)	LOCATION OF ORIGIN IN SURFACE COORDINATES		FRAME AREA (SQFT)	CURB	FRAME U-VALUE (BTU/HR-SQFT-F)	CURB
					X (FT)	Y (FT)				
WI-1	1.0	135.63	6.46	21.00	0.00	0.00	0.00	0.00	0.425	0.000
WI-2	1.0	891.26	6.46	138.00	0.00	0.00	0.00	0.00	0.425	0.000
WI-3	1.0	25.83	6.46	4.00	0.00	0.00	0.00	0.00	0.425	0.000
WI-4	1.0	90.42	6.46	14.00	0.00	0.00	0.00	0.00	0.425	0.000
WI-5	1.0	12.92	6.46	2.00	0.00	0.00	0.00	0.00	0.425	0.000
WI-6	1.0	284.17	6.46	44.00	0.00	0.00	0.00	0.00	0.425	0.000
WI-7	1.0	226.04	6.46	35.00	0.00	0.00	0.00	0.00	0.425	0.000
WI-8	1.0	290.63	6.46	45.00	0.00	0.00	0.00	0.00	0.425	0.000
WI-9	1.0	213.13	6.46	33.00	0.00	0.00	0.00	0.00	0.425	0.000
WI-10	1.0	3.23	6.46	0.50	0.00	0.00	0.00	0.00	0.425	0.000
WI-11	1.0	6.46	6.46	1.00	0.00	0.00	0.00	0.00	0.425	0.000
WI-12	1.0	12.92	6.46	2.00	0.00	0.00	0.00	0.00	0.425	0.000
WI-13	1.0	213.13	6.46	33.00	0.00	0.00	0.00	0.00	0.425	0.000
WI-14	1.0	6.46	6.46	1.00	0.00	0.00	0.00	0.00	0.425	0.000
WI-15	1.0	109.79	6.46	17.00	0.00	0.00	0.00	0.00	0.425	0.000
WI-16	1.0	167.92	6.46	26.00	0.00	0.00	0.00	0.00	0.425	0.000
WI-17	1.0	16.79	6.46	2.60	0.00	0.00	0.00	0.00	0.425	0.000
WI-18	1.0	142.08	6.46	22.00	0.00	0.00	0.00	0.00	0.425	0.000
WI-19	1.0	12.92	6.46	2.00	0.00	0.00	0.00	0.00	0.425	0.000
WI-20	1.0	632.92	6.46	98.00	0.00	0.00	0.00	0.00	0.425	0.000
WI-21	1.0	310.00	6.46	48.00	0.00	0.00	0.00	0.00	0.425	0.000
WI-22	1.0	477.92	6.46	74.00	0.00	0.00	0.00	0.00	0.425	0.000
WI-23	1.0	64.58	6.46	10.00	0.00	0.00	0.00	0.00	0.425	0.000
WI-24	1.0	129.17	6.46	20.00	0.00	0.00	0.00	0.00	0.425	0.000
WI-25	1.0	180.84	6.46	28.00	0.00	0.00	0.00	0.00	0.425	0.000
WI-26	1.0	29.06	6.46	4.50	0.00	0.00	0.00	0.00	0.425	0.000
WI-27	1.0	626.46	6.46	97.00	0.00	0.00	0.00	0.00	0.425	0.000
WI-28	1.0	90.42	6.46	14.00	0.00	0.00	0.00	0.00	0.425	0.000
WI-29	1.0	503.76	6.46	78.00	0.00	0.00	0.00	0.00	0.425	0.000
WI-30	1.0	25.83	6.46	4.00	0.00	0.00	0.00	0.00	0.425	0.000
WI-31	1.0	232.50	6.46	36.00	0.00	0.00	0.00	0.00	0.425	0.000
WI-32	1.0	122.71	6.46	19.00	0.00	0.00	0.00	0.00	0.425	0.000
WI-33	1.0	116.25	6.46	18.00	0.00	0.00	0.00	0.00	0.425	0.000
WI-34	1.0	64.58	6.46	10.00	0.00	0.00	0.00	0.00	0.425	0.000
WI-35	1.0	83.96	6.46	13.00	0.00	0.00	0.00	0.00	0.425	0.000
WI-36	1.0	45.21	6.46	7.00	0.00	0.00	0.00	0.00	0.425	0.000
WI-37	1.0	64.58	6.46	10.00	0.00	0.00	0.00	0.00	0.425	0.000
WI-38	1.0	129.17	6.46	20.00	0.00	0.00	0.00	0.00	0.425	0.000
WI-39	1.0	51.67	6.46	8.00	0.00	0.00	0.00	0.00	0.425	0.000
WI-40	1.0	83.96	6.46	13.00	0.00	0.00	0.00	0.00	0.425	0.000
WI-41	1.0	155.00	6.46	24.00	0.00	0.00	0.00	0.00	0.425	0.000
WI-42	1.0	71.04	6.46	11.00	0.00	0.00	0.00	0.00	0.425	0.000
WI-43	1.0	226.04	6.46	35.00	0.00	0.00	0.00	0.00	0.425	0.000
WI-44	1.0	658.76	6.46	102.00	0.00	0.00	0.00	0.00	0.425	0.000
WI-45	1.0	32.29	6.46	5.00	0.00	0.00	0.00	0.00	0.425	0.000
WI-46	1.0	58.13	6.46	9.00	0.00	0.00	0.00	0.00	0.425	0.000
WI-47	1.0	187.29	6.46	29.00	0.00	0.00	0.00	0.00	0.425	0.000
WI-48	1.0	45.21	6.46	7.00	0.00	0.00	0.00	0.00	0.425	0.000
WI-49	1.0	213.13	6.46	33.00	0.00	0.00	0.00	0.00	0.425	0.000

(Note: u-values include outside air film)

WINDOW NAME	MULTIPLIER	GLASS AREA (SQFT)	GLASS HEIGHT (FT)	GLASS WIDTH (FT)	LOCATION OF ORIGIN		FRAME AREA (SQFT)	CURB AREA	FRAME CURB U-VALUE	
					X (FT)	Y (FT)			(BTU/HR-SQFT-F)	(BTU/HR-SQFT-F)
WI-102	1.0	794.38	6.46	123.00	0.00	0.00	0.00	0.00	0.425	0.000
WI-103	1.0	29.06	6.46	4.50	0.00	0.00	0.00	0.00	0.425	0.000
WI-104	1.0	25.83	6.46	4.00	0.00	0.00	0.00	0.00	0.425	0.000
WI-105	1.0	226.04	6.46	35.00	0.00	0.00	0.00	0.00	0.425	0.000
WI-106	1.0	122.71	6.46	19.00	0.00	0.00	0.00	0.00	0.425	0.000
WI-107	1.0	96.88	6.46	15.00	0.00	0.00	0.00	0.00	0.425	0.000
WI-108	1.0	64.58	6.46	10.00	0.00	0.00	0.00	0.00	0.425	0.000
WI-109	1.0	122.71	6.46	19.00	0.00	0.00	0.00	0.00	0.425	0.000
WI-110	1.0	77.50	6.46	12.00	0.00	0.00	0.00	0.00	0.425	0.000
WI-111	1.0	83.96	6.46	13.00	0.00	0.00	0.00	0.00	0.425	0.000
WI-112	1.0	45.21	6.46	7.00	0.00	0.00	0.00	0.00	0.425	0.000
WI-113	1.0	71.04	6.46	11.00	0.00	0.00	0.00	0.00	0.425	0.000
WI-114	1.0	155.00	6.46	24.00	0.00	0.00	0.00	0.00	0.425	0.000
WI-115	1.0	393.96	6.46	61.00	0.00	0.00	0.00	0.00	0.425	0.000
WI-116	1.0	209.90	6.46	32.50	0.00	0.00	0.00	0.00	0.425	0.000
WI-117	1.0	742.72	6.46	115.00	0.00	0.00	0.00	0.00	0.425	0.000
WI-118	1.0	226.04	6.46	35.00	0.00	0.00	0.00	0.00	0.425	0.000
WI-119	1.0	600.63	6.46	93.00	0.00	0.00	0.00	0.00	0.425	0.000
WI-120	1.0	45.21	6.46	7.00	0.00	0.00	0.00	0.00	0.425	0.000
WI-121	1.0	206.67	6.46	32.00	0.00	0.00	0.00	0.00	0.425	0.000
WI-122	1.0	142.08	6.46	22.00	0.00	0.00	0.00	0.00	0.425	0.000
WI-123	1.0	122.71	6.46	19.00	0.00	0.00	0.00	0.00	0.425	0.000
WI-124	1.0	226.04	6.46	35.00	0.00	0.00	0.00	0.00	0.425	0.000
WI-125	1.0	122.71	6.46	19.00	0.00	0.00	0.00	0.00	0.425	0.000
WI-126	1.0	83.96	6.46	13.00	0.00	0.00	0.00	0.00	0.425	0.000
WI-127	1.0	83.96	6.46	13.00	0.00	0.00	0.00	0.00	0.425	0.000
WI-128	1.0	258.34	6.46	40.00	0.00	0.00	0.00	0.00	0.425	0.000
WI-129	1.0	67.81	6.46	10.50	0.00	0.00	0.00	0.00	0.425	0.000
WI-130	1.0	12.92	6.46	2.00	0.00	0.00	0.00	0.00	0.425	0.000
WI-131	1.0	58.13	6.46	9.00	0.00	0.00	0.00	0.00	0.425	0.000
WI-132	1.0	58.13	6.46	9.00	0.00	0.00	0.00	0.00	0.425	0.000

#3

#2

WINDOW NAME	SETBACK (FT)	GLASS SHADING COEFF	NUMBER OF PANES	CENTER-OF-GLASS U-VALUE (BTU/HR-SQFT-F)	GLASS VISIBLE TRANS	GLASS SOLAR TRANS	SURFACE TO ROUGH OPEN AREA RATIO
WI-1	0.25	0.44	1	0.425	0.680	0.878	1.000
WI-2	0.25	0.44	1	0.425	0.680	0.878	1.000
WI-3	0.25	0.44	1	0.425	0.680	0.878	1.000
WI-4	0.25	0.44	1	0.425	0.680	0.878	1.000
WI-5	0.25	0.44	1	0.425	0.680	0.878	1.000
WI-6	0.25	0.44	1	0.425	0.680	0.878	1.000
WI-7	0.25	0.44	1	0.425	0.680	0.878	1.000
WI-8	0.25	0.44	1	0.425	0.680	0.878	1.000
WI-9	0.25	0.44	1	0.425	0.680	0.878	1.000
WI-10	0.25	0.44	1	0.425	0.680	0.878	1.000
WI-11	0.25	0.44	1	0.425	0.680	0.878	1.000
WI-12	0.25	0.44	1	0.425	0.680	0.878	1.000
WI-13	0.25	0.44	1	0.425	0.680	0.878	1.000
WI-14	0.25	0.44	1	0.425	0.680	0.878	1.000
WI-15	0.25	0.44	1	0.425	0.680	0.878	1.000

WINDOW NAME	SETBACK (FT)	GLASS SHADING COEFF	NUMBER OF PANES	CENTER-OF- GLASS U-VALUE (BTU/HR-SQFT-F)	GLASS VISIBLE TRANS	GLASS SOLAR TRANS	SURFACE TO ROUGH OPEN AREA RATIO
WI-124	0.25	0.44	1	0.425	0.680	0.878	1.000
WI-125	0.25	0.44	1	0.425	0.680	0.878	1.000
WI-126	0.25	0.44	1	0.425	0.680	0.878	1.000
WI-127	0.25	0.44	1	0.425	0.680	0.878	1.000
WI-128	0.25	0.44	1	0.425	0.680	0.878	1.000
WI-129	0.25	0.44	1	0.425	0.680	0.878	1.000
WI-130	0.25	0.44	1	0.425	0.680	0.878	1.000
WI-131	0.25	0.44	1	0.425	0.680	0.878	1.000
WI-132	0.25	0.44	1	0.425	0.680	0.878	1.000

NUMBER OF CONSTRUCTIONS 12

#1

DELAYED 9 QUICK 3

#2

#3

CONSTRUCTION NAME	U-VALUE (BTU/HR-SQFT-F)	SURFACE ABSORPTANCE	SURFACE ROUGHNESS INDEX	SURFACE TYPE	NUMBER OF RESPONSE FACTORS
EW-TYP-GB-CON	0.052	0.70	3	DELAYED	34
EW-TYP-NOGB-CON	0.052	0.70	3	DELAYED	34
EW-FL-CON	0.052	0.70	3	DELAYED	34
UW-CON	0.087	0.70	3	DELAYED	15
IW-CON	0.518	0.70	3	DELAYED	6
RF-CON	0.038	0.70	3	DELAYED	15
SLOPED-RF-CON	0.038	0.70	3	DELAYED	15
SLAB-ON-GRADE	0.070	0.70	3	QUICK	0
FL-CON	1.020	0.70	3	DELAYED	4
CL-CON	0.805	0.70	3	DELAYED	4
DR-CON	0.700	0.70	3	QUICK	0
LD-DR-CON	1.500	0.70	3	QUICK	0

Base Case

REPORT- SV-A System Design Parameters for RTU-CR1 WEATHER FILE- NEW YORK LAGUARDI NY

SYSTEM TYPE	ALTITUDE FACTOR	FLOOR AREA (SQFT)	MAX PEOPLE	OUTSIDE AIR RATIO	COOLING CAPACITY (KBTU/HR)	SENSIBLE (SHR)	HEATING CAPACITY (KBTU/HR)	COOLING EIR (BTU/BTU)	HEATING EIR (BTU/BTU)	HEAT PUMP SUPP-HEAT (KBTU/HR)
VAVS	1.000	157413.5	991.	0.296	2123.977	0.568	0.000	0.000	0.000	0.000

FAN TYPE	CAPACITY (CFM)	DIVERSITY FACTOR (FRAC)	POWER DEMAND (KW)	FAN DELTA-T (F)	STATIC PRESSURE (IN-WATER)	TOTAL EFF (FRAC)	MECH EFF (FRAC)	FAN PLACEMENT	FAN CONTROL	MAX FAN RATIO (FRAC)	MIN FAN RATIO (FRAC)
SUPPLY	42579.	1.00	49.975	3.63	6.5	0.65	0.72	DRAW-THRU	BY USER	1.10	0.30
RETURN	42579.	1.00	19.221	1.40	2.5	0.65	0.72	RETURN	BY USER	1.10	0.30

ZONE NAME	SUPPLY FLOW (CFM)	EXHAUST FLOW (CFM)	FAN (KW)	MINIMUM FLOW (FRAC)	OUTSIDE AIR FLOW (CFM)	COOLING CAPACITY (KBTU/HR)	EXTRACTION SENSIBLE (FRAC)	EXTRACTION RATE (KBTU/HR)	HEATING CAPACITY (KBTU/HR)	ADDITION RATE (KBTU/HR)	ZONE MULT
1-CWSE-CLASS-1-ZN	949.	0.	0.000	0.300	268.	0.00	0.00	20.50	-46.12	-34.49	1.
1-CWSE-CLASS-2-ZN	4551.	0.	0.000	0.300	1951.	0.00	0.00	98.29	-17.49 (BASEBOARDS)	-112.29	1.
1-CWSE-CLASS-3-ZN	1230.	0.	0.000	0.300	400.	0.00	0.00	26.58	-17.49 (BASEBOARDS)	-40.57	1.
1-AUDIO-ZN	237.	0.	0.000	0.307	106.	0.00	0.00	5.11	-11.50 (BASEBOARDS)	-19.11	1.
1-LIBRARY-ZN	1947.	0.	0.000	0.300	149.	0.00	0.00	42.05	-17.49 (BASEBOARDS)	-65.84	1.
1-LIB-SUPPORT-ZN	312.	0.	0.000	0.300	94.	0.00	0.00	6.74	-34.99 (BASEBOARDS)	-20.73	1.
1-OFF-1-ZN	392.	0.	0.000	0.300	39.	0.00	0.00	8.48	-17.49 (BASEBOARDS)	-17.81	1.
1-MED-OFF-ZN	920.	0.	0.000	0.300	91.	0.00	0.00	19.87	-19.07 (BASEBOARDS)	-17.81	1.
1-CWSE-ADMIN-ZN	707.	0.	0.000	0.300	70.	0.00	0.00	15.28	-11.66 (BASEBOARDS)	-29.20	1.
1-SECURITY-ZN	268.	0.	0.000	0.300	27.	0.00	0.00	5.79	-34.37 (BASEBOARDS)	-24.61	1.
1-CWSE-STO-ZN	18.	0.	0.000	1.000	18.	0.00	0.00	0.55	-11.66 (BASEBOARDS)	-15.12	1.
1-CORR-ZN	6226.	0.	0.000	0.300	702.	0.00	0.00	134.49	-13.02 (BASEBOARDS)	-5.18	1.
3-CLASS-1-ZN	921.	0.	0.000	0.300	293.	0.00	0.00	19.89	-0.85 (BASEBOARDS)	-5.83	1.
3-CLASS-2-ZN	2268.	0.	0.000	0.300	1378.	0.00	0.00	49.00	-302.59 (BASEBOARDS)	-125.70	1.
3-CLASS-3-ZN	1010.	0.	0.000	0.300	318.	0.00	0.00	21.81	-5.83 (BASEBOARDS)	-33.88	1.
3-CLASS-4-ZN	2174.	0.	0.000	0.300	1249.	0.00	0.00	46.95	-17.49 (BASEBOARDS)	-62.99	1.
3-CLASS-5-ZN	2365.	0.	0.000	0.300	1514.	0.00	0.00	51.08	-17.49 (BASEBOARDS)	-49.08	1.
3-CLASS-6-ZN	3338.	0.	0.000	0.300	1555.	0.00	0.00	72.10	-17.49 (BASEBOARDS)	-35.81	1.
3-SCIENCE-LAB-ZN	1979.	0.	0.000	0.300	1053.	0.00	0.00	42.75	-17.49 (BASEBOARDS)	-17.49	1.
3-COMP-LAB-ZN	752.	0.	0.000	0.300	307.	0.00	0.00	16.23	-96.18 (BASEBOARDS)	-56.74	1.
3-OFF-1-ZN	261.	0.	0.000	0.300	12.	0.00	0.00	5.63	-17.49 (BASEBOARDS)	-30.23	1.
									-12.67 (BASEBOARDS)	-14.96	1.
									-11.66 (BASEBOARDS)		

REPORT- SV-A System Design Parameters for HEAT-ONLY-SYS

WEATHER FILE- NEW YORK LAGUARDI NY

SYSTEM TYPE	ALTITUDE FACTOR	FLOOR AREA (SQFT)	MAX PEOPLE	OUTSIDE AIR RATIO	COOLING CAPACITY (KBTU/HR)	SENSIBLE (SHR)	HEATING CAPACITY (KBTU/HR)	COOLING EIR (BTU/BTU)	HEATING EIR (BTU/BTU)	HEAT PUMP SUPP-HEAT (KBTU/HR)	
PTAC	1.000	7370.8	23.	0.235	0.000	0.000	0.000	0.285	0.000	0.000	
FAN TYPE	CAPACITY (CFM)	DIVERSITY FACTOR (FRAC)	POWER DEMAND (KW)	FAN DELTA-T (F)	STATIC PRESSURE (IN-WATER)	TOTAL EFF (FRAC)	MECH EFF (FRAC)	FAN PLACEMENT	FAN CONTROL	MAX FAN RATIO (FRAC)	MIN FAN RATIO (FRAC)
SUPPLY	2569.	0.00	0.001	1.82	2.0	0.40	0.44	BLOW-THRU	2-SPEED	0.00	0.00
ZONE NAME	SUPPLY FLOW (CFM)	EXHAUST FLOW (CFM)	FAN FLOW (KW)	MINIMUM FLOW (FRAC)	OUTSIDE AIR FLOW (CFM)	COOLING CAPACITY (KBTU/HR)	SENSIBLE (FRAC)	EXTRACTION RATE (KBTU/HR)	HEATING CAPACITY (KBTU/HR)	ADDITION RATE (KBTU/HR)	ZONE MULT
1-EL-MCH-ZN	12.	0.	0.007	1.000	12.	1.13	0.72	0.63	0.00	0.00	1.
1-MER-ZN	28.	0.	0.016	1.000	28.	2.58	0.72	1.43	0.00	-9.33	1.
1-MER-1-ZN	15.	0.	0.009	1.000	15.	1.41	0.72	0.78	0.00	0.00	1.
1-ELEC-1-ZN	113.	0.	0.066	1.000	113.	10.59	0.72	5.86	0.00	-9.33	1.
1-ELEC-2-ZN	10.	0.	0.006	1.000	9.	0.93	0.68	0.52	0.00	-9.33	1.
1-VEST-1-ZN	435.	0.	0.256	1.000	26.	33.03	0.43	22.57	0.00	-14.00	1.
1-VEST-2-ZN	137.	0.	0.080	1.000	8.	10.10	0.44	7.10	0.00	-14.00	1.
1-STO-1-ZN	717.	0.	0.421	1.000	155.	55.10	0.44	33.69	0.00	-9.33	1.
1-STO-2-ZN	245.	0.	0.144	1.000	53.	18.86	0.44	11.53	0.00	0.00	1.
1-STO-3-ZN	242.	0.	0.142	1.000	52.	18.59	0.44	11.37	0.00	0.00	1.
3-STO-1-ZN	199.	0.	0.117	1.000	43.	15.31	0.44	9.36	0.00	0.00	1.
4-STO-1-ZN	199.	0.	0.117	1.000	43.	15.31	0.44	9.36	0.00	0.00	1.
1-TRASH-ZN	216.	0.	0.126	1.000	47.	16.56	0.44	10.13	0.00	-9.33	1.
1-ELEV-SHAFT-ZN	0.	0.	0.000	0.000	0.	0.00	0.00	0.00	0.00	0.00	1.

#3

#2

#1

#4

#5

*** CIRCULATION LOOPS ***

HEATING CAPACITY (MBTU/HR)	COOLING CAPACITY (MBTU/HR)	LOOP FLOW (GAL/MIN)	TOTAL HEAD (FT)	SUPPLY UA PRODUCT (BTU/HR-F)	SUPPLY LOSS DT (F)	RETURN UA PRODUCT (BTU/HR-F)	RETURN LOSS DT (F)	LOOP VOLUME (GAL)	FLUID HEAT CAPACITY (BTU/LB-F)
PLANT-HW-LOOP-PRIM -8.922	0.000	447.2	36.6	0.0	0.00	0.0	0.00	670.8	1.00
DW-LOOP -0.154	0.000	3.8	6.4	0.0	0.00	0.0	0.00	5.7	1.00
CHW-LOOP 0.000	6.566	1075.3	41.6	0.0	0.00	0.0	0.00	1612.9	1.00

*** PUMPS ***

ATTACHED TO	FLOW (GAL/MIN)	HEAD (FT)	HEAD SETPOINT (FT)	CAPACITY CONTROL	POWER (KW)	MECHANICAL EFFICIENCY (FRAC)	MOTOR EFFICIENCY (FRAC)
HW-PUMP-PRIM PLANT-HW-LOOP-PRIM PRIMARY LOOP	2 PUMP(s) 447.2	150.0	0.0	VFD&STAGED	19.639	0.715	0.900
DHW-REPUMPS DW-LOOP PRIMARY LOOP	1 PUMP(s) 25.0	28.0	0.0	VAR-SPEED	0.301	0.625	0.700
CHW-PUMP CHW-LOOP PRIMARY LOOP	1 PUMP(s) 1075.3	139.0	0.0	VAR-SPEED	35.390	0.884	0.900

*** PRIMARY EQUIPMENT ***

EQUIPMENT TYPE	ATTACHED TO	RATED CAPACITY (MBTU/HR)	FLOW (GAL/MIN)	RATED EIR (FRAC)	RATED HIR (FRAC)	AUXILIARY (KW)
BLR-1 HW-CONDENSING	PLANT-HW-LOOP-PRIM	-2.230	111.8	0.003	1.093	0.500
BLR-2 HW-CONDENSING	PLANT-HW-LOOP-PRIM	-2.230	111.8	0.003	1.093	0.500
Chiller1 ELEC-OPEN-REC	CHW-LOOP	6.706	1093.4	0.370	0.000	0.000

*** DW-HEATERS ***

EQUIPMENT TYPE	ATTACHED TO	CAPACITY (MBTU/HR)	FLOW (GAL/MIN)	EIR (FRAC)	HIR (FRAC)	AUXILIARY (KW)	TANK (GAL)	TANK UA (BTU/HR-F)
DHW-1 GAS DW-HEATER	DW-LOOP	-0.102	2.5	0.000	1.220	0.000	120.0	6.18

GSHP-H&C-DHW								
ELEC DW-HEATER	DW-LOOP	-1.357	33.7	0.001	0.000	0.000	1900.0	190.00
GSHP-C-DHW								
ELEC DW-HEATER	DW-LOOP	-1.373	34.1	0.001	0.000	0.000	1950.0	195.00

	LIGHTS	TASK LIGHTS	MISC EQUIP	SPACE HEATING	SPACE COOLING	HEAT REJECT	PUMPS & AUX	VENT FANS	REFRIG DISPLAY	HT PUMP SUPPLEM	DOMEST HOT WTR	EXT USAGE	TOTAL
--	--------	-------------	------------	---------------	---------------	-------------	-------------	-----------	----------------	-----------------	----------------	-----------	-------

JAN													
KWH	26825.	445.	27318.	471.	556.	0.	1192.	13171.	0.	0.	67.	103.	70146.
MAX KW	112.589	1.837	77.774	3.885	25.596	0.000	8.729	68.526	0.000	0.000	0.092	0.251	264.941
DAY/HR	9/ 9	3/ 9	3/ 9	3/ 8	3/ 7	0/ 0	23/10	3/ 8	0/ 0	0/ 0	22/ 7	1/ 1	9/ 9
PEAK ENDUSE	112.589	1.837	77.774	3.058	0.000	0.000	8.382	61.210	0.000	0.000	0.090	0.000	
PEAK PCT	42.5	0.7	29.4	1.2	0.0	0.0	3.2	23.1	0.0	0.0	0.0	0.0	
FEB													
KWH	24834.	417.	24964.	456.	528.	0.	1155.	12414.	0.	0.	60.	86.	64915.
MAX KW	108.126	1.837	77.774	4.582	19.102	0.000	10.035	83.976	0.000	0.000	0.092	0.251	265.409
DAY/HR	28/ 9	1/ 9	1/ 9	6/ 8	16/ 7	0/ 0	6/ 9	6/ 8	0/ 0	0/ 0	6/ 2	1/ 1	6/ 9
PEAK ENDUSE	100.440	1.837	77.774	4.537	0.000	0.000	10.035	70.694	0.000	0.000	0.092	0.000	
PEAK PCT	37.8	0.7	29.3	1.7	0.0	0.0	3.8	26.6	0.0	0.0	0.0	0.0	
MAR													
KWH	29264.	492.	28248.	341.	1570.	0.	1132.	13687.	0.	0.	66.	93.	74893.
MAX KW	112.007	1.837	77.774	2.366	33.938	0.000	8.135	53.548	0.000	0.000	0.091	0.251	261.653
DAY/HR	17/ 9	1/ 9	1/ 9	6/ 8	15/15	0/ 0	13/ 8	6/ 9	0/ 0	0/ 0	10/ 5	1/ 1	16/14
PEAK ENDUSE	99.456	1.837	75.774	0.499	27.960	0.000	5.394	50.644	0.000	0.000	0.088	0.000	
PEAK PCT	38.0	0.7	29.0	0.2	10.7	0.0	2.1	19.4	0.0	0.0	0.0	0.0	
APR													
KWH	25934.	441.	26634.	160.	4882.	0.	1078.	12473.	0.	0.	63.	90.	71757.
MAX KW	106.655	1.837	77.774	1.801	117.014	0.000	10.494	54.204	0.000	0.000	0.090	0.251	353.087
DAY/HR	13/ 9	3/ 9	3/ 9	4/ 9	27/14	0/ 0	28/12	28/14	0/ 0	0/ 0	8/ 6	1/ 2	27/14
PEAK ENDUSE	99.376	1.837	75.774	0.000	117.014	0.000	5.349	53.651	0.000	0.000	0.086	0.000	
PEAK PCT	28.1	0.5	21.5	0.0	33.1	0.0	1.5	15.2	0.0	0.0	0.0	0.0	
MAY													
KWH	27930.	476.	27938.	44.	16396.	0.	1762.	14960.	0.	0.	65.	87.	89658.
MAX KW	105.041	1.837	77.774	1.167	252.833	0.000	17.123	76.111	0.000	0.000	0.089	0.251	503.749
DAY/HR	8/ 9	1/ 9	1/ 9	2/ 8	23/14	0/ 0	16/14	16/14	0/ 0	0/ 0	2/ 7	1/ 2	25/14
PEAK ENDUSE	99.323	1.837	75.774	0.000	244.672	0.000	8.474	73.583	0.000	0.000	0.085	0.000	
PEAK PCT	19.7	0.4	15.0	0.0	48.6	0.0	1.7	14.6	0.0	0.0	0.0	0.0	
JUN													
KWH	25108.	472.	26514.	0.	31549.	0.	2354.	17723.	0.	0.	62.	77.	103859.
MAX KW	105.387	1.837	77.774	0.000	356.585	0.000	17.509	95.348	0.000	0.000	0.088	0.251	626.179
DAY/HR	14/ 9	1/ 9	1/ 9	0/ 0	9/14	0/ 0	22/12	19/13	0/ 0	0/ 0	6/ 8	1/ 2	9/14
PEAK ENDUSE	99.341	1.837	74.774	0.000	356.585	0.000	10.204	83.353	0.000	0.000	0.085	0.000	
PEAK PCT	15.9	0.3	11.9	0.0	56.9	0.0	1.6	13.3	0.0	0.0	0.0	0.0	
JUL													
KWH	21320.	445.	26225.	0.	53569.	0.	2014.	19719.	0.	0.	64.	84.	123441.
MAX KW	103.771	1.837	76.274	0.000	433.827	0.000	17.509	107.753	0.000	0.000	0.087	0.251	710.619
DAY/HR	18/10	3/ 9	3/ 9	0/ 0	13/14	0/ 0	18/12	10/12	0/ 0	0/ 0	11/ 6	1/ 2	13/14
PEAK ENDUSE	94.383	1.837	74.774	0.000	433.827	0.000	10.877	94.836	0.000	0.000	0.084	0.000	
PEAK PCT	13.3	0.3	10.5	0.0	61.0	0.0	1.5	13.3	0.0	0.0	0.0	0.0	
AUG													
KWH	23463.	492.	26994.	0.	48432.	0.	2300.	20803.	0.	0.	64.	92.	122639.
MAX KW	102.411	1.837	76.274	0.000	399.155	0.000	17.509	103.475	0.000	0.000	0.087	0.251	683.108
DAY/HR	14/10	1/ 9	1/ 9	0/ 0	25/14	0/ 0	17/14	28/14	0/ 0	0/ 0	19/ 6	1/ 2	25/14
PEAK ENDUSE	94.326	1.837	74.774	0.000	399.155	0.000	11.385	101.546	0.000	0.000	0.084	0.000	
PEAK PCT	13.8	0.3	10.9	0.0	58.4	0.0	1.7	14.9	0.0	0.0	0.0	0.0	

#3

#2

#4

#5

#1

#1

REPORT- PS-E Energy End-Use Summary for all Electric Meters

WEATHER FILE- NEW YORK LAGUARDI NY

----- (CONTINUED) -----

SEP

KWH	25460.	441.	26370.	0.	26567.	0.	2553.	17393.	0.	0.	62.	90.	98937.
MAX KW	108.633	1.837	77.774	0.000	246.360	0.000	17.509	97.470	0.000	0.000	0.088	0.251	517.871
DAY/HR	14/ 9	1/ 9	21/ 9	0/ 0	13/14	0/ 0	5/12	11/14	0/ 0	0/ 0	30/24	1/ 2	13/14
PEAK ENDUSE	99.418	1.837	74.774	0.000	246.360	0.000	9.429	85.967	0.000	0.000	0.085	0.000	
PEAK PCT	19.2	0.4	14.4	0.0	47.6	0.0	1.8	16.6	0.0	0.0	0.0	0.0	

OCT

KWH	27430.	461.	27625.	86.	13138.	0.	1441.	14040.	0.	0.	65.	93.	84379.
MAX KW	112.007	1.837	77.774	1.431	155.387	0.000	13.417	57.503	0.000	0.000	0.089	0.251	395.232
DAY/HR	6/ 9	2/ 9	2/ 9	31/ 9	5/14	0/ 0	12/11	24/14	0/ 0	0/ 0	28/ 6	1/ 2	5/14
PEAK ENDUSE	99.428	1.837	75.774	0.000	155.387	0.000	6.056	56.665	0.000	0.000	0.086	0.000	
PEAK PCT	25.2	0.5	19.2	0.0	39.3	0.0	1.5	14.3	0.0	0.0	0.0	0.0	

NOV

KWH	26546.	441.	26639.	164.	3502.	0.	1047.	12407.	0.	0.	63.	96.	70906.
MAX KW	113.172	1.837	77.774	2.300	56.134	0.000	7.115	52.875	0.000	0.000	0.090	0.251	292.420
DAY/HR	1/ 9	1/ 9	1/ 9	27/ 8	9/12	0/ 0	27/ 9	7/14	0/ 0	0/ 0	24/ 2	1/ 2	9/14
PEAK ENDUSE	101.153	1.837	75.774	0.000	55.553	0.000	6.268	51.749	0.000	0.000	0.087	0.000	
PEAK PCT	34.6	0.6	25.9	0.0	19.0	0.0	2.1	17.7	0.0	0.0	0.0	0.0	

DEC

KWH	26933.	445.	27198.	379.	550.	0.	1031.	12919.	0.	0.	66.	107.	69628.
MAX KW	114.341	1.837	77.774	2.548	19.956	0.000	7.993	53.635	0.000	0.000	0.091	0.251	253.147
DAY/HR	11/ 9	1/ 9	1/ 9	4/ 8	1/ 8	0/ 0	7/ 8	4/ 9	0/ 0	0/ 0	3/ 7	1/ 1	11/ 9
PEAK ENDUSE	114.341	1.837	77.774	1.974	0.000	0.000	5.808	51.326	0.000	0.000	0.088	0.000	
PEAK PCT	45.2	0.7	30.7	0.8	0.0	0.0	2.3	20.3	0.0	0.0	0.0	0.0	

=====

KWH	311047.	5468.	322667.	2101.	201238.	0.	19058.	181710.	0.	0.	768.	1100.	1045157.
MAX KW	114.341	1.837	77.774	4.582	433.827	0.000	17.509	107.753	0.000	0.000	0.092	0.251	710.619
MON/DY	12/11	1/ 3	1/ 3	2/ 6	7/13	0/ 0	6/22	7/10	0/ 0	0/ 0	2/ 6	1/ 1	7/13
PEAK ENDUSE	94.383	1.837	74.774	0.000	433.827	0.000	10.877	94.836	0.000	0.000	0.084	0.000	
PEAK PCT	13.3	0.3	10.5	0.0	61.0	0.0	1.5	13.3	0.0	0.0	0.0	0.0	

	LIGHTS	TASK LIGHTS	MISC EQUIP	SPACE HEATING	SPACE COOLING	HEAT REJECT	PUMPS & AUX	VENT FANS	REFRIG DISPLAY	HT PUMP SUPPLEM	DOMEST HOT WTR	EXT USAGE	TOTAL
JAN													
MBTU	0.	0.	1.	279.	0.	0.	1.	0.	0.	0.	60.	0.	341.
MAX MBTU/HR	0.0	0.0	0.0	4.7	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.0	4.9
DAY/HR	0/ 0	0/ 0	1/ 1	3/ 8	0/ 0	0/ 0	1/ 1	0/ 0	0/ 0	0/ 0	1/12	0/ 0	3/ 8
PEAK ENDUSE	0.0	0.0	0.0	4.7	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.0	
PEAK PCT	0.0	0.0	0.0	97.4	0.0	0.0	0.0	0.0	0.0	0.0	2.6	0.0	
FEB													
MBTU	0.	0.	1.	283.	0.	0.	1.	0.	0.	0.	58.	0.	342.
MAX MBTU/HR	0.0	0.0	0.0	5.2	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.0	5.4
DAY/HR	0/ 0	0/ 0	4/ 1	6/ 8	0/ 0	0/ 0	1/ 1	0/ 0	0/ 0	0/ 0	1/ 8	0/ 0	6/ 8
PEAK ENDUSE	0.0	0.0	0.0	5.2	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.0	
PEAK PCT	0.0	0.0	0.0	97.6	0.0	0.0	0.0	0.0	0.0	0.0	2.3	0.0	
MAR													
MBTU	0.	0.	1.	136.	0.	0.	1.	0.	0.	0.	64.	0.	202.
MAX MBTU/HR	0.0	0.0	0.0	2.9	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.0	3.0
DAY/HR	0/ 0	0/ 0	4/ 1	6/ 8	0/ 0	0/ 0	1/ 1	0/ 0	0/ 0	0/ 0	1/ 8	0/ 0	6/ 8
PEAK ENDUSE	0.0	0.0	0.0	2.9	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.0	
PEAK PCT	0.0	0.0	0.0	95.8	0.0	0.0	0.1	0.0	0.0	0.0	4.1	0.0	
APR													
MBTU	0.	0.	1.	46.	0.	0.	1.	0.	0.	0.	60.	0.	107.
MAX MBTU/HR	0.0	0.0	0.0	0.8	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.0	0.9
DAY/HR	0/ 0	0/ 0	1/ 2	4/ 9	0/ 0	0/ 0	1/ 2	0/ 0	0/ 0	0/ 0	1/ 8	0/ 0	4/ 9
PEAK ENDUSE	0.0	0.0	0.0	0.8	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.0	
PEAK PCT	0.0	0.0	0.2	87.4	0.0	0.0	0.0	0.0	0.0	0.0	12.5	0.0	
MAY													
MBTU	0.	0.	1.	12.	0.	0.	0.	0.	0.	0.	56.	0.	69.
MAX MBTU/HR	0.0	0.0	0.0	0.3	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.0	0.4
DAY/HR	0/ 0	0/ 0	5/ 1	2/ 8	0/ 0	0/ 0	1/ 2	0/ 0	0/ 0	0/ 0	1/12	0/ 0	2/ 8
PEAK ENDUSE	0.0	0.0	0.0	0.3	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.0	
PEAK PCT	0.0	0.0	0.3	73.4	0.0	0.0	0.0	0.0	0.0	0.0	26.3	0.0	
JUN													
MBTU	0.	0.	1.	0.	0.	0.	0.	0.	0.	0.	47.	0.	48.
MAX MBTU/HR	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.0	0.1
DAY/HR	0/ 0	0/ 0	2/ 1	0/ 0	0/ 0	0/ 0	1/ 4	0/ 0	0/ 0	0/ 0	1/13	0/ 0	3/13
PEAK ENDUSE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.0	
PEAK PCT	0.0	0.0	1.9	0.0	0.0	0.0	0.0	0.0	0.0	0.0	98.1	0.0	
JUL													
MBTU	0.	0.	1.	0.	0.	0.	0.	0.	0.	0.	43.	0.	44.
MAX MBTU/HR	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.0	0.1
DAY/HR	0/ 0	0/ 0	1/ 2	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0	15/13	0/ 0	15/13
PEAK ENDUSE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.0	
PEAK PCT	0.0	0.0	2.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	97.9	0.0	
AUG													
MBTU	0.	0.	1.	0.	0.	0.	0.	0.	0.	0.	40.	0.	41.
MAX MBTU/HR	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.0	0.1
DAY/HR	0/ 0	0/ 0	4/ 1	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0	0/ 0	19/13	0/ 0	19/13
PEAK ENDUSE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.0	
PEAK PCT	0.0	0.0	2.3	0.0	0.0	0.0	0.0	0.0	0.0	0.0	97.7	0.0	

REPORT- PS-E Energy End-Use Summary for all Fuel Meters

WEATHER FILE- NEW YORK LAGUARDI NY

(CONTINUED)

SEP													
MBTU	0.	0.	1.	0.	0.	0.	0.	0.	0.	0.	38.	0.	39.
MAX MBTU/HR	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.0	0.1
DAY/HR	0/ 0	0/ 0	1/ 1	0/ 0	0/ 0	0/ 0	29/ 7	0/ 0	0/ 0	0/ 0	30/13	0/ 0	30/13
PEAK ENDUSE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.0	0.0
PEAK PCT	0.0	0.0	2.3	0.0	0.0	0.0	1.5	0.0	0.0	0.0	96.2	0.0	0.0
OCT													
MBTU	0.	0.	1.	24.	0.	0.	0.	0.	0.	0.	42.	0.	67.
MAX MBTU/HR	0.0	0.0	0.0	0.4	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.0	0.5
DAY/HR	0/ 0	0/ 0	1/ 2	31/ 9	0/ 0	0/ 0	1/ 2	0/ 0	0/ 0	0/ 0	28/13	0/ 0	31/ 9
PEAK ENDUSE	0.0	0.0	0.0	0.4	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.0	0.0
PEAK PCT	0.0	0.0	0.3	84.8	0.0	0.0	0.0	0.0	0.0	0.0	14.9	0.0	0.0
NOV													
MBTU	0.	0.	1.	59.	0.	0.	1.	0.	0.	0.	46.	0.	107.
MAX MBTU/HR	0.0	0.0	0.0	2.8	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.0	2.9
DAY/HR	0/ 0	0/ 0	3/ 1	27/ 8	0/ 0	0/ 0	1/ 6	0/ 0	0/ 0	0/ 0	27/13	0/ 0	27/ 8
PEAK ENDUSE	0.0	0.0	0.0	2.8	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.0	0.0
PEAK PCT	0.0	0.0	0.0	96.5	0.0	0.0	0.1	0.0	0.0	0.0	3.4	0.0	0.0
DEC													
MBTU	0.	0.	1.	194.	0.	0.	1.	0.	0.	0.	54.	0.	251.
MAX MBTU/HR	0.0	0.0	0.0	3.2	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.0	3.4
DAY/HR	0/ 0	0/ 0	2/ 1	4/ 8	0/ 0	0/ 0	1/ 1	0/ 0	0/ 0	0/ 0	1/12	0/ 0	4/ 8
PEAK ENDUSE	0.0	0.0	0.0	3.2	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.0	0.0
PEAK PCT	0.0	0.0	0.0	96.6	0.0	0.0	0.0	0.0	0.0	0.0	3.3	0.0	0.0
=====	=====	=====	=====	=====	=====	=====	=====	=====	=====	=====	=====	=====	=====
MBTU	0.	0.	10.	1032.	0.	0.	6.	0.	0.	0.	610.	0.	1659.
MAX MBTU/HR	0.0	0.0	0.0	5.2	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.0	5.4
MON/DY	0/ 0	0/ 0	1/ 1	2/ 6	0/ 0	0/ 0	1/ 1	0/ 0	0/ 0	0/ 0	1/ 1	0/ 0	2/ 6
PEAK ENDUSE	0.0	0.0	0.0	5.2	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.0	0.0
PEAK PCT	0.0	0.0	0.0	97.6	0.0	0.0	0.0	0.0	0.0	0.0	2.3	0.0	0.0