DOMESTIC HOT WATER, ALTERNATIVE ENERGY STUDY

NYC SCHOOL CONSTRUCTION AUTHORITY



OLA PROJECT NO.: NSCA1002.01

May 7, 2021



TABLE OF CONTENTS

1.0	Executive Summary	3
2.0	Existing Schools: Conditions and Typical Operation	5
2.1	School A Domestic Hot Water Sub-Meter Analysis and Survey	5
2.2	School B Domestic Hot Water Sub-Meter Analysis and Survey	7
2.3	School C Domestic Hot Water Sub-Meter Analysis and Survey	8
2.4	School D Domestic Hot Water Sub-Meter Analysis and Survey	. 10
3.0	Metering Domestic Hot Water Daily Consumption	. 11
3.1	Metering Approach	. 11
3.2	Metering Results	. 11
3.2.1	School A Metering Results	. 11
3.2.2	School B Metering Results	. 12
3.2.3	School C Metering Results	. 12
3.2.4	Summary of Domestic Hot Water Metering Results	. 12
4.0	Domestic Hot Water Alternatives	. 13
4.1	Summary of Domestic Hot Water Alternatives Considered	. 13
4.1.1	Option 1: Solar Photovoltaic System with Electric Heat Pump	. 13
4.1.2	Option 2: Solar Thermal System with Electric Heat Pump Backup	. 18
4.1.3	Option 3: Solar Thermal System with Gas-Fired Backup	20
4.1.4	Option 4: Hybrid Solar Thermal and PV System with Electric Heat Pump Backup	20
4.1.5	Option 5: Point of Use Electric	. 21
4.2	School A Domestic Hot Water Alternatives	. 22
4.2.1	Option 1: Solar Photovoltaic System with Electric Heat Pump	. 22
4.2.2	Option 2 or 3: Thermal DHW Closed Loop Drainback System with Gas Fired or Electric Heat Pump Auxiliary heat.	c . 23
4.2.3	Option 4: Hybrid Solar Thermal and PV System with Electric Heat Pump Backup	. 24
4.3	School B Domestic Hot Water Alternatives	.24
4.3.1	Option 1: Solar Photovoltaic System with Electric Heat Pump Backup	. 24
4.3.2		
	Option 2 or 3: Thermal DHW Closed Loop Glycol System with Gas Fired Backup	. 25
4.3.3	Option 2 or 3: Thermal DHW Closed Loop Glycol System with Gas Fired Backup Option 4: Hybrid Solar Thermal and PV System with Electric Heat Pump Backup	. 25 . 25
4.3.3 4.4	Option 2 or 3: Thermal DHW Closed Loop Glycol System with Gas Fired Backup Option 4: Hybrid Solar Thermal and PV System with Electric Heat Pump Backup School C Domestic Hot Water Alternatives	25 25 26
4.3.3 4.4 4.4.1	Option 2 or 3: Thermal DHW Closed Loop Glycol System with Gas Fired Backup Option 4: Hybrid Solar Thermal and PV System with Electric Heat Pump Backup School C Domestic Hot Water Alternatives Option 1: Solar Photovoltaic System with Electric Heat Pump Backup	25 25 26 26
4.3.3 4.4 4.4.1 4.4.2	Option 2 or 3: Thermal DHW Closed Loop Glycol System with Gas Fired Backup Option 4: Hybrid Solar Thermal and PV System with Electric Heat Pump Backup School C Domestic Hot Water Alternatives Option 1: Solar Photovoltaic System with Electric Heat Pump Backup Option 2 or 3: Thermal DHW Closed Loop Drainback System with Gas Fired Backup	. 25 . 25 . 26 . 26 . 27
 4.3.3 4.4 4.4.1 4.4.2 4.4.3 	Option 2 or 3: Thermal DHW Closed Loop Glycol System with Gas Fired Backup Option 4: Hybrid Solar Thermal and PV System with Electric Heat Pump Backup School C Domestic Hot Water Alternatives Option 1: Solar Photovoltaic System with Electric Heat Pump Backup Option 2 or 3: Thermal DHW Closed Loop Drainback System with Gas Fired Backup Option 4: Hybrid Solar Thermal and PV System with Electric Heat Pump Backup	. 25 . 25 . 26 . 26 . 27 . 27
 4.3.3 4.4 4.4.1 4.4.2 4.4.3 5.0 	Option 2 or 3: Thermal DHW Closed Loop Glycol System with Gas Fired Backup Option 4: Hybrid Solar Thermal and PV System with Electric Heat Pump Backup School C Domestic Hot Water Alternatives Option 1: Solar Photovoltaic System with Electric Heat Pump Backup Option 2 or 3: Thermal DHW Closed Loop Drainback System with Gas Fired Backup Option 4: Hybrid Solar Thermal and PV System with Electric Heat Pump Backup Results	25 25 26 26 27 27 27
 4.3.3 4.4 4.4.1 4.4.2 4.4.3 5.0 6.0 	Option 2 or 3: Thermal DHW Closed Loop Glycol System with Gas Fired Backup Option 4: Hybrid Solar Thermal and PV System with Electric Heat Pump Backup School C Domestic Hot Water Alternatives Option 1: Solar Photovoltaic System with Electric Heat Pump Backup Option 2 or 3: Thermal DHW Closed Loop Drainback System with Gas Fired Backup Option 4: Hybrid Solar Thermal and PV System with Electric Heat Pump Backup Results Specific Recommendations for Example Schools	25 25 26 26 27 27 27 29 31
4.3.3 4.4 4.4.1 4.4.2 4.4.3 5.0 6.0 6.1	Option 2 or 3: Thermal DHW Closed Loop Glycol System with Gas Fired Backup Option 4: Hybrid Solar Thermal and PV System with Electric Heat Pump Backup School C Domestic Hot Water Alternatives Option 1: Solar Photovoltaic System with Electric Heat Pump Backup Option 2 or 3: Thermal DHW Closed Loop Drainback System with Gas Fired Backup Option 4: Hybrid Solar Thermal and PV System with Electric Heat Pump Backup Results Specific Recommendations for Example Schools School A	25 25 26 26 27 27 27 29 31 31
4.3.3 4.4 4.4.1 4.4.2 4.4.3 5.0 6.0 6.1 6.2	Option 2 or 3: Thermal DHW Closed Loop Glycol System with Gas Fired Backup Option 4: Hybrid Solar Thermal and PV System with Electric Heat Pump Backup School C Domestic Hot Water Alternatives Option 1: Solar Photovoltaic System with Electric Heat Pump Backup Option 2 or 3: Thermal DHW Closed Loop Drainback System with Gas Fired Backup Option 4: Hybrid Solar Thermal and PV System with Electric Heat Pump Backup Results Specific Recommendations for Example Schools School A School B	. 25 . 25 . 26 . 26 . 27 . 27 . 27 . 29 . 31 . 31 . 31

 6.5 Sample Design School #2	6.4	Sample Design School #1	32
7.0 Appendices	6.5	Sample Design School #2	32
Appendix A: Metering Data Appendix B: PV analysis Appendix C: Solar Thermal Analysis Appendix D: Equipment Cutsheets Appendix E: <i>Deleted</i> Appendix F: Energy Calculations	7.0	Appendices	33
Annondiv C: Schematia Diagrama and Skatahaa	Appendi Appendi Appendi Appendi Appendi	ix A: Metering Data ix B: PV analysis ix C: Solar Thermal Analysis ix D: Equipment Cutsheets ix E: <i>Deleted</i> ix F: Energy Calculations	

Appendix G: Schematic Diagrams and Sketches Appendix H: Sample Design School #1 DHW Schematic Diagrams Appendix I: Sample Design School #2 Floor Plan and Schematic Diagram

1.0 Executive Summary

OLA Consulting Engineers (OLA) was tasked with providing an alternative energy domestic hot water (DHW) study for the New York City School Construction Authority (SCA). The intent of this study is to determine the feasibility of removing the use of fossil fuels from DHW systems while considering maintenance and operational requirements.

Often domestic hot water systems are considered to be oversized. Conventions and code process establishes sizing methods that appear to far exceed consumption in schools given today's programming and usage. To better understand the actual domestic hot water consumption, four schools were visited and a water meter was installed on the domestic hot water piping to obtain an estimated daily consumption profile for each school. The approach for metering is found in the study and as suspected, the consumption was far less than the existing design anticipated. Although this testing was a sample of the types of schools, it informed the economics of the options considered. The metering data was utilized to generate a domestic hot water load profile and to determine a base daily consumption for each school. The meter was installed in four (4) NYC Public Schools with each school varying in size, number of occupants, and function (elementary vs. high school).

After initial review of options for an alternative energy domestic hot water system with the SCA, five (5) systems were selected to be further developed for study. The options are described as follows:

- Option 1: Solar Photovoltaic (PV) with electric heat pump (all electric)
- Option 2: Solar Thermal DHW with electric heat pump backup (auxiliary heat)
- Option 3: Solar Thermal DHW with gas fired backup (auxiliary heat)
- Option 4: Combination of Solar Thermal and Solar PV, with electric heat pump
- Option 5: Point of Use electric DHW

This study found that Option 1 appears to have the least first cost in most cases to get to a 100% renewable domestic hot water system. Note that these systems will be renewable in the sense that the local installed PV arrays offset the net energy consumed by the heat pumps. This approach eliminates the fossil fuel use for DHW onsite. Energy cost savings may or may not actually be realized with this option depending on the specific demand profile and demand rates at a particular school. Some control optimization to mitigate demand impacts would be needed for this and the other options.

Option 2 and 3 were explored extensively during this study, and it was found that the solar thermal systems are not able to cost effectively provide a 100% renewable solution. They can be effective at providing about 55% renewable DHW, and still generate some energy cost savings and avoided fossil fuel use onsite.

Option 4 combines the best features of both Option 1 and Option 2. By using the solar thermal installation, onsite fossil fuel use for DHW can be removed, while the electric auxiliary heat pump usage is minimized and offset by the PV system. This system can be said to be 100% renewable, again in a virtual sense due to the nature of the PV system. This option has the drawback of multiple technologies (i.e. thermal and PV along with backup electric) which can increase first costs and complicate maintenance and operations.

Option 5 was found to have some advantages and disadvantages. The primary advantage of the point-of-use system is that it eliminates the system losses associated with recirculating hot water systems and reduces energy consumption compared to the gas fired baseline or existing systems. The disadvantages are increased operational cost due to heavy electric demand increase, increase to electrical service, and energy performance

not as high performing as the heat pump options. In addition, in order to be considered 100% renewable as Option 1 and 4 were, the PV system provided would have to be 3 times larger. Option 5 therefore would be expected to be the most expensive system to install.

This study includes more details of the investigated options for alternative energy domestic hot water to be implemented at NYC Public Schools including schematics, potential installation costs, and annual savings of each option. Options that have been considered are scalable for a variety of school types and resulting DHW demand.

2.0 Existing Schools: Conditions and Typical Operation

2.1 School A Domestic Hot Water Sub-Meter Analysis and Survey

School A is a three story (plus basement), 83,000 square foot elementary school serving grades pre-kindergarten – 5^{th} grade. Typical school hours last from 8:00 am – 2:30 pm. After school activities such as YMCA programs begin after 2:30 pm and continue until approximately 5:00 pm. During this time cleaning crews are also actively cleaning throughout the school and continue to clean into the evening hours.

The domestic hot water loads throughout the building are served by one (1) gasfired domestic hot water heater and one (1) 318 gallon storage tank (Photo 1). The domestic hot water system provides 140° F hot water to the kitchen, and provides tempered hot water to the rest of the hot water fixtures via a three-way mixing valve (Photo 2). Table 1 provides a summary of the existing domestic hot water equipment for this school. The domestic hot water loads throughout the building consist of lavatories, classroom sinks, janitor sinks, service sinks, and kitchen sinks (Photo 3 and Photo 4). The kitchen serves two meals a day beginning with breakfast from 8:00 am – 9:30 am and lunch from 11:05 am – 12:50 pm.

Table 1. School A Existing Domestic Hot Water Equipment Summary								
				Heating	Storage			
				Capacity	Capacity			
School	Manufacturer	Heater Model	Tank Model	(Btu)	(gal)	Efficiency		
School A	Lochinvar	CWN399PM	RGA0318	399,000	318	82%		



Photo 1. School A DHW Storage Tank



Photo 2. School A DHW Piping and Three-Way Mixing Valve



Photo 3. School A Typical Kitchen Sink



Photo 4. School A Typical Lavatory Sinks

The school's existing domestic hot water heater and storage tank is located in the basement boiler room. Domestic hot water is distributed throughout the building by three (3) recirculation pumps. One recirculation pump serves the kitchen hot water, another pump serves the tempered hot water, and the third pump serves a small tempered hot water line serving the basement bathrooms and janitor closets. The domestic hot water system is located in close proximity to an existing chimney that is currently not in operation. The school is currently using the chimney as a shaft to run conduit and other electrical items through it (Photo 5). The chimney penetrates through the roof, so it would be feasible to run conduit or piping from the roof and down into the boiler room (Photo 6). The roof of School A also has no roof-mounted mechanical equipment, which will make mounting any additional equipment on the roof feasible.



Photo 5. School A Inside Chimney Shaft



Photo 6. School A Chimney Shaft Through Roof

2.2 School B Domestic Hot Water Sub-Meter Analysis and Survey

School "B" is a four story, 180,000 square foot high school serving grades 9 - 12. Typical school hours last from 7:55 am - 2:10 pm. After school activities and after school sports programs begin after 2:10 pm and continue until approximately 5:00 pm. Cleaning crews are actively cleaning the building at 5:00 pm and continue into the evening hours.

The domestic hot water loads throughout the building are served by one (1) gas-fired domestic hot water heater and one (1) 700 gallon storage tank (Photo 7). The domestic hot water system provides 140° F hot water to the kitchen, and provides tempered hot water to the rest of the hot water fixtures via a three-way mixing valve (Photo 8). Table 2 provides a summary of the existing domestic hot water equipment for this school. The domestic hot water loads throughout the building consist of lavatories, classroom sinks, janitor sinks, service sinks, and kitchen sinks (Photo 9). The kitchen serves two meals a day beginning with breakfast from 7:30 am – 7:50 am and lunch from 11:03 am – 11:48 am.

Table 2. School B Existing Domestic Hot Water Equipment Summary								
				Heating	Storage			
				Capacity	Capacity			
School	Manufacturer	Heater Model	Tank Model	(Btu)	(gal)	Efficiency		
School B	Lochinvar	CWN0986PM	RGA0700H	986,000	700	81%		



Photo 7. School B Existing Gas-Fired DHW Heater and Storage Tank



Photo 8. School B DHW Piping and Three-Way Mixing Valve



Photo 9. School B Typical Kitchen Sink

The school's existing domestic hot water heater and storage tank is located in a penthouse on the roof of the school. Two (2) recirculation pumps recirculate domestic hot water from the kitchen and the tempered hot water from the rest of the building. There are numerous air handlers, exhaust fans, and smoke hatches located on the roof.

2.3 School C Domestic Hot Water Sub-Meter Analysis and Survey

School C is a three story (plus basement), 45,000 square foot elementary school serves grades pre-kindergarten – 2^{nd} grade. Typical school hours last from 8:00 am – 2:30 pm.

The domestic hot water loads throughout the building are served by one (1) gas-fired domestic hot water heater (Photo 10). The domestic hot water system provides 140°F hot water to the kitchen, and provides tempered hot water to the rest of the hot water fixtures via a three-way mixing valve (Photo 11). Table 3 provides a summary of the existing domestic hot water equipment for this school. The domestic hot water loads throughout the building consist of lavatories, classroom sinks, janitor sinks, service sinks, and kitchen sinks (Photo 12). The kitchen serves two meals a day beginning with breakfast from 8:10 am – 8:30 am and lunch from 10:40 am – 12:34 pm.

Table 3. School C Existing Domestic Hot Water Equipment Summary								
			Heating	Storage				
			Capacity	Capacity				
School	Manufacturer	Heater Model	(Btu)	(gal)	Efficiency			
School C	AO Smith	BTR275118	275,000	100	80%			





Photo 10. School C Existing Gas-Fired Domestic Water Heater

Photo 11. School C DHW Piping and Three-Way Mixing Valve



Photo 12. School C Typical Kitchen Sink



Photo 13. School C Decommissioned Water Heater

The school's existing domestic hot water heater is located in the basement boiler room. The original domestic hot water tank has been decommissioned and replaced with a new domestic hot water tank (Photo 13). The existing system capacity was sized for 600,000 Btu capacity. Two (2) recirculation pumps recirculate domestic hot water from the kitchen and the tempered hot water from the rest of the building. The roof of the school has roof mounted chillers, air handlers, and exhaust fans making roof space limited. There is a higher penthouse roof that may be the best location for mounting any additional roof mounted equipment. There is no direct path to run piping or conduit from the roof down to the basement boiler room. There is one shaft that runs from the roof to the basement but is located behind a wall.

2.4 School D Domestic Hot Water Sub-Meter Analysis and Survey

School D is a four story (plus basement), 373,000 square foot high school serving grades 9 - 12. Typical school hours last from 8:45 am - 3:35 pm. There are after school activities ongoing throughout the school after dismissal. There are also continuing education classes for adults from 5:30 pm - 8:30 pm. Cleaning crews are active in the building from 8:30 pm - midnight.

The domestic hot water loads throughout the building are served by one (1) gas-fired domestic hot water heater and one (1) 175 gallon storage tank (Photo 14). Unlike the other schools, there is no separate 140° F domestic hot water line serving the kitchen. The domestic hot water system provides tempered hot water to all hot water fixtures in the building including the kitchen via a three-way mixing valve (Photo 15). Table 4 provides a summary of the existing domestic hot water equipment for this school. The domestic hot water loads throughout the building consist of lavatories, classroom sinks, janitor sinks, service sinks, and kitchen sinks. The kitchen serves two meals a day beginning with breakfast from 7:30 am – 8:30 am and lunch from 10:30 am – 1:00 pm.

Table 4. School D Existing Domestic Hot Water Equipment Summary								
Heating Storage								
				Capacity	Capacity			
School	Manufacturer	Heater Model	Tank Model	(Btu)	(gal)	Efficiency		
School D Lochinvar CWN0497PM ST175 495,000 175 81%								





Photo 14. School D Existing Gas-Fired DHW Heater and Storage Tank

Photo 15. School D DHW Piping and Three-Way Mixing Valve

The school's existing domestic hot water heater and storage tank are located in the basement boiler room. The original design drawings show two large gas-fired domestic hot water heaters. These have since been replaced by one domestic hot water heater and storage tank. There are two (2) recirculation pumps serving the domestic hot water system. These pumps are piped in parallel and both were operating simultaneously during the site visit. The roof of the school is relatively open and has various small roof-mounted equipment such as exhaust fans. There is a relatively straight run from the roof down to the boiler room along the side of the building next to the adjacent courtyard. This location appears to be feasible for running piping into the boiler room.

3.0 Metering Domestic Hot Water Daily Consumption

3.1 Metering Approach

The meter that was used for the analysis was a Fuji Portaflow-C FSC-2 ultrasonic flow meter. This is a clamp-on flow meter that attaches to the outside of the pipe that is being metered (Photo 16). Once the flow meter is securely attached to the pipe, it generates ultrasonic waves that travel through the inside of the pipe that determine the amount of flow inside the pipe. The flow meter is able to record data such as flow rate, fluid velocity and total consumption (Photo 17).





Photo 16. Clamp-On Ultrasonic Meter Attached to Domestic Water Inlet Piping

Photo 17. Data Logger Recording Metering Data

For each school studied, the goal was to meter the domestic hot water consumption for the duration of a typical school day. The meter was installed at each school in the early morning hours before the building was occupied. Having the meter installed early in the morning would show any early morning kitchen consumption in the data collected. The meter continued to record data for the entirety of the school day encompassing lunch periods, after lunch kitchen clean-up, and any other domestic hot water usage such as washing of hands or gym showers. The meter continued to record data after dismissal to capture the domestic hot water consumption during after school activities and any cleaning crew water consumption.

3.2 Metering Results

3.2.1 School A Metering Results

The peak hot water demand for school School A was found to be during the lunch hours of 11:35 am – 12:19 pm consuming a total of approximately 43 gallons. There was also a peak hot water demand around the time of dismissal from 1:27 pm – 2:04 pm consuming a total of approximately 41 gallons. The total daily consumption of domestic hot water was found to be approximately 162 gallons metered from 7:05 am – 4:30 pm. Refer to Appendix A for the metering data for this school.

3.2.2 School B Metering Results

School B showed a relatively constant demand of hot water consumption throughout the school day. There was not one specific period of large peak domestic hot water consumption; however, the data shows five (5) shorter peaks of domestic hot water consumption throughout the day. The largest peak occurred around the time of dismissal from 1:09 pm – 1:48 pm and then again at 2:06 pm – 2:28 pm. This peak period consumed a total of approximately 129 gallons. The total daily consumption of domestic hot water was found to be approximately 436 gallons metered from 6:55 am – 4:44 pm. Refer to Appendix A for the metering data for this school.

3.2.3 School C Metering Results

School C had a relatively low domestic hot water load throughout the day. Nearly all of the domestic hot water load of this school was used by the kitchen during lunch hours. The peak hot water demand for the school was found to be during the lunch hours of 11:10 am – 1:24 pm consuming a total of approximately 214 gallons. Roughly 84% of the total domestic hot water consumption was used during this lunch period. The total daily consumption of domestic hot water was found to be approximately 255 gallons metered from 6:45 am – 4:27 pm. Refer to Appendix A for the metering data for this school.

3.2.4 Summary of Domestic Hot Water Metering Results

Table 5 summarizes the domestic hot water metering results for the schools included in this study. Table 5 shows that school School C had the highest gal/student ratio with 0.73 gal/student/day, and that school School B had the most daily hot water consumption with 436 gal/day. According to published ASHRAE values, the average domestic hot water consumption for a typical school is 0.60 gal/student/day (ASHRAE HVAC Applications 2015). For these three schools, the average daily domestic hot water consumption equates to 0.44 gal/student/day. On average, the metered schools consume approximately 27% less domestic hot water per day when compared to ASHRAE values.

	Table 5. Domestic Hot Water Metering Results								
School	Area (ft ²)	Number of Students	Peak GPM	gal/day	Average gal/student/day				
School A	83,000	718	6.8	162	0.23				
School B	180,000	1,244	12.8	436	0.35				
School C	45,000	350	10.4	255	0.73				
School D*	373,000	2,492	20.8	1,404*	0.56*				
	Average*								
	ASHRAE Average Value**								

*The metering data for school "D" was disregarded for the purposes of this study due to the excessive water usage observed, caused by operational issue noted on the day of the survey. The average gal/student/day excludes School D.

**ASHRAE HVAC Applications 2015, Chapter 50, page 50.10 table 6

From the above metering results, it can be inferred that the typical NYC school is likely using less than the average ASHRAE expected value. This seems reasonable considering that the schools surveyed did not appear to have heavily active cooking kitchens. It did not appear that the showers were in use much during a normal day (which has become more typical for schools).

4.0 Domestic Hot Water Alternatives

4.1 Summary of Domestic Hot Water Alternatives Considered

4.1.1 Option 1: Solar Photovoltaic System with Electric Heat Pump

This option includes replacing (or supplementing) the existing gas-fired domestic hot water heater with an electric heat pump water heater, coupled with solar photovoltaic panels. The electric heat pump (sometimes called hybrid water heaters), would be sized to provide 100% of the daily domestic hot water consumption used at the schools. Since most of the daily hot water usage of the schools occurs during a 1 to 2 hour peak period, providing an adequate amount of storage is necessary.

There are generally two styles of heat pump water heaters on the market currently: The integral tank hybrid type, and commercial style heat pump water heaters. An example hybrid-style heat pump is shown in Figure 1. There are many manufacturer's currently of this type of water heater.



Figure 1. Hybrid Style Electric Heat Pump Domestic Hot Water Heater

The hybrid-style heat pumps reviewed were able to produce high hot water temperatures suitable for kitchen needs. This style of heat pump water heater provides its own storage capacity. These heat pump water heaters provide relatively low recovery rates while in heat pump mode (the most energy efficient mode). This would require multiple heat pump water heaters to be installed so the domestic hot water system can recover the storage tank without using the electric resistance mode during the building unoccupied hours.

The commercial-style heat pump water heater operates similar to the hybridstyle heat pump, but with increased water heating capacities, slightly better efficiencies, and more sophisticated controls. (These units do not have an electric resistance heating mode). One main difference between the commercial and hybrid-style heat pump water heater is the commercial heat pump does not offer any storage capacity. The commercial heat pump must be paired with a storage tank capable of meeting the hot water load of the building during peak periods.

In schools where existing storage tanks exist, the commercial heat pump may be a more logical option than the hybrid-style. In addition, only one commercial-style heat pump water heater would need to be installed to satisfy the domestic hot water heating loads in the schools included in this report (since the commercial heat pump can satisfy larger water heating demands). Example commercial-style heat pump water heaters are shown in Figure 2 and Figure 3 below.



Figure 2. Commercial Electric Heat Pump Domestic Hot Water Heater



Figure 3. Commercial Electric Heat Pump Domestic Hot Water Heater

In addition to the above two types of heat pump water heaters, a third technology available are chiller-heater air-source heat pumps. These are heat pumps usually intended for HVAC applications but with an added heat exchanger, can be easily adapted to make domestic hot water. These type of heat pumps are similar to the commercial heat pumps described above and can make hot water up to 145 °F. Example chiller-heater air source heat pump water heaters are shown in Figure 4 and Figure 5 below.



In both heat pump water heater scenarios, it is desirable to locate these heat pump water heaters in areas of the building where either "free" space heat is available (i.e. boiler rooms or kitchens), and/or where spot cooling is needed. This will increase the efficiency of the heat pumps. The heat loss generated by the boiler casing losses or the heat generated from the cooking and refrigeration equipment would be able to be absorbed by the heat pump water heater. Figure 6 shows a representation how the heat from the surrounding space would be absorbed from the heat pump water heater, in the example of a boiler room.



Figure 6. Example Boiler Plant and Heat Pump Water Heater Heat Absorption Diagram

In the above example, heat losses from the boilers typically range about 0.5% to 2% of their rated input. During most of the year, losses from the boilers would provide a suitable heat source for the heat pumps. During shoulder seasons when the boilers are off (May to September), outside air can be introduced to the boiler rooms to avoid overcooling of the space.

Both commercial and hybrid-style heat pump water heater options are capable of serving cooling needs to nearby spaces. During periods of recovery, the heat pump water heaters absorb heat from the surrounding spaces and reject cool air. Ideally, the heat pump water heaters should be installed in boiler rooms, kitchens, or in close proximity to MDF/IDF closets and other spaces where cooling is needed. The cooling air is also capable of being ducted into adjacent spaces if the heat pump water heaters are installed in close proximity to spaces that require cooling. This would reduce the consumption of HVAC cooling equipment in these spaces and would further decrease the overall energy usage of the building.

Note that in some existing schools, (or schools that do not have a boiler room) the configuration of such spaces may not allow for this optimal placement of heat pumps. In such cases, an outdoor rated commercial heat pump water heater could be considered. Refer to specific recommendations for the sample schools studied in this report for more information on this option.

The heat pump technology would be used in conjunction with the solar photovoltaic (PV) system, which would be sized to offset the projected energy usage of the electric heat pump, resulting in a net energy cost of \$0 (assuming demand charges are not increased), and net-zero energy use for domestic water production. An example PV panel is shown in Figure 7. Note that with any of the heat pump water heater options described in this report, it may be necessary to consider exhaust and/or intake air ducts depending on the size of the room where the heat pumps are located and to optimize the unit efficiency. The intake or exhaust would be configured to avoid over-cooling the space containing the heat pump. In addition, it has been assumed that demand limiting strategies would be employed to avoid incurring increased electrical demand charges. Based on the load profiles observed at the schools, we expect this should be achievable.

Heat pump operation would be limited to times when it will not increase the building's peak electric demand. Typically, the schools have at least 12 hours of unoccupied periods during which hot water demand is limited and recovery of the storage tank can take place.



Figure 7. Photovoltaic (PV) Panels

Refer to Schematic #1 in the Appendix G for a diagram of this option.

This option is easily scalable by adding additional heat pump water heaters as needed to meet the hot water demand of a larger school, increasing the size of the storage tank, and/or adding PV panels accordingly subject to available roof space.

Option 1 Pros:

- 100% renewable
- Lowest incremental costs compared to other options
- Heat pump is able to cool adjacent spaces and potentially reduce overall building energy usage

Option 1 Cons:

- Requires roof area for PV
 panels
- Demolition/replacement of existing water heaters must be coordinated
- Floor space required for installing new heat pump water heaters

4.1.2 Option 2: Solar Thermal System with Electric Heat Pump Backup

This option would utilize roof-mounted solar thermal collectors as the renewable energy source, coupled with adequate solar thermal storage tanks. The tanks would serve as 'preheat' for the domestic hot water. The system would be coupled with electric heat pumps as auxiliary heating. As explained below, serving the domestic hot water load with 100% solar thermal is neither practical nor cost effective.

During our research for this study, it was determined that the most desirable configuration for a solar thermal collection system is to provide 100% of a given energy load on the 'best day' of the year, not 100% for the entire year. The reasoning to design for 100% on the 'best day' is to not oversize the system during that period and avoid overheating of the system fluid and possible damage to it and the panels. This reasoning will also make the annual operation of the system most efficient in the energy conversion. This approach results in there being less contribution to the hot water load (lower solar fraction) for all the other days of the year. During the winter, the contribution will be low and during the summer the solar fraction will be high. This is a natural function of the conditions that exist during the different seasons.

During the course of this study, we analyzed several configurations of solar thermal collectors and storage tanks. The conclusion reached is that it is neither practical nor economical to design a solar collection system that will provide 100% of the annual hot water load for a northern climate. Increasing the collector area will in fact increase the solar fraction (to a point), yet at the same time reduce system efficiency. Maximizing size to address the full consumption creates a trend of diminishing returns with respect to adding more collectors. This relationship is illustrated in Figure 8 below. This figure was extracted from "Viessmann" literature.



Figure 8. Solar Thermal System Efficiency

Page 18 of 32

For a properly designed solar thermal system, it is necessary to provide adequate storage volume of hot water, which is a function of the area of collectors. The more collectors, the more the solar storage volume is required. In the New York region that ratio is most commonly between 1.25 to 1.5 gallons of storage for each square foot of collector. This strategy provides for best efficiencies and is necessary to protect the panels from overheating.

The prototype designs in this study utilize several pre-heat storage tanks with integral solar heating coils (Figure 9). For larger buildings, a separate preheat heat exchanger and storage tank may be used. The existing gas-fired domestic hot water heaters would be replaced by a high efficient electric heat pump acting as auxiliary heat to supplement the solar thermal system.



Figure 9. Solar Thermal Preheat Tank

Refer to Schematic #2 in the Appendix G for a diagram of this option. This option cannot provide a practical, 100% renewable solution.

Option 2 Pros:

- Reduces annual DHW heating costs
- Heat pump is able to cool adjacent spaces and potentially reduce overall building energy usage

Option 2 Cons:

- Not a 100% renewable system
- Requires roof area for solar thermal collectors
- Solar thermal panels are relatively expensive compared to PV.
- Glycol must be used to prevent freezing
- Additional solar thermal preheat tanks may be required
- Demolition/replacement of existing water heaters must be coordinated

4.1.3 Option 3: Solar Thermal System with Gas-Fired Backup

This option is essentially equivalent to Option 2 previously described and all the same considerations still apply. In this option, the existing gas-fired domestic hot water heaters would remain and would act as the auxiliary heat to supplement the solar thermal system.

Refer to Schematic #3 in the Appendix G for a diagram of this option. This option cannot provide a practical, 100% renewable solution.

Option 3 Pros:

- Reduces annual DHW heating costs
- Existing gas-fired water heaters will be utilized. No coordinating needed with installing new water heaters
- Incremental costs could be lower in some cases when utilizing existing water heaters

Option 3 Cons:

- Not a 100% renewable system
- Requires roof area for solar thermal collectors
- Solar thermal panels are relatively expensive compared to PV.
- Glycol must be used to prevent freezing
- Additional solar thermal preheat tanks may be required

4.1.4 Option 4: Hybrid Solar Thermal and PV System with Electric Heat Pump Backup

This option would use a combination of both a PV system and a solar thermal system. This option incorporates the features of Option 1 and Option 2 together allowing a smaller PV system to be used. Since some of the domestic hot water load will be provided by the solar thermal system, the electric energy used by the heat pump will be reduced, and therefore a smaller PV system can offset its consumption.

By merging the solar thermal with the electric heat pump and PV system, this option can provide a 100% renewable solution. Refer to Schematic #4 in the Appendix G for a diagram of this option.

Option 4 Pros:

- 100% renewable system
- Reduces annual DHW heating costs to \$0
- Heat pump is able to cool adjacent spaces and reduce overall building energy usage

Option 4 Cons:

- Highest incremental costs since utilizing both PV and solar thermal
- Requires additional roof area for PV and solar thermal collectors
- Glycol must be used to prevent freezing during the winter months
- Additional solar thermal preheat tanks may be required in addition to electric heat pump water heaters
- Demolition/replacement of existing water heaters must be coordinated

4.1.5 Option 5: Point of Use Electric

This option is to utilize "point of use" electric hot water heaters installed close to the end uses, such as under the lavatories and sinks, or near to a group of bathroom lavatories, or in the kitchen to serve each sink. This type of electric heater is also referred to as a "tankless" electric water heater. The point of use heaters are only active when a sink demand for hot water exists. Point of use heaters, since they are located near the end use, do not require a circulating hot water system and storage tank, which is their prime advantage.

The prime disadvantage of the point of use heater is that the peak electrical demand of the building would be increased significantly, and in some cases the building's electric service would be affected as well. This option is not well suited for a school with large kitchen use. Storage tanks are typically going to be required to serve the kitchens in order to avoid large peak demand costs. The point of use heaters do have the potential to reduce site energy consumption however, and were therefore included in this study.

In order to quantify the potential energy use benefits, a high level energy analysis was performed for School B in order to verify the increase in energy costs and decrease in energy use. School B was selected since reliable metering was collected, and it represents an average size SCA School At 180,000 square feet.

Table 6 below summarizes the energy usage and costs of the point of use electric hot water heaters as compared to the existing gas-fired domestic hot water system for school School B. Note that the heat losses associated with the existing domestic hot water recirculation piping, storage tank, and recirculating pumps are factored into the annual heating energy usage and cost for the purposes of this evaluation. The results highlight that although consumption is less for point of use heaters compared to a gas-fired system, the penalty associated with demand charges is significant.

One benefit of point of use electric heaters is the reduced CO₂ emissions when compared to the SCA current standard gas fired DHW recirculating system. It was estimated that the annual heating energy associated with the additional piping losses and storage tank for School B is approximately 36% of the total domestic water system heating energy input. A similar study by another SCA consultant found that for PS 2Q (a smaller school), the recirculating system losses were about 20%. In general, it can be extrapolated that the larger the size the recirculation system, the larger system heat losses and the greater potential benefit of point of use heaters.

Elimination of the recirculation system and pump results in substantial energy savings and associated GHG emissions, however will increase the building's source energy input in most cases do the fuel switching and associated site-to-source conversions. In addition, point of use heaters will not save as much energy when compared to electric heat pump water heaters. This is primarily due to the significantly higher efficiencies achieved by heat pumps. The results of this analysis are summarized below. Option 5 Pros:

- May be acceptable for schools with small kitchens
- High Thermal Efficiencies
- Eliminates recirculation system losses.
- Lower building site energy and CO₂ emissions compared to DHW recirculating system

Option 5 Cons:

- Significantly increases electrical demand and operating costs
- Will likely impact building electrical service
- Large kitchens will be very costly to operate.
- Higher site energy and CO₂ emissions when compared to electric heat pumps.
- Increased building source energy.
- Increased electric consumption compared to heat pumps would require larger PV array to offset
- Likely higher first cost than heat pump systems for retrofit projects.

	Table 6. Option 5 Energy Usage and Cost Summary for School B with Point of Use Heaters								
School	Option	Approximate System Cost (\$)	Annual Water Heating Energy (therms)	Annual Electric Energy Input (kWh)	Annual Water Heating Energy (kBtu)	Annual Energy Cost (\$)	Annual Demand Penalty (Cost) (\$)	Annual CO2 Emissions Avoided (lbs/year)	
Sahaal P	Existing Gas-Fired DHW Heater	-	1,059	2,902 ¹	133,127	\$1,982	-	0	
SCHOOL P	Point of Use Electric Hot Water Heaters	\$450,000	-	25,406	85,817	\$1,385	\$8,946	4,908	

Notes:

1. Electric energy associated with DHW recirculation pumps.

4.2 School A Domestic Hot Water Alternatives

The sections below summarize the specifics of the Options and how they could be applied for School A.

4.2.1 Option 1: Solar Photovoltaic System with Electric Heat Pump

Two (2) new electric domestic hot water heat pumps would be located in the basement boiler room in close proximity to the existing gas-fired domestic hot water heater. Power would be distributed to the heat pumps from an existing electric panel. The PV panels would be roof-mounted in a South inclined orientation on the roof of the school. This school did not have much roof-mounted equipment located on the roof, so there will be ample space for mounting PV panels in an optimal orientation (Photo 18). Power can be routed from the roof and down through the existing chimney to a suitable tie-in location to be determined.



Photo 18. School A Roof

Table 7 shows the requirements for this option. A 3 kW solar PV system would need to be installed to offset the annual kWh usage of the heat pump. The total roof area required for this option is 190 ft² with nine (9) PV panels in total. The PV system would generate 3,720 kWh annually.

Table 7. School A Option 1 Requirements								
	Annual	Number of						
			kWh	Electric Heat				
Size of PV	Number of	Roof Area	Generated	Pump Water				
array	Panels	Required (ft ²)	by PV	Heaters				
3 kW	9	190	3,720	2				

4.2.2 Option 2 or 3: Thermal DHW Closed Loop Drainback System with Gas Fired or Electric Heat Pump Auxiliary heat.

Solar thermal collectors would be mounted on the roof of the school and a closed loop piping system would be routed through the chimney and into the basement boiler room. The closed loop solar thermal system would recirculate a heat transfer fluid, heated by solar energy, using a pump. The heat transfer fluid will flow to a heat exchanger, where it will heat the domestic hot water. The solar heated domestic water would be stored in a preheat tank. Depending on site specific conditions, an external heat exchanger could be used or the heat exchanger could be located inside the preheat tank (as shown in Figure 2).

Table 8 shows the requirements for this option. A 36,000 Btu/hr solar thermal collector array would need to be installed to efficiently contribute to the domestic hot water heating system. This would require six (6) solar thermal collectors to be installed on the roof totaling 162 ft² of collector area.

Table 8. School A Option 2 and 3 Requirements							
Installed			Annual Solar	Solar			
Collector		Roof Area	Contribution to	Thermal			
Power	Number of	Required	DHW System	Fraction			
(kBtu/hr)	Collectors	(ft ²)	(MBtu)	%			
36	6	162	17	53.4%			

4.2.3 Option 4: Hybrid Solar Thermal and PV System with Electric Heat Pump Backup

Solar thermal collectors would be mounted on the roof of the school and a closed loop piping system would be routed through the chimney and into the basement boiler room. The PV panels would be roof-mounted in a South inclined orientation on the roof of the school. Two (2) new electric domestic hot water heat pumps would be located in the basement boiler room in close proximity to the existing gas-fired domestic hot water heater. This option would require the same amount of solar thermal collectors as in Option 2 and 3, but would require a 2 kW PV system to cover the rest of the domestic hot water load. Table 9 summarizes the PV requirements for this option.

Table 9. School A Option 4 Requirements									
				Number of					
			Annual	Electric	Solar				
Size of		Roof Area	kWh	Heat Pump	Thermal				
PV	Number	Required	Generated	Water	Fraction				
array	of Panels	(ft ²)	by PV	Heaters	%				
2 kW	6	126	1,456	2	53.4%				

4.3 School B Domestic Hot Water Alternatives

The sections below summarize the specifics of the Options and how they could be applied for School B.

4.3.1 Option 1: Solar Photovoltaic System with Electric Heat Pump Backup

Four (4) new electric domestic hot water heat pumps would be located in the roof penthouse where the existing gas-fired domestic hot water heater is currently located. Finding a location for this heat pump may be difficult since there is limited space inside of the penthouse. There are electric panels located inside the penthouse where power could be drawn from to power the new electric heat pumps. The PV panels would be roof-mounted in a South-West orientation on the roof of the school. This school has a number of air handlers, exhaust fans, sanitary vents, and smoke hatches located on the roof (Photo 19). The PV panels would need to be mounted such that clearance requirements are maintained with the existing roof-mounted equipment.



Photo 19. School B Roof

Table 10 shows the requirements for this option. An 8 kW solar PV system would be required to offset the annual kWh usage of the heat pumps. The total roof area required for this option is 484 ft² with twenty-three (23) PV panels in total. The PV system would generate 9,920 kWh annually.

Due to the small size of the penthouse, this installation may require additional intake and exhaust ductwork to allow the heat pumps to operate without overcooling the space.

Table 10. School B Option 1 Requirements								
	Annual Number of							
			kWh	Electric Heat				
Size of PV	Number of	Roof Area	Generated	Pump Water				
array	Panels	Required (ft ²)	by PV	Heaters				
8 kW	23	484	9,920	4				

4.3.2 Option 2 or 3: Thermal DHW Closed Loop Glycol System with Gas Fired Backup

Solar thermal collectors would be mounted on the roof of the school and a closed loop piping system would be routed from the collectors and into the roof penthouse. The closed loop solar thermal system would recirculate a heat transfer fluid, heated by solar energy, using a pump. The heat transfer fluid will flow to a heat exchanger, where it will heat the domestic hot water. The solar heated domestic water would be stored in a preheat tank. Depending on site specific conditions, an external heat exchanger could be used or the heat exchanger could be located inside the preheat tank (as shown in Figure 2). Since the existing water heater is located in the roof penthouse, it would not be possible for the system to drain down during the winter months. Therefore, this school would need to use a closed-loop pressurized system. The closed loop solar thermal system would need to be filled with a glycol mixture to prevent freezing in the collectors during the winter months.

Table 11 shows the requirements for this option. A 72,000 Btu/hr solar thermal collector array would need to be installed to efficiently contribute to the domestic hot water heating system. This would require twelve (12) solar thermal collectors to be installed on the roof totaling 324 ft² of collector area.

Table 11. School B Option 2 and 3 Requirements							
Installed			Annual Solar	Solar			
Collector	Collector Roof Area Contribution to Thermal						
Power	Number of	Required	DHW Heating	Fraction			
(kBtu/hr)	Collectors	(ft ²)	System (MBtu)	%			
72	12	324	45	52.3%			

4.3.3 Option 4: Hybrid Solar Thermal and PV System with Electric Heat Pump Backup

Solar thermal collectors would be mounted on the roof of the school and a closed loop piping system would be routed from the collectors and into the roof penthouse. The PV panels would be roof-mounted in a South-West inclined orientation on the roof of the school. Four (4) new electric domestic hot water heat pumps would be located in the roof penthouse where the

existing gas-fired domestic hot water heater is currently located. This option would require the same amount of solar thermal collectors as in Option 2 and 3, but would require a 4 kW PV system to cover the rest of the domestic hot water load. Table 12 summarizes the PV requirements for this option.

Table 12. School B Option 4 Requirements							
	Number of						
			Annual	Electric	Solar		
Size of	Roof Area kWh Heat Pump						
PV	Number	Required	Generated	Water	Fraction		
array	of Panels	(ft ²)	by PV	Heaters	%		
4 kW	12	253	3,999	4	52.3%		

4.4 School C Domestic Hot Water Alternatives

The sections below summarize the specifics of the Options and how they could be applied for School C.

4.4.1 Option 1: Solar Photovoltaic System with Electric Heat Pump Backup

The new electric domestic hot water heat pump could be located in the basement boiler room in close proximity to the existing gas-fired domestic hot water heater. Power would be distributed to the heat pump from an existing electric panel located in the basement electrical room. The PV panels would be roof-mounted in a nearly South inclined orientation on the roof of the school. This school has numerous mechanical equipment, exhaust fans, and smoke hatches located on the roof (Photo 20).



Photo 20. School C Roof

13 shows the requirements for this option. A 5 kW solar PV system would need to be installed to offset the annual kWh usage of the heat pump. The total roof area required for this option is 316 ft² with fifteen (15) PV panels in total. The PV system would generate 6,200 kWh annually.

Table 13. School C Option 1 Requirements								
Annual Number of								
	kWh Electric He							
Size of PV	Number of	Roof Area	Generated	Pump Water				
array	Panels	Required (ft ²)	by PV	Heaters				
5 kW	15	316	6,200	2				

4.4.2 Option 2 or 3: Thermal DHW Closed Loop Drainback System with Gas Fired Backup

Solar thermal collectors would be mounted on the roof of the school and a closed loop piping system would be routed from the roof and into the basement boiler room. There is no easily accessible shaft located in the school to route this piping. There is one main shaft that runs from the roof to the basement; however, gaining access to this shaft would require demolition of walls. The closed loop solar thermal system would recirculate a heat transfer fluid, heated by solar energy, using a pump. The heat transfer fluid will flow to a heat exchanger to where it will heat the domestic hot water. The solar heated domestic water would be stored in a preheat tank. Depending on site specific conditions, an external heat exchanger would be used or the heat exchanger could be located inside the preheat tank (as shown in Figure 2). A drainback tank would be installed somewhere inside the building to prevent heat transfer fluid (water) from freezing inside the solar collectors during the winter months.

Table 14 shows the requirements for this option. A 48,000 Btu/hr solar thermal collector array would be installed to efficiently contribute to the domestic hot water heating system. This would require eight (8) solar thermal collectors to be installed on the roof totaling 216 ft² of collector area.

Table 14. School C Option 3 Requirements									
Installed	Annual Solar Solar								
Collector		Roof Area Contribution to Thermal							
Power	Number of	Required	DHW Heating	Fraction					
(kBtu/hr)	Collectors	(ft ²)	System (MBtu)	%					
48	8	216	26	51.4%					

4.4.3 Option 4: Hybrid Solar Thermal and PV System with Electric Heat Pump Backup

Solar thermal collectors would be mounted on the roof of the school and a closed loop piping system would be routed from the collectors and into the basement boiler room. The PV panels would be roof-mounted in a South-West inclined orientation on the roof of the school. Two (2) new electric domestic hot water heat pumps would be located in the basement boiler room where the existing gas-fired domestic hot water heater is currently located. This option would require the same amount of solar thermal collectors as in Option 2 and 3, but would require a 3 kW PV system to cover the rest of the domestic hot water load. Table 15 summarizes the PV requirements for this option.

Table 15. School C Option 4 Requirements							
	Number of						
			Annual	Electric	Solar		
Size of		Roof Area	kWh	Heat Pump	Thermal		
PV	Number	Required	Generated	Water	Fraction		
array	of Panels	(ft ²)	by PV	Heaters	%		
3 kW	9	190	2,386	2	51.4%		

5.0 Results

Table 16 provides a summary of the incremental costs and energy cost saving potential of each of the investigated options.

Table 16. Incremental Costs and Summary of Options							
School	Option	Approximate Incremental Costs ^{3,4} (\$)	\$/ft ² Incremental Costs	Annual Energy Cost Savings ^{1,2} (\$/year)	Percent of Renewable Energy (%)	Annual CO ₂ Emissions Avoided ^{5,6} (lbs/year)	\$/lbs CO ₂ Emissions Avoided
	Option 1: PV System with Electric Heat Pump	\$80,000	\$0.96	\$488	100%	4,558	\$17.6
Cabaal A	Option 2: Solar Thermal System with Electric Heat Pump	\$145,000	\$1.75	\$94	53.4%	3,632	\$39.9
School A	Option 3: Solar Thermal System with Gas-Fired Heater	\$100,000	\$1.20	\$260	53.4%	2,434	\$41.1
	Option 4: Hybrid Solar Thermal System and PV System with Electric Heat Pump	\$170,000	\$2.05	\$488	100%	4,558	\$37.3
	Option 1: PV System with Electric Heat Pump ⁷	\$140,000	\$0.75	\$1,324	100%	12,379	\$11.3
Ocheck	Option 2: Solar Thermal System with Electric Heat Pump	\$155,000	\$0.86	\$245	52.3%	9,837	\$15.8
SCNOOL R	Option 3: Solar Thermal System with Gas-Fired Heater	\$120,000	\$0.67	\$693	52.3%	6,474	\$18.5
	Option 4: Hybrid Solar Thermal System and PV System with Electric Heat Pump	\$230,000	\$1.28	\$1,324	100%	12,379	\$18.6
	Option 1: PV System with Electric Heat Pump	\$80,000	\$1.78	\$785	100%	7,340	\$10.9
School C	Option 2: Solar Thermal System with Electric Heat Pump	\$150,000	\$3.33	\$141	51.4%	5,823	\$25.8
	Option 3: Solar Thermal System with Gas-Fired Heater	\$110,000	\$2.44	\$404	51.4%	3,773	\$29.2
	Option 4: Hybrid Solar Thermal System and PV System with Electric Heat Pump	\$175,000	\$3.89	\$785	100%	7,340	\$23.8

Notes:

1. Energy cost savings stated are order of magnitude only.

2. For electric heat pump options, it is assumed that controls and sufficient water storage will be provided to mitigate increased demand charges for electric heat pump systems.

3. Costing is for order of magnitude values only and is not intended to be used for construction costs.

4. Costing is developed for the existing buildings in this study. If these options are to be implemented in new buildings, the expectation is that the construction costs will be less.

5. $11.7 \text{ lbs CO}_2/\text{therm from EPA}$.

6. 635.8 lbs CO2/MWh from EPA eGrid 2016 data. Options 1 and 4 are both intended to be 100% renewable, and therefore have the same CO2 avoided emissions.

7. Oversized outdoor rated heat pump was used in the analysis to keep Option 1 100% renewable.

Page 29 of 32

The above results summary in Table 16 indicates that Option 1, heat pumps coupled with PV arrays, will likely be the most cost effective alternative energy solution for typical NYC schools. The expected cost for these systems is between \$1.00 to \$1.80 per square foot, and would depend on the size of the school (smaller schools having a higher cost per square foot). The specific heat pump type (commercial or hybrid type) and installation location at a given school would have to be evaluated on a case by case basis. As described in Section 4.0, placement of heat pumps in or near 'free' heat sources such as boiler rooms, kitchen refrigerators, or IDF rooms would optimize their performance, and in some cases offset other cooling needs. Some existing schools may not have this opportunity, but could use outdoor rated heat pumps instead.

In general new schools could benefit from the cost effective hybrid style heat pumps with integral storage, as long as the sizing takes into account the need for enough storage to cover the peak period usage. Larger schools would necessarily benefit from using commercial grade heat pumps and large storage tanks (see below Sample Design School #1 as an example). For the two larger schools studied (School A and School B) the peak period usage accounted for 50-60% of the daily usage, and lasted about 1.5 hours. A smaller school is expected to have a higher percentage of usage during the peak period. As an example, School C used 80% of the daily hot water during the peak period of 2.5 hours. The peak period usage should be carefully estimated for schools using integral tank-hybrid type heat pump water heaters, since the recovery rates are lower than conventional water heaters of similar tank size, and the goal is to avoid using the electric resistance mode. Existing schools with enough storage capacity could use a commercial style (no integral storage) heat pump to take advantage of the existing storage.

The following section includes some design recommendations specific to the schools surveyed during this study, as wells as some additional school currently being developed, and these concepts could be applied to similar schools.

6.0 Specific Recommendations for Example Schools

6.1 School A

Option 1: PV System with Electric Heat Pump is recommended for School A. This school already utilizes a 318 gallon storage tank located in the boiler room, which provides a surplus of hot water storage capacity. Pairing a commercial heat pump water heater with the existing storage tank would be a viable option and locating the heat pump(s) in the boiler room is feasible. The boiler heat losses would provide enough energy to be absorbed by the commercial heat pump most of the year, thus maximizing its efficiency. The school would also benefit from the increased recovery rate and efficiency provided by the commercial heat pump over the hybrid heat pump water heaters. The roof of this school has no equipment on the roof which will allow ample space for a PV array to be installed.

6.2 School B

Option 1: PV System with Electric Heat Pump is recommended for School B. This school already utilizes a 700-gallon storage tank located in the penthouse MER, which provides a surplus of hot water storage capacity. Pairing a commercial heat pump water heater with the existing storage tank would be a viable option.

Unfortunately, there is no "free" waste heat source in the room. If a heat pump water heater were to be installed inside the penthouse, the temperature within the penthouse could drop below freezing conditions at times, if the heat pump was not ducted to the outdoors. In this situation, we recommend locating the commercial heat pump outdoors to avoid any ductwork modifications within the penthouse, avoid overcooling the space, and ultimately save on installation costs.

The results shown above in Table 15 were based on using an oversized commercial heat pump that could provide 140°F hot water under all outdoor conditions. An alternate option is to use a hybrid system and a smaller outdoor rated heat pump. The results of this option are shown below in Table 17. The smaller sized commercial heat pump output would not be able to generate 140°F water during sub-freezing winter temperatures. The existing gas fired water heater would be utilized during some winter hours to supplement the hot water temperature. This arrangement would make the system less than 100% renewable, but reduce first cost. It is estimated that the gas-fired water heater would have to provide about 14% of the hot water heating throughout the year in this scenario. Table 17 provides a summary of the incremental costs and energy cost saving potential of this situation. The large roof of this school provides ample space for a PV array to be installed.

Table 17. School B Incremental Costs and Summary of Outdoor Rated Heat Pump Water Heater and Gas-Fired Supplemental Water Heater							
School	Option	Approximate Incremental Costs ^{3,4} (\$)	\$/ft ² Incremental Costs	Annual Energy Cost Savings ^{1,2} (\$/year)	Percent of Renewable Energy (%)	Annual CO ₂ Emissions Avoided ^{5,6} (lbs/year)	\$/lbs CO ₂ Emissions Avoided
School B	PV System with Electric Heat Pump and Gas-Fired Heater	\$120,000	\$0.67	\$1,139	86%	10,646	\$11.3

6.3 School C

Option 1: PV System with Electric Heat Pump is recommended for School C. This school only utilizes a 100 gallon storage tank located in the boiler room, which does not provide enough storage to be paired with a commercial heat pump. Utilizing the storage of two (2) hybrid-style heat pump water heaters in addition to the 100 gallon storage tank would be a viable option. The boiler heat losses would provide enough energy to be absorbed by the hybrid-style heat pumps most of the year, thus

maximizing their efficiency. The heat pumps would have enough recovery capacity with two (2) hybrid heat pumps operating during off-hours to heat the storage for the following school day. The roof of this school has various mechanical equipment, exhaust fans, and smoke hatches on the roof, but a roof-mounted PV array would still be feasible.

6.4 Sample Design School #1

As part of a separate project, an electric heat pump water heater design for a new large high school was completed for SCA. This design has been designated as Sample Design School #1. Sample Design School #1 is approximately 308,000 square feet and will serve 3,870 students. The design scheme is included in this report for reference. The recommendation for Sample Design School #1 is primarily based on Option 1: Electric Heat Pumps, but with some modifications to the study concept. The proposed design for this school features two (2) commercial-style electric heat pump water heaters and one (1) 500 gallon storage tank to serve the domestic hot water system. (The PV system was not part of the project). Ideally, a larger storage tank would have been provided, however due to space constraints in the proposed boiler room, the 500 gallon tank was size was utilized. The heat pump water heaters were selected to provide equivalent recovery rate as the standard gas-fired system (roughly 287,000 Btu/hr for both, or 190 gph recovery rate).

The heat pump hot water heaters are proposed to be located outdoors on the roof of the building, as there was no allotted space in the boiler room. The storage tank is to be installed in the boiler room. In addition, one (1) plate and frame heat exchanger was included in the design to separate the heat pump circulating glycol loop from the domestic hot water. This accomplishes freeze protection for the heat pumps without relying on electrical heat trace for the small amount of domestic water piping that would be outdoors. Proposed DHW system schematics for Sample Design School #1 have been included in Appendix H of this report.

6.5 Sample Design School #2

Another school for which heat pump water heaters are currently being designed has been included in this report as an example, and has been designated Sample Design School #2. Sample Design School #2 is about 50,000 square feet. Domestic hot water for this proposed school is to be provided by two (2) electric heat pump hot water heaters, each with peak outputs of 151 MBH and 222 MBH respectively. Domestic water is stored in one (1) 200 gallon DHW storage tank. The storage tank is equipped with a 72kW electrical resistance coil to provide supplemental heat when required. The heat pump water heaters and storage tank are all located in the rooftop MER of the building with heat pumps supply and exhaust air ducted to the outdoors. This design eliminates the need for the heat exchanger and glycol loop since the heat pumps are entirely inside the building. A floor plan layout and schematic diagram for this design has been included in Appendix I of this report.

7.0 Appendices

Appendix A:

Metering Data


				_			_														
•																					
40 PM	50 PM	MP OC	10 PM	20 PM	30 PM	40 PM	50 PM	MP OC	10 PM	20 PM	30 PM	40 PM	50 PM	MH OC	10 PM	20 PM	30 PM	40 PM	50 PM	MP OC	10 PM
2:16:4	2:22:	2:29:(2:35:	2:41:	2:47:(2:53:4	2:59:	3:06:(3:12:	3:18:2	3:24:(3:30:4	3:36:{	3:43:(3:49:	3:55:2	4:01:(4:07:4	4:13:{	4:20:(4:26:



≥ L	Σd	Ρ	PM	PM	PM	PM	PM	ΡM	ΡM	PΜ	PΜ	PM	PM	PM	PM	PΜ	PΜ	PΜ	ΡM	PΜ	PM
0.40	2:50	00:6	35:10	1:20	7:30	3:40	9:50	00:90	12:10	8:20	4:30	30:40	6:50	I3:00	t9:10	55:20	1:30	07:40	3:50	00:00	6:10



	_		_	_				_														-
/																						
MAC	M C	M C	M C	M C	M C	M C	M C	M C	M C	M C	M C	M C	M C	M C	M C	M C	M C	M C	M C	M C	M C	M C
2:24:4(2:31:0(2:37:2(2:43:4(2:50:0(2:56:2(3:02:4(3:09:0(3:15:2(3:21:4(3:28:00	3:34:2(3:40:4(3:47:0(3:53:2(3:59:4(4:06:0(4:12:2(4:18:4(4:25:0(4:31:2(4:37:4(4:44:0(



2:37:20 PM 2:37:20 PM 2:43:40 PM 2:56:20 PM 3:02:40 PM 3:02:40 PM 3:15:20 PM 3:15:20 PM 3:15:20 PM		
37:20 PM 56:00 PM 56:20 PM 02:40 PM 03:00 PM 15:20 PM 15:20 PM 15:20 PM		
43:40 PM 56:20 PM 02:40 PM 03:00 PM 15:20 PM 15:20 PM 15:20 PM		
50:00 PM 56:20 PM 02:40 PM 09:00 PM 15:20 PM 15:20 PM 15:20 PM		
56:20 PM 02:40 PM 09:00 PM 15:20 PM 15:20 PM 221:40 PM		
02:40 PM 09:00 PM 15:20 PM 21:40 PM		
:09:00 PM 15:20 PM 21:40 PM		
:15:20 PM :21:40 PM		
221:40 PM		
:28:00 PM		
:34:20 PM		
.40:40 PM		
M2:00 PM		
53:20 PM		
59:40 PM		
:06:00 PM		
12:20 PM		
.18:40 PM		
25:00 PM		
31:20 PM		
37:40 PM		
44:00 PM		



				7۔	مر																
Σ	Σ	Σ	Σ	Σ	Σ	Σ	Σ	Σ	Σ	Σ	Σ	Σ	Σ	Σ	Σ	Σ	Σ	Σ	Σ	Σ	Σ
08:20 P	14:40 P	21:00 P	27:20 P	33:40 P	40:00 P	46:20 P	52:40 P	59:00 P	05:20 P	11:40 P	18:00 P	24:20 P	30:40 P	37:00 P	43:20 P	49:40 P	56:00 P	02:20 P	08:40 P	15:00 P	21:20 P
5.	2	5	5	0	 Ю	́	5	5	Θ	ю.	ю.	č	č	č	ю́.	ю́.	ë	4:	4	4:	4



7	V	V	Ν				V	V	V	V	V	V	V	V	V	V	V	V	V	V	V	
102:20 PN	2:14:40 PN	2:21:00 PN	27:20 PN	2:33:40 PN	2:40:00 PN	2:46:20 PN	2:52:40 PN	2:59:00 PN	3:05:20 PN	3:11:40 PN	3:18:00 PN	3:24:20 PN	3:30:40 PN	3:37:00 PN	3:43:20 PN	3:49:40 PN	3:56:00 PN	1:02:20 PN	1:08:40 PN	I:15:00 PN	I:21:20 PN	
V		L N	. 1	. 1	. 1		. 1	. 1	()	(1)	(1)	(1)	(1)	(,)	(1)	(1)	(1)	7	Z	7	7	



				-																			
Σ	≥	∑	Z	Z	∑	∑	Σ	Z	Z	Z	Z	Z	Z	Z	Z	Z	Z	Z	Z	Z	Z	∑	
3:20 P	0:10 P	7:00 P	3:50 P	0:40 P	7:30 P	4:20 P	1:10 P	8:00 P	4:50 P	1:40 P	8:30 P	5:20 P	2:10 P	9:00 P	5:50 P	2:40 P	9:30 P	6:20 P	3:10 P	0:00 P	6:50 P	3:40 P	
2:3	2:4	2:4	2:5	3:0	3:0	3:1	3:2	3:2	3:3	3:4	3:4	3:5	4:0	4:0	4:1	4:2	4:2	4:3	4:4	4:5	4:5	5:0	



Appendix B:

PV System Analysis



Caution: Photovolaic system performance predictions calculated by PVWatts[®] include many inherent assumptions and uncertainties and do not reflect variations between PV technologies nor site-specific characteristics except as represented by PVWatts[®] inputs. For example, PV modules with better performance are not differentiated within PVWatts[®] from lesser performing modules. Both NREL and private companies provide more sophisticated PV modeling tools (such as the System Advisor Model at http://sam.nrel.gov) that alow for more precke and complex modeling of PV systems.

The expected range is based on 30 years of actual weather data at the given location and is intended to provide an indication of the variation you might see. For more information, please refer to this NREL report: The Error Report.

Disclaimer: The PVWatts^(®) Model ("Model") is provided by the National Renewable Energy Laboratory ("NREL"), which is operated by the Aliance for Sustainable Energy, LLC ("Aliance") for the U.S. Department Of Energy ("DOE") and may be used for any purpose whatsoever.

The names DOE/NREL/ALLIANCE shall not be used in any representation, advertising, publicity or other manner whatsoever to endorse or promote any entity that adopts or uses the Model. DOE/NREL/ALLIANCE shall not provide

any support, consulting, training or assistance of any kind with regard to the use of the Model or any updates, revisions or new versions of the Model.

YOU AGREE TO INDEMNIFY DOE/NREL /ALLANCE, AND ITS AFFLIATES, OFFICERS, ACENTS, AND EMPLOYES AGAINST ANY CLAIM OR DEMAND, INCLIDING REASONABLE ATTORNEYS' FEES, RELATED TO YOUR USE, RELIANCE, OR ADOPTION OF THE MODEL FOR ANY PURPOSE WHATSOEVER. THE MODEL IS PROVIDED BY DOE/NREL/ALLANCE "AS IS' AND ANY EXPRESS OR IMPLIED WARRANTIES, INCLUDING BUT NOT LIMITED TO THE IMPLIED WARRANTIES OF MERCHANTABLITY AND FITNESS FOR A PARTICULAR PURPOSE ARE EXPRESSLY DISCLAIMED. IN NO EVENT SHALL DOF/NREL/ALLIANCE BE LIABLE FOR ANY SPECIAL, INDRECT OR CONSEQUENTIAL DAMAGES OR ANY DAMAGES WHATSOEVER, INCLUDING BUT NOT LIMITED TO CLAIMS ASSOCIATED WITH THE LOSS OF DATA OR PROFITS, WHICH MAY RESULT FROM ANY ACTION IN CONTRACT, NEGLIGENCE OR OTHER TORTIOUS CLAIM THAT ARISES OUT OF OR IN CONNECTION WITH THE USE OR PROFILMENT OF THE MODEL.

The energy output range is based on analysis of 30 years of historical weather data for nearby, and is hitended to provide an indication of the possible interannual variability in generation for a fixed (open rack) PV system at this location.



3,720 kWh/Year*

System output may range from 3,571 to 3,845kWh per year near this location.

Month	Solar Radiation (kWh/m ² /day)	AC Energy (kWh)	Energy Value (\$)
January	2.80	219	25
February	3.40	242	28
March	3.92	299	35
April	4.90	355	41
Мау	5.50	407	47
June	5.19	362	42
July	5.26	375	43
August	5.49	392	45
September	4.70	329	38
October	4.54	336	39
November	2.74	202	23
December	2.63	204	24
Annual	4.26	3,722	\$ 430

Location and Station Identification

Requested Location	School A Address
Weather Data Source	(TMY3) NEW YORK LAGUARDIA ARPT, NY 6.5 mi
Latitude	40.78° N
Longitude	73.88° W
PV System Specifications (Commercial)	
DC System Size	3 kW
Module Type	Premium
Array Type	Fixed (roof mount)
Array Tilt	41°
Array Azimuth	225°
System Losses	14.08%
Inverter Efficiency	96%
DC to AC Size Ratio	1.1
Economics	
Average Cost of Electricity Purchased from Utility	0.12 \$/kWh
Performance Metrics	
Capacity Factor	14.2%



Caution: Photovotaic system performance predictions calculated by PVWatts[®] include many inherent assumptions and uncertainties and do not reflect variations between PV technologies nor site-specific characteristics except as represented by PVWatts[®] inputs. For example, PV modules with better performance are not differentiated within PVWatts[®] from lesser performing modules. Both NREL and private companies provide more sophisticated PV modeling tools (such as the System Advisor Model at http://sam.nrel.gov) that allow for more precise and complex modeling of PV systems.

The expected range is based on 30 years of actual weather data at the given location and is intended to provide an indication of the variation you might see. For more information, please refer to this NREL report: The Error Report.

Disclaimer: The PVWatts[®] Model ("Model") is provided by the National Renewable Energy Laboratory ("NREL"), which is operated by the Aliance for Sustainable Energy, LLC ("Aliance") for the U.S. Department Of Energy ("DOE") and may be used for any purpose whatsoever.

The names DOE/NREL/ALLIANCE shall not be used in any representation, advertising, publicity or other manner whatsoever to endorse or promote any entity that adopts or uses the Model. DOE/NREL/ALLIANCE shall not provide

any support, consulting, training or assistance of any kind with regard to the use of the Model or any updates, revisions or new versions of the Model.

YOU AGREE TO INDEMNIFY DOE/NREL /ALLANCE, AND ITS AFFLIATES, OFFICERS, ACENTS, AND EMPLOYES AGAINST ANY CLAIM OR DEMAND, INCLIDING REASONABLE ATTORNEYS' FEES, RELATED TO YOUR USE, RELIANCE, OR ADOPTION OF THE MODEL FOR ANY PURPOSE WHATSOEVER. THE MODEL IS PROVIDED BY DOE/NREL/ALLANCE "AS IS' AND ANY EXPRESS OR IMPLIED WARRANTIES, INCLUDING BUT NOT LIMITED TO THE IMPLIED WARRANTIES OF MERCHANTABLITY AND FITNESS FOR A PARTICULAR PURPOSE ARE EXPRESSLY DISCLAIMED. IN NO EVENT SHALL DOF/NREL/ALLIANCE BE LIABLE FOR ANY SPECIAL, INDRECT OR CONSEQUENTIAL DAMAGES OR ANY DAMAGES WHATSOEVER, INCLUDING BUT NOT LIMITED TO CLAIMS ASSOCIATED WITH THE LOSS OF DATA OR PROFITS, WHICH MAY RESULT FROM ANY ACTION IN CONTRACT, NEGLIGENCE OR OTHER TORTIOUS CLAIM THAT ARISES OUT OF OR IN CONNECTION WITH THE USE OR PROFILMENT OF THE MODEL.

The energy output range is based on analysis of 30 years of historical weather data for nearby, and is hitended to provide an indication of the possible interannual variability in generation for a fixed (open rack) PV system at this location.



9,920 kWh/Year*

System output may range from 9,522 to 10,252kWh per year near this location.

Month	Solar Radiation (kWh/m ² /day)	AC Energy (kWh)	Energy Value (\$)
January	2.80	583	67
February	3.40	644	74
March	3.92	798	92
April	4.90	946	109
Мау	5.50	1,085	125
June	5.19	965	111
July	5.26	999	115
August	5.49	1,046	121
September	4.70	876	101
October	4.54	896	103
November	2.74	538	62
December	2.63	544	63
Annual	4.26	9,920	\$ 1,143

Location and Station Identification

School B Address (TMY3) NEW YORK LAGUARDIA ARPT, NY 40.78° N 73.88° W	7.4 mi
(TMY3) NEW YORK LAGUARDIA ARPT, NY 40.78° N 73.88° W 8 kW	7.4 mi
40.78° N 73.88° W 8 kW	
73.88° W	
8 kW	
8 kW	
•	
Premium	
Fixed (roof mount)	
41°	
225°	
14.08%	
96%	
1.1	
0.12 \$/kWh	
14.2%	
	8 kW Premium Fixed (roof mount) 41° 225° 14.08% 96% 1.1 0.12 \$/kWh 14.2%



Caution: Photovolaic system performance predictions calculated by PVWatts[®] include many inherent assumptions and uncertainties and do not reflect variations between PV technologies nor site-specific characteristics except as represented by PVWatts[®] inputs. For example, PV modules with better performance are not differentiated within PVWatts[®] from lesser performing modules. Both NREL and private companies provide more sophisticated PV modeling tools (such as the System Advisor Model at http://sam.nrel.gov) that alow for more precke and complex modeling of PV systems.

The expected range is based on 30 years of actual weather data at the given location and is intended to provide an indication of the variation you might see. For more information, please refer to this NREL report: The Error Report.

Disclaimer: The PVWatts[®] Model ("Model") is provided by the National Renewable Energy Laboratory ("NREL"), which is operated by the Aliance for Sustainable Energy, LLC ("Aliance") for the U.S. Department Of Energy ("DOE") and may be used for any purpose whatsoever.

The names DOE/NREL/ALLIANCE shall not be used in any representation, advertising, publicity or other manner whatsoever to endorse or promote any entity that adopts or uses the Model. DOE/NREL/ALLIANCE shall not provide

any support, consulting, training or assistance of any kind with regard to the use of the Model or any updates, revisions or new versions of the Model.

YOU AGREE TO INDEMNIFY DOE/NREL /ALLANCE, AND ITS AFFLIATES, OFFICERS, ACENTS, AND EMPLOYES AGAINST ANY CLAIM OR DEMAND, INCLIDING REASONABLE ATTORNEYS' FEES, RELATED TO YOUR USE, RELIANCE, OR ADOPTION OF THE MODEL FOR ANY PURPOSE WHATSOEVER. THE MODEL IS PROVIDED BY DOE/NREL/ALLANCE "AS IS' AND ANY EXPRESS OR IMPLIED WARRANTIES, INCLUDING BUT NOT LIMITED TO THE IMPLIED WARRANTIES OF MERCHANTABLITY AND FITNESS FOR A PARTICULAR PURPOSE ARE EXPRESSLY DISCLAIMED. IN NO EVENT SHALL DOF/NREL/ALLIANCE BE LIABLE FOR ANY SPECIAL, INDRECT OR CONSEQUENTIAL DAMAGES OR ANY DAMAGES WHATSOEVER, INCLUDING BUT NOT LIMITED TO CLAIMS ASSOCIATED WITH THE LOSS OF DATA OR PROFITS, WHICH MAY RESULT FROM ANY ACTION IN CONTRACT, NEGLIGENCE OR OTHER TORTIOUS CLAIM THAT ARISES OUT OF OR IN CONNECTION WITH THE USE OR PROFILMENT OF THE MODEL.

The energy output range is based on analysis of 30 years of historical weather data for nearby, and is hitended to provide an indication of the possible interannual variability in generation for a fixed (open rack) PV system at this location.



6,200 kWh/Year*

System output may range from 5,951 to 6,408kWh per year near this location.

Month	Solar Radiation (kWh/m ² /day)	AC Energy (kWh)	Energy Value (\$)
January	2.80	364	42
February	3.40	403	46
March	3.92	499	58
April	4.90	591	68
Мау	5.50	678	78
June	5.19	603	70
July	5.26	625	72
August	5.49	653	75
September	4.70	548	63
October	4.54	560	65
November	2.74	336	39
December	2.63	340	39
Annual	4.26	6,200	\$ 715

Location and Station Identification

Requested Location	School C Address
Weather Data Source	(TMY3) NEW YORK LAGUARDIA ARPT, NY 1.8 mi
Latitude	40.78° N
Longitude	73.88° W
PV System Specifications (Commercial)	
DC System Size	5 kW
Module Type	Premium
Аггау Туре	Fixed (roof mount)
Array Tilt	41°
Array Azimuth	225°
System Losses	14.08%
Inverter Efficiency	96%
DC to AC Size Ratio	1.1
Economics	
Average Cost of Electricity Purchased from Utility	0.12 \$/kWh
Performance Metrics	
Capacity Factor	14.2%

Appendix C:

Solar Thermal System Analysis





Results of annual simulation

Natural gas (H) savings: CO2 emissions avoided: DHW solar fraction: System efficiency:		332.0 therm 4,353.71 lbs 53.4 % 33.6 %
DHW heating energy supply: Solar contribution to DHW: Energy from auxiliary heating:	36.72 MMBtu 22.26 MMBtu 19.4 MMBtu	
Installed collector power: Installed solar surface area (gross): Irradiation on to collector surface (active): Energy delivered by collectors: Energy delivered by collector loop:	35.97 kBtu/hr 162.12 ft ² 66.17 MMBtu 30.27 MMBtu 25.96 MMBtu	439.73 kBtu/ft² 201.16 kBtu/ft² 172.51 kBtu/ft²



Site data

Climate data

Location: Climate data record: Total annual global irradiation: Latitude: Longitude:

Domestic hot water

Average daily consumption: Desired temperature: Consumption profile: Cold water temperature: Circulation:

NEW YORK LAGUARDIA ARPT "NEW YORK LAGUARDIA ARPT" 1436.389 kWh/m² 40.77 ° 73.87 °

162.5 gal 130 °F High School February:50.9 °F / August:62.6 °F No

System components

Collector loop

Manufacturer:

Type: Number: Total gross surface area: Total active solar surface area: Tilt angle: Azimuth:

DHW standby tank

Manufacturer: Type: Volume:

Solar preheating tank

Manufacturer: Type: Volume:

Auxiliary heating

Manufacturer: Type: Nominal output:

Legend

center With test report

Viessmann Manufacturing Company (US) Inc. 200-FM, SV2F/SH2F 6.00 162.12 ft² 150.48 ft² 60 ° 45 °

Existing Hot water tank - 300 gal 300 gal

Viessmann Manufacturing US Inc 2 x Vitocell 300-V 2 x 119 gal

Standard Gas-fired boiler -400 kBtu/hr 400 kBtu/hr





Solar energy consumption as percentage of total consumption

Daily maximum collector temperature



These calculations were carried out by T*SOL Pro 5.0 - the simulation program for solar thermal heating systems. The results are determined from the computation of a mathematical model with variable time steps of up to 6 minutes. Actual yields can deviate from these values due to fluctuations in climate, consumption and other factors. The system schematic diagram above does not represent and cannot replace a full technical drawing of the solar system.

T*SOL Pro 5.0 (R 6)

Dr. Valentin EnergieSoftware GmbH



A Viessmann solar system will enjoy a significantly longer life if regular stagnation is not designed into the system. When a year-round use for the collected solar heat cannot be identified, then a small inexpensive heat dump is recommended. A heat dump should be installed for the following situations:

- 1. Oversized solar DHW systems and/or where extended periods of stagnation are anticipated.
- 2. If the T*SOL report shows numerous instances of maximum collector temperature over 200F.

*If a system falls under any of these categories, then a heat dump should be installed and sized based on 225 Btu / square foot of collector absorber area.



Energy balance schematic



Legend

1	Irradiation on to collector surface (active)	66 MMBtu
1.1	Optical collector losses	18 MMBti
1.2	Thermal collector losses	18 MMBtu
2	Energy from collector array	30 MMBti
2.2	Solar energy to preheating tank	26 MMBtu
2.5	Internal piping losses	2,172 kBtı
2.6	External piping losses	2,139 kBtı
3.1	Tank losses	5 MMBtu
3.3	Preheating tank to tank	22 MMBtu
4.1	Tank losses (S)	4 MMBti
6	Final energy	26 MMBtu
6.1	Supplementary energy to tank	19 MMBti
6.5	Electric element	0 kBtı
9	DHW energy from tank	37 MMBtu



Glossary

1	Irradiation on to collector surface (active)
	Solar energy irradiated onto tilted collector area (active surface area)
1.1	Optical collector losses
	Reflection and other losses
1.2	Thermal collector losses
	Heat conduction and other losses
2	Energy from collector array
	Energy output at collector array outlet (i.e. before piping)
2.2	Solar energy to preheating tank
	Collector array energy minus piping losses
2.5	Internal piping losses
	Internal piping losses
2.6	External piping losses
	External piping losses
3.1	Tank losses
	Heat losses via surface area
3.3	Preheating tank to tank
	Heat from preheating tank to tank
4.1	Tank losses (S)
	Heat losses via surface area
6	Final energy
	Final energy supply to system. This can be from natural gas, oil or electricity (not including
	solar energy) and takes efficiency into account.
6.1	Supplementary energy to tank
	Supplementary energy (e.g. boiler) to tank
6.5	Electric element
	Energy from electric water heater element
9	DHW energy from tank
	Heat from tank (exluding circulation) for DHW consumption





Results of annual simulation

71.95 kBtu/hr	
143.03 MMBtu	475.27 kBtu/ft ²
65.28 MMBtu 62.52 MMBtu	216.91 kBtu/ft ²
	207.75 KDtu/It-
98.47 MMBtu	
54.92 MMBtu	
50.1 MMBtu	
	827.2 therm
	10,847.50 lbs
	52.3 %
	38.4 %
	71.95 kBtu/hr 324.24 ft ² 143.03 MMBtu 65.28 MMBtu 62.52 MMBtu 98.47 MMBtu 54.92 MMBtu 50.1 MMBtu



Site data

Climate data

Location: Climate data record: Total annual global irradiation: Latitude: Longitude:

Domestic hot water

Average daily consumption: Desired temperature: Consumption profile: Cold water temperature: Circulation:

NEW YORK LAGUARDIA ARPT "NEW YORK LAGUARDIA ARPT" 1436.389 kWh/m² 40.77 ° 73.87 °

435.8 gal 130 °F High School February:50.9 °F / August:62.6 °F No

System components

Collector loop

Manufacturer:

Type: Number: Total gross surface area: Total active solar surface area: Tilt angle: Azimuth:

DHW standby tank

Manufacturer: Type: Volume:

Solar preheating tank

Manufacturer: Type: Volume:

Auxiliary heating

Manufacturer: Type: Nominal output:

Legend

center With test report

Viessmann Manufacturing Company (US) Inc. 200-FM, SV2F/SH2F 12.00 324.24 ft² 300.96 ft² 45 ° 45 °

Existing Hot water tank - 500 gal 500 gal

Viessmann Manufacturing US Inc 4 x Vitocell 300-V 4 x 119 gal

Standard Gas-fired boiler -500 kBtu/hr 500 kBtu/hr





Solar energy consumption as percentage of total consumption

Daily maximum collector temperature



These calculations were carried out by T*SOL Pro 5.0 - the simulation program for solar thermal heating systems. The results are determined from the computation of a mathematical model with variable time steps of up to 6 minutes. Actual yields can deviate from these values due to fluctuations in climate, consumption and other factors. The system schematic diagram above does not represent and cannot replace a full technical drawing of the solar system.

T*SOL Pro 5.0 (R 6)

Dr. Valentin EnergieSoftware GmbH



A Viessmann solar system will enjoy a significantly longer life if regular stagnation is not designed into the system. When a year-round use for the collected solar heat cannot be identified, then a small inexpensive heat dump is recommended. A heat dump should be installed for the following situations:

1. Oversized solar DHW systems and/or where extended periods of stagnation are anticipated.

2. If the T*SOL report shows numerous instances of maximum collector temperature over 200F.

*If a system falls under any of these categories, then a heat dump should be installed and sized based on 225 Btu / square foot of collector absorber area.


Energy balance schematic



Legend

1	Irradiation on to collector surface (active)	143 MMBtu
1.1	Optical collector losses	39 MMBtu
1.2	Thermal collector losses	39 MMBtu
2	Energy from collector array	65 MMBtu
2.2	Solar energy to preheating tank	63 MMBtu
2.5	Internal piping losses	388 kBtu
2.6	External piping losses	2,374 kBtu
3.1	Tank losses	7 MMBtu
3.3	Preheating tank to tank	55 MMBtu
4.1	Tank losses (S)	8 MMBtu
6	Final energy	66 MMBtu
6.1	Supplementary energy to tank	50 MMBtu
6.5	Electric element	0 kBtu
9	DHW energy from tank	98 MMBtu



Glossary

1	Irradiation on to collector surface (active)
	Solar energy irradiated onto tilted collector area (active surface area)
1.1	Optical collector losses
	Reflection and other losses
1.2	Thermal collector losses
	Heat conduction and other losses
2	Energy from collector array
	Energy output at collector array outlet (i.e. before piping)
2.2	Solar energy to preheating tank
	Collector array energy minus piping losses
2.5	Internal piping losses
	Internal piping losses
2.6	External piping losses
	External piping losses
3.1	Tank losses
	Heat losses via surface area
3.3	Preheating tank to tank
	Heat from preheating tank to tank
4.1	Tank losses (S)
	Heat losses via surface area
6	Final energy
	Final energy supply to system. This can be from natural gas, oil or electricity (not including
	solar energy) and takes efficiency into account.
6.1	Supplementary energy to tank
	Supplementary energy (e.g. boiler) to tank
6.5	Electric element
	Energy from electric water heater element
9	DHW energy from tank
	Heat from tank (exluding circulation) for DHW consumption





Results of annual simulation

Installed collector power:	47.96 kBtu/hr	
Installed solar surface area (gross):	216.16 ft ²	
Irradiation on to collector surface (active):	88.22 MMBtu	439.73 kBtu/ft ²
Energy delivered by collectors:	41.07 MMBtu	204.71 kBtu/ft ²
Energy delivered by collector loop:	37.15 MMBtu	185.18 kBtu/ft ²
DHW heating energy supply:	57.66 MMBtu	
Solar contribution to DHW:	32.00 MMBtu	
Energy from auxiliary heating:	30.3 MMBtu	
Natural gas (H) savings:		478.3 therm
CO2 emissions avoided:		6,272.02 lbs
DHW solar fraction:		51.4 %
System efficiency:		36.3 %

T*SOL Pro 5.0 (R 6)



Site data

Climate data

Location: Climate data record: Total annual global irradiation: Latitude: Longitude:

Domestic hot water

Average daily consumption: Desired temperature: Consumption profile: Cold water temperature: Circulation:

NEW YORK LAGUARDIA ARPT "NEW YORK LAGUARDIA ARPT" 1436.389 kWh/m² 40.77 ° 73.87 °

255.2 gal 130 °F High School February:50.9 °F / August:62.6 °F No

System components

Collector loop

Manufacturer:

Type: Number: Total gross surface area: Total active solar surface area: Tilt angle: Azimuth:

DHW standby tank

Manufacturer: Type: Volume:

Solar preheating tank

Manufacturer: Type: Volume:

Auxiliary heating

Manufacturer: Type: Nominal output:

Legend

center With test report

Viessmann Manufacturing Company (US) Inc. 200-FM, SV2F/SH2F 8.00 216.16 ft² 200.64 ft² 60 ° 45 °

Existing Hot water tank - 255 gal 255 gal

Viessmann Manufacturing US Inc 3 x Vitocell 300-V 3 x 119 gal

Standard Gas-fired boiler -300 kBtu/hr 300 kBtu/hr





Solar energy consumption as percentage of total consumption

Daily maximum collector temperature



These calculations were carried out by T*SOL Pro 5.0 - the simulation program for solar thermal heating systems. The results are determined from the computation of a mathematical model with variable time steps of up to 6 minutes. Actual yields can deviate from these values due to fluctuations in climate, consumption and other factors. The system schematic diagram above does not represent and cannot replace a full technical drawing of the solar system.

T*SOL Pro 5.0 (R 6)

Dr. Valentin EnergieSoftware GmbH



A Viessmann solar system will enjoy a significantly longer life if regular stagnation is not designed into the system. When a year-round use for the collected solar heat cannot be identified, then a small inexpensive heat dump is recommended. A heat dump should be installed for the following situations:

1. Oversized solar DHW systems and/or where extended periods of stagnation are anticipated.

2. If the T*SOL report shows numerous instances of maximum collector temperature over 200F.

*If a system falls under any of these categories, then a heat dump should be installed and sized based on 225 Btu / square foot of collector absorber area.



Energy balance schematic



Legend

1	Irradiation on to collector surface (active)	88 MMBtu
1.1	Optical collector losses	24 MMBtu
1.2	Thermal collector losses	23 MMBtu
2	Energy from collector array	41 MMBtu
2.2	Solar energy to preheating tank	37 MMBtu
2.5	Internal piping losses	1,952 kBtu
2.6	External piping losses	1,966 kBtu
3.1	Tank losses	5 MMBtu
3.3	Preheating tank to tank	32 MMBtu
4.1	Tank losses (S)	5 MMBtu
6	Final energy	40 MMBtu
6.1	Supplementary energy to tank	30 MMBtu
6.5	Electric element	0 kBtu
9	DHW energy from tank	58 MMBtu



Glossary

1	Irradiation on to collector surface (active)
	Solar energy irradiated onto tilted collector area (active surface area)
1.1	Optical collector losses
	Reflection and other losses
1.2	Thermal collector losses
	Heat conduction and other losses
2	Energy from collector array
	Energy output at collector array outlet (i.e. before piping)
2.2	Solar energy to preheating tank
	Collector array energy minus piping losses
2.5	Internal piping losses
	Internal piping losses
2.6	External piping losses
	External piping losses
3.1	Tank losses
	Heat losses via surface area
3.3	Preheating tank to tank
	Heat from preheating tank to tank
4.1	Tank losses (S)
	Heat losses via surface area
6	Final energy
	Final energy supply to system. This can be from natural gas, oil or electricity (not including
	solar energy) and takes efficiency into account.
6.1	Supplementary energy to tank
	Supplementary energy (e.g. boiler) to tank
6.5	Electric element
	Energy from electric water heater element
9	DHW energy from tank
	Heat from tank (exluding circulation) for DHW consumption

Appendix D:

Equipment Cutsheets

Technical Data Manual

Model Nos. and pricing: see Price List

Flat plate solar collectors for the harnessing of solar energy Panels with 25 ft² (2.32 m²) absorber surface

VITOSOL. 200-FM





Product may not be exactly as shown

Flat plate solar collectors

For vertical (model SV) or horizontal (model SH) installation on sloped and flat roofs. For integration on walls (model SH only).

To produce domestic hot water, or to supplement low-temperature heating systems or swimming pools via a heat exchanger.

0C-100 Cortifi



Benefits

- High performance, premium version flat plate collector, thanks to unique frame design and highly efficient ThermProtect coated aluminum absorbers.
- Suitable for many residential or commercial applications with vertical or horizontal versions available. Suitable for DHW or pool heating, space heating applications.
- Attractive appearance with powder coated dark blue frame, endless glass seal and minimal space between collectors. No screws or rivets used in frame for clean, neat finish.
- Rugged, high-quality construction using impact-resistant low-iron solar glass, copper piping, aluminum absorber and frame and non-degrading thermal insulation.
- Permanently sealed and high stability through all-around folded aluminum frame and endless glass seal.
- Universal application on flat, sloped roofs or freestanding, vertical (model SV) or horizontal (model SH) orientation. Model SH is suitable for installations on walls. Connect up to 12 collectors in one array for commercial or residential systems.
- Fast installation with flexible connection pipes and quick-connect fittings. Prefabricated collector mounting hardware ensures easy connection to roofs.
- Maximum system performance and reliability with a full range of solar system components designed to integrate seamlessly.
- **Quality tested** to Solar Keymark testing requirements.
- **Certified** to the Solar Rating and Certification Corporation (SRCC) OG-100 Standard.



Legend

- A Solar glass cover, 0.13" (3.2 mm) thick
- (B) Aluminum cover strip in dark blue
- C Continuous flexible seal for solar glass cover
- D Aluminum absorber sheet with ThermProtect coating
- (E) Meander-shaped copper pipe
- (F) Melamine resin foam insulation
- (G) Melamine resin foam insulation
- (H) Aluminum frame in dark blue
- K Aluminum-zinc coated sheet steel back panel



Construction and function

The main component of the Vitosol 200-FM is the ThermProtect switching absorber. It ensures high absorption of solar radiation and low emission of thermal radiation. When the collector temperature becomes elevated > 167°F (>75°C) the absorber will switch or transition to a higher rate of thermal emission. The net result is that the collector will operate at a reduced temperature as the absorber will be rejecting excess thermal radiation. The ThermProtect switching absorber limits the maximum or stagnation temperature of the collector 293°F (145°C). A meandershaped copper pipe, through which the heat transfer medium flows, is permanently embedded into the absorber.

The heat transfer medium channels the absorber heat through the copper pipe. The absorber is encased in a highly insulated collector housing, which minimizes collector heat losses. The high quality thermal insulation provides temperature stability and is free from gas emissions.

The cover consists of a solar glass panel with a very low iron content, thereby reducing reflection losses. The tempered solar glass is 3.2 mm thick, making it very resistant to weather influences.

The glass is set into the collector frame with a continuous profiled seal, preventing water from penetrating into the collector. This ensures a long and reliable service life for all internal components.

The collector housing consists of a one-piece powder-coated aluminum frame into which the solar glass is permanently sealed.

Up to twelve collectors can be joined quickly and easily to form a single collector array. For this, the standard equipment includes flexible connection pipes, sealed with O-rings (see picture below).

A connection kit with clamping ring fittings enables the collector array to be quickly connected to the pipes of the solar circuit. The collector temperature sensor is installed in the solar circuit flow using a sensor well set.



Specification

Vitosol 200-FM		SV2F	SH2F
Gross area	ft ² (m ²)	27.0 (2.51)	27.0 (2.51)
Absorber area	ft ² (m ²)	25.0 (2.32)	25.0 (2.32)
Aperture area * 1	ft ² (m ²)	25.1 (2.33)	25.1 (2.33)
Spacing between collectors	in. (mm)	3⁄4 (21)	3⁄4 (21)
Dimensions*2			
Width	in. (mm)	41¾ (1056)	93¾ (2380)
Height	in. (mm)	93¾ (2380)	41¾ (1056)
Depth	in. (mm)	3½ (90)	3½ (90)
Optical efficiency*3	%	81.3	81.3
Heat loss coefficient U1	W/(m ² ·K)	4.421	4.579
Heat loss coefficient U2	W/(m ² · K ²)	0.0210	0.0239
Thermal capacity	kJ/(m² · K)	4.9	5.97
Weight (dry)	lb (kg)	90.2 (40.9)	90.2 (40.9)
Fluid capacity	USG	0.48	0.63
(heat transfer medium)	(L)	(1.83)	(2.40)
Maximum working pressure*4	psig (bar)	87 (6)	87 (6)
Maximum stagnation temperature*5	°F (°C)	293 (145)	293 (145)
Connection	in. (mm)	3⁄4 (22)	3⁄4 (22)
Requirements for installation surface and		Roof construction with a	dequate load capacity
anchorage		for prevailing wind forces	;
Mechanical test load			
Max. tested positive load	lb/ft ² (Pa)	73.1 (3500)	73.1 (3500)
Max. tested negative load	lb/ft ² (Pa)	62.7 (3000)	62.7 (3000)

*1 Important for system design considerations.

*2 Dimensions rounded to the nearest $\frac{1}{4}$ inch.

*3 Based on absorber area.

*4 In sealed systems, operating pressure of at least 44 psig + 0.45 psig x static head (ft.)
 (3.0 bar + 0.1 bar x static head (m) must be present in the collectors in cold condition.

*5 The stagnation temperature is the temperature which applies to the hottest point of the collector at a global radiation intensity of 3412 Btu/h / 1000 W when no heat is conducted by the heat transfer medium.





Model SH2F (Horizontal mounting)



Product Information Standard Equipment/Accessories

Standard equipment

Vitosol 200-FM, Models SH2F and SV2F come fully assembled in shrink-wrap packaging and ready to be connected.

Note: Viessmann offers complete solar heating system combi packages, as well as comprehensive design support in order to facilitate the component selection process.

Accessories

- Accessories (individually packed, depending on order):
- Mounting hardware with technical literature
- Interconnection pipes with insulation
- General connection set
- Sensor well set
- Solar Divicon (pumping station for the collector circuit)
- Electronic differential temperature control
- Automatic air vent with air separator
- Fast air vent valve with tee and shutoff valve
- System filling manifold
- Solar hand pump
- Solar expansion tank
- Heat transfer medium

Mounting hardware

The mounting hardware consists of components required for the relevant method of installation, such as:

Roof brackets, mounting plates, mounting rails,

connecting elements for mounting rails, clamping bolts, screws and nuts.

Sloped roof hardware

Required for mounting collector directly onto shingled roof. Raises collector $3\frac{1}{2}$ " (88.9 mm) above the roof.





Flat roof hardware

Required for freestanding, flat roof installations.



General connection set

Required to connect solar collector to system piping. One set required per collector array - max. 269 ft² (25 m²).

Pipe connection set

Required to connect multiple solar collectors.



SCU 124/224/345

Electronic differential temperature control for solar heating.



Solar Divicon

Preassembled pumping station for solar collector circuit. Includes: 3-speed pump (2 sizes), pressure gauge, 2 thermometers, 2 ball valves, pressure relief valve, flow meter, 2 flow check valves, air separator, system fill manifold, and foam insulation cover.



Heat transfer medium

All Vitosol collectors have a minimum required flow rate (low flow) and maximum flow rate (high flow). The collectors must operate within this range and the system designer must choose a flow rate based on the specific parameters of the system. At the same collector output, a higher flow rate means a lower ΔT or temperature spread across the collector array. Inversely a lower flow rate will have a higher ΔT or temperature spread across the collector array. When the ΔT or temperature spread across the collector array becomes too large, the efficiency of the collectors will also decrease.

For larger solar installations, high flow is usually not recommended as this results in bigger pumps and larger pipe sizes. Typically low flow would be used as the decreased flow requirements result in smaller pumps which would use less energy, and small pipe sizes, reducing the overall installation and operating cost for the system.

Operating modes:

Low flow operation

Operation with flow rates up to approx. 0.014 USG/min/ft² 0.010 - 0.0143 USG/min/ft² (25 - 35 L/h/m²)

High flow operation

Operation with flow rates greater than 0.014 USG/min/ft² 0.0143 - 0.0245 USG/min/ft² (35 - 60 L/h/m²)

Flow Velocity

To minimize the pressure drop through the solar thermal system pipework, the flow velocity in the pipe should not exceed 3.3 ft/s (1 m/s). We recommend flow velocities of between 1.3 and 2.3 ft/s (0.4 and 0.7 m/s). At these flow velocities, a pressure drop of between 0.12 and 0.3 "w.c. (1 and 2.5 mbar) /m pipe length will result. For the installation of collectors, we recommend sizing the pipes as for a normal heating system according to flow rate and velocity.

Note: A higher flow velocity results in a higher pressure drop and potentially could erode the walls of the pipework. If the flow velocity is too low, the system will not capture or move the air trapped in the system.

Any residual air that has collected at the collector must be routed downwards through the solar return line to the air vent in the solar divicon. This will have to be manually vented.

High-flow mode

High-flow mode is best suited for small scale systems consisting of less than 8 collectors.

Medium and low-flow modes

Medium and low-flow modes are best suited for larger scale collector arrays consisting of greater than 8 collectors.

Vitosol 200-FM recommended flow rates per individual collector

Flow	High flow mode	Medium flow mode	Low flow mode
	USG/min (L/min)	USG/min (L/min)	USG/min (L/min)
SV and SH models	0.61 (2.32)	0.45 (1.74)	0.31 (1.16)

Collector array flow rates

Flow	High flow mode USG/min (L/min)	Medium flow mode USG/min (L/min)	Low flow mode USG/min (L/min)
2 collectors	1.22 (4.6)		
3 collectors	1.83 (6.9)		
4 collectors	2.44 (9.2)		
5 collectors	3.05 (11.5)		
6 collectors	3.66 (13.8)		
8 collectors		3.6 (13.6)	2.48 (9.4)
10 collectors		4.5 (17.0)	3.1 (11.7)
12 collectors		5.4 (20.4)	3.72 (14.1)

Vitosol-FM, Type SV and SH High Flow Operation (single-sided connection)



Legend

(A) Collector temperature sensor (field installed)

Vitosol-FM, Type SV and SH Low Flow Operation (single-sided connection)



Single array less than or equal to (\leq) 8x flat plate collectors

Legend

A Collector temperature sensor (field installed)

Vitosol-FM, Type SV and SH High Flow Operation (connection on alternate sides)



Legend

(A) Collector temperature sensor (field installed)

Vitosol-FM, Type SV and SH Low Flow Operation (connection on alternate sides)



Single array less than or equal to (\leq) 10x flat plate collectors

Legend

(A) Collector temperature sensor (field installed)

Vitosol 200-FM Technical Data Pressure Drop of Vitosol-FM, Type SV and SH



Relative to water, corresponds to Tyfocor HTL at approx. $140^{\circ}C$ (60°C).

Note: For multiple Vitosol-F collector arrays, use the flow rate per individual collector to calculate the pressure drop.

Product Information Determining the Collector Row Distance "z"



 $z = \underline{h \bullet \sin (180^{\circ} - (\alpha + \beta))}{\sin \beta}$

Legend:

- z = Collector row distance
- h = Collector height
- 200-FM model SV = 93¼ in. (2380 mm) 200-FM model SH = 41¼ in. (1056 mm)
- α = Collector angle of inclination 200-FM model SV = 25° - 60°
 - 200-FM model SH = $25^{\circ} 80^{\circ}$ = Solar angle

$$\beta =$$
Solar ang

 $\beta = (90^{\circ} - 23.5^{\circ}) - Latitude$

IMPORTANT

When installing several collectors in series, maintain a distance of "z".

Example:

Model SV Toronto is located at approx. 43° latitude.

 Determine the angle of the sun b. This should be chosen so that the midday sun December 21 falls on the second row of collectors without being obstructed by shadows.

Solar angle β : $\beta = (90^{\circ} - 23.5^{\circ})$ - latitude (23.5° should be accepted as constant value for northern latitudes)

 $\beta = (90^{\circ} - 23.5^{\circ}) - 43^{\circ} = 23.5^{\circ}$

2. Calculating dimension "z": h = 2380 mm $\alpha = 45^{\circ}$

 $\beta = 23.5^{\circ}$

- $z = \frac{2380 \text{ mm} \cdot \sin (180^{\circ} (45^{\circ} + 23.5^{\circ}))}{\sin 23.5^{\circ}}$
- $z = \frac{2380 \text{ mm} \cdot \sin 111.5^{\circ}}{\sin 23.5^{\circ}}$
- z = 218.6 in. (5553 mm)



Refer to Vitosol System Design Guide for more information on calculating "z".

Note: Contact Viessmann Solar Tech Support for assistance with calculating distance "z".

Solar System Design

When designing a solar thermal system, the engineer or installing contractor must carefully select system components to ensure efficient, trouble free operation. During the design phase it is recommended that the following details be addressed:

- Type of collector to be used and how it will be installed
- The recommended flow rate for each collector or collector array
- The supply/return pipe size, material and total length of run
- Recommended size of the solar storage/buffer tank

- The pressure drop of the solar collectors, piping, solar pumps, tanks, heat exchangers and other hydronic devices added to the system
- The size of the solar pump required based on flow and pressure drop of the system
- The size of the expansion tank required based on the height of the installation and the thermal expansion of the solar fluid. Since there is a potential for steam to be created, this will also need to be considered when sizing the expansion tank



Refer to Vitosol System Design Guide System sizing information which is available online.

Note: Contact Viessmann Solar Tech Support for assistance with solar sizing.

ThermProtect Absorber Coating

ThermProtect temperature characteristics

Solar collector	Solar tank operation	Emission	
temperature		3	
up to 167°F	Solar storage tank	~ 5%	
(75°C)	being heated		
from 167°F to	Solar storage tank at	$\sim 5\%$ increases	
293°F	max. temperature	to ~ 40%	
(75°C to 145°C)			

- The absorber selective coating (ThermProtect), optical characteristics changes depending on operating temperature
- The rate of absorption α does not change
- The rate of emission ε automatically adapts to the system





Scan for digital copy of this document



Viessmann Manufacturing Company Inc. 750 McMurray Road Waterloo, Ontario • N2V 2G5 • Canada **TechInfo Line 1-888-484-8643** 1-800-387-7373 • Fax (519) 885-0887 www.viessmann.ca • info@viessmann.ca Viessmann Manufacturing Company (U.S.) Inc. 45 Access Road Warwick, Rhode Island • 02886 • USA **TechInfo Line 1-888-484-8643** 1-800-288-0667 • Fax (401) 732-0590 www.viessmann-us.com • info@viessmann-us.com



DHW storage tanks **VITOCELL**



Heating Systems Industrial Systems Refrigeraation Systems



Vitocell domestic hot water storage tanks 42 to 119 USG / 160 to 450 ltr $\,$

Rediscover domestic hot water comfort

With a Vitocell tank from Viessmann, you increase your comfort level and your savings at the same time - the Vitocell line offers something for everyone.

With a new Vitocell tank from Viessmann, you increase your comfort level and your savings at the same time! Fast recovery rates, large water volume, low standby losses translate into comfort, convenience, efficiency and reliability. Choose Vitocell – choose peace of mind.

Something for everyone

Tanks are available in vertical and horizontal designs, for placement beside or underneath a boiler, from 42 to 119 USG / 160 to 450 liters. Also, with Viessmann Integrated System Technology, boiler, tank and control match perfectly. Everything fits together, installs quickly and arrives factory-adjusted - fast installation and maximum system performance are guaranteed. Find out on the following pages how you can improve your domestic hot water experience today.

Vitocell 300

Made of high-alloy stainless steel, the Vitocell 300 models are not only extremely hygienic, but are known for their operational reliability and long service life.

Vitocell 100

This series is an economical choice for convenient and efficient domestic hot water production. The Vitocell 100 models are made of steel with a Ceraprotect two-coat enamel finish and a consumable anode to protect against corrosion.

Satisfaction guaranteed

The large heat exchanger surfaces of the Vitocell tanks extend right to the tank bottom and ensure an abundant supply of hot water and even water temperatures all day long. The heat exchanger coils are arranged for efficient venting and draining and facilitate start-up and smooth operation. HCFC-free insulation (foamed-in-place or wrap-around) reduces standby losses and increases operating efficiency.

Maximum System Performance

In contrast to most conventional direct-fired tanks, indirect-fired tanks from Viessmann, such as the Vitocell line, use the heating water from the boiler to heat the tank water. Space heating and domestic hot water production are integrated into one system - maximum system performance regulated by one control, powered by one burner!



Did you know? You can save up to 50% in operating cost with Viessmann indirect-fired domestic hot water storage tanks.





VITOCELL 100-V

High performance and quality construction for economical domestic hot water Vertical, indirect-fired domestic hot water tank, 42 to 119 USG

The Vitocell 100 tank series is the economical choice for reliable and efficient domestic hot water production. Single-coil tanks are available in 4 sizes from 42 to 119 USG / 160 to 450 ltr. Dual-coil tanks for use in solar thermal applications are available in 2 sizes, 79 and 119 USG / 300 and 450 ltr.

Quality construction

The steel construction of the Vitocell 100 tanks has a two-coat enamel finish which protects all interior surfaces from corrosion.

While the base layer provides a solid bond between the steel construction and the enamel finish, the second layer protects the tank from corrosion.

For additional protection each tank comes with a consumable anode.



Convenience

Fast recovery rates and the large heat exchanger surfaces of the tank coil ensure an abundant supply of hot water and even water temperatures at all times.

For more flexibility and to meet larger domestic hot water demands, take advantage of a multi-tank installation (Vitocell-V 100, 79 and 119 USG / 300 and 450 ltr only).

Economy

Extremely efficient domestic hot water production via boiler (indirect-fired). Save up to 50% in operating cost compared to most conventional (direct-fired) domestic hot water production.

Highly-effective HCFC-free foamedin-place or wrap-around insulation reduces standby losses and operating cost.

Solar tank

Discover new ways of domestic hot water production! With the Vitocell-B 100 dual-coil tank you can have it two ways - via solar collector and/or the heating boiler. Find out more on pages 8/9.

Vitocell 100-V single-coil tank

- Heat exchanger coil : heat is transferred from the boiler to the tank water
- Magnesium anode : provides additional active corrosion protection
- 3 HCFC-free, foamed-in-place insulation





Specifications

- Four single-coil tank sizes from 42 to 119 USG / 160 to 450 ltr
- Two dual-coil tank sizes from 79 and 119 USG / 300 and 450 ltr
- Vitocell 100-V, 119 USG / 450 ltr is supplied with removable soft polyester fiber (PET) insulation for easy handling.

Benefits at a glance

- Large heat exchanger surfaces for fast recovery rates and a constant and reliable DHW supply.
- Tank coil extends to tank bottom which guarantees even and consistent water temperatures at all times.
- Quality steel construction and Viessmann Ceraprotect permanent two-coat enamel finish for operational reliability and long service life.
- Magnesium anode provides additional active corrosion protection.
- Save up to 50% of your operating costs with extremely efficient indirect hot water production by a condensing boiler.
- Highly effective, HCFC-free insulation keeps standby losses and operating cost to a minimum.
- Ideal for small spaces with zero clearance to combustibles.
- Satisfy large DHW demands by connecting multiple Vitocell 100-V tanks (79 and 119 USG) to form a tank battery.



VITOCELL 300-V/-H

Comfort, convenience and reliability for abundant supply of domestic hot water Vertical and horizontal, indirect-fired domestic hot water tank, 42 to 119 USG

The Vitocell 300 is the leading tank series in the Vitocell line of domestic hot water storage tanks. It's extremely durable, efficient, hygienic and provides all the hot water you need.

Available in vertical and horizontal designs, from 42 to 119 USG / 160 to 450 liters.

Long Service Life

Both tank and heat exchanger are made of SA240-316 Ti high-performance stainless steel, a material known for its durability, hygiene, acid resistance and aesthetic appearance. There is minimal wear - no corrosion protection is needed - and this maximizes your cost savings.

Comfort

Fast recovery rates due to large heat exchanger surfaces of the tank coil ensure an abundant supply of hot water and even water temperatures at all times. To meet the requirements of multiple-family housing you have the option of combining several Vitocell 300 tanks into 'tank batteries' - beside each other when room is available, or stacked (horizontal design) when space is at a premium.

Efficiency

Extremely efficient domestic hot water production via condensing boiler (indirect-fired). Save up to 50% in operating cost compared to most conventional (direct-fired) domestic hot water production. Highly effective HCFC-free foamed-in-place or wrap-around insulation reduces standby losses and operating cost.

Solar tank

Discover new ways of domestic hot water production! With the Vitocell-B 300 dual-coil tank you can have it two ways - via solar collector and/or the heating boiler. Find out more on pages 8/9.



Vitocell 300-H horizontal tank

- Stainless steel heat exchanger coil extends to tank bottom to heat entire water volume
- 2 Foamed-in-place HCFC-free insulation
- 3 316Ti Stainless steel construction
- Clean-out opening





Specifications

- Three vertical single-coil tank sizes from 53 to 119 USG / 200 to 450 ltr
- Four horizontal single-coil tank sizes from 42 to 119 USG / 160 to 450 ltr
- Two vertical dual-coil tank sizes from 79 to 119 USG / 300 and 450 ltr
- Tank body and heat exchanger coil constructed of SA240-316 Ti stainless steel

Benefits at a glance

- Peace of mind with lifetime warranty for residential installations.
- Large heat exchanger surfaces for fast recovery rates and a constant and reliable DHW supply.
- Tank coil extends to tank bottom guaranteeing even and consistent water temperatures at all times.
- High alloy stainless steel construction provides operational reliability and a long service life.
- Scale and corrosion resistant, the Vitocell 300 is ideal for areas with poor water quality.
- Save up to 50% of your operating with extremely efficient indirect hot water production by a condensing boiler.
- Highly effective (HCFC-free) insulation keeps standby losses and operating cost at a minimum.
- Satisfy large DHW demands by connecting multiple Vitocell 300
 DHW tanks to form a tank battery. Horizontal tanks can be stacked.
- Ideal for small spaces with zero clearance to combustibles.

VITOCELL 300-B/100-B

Solar thermal sytems are ideal for integration with your indirect-fired DHW tank Vertical, indirect-fired dual-coil DHW tank, 79 to 120 USG



Vitosol 200-F flat plate solar collectors

Integrating indirect-fired domestic hot water (DHW) heating with your gas-fired condensing boiler can save as much as 50% in operating costs when compared to conventional direct-fired hot water production.

Our complete line of DHW storage tanks offers high-quality construction and fast recovery rates for an abundant supply of DHW at all times. Plus, with thick thermal insulation, your DHW is guaranteed to stay hot. In addition to vertical and horizontal DHW storage tanks, choose from economical enamel-lined or premium stainless steel construction for a variety of applications.

Your economical choice

The Vitocell 100 Series meets all demands for comfortable and economical DHW heating. With steel construction, Ceraprotect enamel coating and a magnesium anode, the Vitocell 100 ensures operational reliability and a long service life. Single-coil tanks are available in 4 sizes from 42 to 119 USG. Dual-coil tanks for use in solar thermal applications are available in 2 sizes, 79 and 119 USG.

Your premium choice

Vitocell 300 tanks are made from corrosionresistant, high-alloy stainless steel to satisfy the most stringent hygiene standards. With its premium-quality construction, the Vitocell 300 offers long-term, reliable operation and comes with a lifetime warranty. Vitocell 300 tanks meet the stringent standards required to carry the Environmental Choice logo. Single-coil tanks are available in 7 sizes from 42 to 119 USG. Dual-coil tanks are available in 2 sizes, 79 and 119 USG.

Solar hot water heating

Our dual-coil solar tank allows both the solar collectors and gas-fired condensing boiler to produce your home's DHW. Solar heat is transferred using the lower coil, while backup heat is supplied by the heating boiler, as required, via the upper coil (see illustration). By using solar energy to help generate your home's DHW, you can lower your heating bill further without compromising your hot water supply.

Vitocell 100-B dual-coil solar tank

- 1 Lower coil : Heat is transferred from the solar collectors to the tank water
- 2 Upper coil : Additional heat supplied by the high-efficiency boiler
- 3 Stainless steel construction (Vitocell 300)
- 4 Clean-out opening



How it works

The tank has two coils. Via the bottom coil, heat is transferred from the solar collectors to the tank water. On days when the heat transfer from the solar collectors is too low, the boiler uses the top coil to supply additional heat to the tank water.

Integration with an indirect-fired hot water tank

If your home uses a hot water based heating system, you have the option of an integrated single-tank system. Using a dual-coil storage tank, both the solar collectors and gas-fired condensing boiler contribute to DHW production.

High performance solar systems

Built on more than 30 years of experience, our high-performance flat plate and vacuum tube solar collectors and system components deliver superior year-round performance in a variety of applications. Plus, for residential installations, we offer complete solar system packages that simplify ordering and installation.



Technical Specifications



Vitocell 100-V and Vitocell 100-B indirect-fired vertical DHW storage tank

Model		CVA	CVA	CVA	CVA	CVB*	CVB*
Capacity	USG	42	53	79	119	79	119
	ltr	160	200	300	450	300	450
Dimensions	Width	23	23	25	33.5	25	33.5
(inches)	Depth	24	24	27.75	35.25	28	36
	Height	47	55.5	68.75	77	69	77
Weight	lbs	190	214	333	399	353	452

*Bivalent, dual-coil hot water production via solar collector and boiler.



Vitocell 300-V and Vitocell 300-B indirect-fired vertical DHW storage tank

Model		EVI	EVI	EVI	EVB*	EVB*
Capacity	USG	53	79	119	79	119
	ltr	200	300	450	300	450
Dimensions	Width	23	25	36	25	36.5
(inches)	Depth	25.5	27.75	38.5	27.75	38.5
	Height	56	70	69.5	70	68.5
Weight	lbs	168	220	245	251	275

*Bivalent, dual-coil hot water production via solar collector and boiler.



Vitocell 300-H indirect-fired horizontal DHW storage tank

Model		EHA	EHA	EHA	EHA
Capacity	USG	42	53	92	119
	ltr	160	200	350	450
Dimensions	Width	25.25	25.25	32.75	35.75
(inches)	Depth	42.25	48.25	62.5	65
	Height	25.75	25.75	31	35
Weight	lbs	168	185	379	421

Viessmann - The Company

Viessmann - climate of innovation

The Viessmann brand promise concisely expresses all that we hope to achieve. It is our key brand message and, together with our brand label, an identifying feature throughout the world. "Climate of innovation" is a promise on three levels: It is a commitment to a culture of innovation. It is a promise of high product utilization and, at the same time, an obligation to protect the environment.

Comprehensive range of products and services for all fuel types

Viessmann is one of the leading international manufacturers of heating systems and, with its comprehensive range of products and services, offers individual solutions of efficient systems for all applications and fuel types. As an environmental pioneer, the company has been supplying particularly efficient and clean heating systems for decades.

Acting in a sustainable manner

For Viessmann, to take responsibility, means a commitment to act in a sustainable way. This means bringing ecology, economy and social responsibility into harmony with each other, ensuring that current needs are satisfied without limiting the basis for life for the generations to come.

Efficiency program

With our efficiency program, Viessmann shows that the political goals set for 2020 with regard to climate and energy can already be achieved today with commercially available technology.

This project demonstrates:

- Environmental protection
- Efficiency with resources
- Securing manufacturing sites for the future

As a result, fossil fuels have been cut by 40 percent and CO_2 emissions reduced by a third.



Deutscher Nachhaltigkeitspreis Deutschlands nachhaltigste Marke 2013

Viessmann won the German Sustainability Award 2013 for its commitment to climate protection and efficient use of resources.



For the particularly efficient utilization of energy through the innovative heat recovery center at the company's main site in Allendorf/Eder, Viessmann was rewarded with the Energy Efficiency Award 2010.

Viessmann Werke GmbH & Co. KG

Company details

- Established in: 1917
- Employees: 11,500
- Group turnover: 2.2 billion Euro
- Export share: 56 percent
- 22 factories in 11 countries
- Operating in 74 countries
- 120 sales offices worldwide

Performance spectrum

- Condensing technology for oil and gas
- Solar thermal systems
- Heat pumps
- Wood combustion systems
- CHP modules
- Biogas plants
- Services



Viessmann Manufacturing Company Inc.

Waterloo, ON Canada Tel. (519) 885-6300 Fax (519) 885-0887 www.viessmann.ca

Viessmann Manufacturing Company Inc.

Langley, BC Canada Tel. (604) 533-9445 Fax (604) 533-9439 www.viessmann.ca

Other Viessmann Group facilities in North America

Viessmann Manufacturing

Company (U.S.) Inc. Warwick, RI U.S.A. Tel. (401) 732-0667 Fax (401) 732-0590 www.viessmann.us

BIOFerm[™] Energy Systems

Verona, WI U.S.A. Tel. (608) 845-2193 www.bioferm-es.com





Advanced Heating & Hot Water Systems

DRAIN BACK TANK 316L Stainless Steel Tank

The **Drain Back Tank** is designed to allow the solar collectors to drain all the water from collector and related pipe connections into the drain back tank reservoir to protect the system from both freezing and overheating. The Drain Back Tank comes with either an internal heat exchanger for use with a storage tank or without a heat exchanger to be connected to a tank with an internal heat exchanger or plate frame heat exchanger. Drain back systems are a smart choice when designing a solar thermal system to supplement central heating and domestic hot water heating when



overheating during the warmer months is a problem. Drain back systems have less components, so maintenance is reduced, compared to a pressurized glycol system. Drain back systems also provide protection where water quality may be a problem.





Drain Back Features

- Tank constructed of durable
 316L stainless steel
- Plastic Jacket will not dent
- Light weight construction
- Maintenance free operation
- 5 year warranty against leaks
- Available with or without heat exchanger
- Highly efficient Copper Heat Exchanger with large surface area
- Site Glass to monitor water level
- Internal dip tube enhance heat exchanger performance

SSU-DBX with Heat Exchanger

SSU-DB without Heat Exchanger

How the Drain Back Tank works

There are two sensors that are connected to the solar control – one on collector and the other inside of the storage tank. The sensors monitor the temperature differential between the collector and the storage tank. Once the program differential is reached, the pump is activated and starts circulating water from the drain back tank reservoir through the solar collector to start absorbing the suns energy. The control will deactivate the circulator pump when the temperature difference drops below the programmed set point.

The drain back system is used in a closed loop system where the water is only introduced when commissioning

œ_____

the system. When the circulator shuts down, all the water must drain back into the tank reservoir so any exposed piping or system components will not freeze. All drain back tanks are equipped with a site glass to determine water level inside the tank.



Model	A	В	C	D	Inlet/Outlet	Capacity	Heat Hx	Ship. Weight	Total Tank Vol W/HX	Useable Tank Vol Above Internal HX
SSU-10 DB	19.25	20.00	15.00	4.50	3/4" NPT	10 Gal	N/A	31 lbs.	-	-
SSU-10 DBX	19.25	20.00	15.00	4.50	3/4" NPT	10 Gal	10 Sq. Ft.	39.7 lbs.	12 Gal	7.8 Gal
SSU-15 DB	19.25	22.00	17.00	4.50	3/4" NPT	15 Gal	N/A	33 lbs.	_	_
SSU-15 DBX	19.25	22.00	17.00	4.50	3/4" NPT	15 Gal	15 Sq. Ft.	47.5 lbs.	14.1 Gal	9.8Gal
SSU-20 DB	19.25	27.00	21.75	4.50	1" NPT	20 Gal	N/A	37 lbs.	-	_
SSU-20 DBX	19.25	27.00	21.75	4.50	1" NPT	20 Gal	20 Sq. Ft.	54.1 lbs.	17.8 Gal	13.5Gal
SSU-30 DB	19.25	39.50	33.75	4.50	1" NPT	30 Gal	N/A	49 lbs.	-	-
SSU-30 DBX	19.25	39.50	33.75	4.50	1" NPT	30 Gal	20 Sq. Ft.	75 lbs.	23.4 Gal	18.8 Gal
SSU-40 DB	19.25	51.875	46	4.50	1.5" NPT	40 Gal	N/A	61 lbs.	-	-
SSU-40 DBX	19.25	51.875	46	4.50	1.5" NPT	40 Gal	20 Sq. Ft.	84 lbs.	32.8 Gal	28.3 Gal
SSU-60 DB	23.25	52.125	46.25	4.50	1.5" NPT	60 Gal	N/A	90 lbs.	_	_
SSU-60 DBX	23.25	52.125	46.25	4.50	1.5" NPT	60 Gal	20 Sq. Ft.	116 lbs.	51.9 Gal	44.2 Gal
SSU-80 DB	23.25	71.5	65.5	4.50	1.5" NPT	80 Gal	N/A	125 lbs.	-	-
SSU-80 DBX	23.25	71.5	65.5	4.50	1.5" NPT	80 Gal	40 Sq. Ft.	151 lbs.	74.4 Gal	68 Gal

Drain Back Application with Heat Exchanger


www.hhi-green.com/solar/en

Hyundai Solar Module

Hyundai Heavy Industries was founded in 1972 and is a Fortune 500 company. The company employs more than 48,000 people, and has a global leading 7 business divisions with sales of 51.3 Billion USD in 2013. As one of our core businesses of the company, Hyundai Heavy Industries is committed to develop and invest heavily in the field of renewable energy.

Hyundai Solar is the largest and the longest standing PV cell and module manufacturer in South Korea. We have 600 MW of module production capacity and provide high-quality solar PV products to more than 3,000 customers worldwide. We strive to achieve one of the most efficient PV modules by establishing an R&D laboratory and investing more than 20 Million USD on innovative technologies.

Multi-crystalline Type

HIS-M300TI | HIS-M305TI | HIS-M310TI | HIS-M315TI | HIS-M320TI | HIS-M325TI

Mono-crystalline Type

HIS-S325TI | HIS-S330TI | HIS-S335TI | HIS-S340TI | HIS-S345TI | HIS-S350TI

Mechanical Characteristics

TI-Series

* Several models are under certification process.

Dimensions	998 mm (39.29″)(W) × 1,960 mm (77.17″)(L) × 50 mm (1.97″)(H)
Weight	Approx. 23.2 kg (51.1 lbs)
Solar cells	72 cells in series (6 \times 12 matrix) (Hyundai cell, Made in Korea)
Output cables	4 mm² (12AWG) cables with polarized weatherproof connectors, IEC certified (UL listed), Length 1.2 m (47.2")
Junction box	IP67, weatherproof, IEC certified (UL listed)
Bypass diodes	3 bypass diodes to prevent power decrease by partial shade
Construction	Front : High transmission low-iron tempered glass, 3.2 mm (0.126") Encapsulant : EVA Back Sheet : Weatherproof film
Frame	Clear anodized aluminum alloy type 6063

High Quality

- UL listed (UL 1703), Type 1 for Class A Fire Rating
- Output power tolerance +3/-0 %
- ISO 9001:2000 and ISO 14001:2004 Certified
- Advanced Mechanical Test (5,400 Pa) Passed (IEC) / Mechanical Load Test (40 Ibs/ft²) Passed (UL)
- Ammonia Corrosion Resistance Test Passed
- IEC 61701 (Salt Mist Corrosion Test) Passed

Fast and Inexpensive Mounting

- Delivered ready for connection
- IEC (UL) certified and weatherproof connectors
- Integrated bypass diodes

Limited Warranty

- 10 years for product defect
- \bullet 10 years for 90 % of warranted min. power
- $\bullet\,25$ years for 80 % of warranted min. power

***** Important Notice on Warranty

The warranties apply only to the PV modules with Hyundai Heavy Industries Co., Ltd.'s logo (shown below) and product serial number on it.





Electrical Characteristics

| Multi-crystalline Type |

				HiS-M[
		300	305	310	315	320	325
Nominal output (Pmpp)	W	300	305	310	315	320	325
Voltage at Pmax (Vmpp)	V	35.8	36.0	36.1	36.2	36.4	36.6
Current at Pmax (Impp)	А	8.4	8.5	8.6	8.7	8.8	8.8
Open circuit voltage (Voc)	V	44.9	45.1	45.3	45.5	45.7	45.9
Short circuit current (Isc)	Α	8.7	8.8	8.9	9.0	9.0	9.1
Output tolerance	%			+3	/-0		
No. of cells & connections	pcs			72 in	series		
Cell type	-		6" Multi-ci	ystalline silicon (H	lyundai cell, Mad	e in Korea)	
Module efficiency	%	15.3	15.6	15.8	16.1	16.4	16.6
Temperature coefficient of Pmpp	%/K	-0.41	-0.41	-0.41	-0.41	-0.41	-0.41
Temperature coefficient of Voc	%/K	-0.32	-0.32	-0.32	-0.32	-0.32	-0.32
Temperature coefficient of lsc	%/K	0.039	0.039	0.039	0.039	0.039	0.039

** All data at STC (Standard Test Conditions). Above data may be changed without prior notice.

| Mono-crystalline Type |

				HiS-S [
		325	330	335	340	345	350
Nominal output (Pmpp)	W	325	330	335	340	345	350
Voltage at Pmax (Vmpp)	V	37.8	38.0	38.2	38.4	38.6	38.7
Current at Pmax (Impp)	А	8.6	8.7	8.78	8.9	9.0	9.0
Open circuit voltage (Voc)	V	46.1	46.3	46.5	46.7	46.9	47.1
Short circuit current (Isc)	А	9.2	9.3	9.4	9.5	9.6	9.6
Output tolerance	%			+3	/-0		
No. of cells & connections	pcs			72 in	series		
Cell type	-		6" Mono-c	rystalline silicon (l	Hyundai cell, Mad	e in Korea)	
Module efficiency	%	16.6	16.9	17.1	17.4	17.6	17.9
Temperature coefficient of Pmpp	%/K	-0.42	-0.42	-0.42	-0.42	-0.42	-0.42
Temperature coefficient of Voc	%/K	-0.30	-0.30	-0.30	-0.30	-0.30	-0.30
Temperature coefficient of lsc	%/K	0.047	0.047	0.047	0.047	0.047	0.047

* All data at STC (Standard Test Conditions). Above data may be changed without prior notice.

| Module Diagram |



(unit : mm, inch)

|Installation Safety Guide |

- Only qualified personnel should install or perform maintenance.
- Be aware of dangerous high DC voltage.
- Do not damage or scratch the rear surface of the module.
- Do not handle or install modules when they are wet.

Nominal Operating Cell Temperature	46°C±2
Operating Temperature	-40 - 85°C
Maximum System Voltage	DC 1,000 V (IEC) DC 1,000 V (UL)
Maximum Reverse Current	15 A

[Printed Date : December 2015]



Sales & Marketing Hyundai Bldg., 75, Yulgok-ro, Jongno-gu, Seoul 03058, Korea Tel:+82-2-746-8406, 7422, 8525 Fax:+82-2-746-7675





Heat Pump Models

Lochinvar's Heat Pump residential electric models are available in 50, 66 and 80 gallon capacities and feature a heat pump operating with environmentally-friendly R134a refrigerant that will absorb ambient heat from the surrounding air reducing electrical consumption by up to 66%.

Standard Features

- ENERGY STAR[®] The Heat Pump water heater meets the ENERGY STAR requirement with 3.06 to 3.24 Energy Factor in hybrid mode and are eligible for most utility rebate programs.
- Code Compliance Complies with the Federal Energy Conservation Standards effective April 16, 2015, in accordance with the Energy Policy and Conservation Act, (EPCA), as amended.
- Electronic Control The electronic control features an LED display and four operating modes to match the heating requirements of the environment. The LED display will also read-out current status, set point and fault codes.
- Immersion Heating Elements Zinc-coated copper sheath design for longer life in hard, aggressive water. The elements screw in for easy service and replacement.
- **Glass-Lined Steel Tank** The durable glass lining is fused to the steel tank at 1600°F to assure lasting protection against rust and corrosion while providing clear, clean hot water. 300 PSI test pressure; 150 PSI working pressure.
- Non-CFC Foam Insulation A uniform coverage of thick closedcell foam insulation minimizes standby heat loss, maximizes heat retention and delivers a high Energy Factor.
- **Tank Saver Anode** A large diameter, high capacity anode inhibits corrosion of the tank interior for long, trouble-free service.
- Heat Trap Heat traps are built into the inlet and outlet connections to eliminate heat migration and heat loss in the water piping.
- Temperature & Pressure Relief Valve Factory installed for optimum safety.
- **Brass Drain Valve** An enhanced ball valve design for effective drainage and positive shut-off.
- 10 Year Limited Tank & Parts Warranty* See warranty sheet for details.

* 1-year limited tank & parts warranty when installed in a commercial application.

Heat Pump Residential Electric Water Heaters



All models meet or exceed Federal and ASHRAE Energy Efficiency Standards

Dimensions and Specifications





This heater has a 10 year warranty. It is a heat pump model, has a 50 gallon capacity with a 240 volt 4500 watt upper element and 4500 watt lower element.

	Nomina	l Rated										
Model	Gallon	Storage	Input	Standard	1st Hr.							Ship.
Number	Cap	Cap.	Watts	Voltage	Rating	UEF	A	B	C	D	E	Wt.
HPA052KD	50	46	4500	208V/240V	66	3.42	63″	22″	40-1/2″	3-3/4″	40-1/2″	196
HPA068KD	66	67	4500	208V/240V	79	3.00	61″	27″	38″	4″	38″	289
HPA082KD	80	82	4500	208V/240V	84	2.73	69″	27″	46″	4″	46″	307

Water connections are 3/4" NPT.

Available Air Kits

- Inlet & Outlet Outdoor Air Kit The Inlet & Outlet Air Kit adapts the Heat Pump water heater to work with outdoor air. This allows the Heat Pump to be installed in confined spaces and spaces with conditioned air. The kit works with standard 8" flexible duct (field supplied) up to 10 total feet.
- **Booster Fan Kit** By adding the Booster Fan Kit to the Inlet & Outlet Air Kit, the flexible duct can extend to 25 total feet.





Outlet Adapter

Part		Shipping
Number	Description	Weight
100234320	Inlet & Outlet Outdoor Air Kit	5
100131328	Booster Fan Kit	10

Certified for Potable Water and Space Heating Applications This water heater is suitable for water heating and space heating. Toxic chemicals, such as those used for boiler water treatment shall NEVER be introduced into this system. This water heater may NEVER be connected to any existing heating system or components previously used with non-potable water heating appliances.



Lochinvar, LLC 300 Maddox Simpson Parkway Lebanon, Tennessee 37090 P: 615.889.8900 / F: 615.547.1000



Lochinvar Hybrid Heat Pump Water Heater Specs: Max Supply Water Temp: 150F Recovery: 27 GPH @ 90F Rise Storage: 80 Gallons Cooling Capacity: 5,000 Btu/hr



Smith. COMMERCIAL-GRADE RESIDENTIAL ELECTRIC WATER HEATERS

VOLTEX[®] HYBRID ELECTRIC HEAT PUMP WATER HEATER

The Voltex Hybrid Electric heat pump water heater from A. O. Smith is the most cost effective energy-efficient option available for consumers who want to save money on their utility bills. Voltex can reduce water heating costs up to 73% and provide payback in 2-3 years. With annual savings of \$305 or more, there is no better way to go green than Voltex.

HOW DO THEY WORK?

Absorb ambient heat from the surrounding air to heat water using a compressor and "Environmentally-Friendly" R134a refrigerant

- Self-contained heat pump unit is integrated into the top of the tank
- Multiple operating modes to maximize efficiency and performance

QUALIFIES FOR MANY STATE AND LOCAL UTILITY REBATES -CHECK WWW.DSIREUSA.ORG

INCREASED ENERGY EFFICIENCY

 Improved efficiency designed in, to ensure available hot water at the lowest possible cost. Up to a 3.52 Uniform Energy Factor (UEF) Rating conserves energy and meets ENERGY STAR[®] qualifications

CHOICE OF OPERATING MODES

- Select from Efficiency, Hybrid, or Electric modes to match heating requirements to environmental conditions.
- Hybrid mode automatically adjusts between compressor and element, depending upon heat requirements.
- Vacation mode reduces operating costs and provides freeze protection during extended absence

BACKUP ELECTRIC ELEMENTS

• Long-lasting backup heating elements help heat water according to environmental conditions, demand, and the chosen operating mode

COREGARD[™] ANODE ROD

- Our anode rods have a stainless steel core that extends the life of the anode rod allowing superior tank protection far longer than standard anode rods
- 66 and 80 gallon models have dual anodes for added protection.

DRY FIRE PROTECTION

• Control system checks to ensure the tank is full of water during start up to prevent dry firing the heating elements

ELECTRONIC USER INTERFACE

- User-friendly electronic interface allows easy control of temperature setting, operating mode, and communicates diagnostics
- Easy to read temperature display (see back) shows temperature in °F or °C
- Advanced diagnostics convey error messages for service purposes. The last four error messages are saved in the control system memory.

OTHER FEATURES

- Ideal for basements or garage installations; the compressor transfers heat to the water while dehumidifying and cooling the ambient air
- Washable air filter is easily removed for routine cleaning

OPTIONAL AIR DUCT ADAPTER KIT

• Permits installation in confined spaces

SIX YEAR LIMITED WARRANTY

• For complete information, consult written warranty or go to hotwater.com





© May 2018 A. O. Smith Corporation. All Rights Reserved



Model	Nominal	Rated		First Hour		Dim	ensions in In	ches		Approx.	Warranty
Number	Capacity	Storage Volume	UEF	Rating (Gallons)	А	В	С	D	E	Shipping Weight (lbs)	Term
FPTU-50	50	46	3.42	66	63	22	40-5/8	3-3/4	40-1/2	196	6
FPTU-66	66	67	3.52	66	61	27	38	4	38	289	6
FPTU-80	80	82	2.73	84	69	27	46	4	46	307	6

Requires 30 amp breaker. Top T&P option not available.



ELECTRONIC USER INTERFACE

- User friendly, easy to read display.
- LEDs clearly indicate the current operating mode.
- Easily select operating mode:
 - Efficiency
 - Hybrid
 - Electric
 - Vacation
- Display communicates current status, mode and set point, and displays error messages when applicable.

EFFICIENCY MODE

- Utilizes the heat pump for all water heating.
- Automatically reverts to heating element if ambient air or water temperatures are outside optimal operating range for heat pump.

HYBRID MODE

• Utilizes the heat pump or heating element, depending on demand.

ELECTRIC MODE

• Standard electric water heater operation.

VACATION MODE

- One touch operation maintains tank temperature of 60°F (15.6°C) during vacation or extended absence to reduce operating costs and provide freeze protection.
- Programmable up to 99 days.



OTHER FEATURES:

- Sacrificial anode to protect against tank corrosion.
- Environmentally-friendly non-CFC foam insulation.
- Durable, enhanced-flow brass drain valve.
- CSA certified and ASME rated temperature & pressure relief valve.

OPERATING REQUIREMENTS:

- Requires provision for condensate draining; if a suitable drain is not available, a condensate pump is required.
- 208/240 VAC 60Hz single phase 30 amp power supply.

For Technical Information, call 800-527-1953. A. O. Smith Corporation reserves the right to make product changes or improvements without prior notice.

© May 2018 A. O. Smith Corporation. All Rights Reserved www.hotwater.com | 800-527-1953 Toll-Free USA

Air Source Heat Pump Water Heaters





Standard Features

- 140°F 160°F hot water temperatures to prevent and eradicate Legionella
- Single or multi-pass capability for easy integration into new or existing systems
- Vented double wall, stainless steel, heat exchanger ensuring safe, potable water
- Integrated stainless steel circulator pump
- Industrial electro-mechanical controls

	HPWH Model (60 Hz)	Heating Capacity (MBH)	Cooling Capacity (MBH)	Heating COP	Cooling COP	Combined COP	Hot Water Flow Rate (GPM)	Airflow (CFM)
u	HPA7	110	88	4.5	3.6	8.1	3.1	4000
r Fa	HPA9	131	104	4.5	3.6	8.1	3.7	4000
elle	HPA11	170	137	4.7	3.8	8.5	4.9	4000
ope	HPA12	209	169	4.9	4.0	8.9	6.0	4000
Ы	HPA15	267	210	4.4	3.5	7.9	7.6	6000
c	HPA4	66	53	4.9	4.0	8.9	1.9	1200
Fai	HPA7	110	88	3.7	3.0	6.7	3.1	4000
ıgal	HPA9	131	104	3.8	3.1	6.9	3.7	4000
rifu	HPA11	170	137	4.2	3.3	7.5	4.9	4000
Cent	HPA12	209	169	4.4	3.6	8.0	6.0	4000
0	HPA15	267	210	3.9	3.1	7.0	7.6	6000

Based on 75°F entering air wet bulb temperature, 70°F entering potable water temperature and 140°F leaving potable water temperature.



Air Source Heat Pump Water Heaters





Applications

- Hotels
- Apartments
- Offices
- Dormatories
- Laundries

- Hospitals
- Schools
- Industrial Process
- Pools
- Hydronic Heating

Optional Features

- High Temperature Circuit to produce up to 185°F water
- Compressor VFD for additional operational cost savings
- PLC control with BMS communication
- Electronic Expansion Valve (EEV) for improved performance over varying conditions
- Galvanized, aluminum, or stainless steel enclosure
- Copper, Polycoat, or Electroplate evaporator construction
- Coaxial condensers for poor water quality or pool heating applications
- Defrost and freeze protection
- Protective screen and rain hood for outdoor applications









401 N. Lincoln • P.O. Box 72 • Colville, WA 99114 • USA Tel (509) 684-4505 • Fax (509) 684-4500 • Toll Free (800) 926-5622 sales@colmacwaterheat.com • www.colmacwaterheat.com



CUSTOMER NAME :	Highmark	JOB NAME :	SCA
	NUMBER OF	UNITS : 1	
SALES CONTACT :	Bart Ransom		
	ПГА		
	CABINET CONST	RUCTION	
	CABINET MATERIAL :	304 STAINLESS STE	EL (S)
	FIN MATERIAL :	MICROCHANNE	EL
	FAN TYPE :	PROP FAN	
	ELECTRICAL SPECI		
	VOLTAGE :	230V / 60Hz / 1I	Ph
	TOTAL PANEL AMPACITY (FLA) :	19.1 A	
	MINIMUM CIRCUIT AMPACITY (MCA) :	23.3 A	
	FEEDER WIRE GAUGE :	12 AWG	
N	1AXIMUM OVERCURRENT PROTECTION (MOP) :	30 A	
	*APPROXIMATE VALUES, SU	BJECT TO CHANGE	
		NDITIONS	
	ENTERING AIR WET BULB TEMP :	42 °F	
	ENTERING POTABLE WATER TEMP :	50 °F	
	LEAVING POTABLE WATER TEMP :	140 °F	
	POTABLE FLOW RATE AT DESIGN CONDITION :	0.6 GPM	
REQUIRED PC	DTABLE FLOW FOR MINIMUM LIFT CONDITION :	3.1 GPM	
	PERFORMANCE SPEC	IFICATIONS**	
	HEATING CAPACITY:	30,506 BTU/hi	r
	HEATING CAPACITY:	3 Tons	
	SUCTION TEMPERATURE:	24 °F	
	COOLING CAPACITY:	19,183 BTU/hi	r
	HEATING COP:	2.5	
	COOLING COP:	1.5	
	COMBINED COP:	4.0	

**APPROXIMATE VALUES, SUBJECT TO CHANGE. VALUES BASED ON CONDITIONS SPECIFIED ABOVE. IF ACTUAL CONDITIONS DIFFER, PERFORMACE WILL ALSO DIFFER.

INCLUDED OPTIONS : POLYESTER AIR FILTER, PLC

COMPRESSOR: COPELAND ZR34K5E-PFV-160 POTABLE PUMP: GRUNDFOS UPS 15-55 x 1

NOTES:

Date Generated: 8/31/2018



CUSTOMER NAME :	Highmark	JOB NAME :	SCA
	NUMBER OF	UNITS : 1	
SALES CONTACT :	Bart Ransom		
	HPA	2 PLC	
		•	
	CABINET CONST	RUCTION	
	CABINET MATERIAL :	304 STAINLESS STE	EL (S)
	FIN MATERIAL :	MICROCHANNE	L
	FAN TYPE :	PROP FAN	
		230V / 60Hz / 1E	Ph
	TOTAL PANEL AMPACITY (FLA)	191A	
	MINIMUM CIRCUIT AMPACITY (MCA)	23.3 A	
	FEEDER WIRE GAUGE :	12 AWG	
	MAXIMUM OVERCURRENT PROTECTION (MOP) :	30 A	
	*APPROXIMATE VALUES, SU	BJECT TO CHANGE	
	OPERATING CON	NDITIONS	
	ENTERING AIR WET BULB TEMP :	59 °F	
	ENTERING POTABLE WATER TEMP :	50 °F	
	LEAVING POTABLE WATER TEMP :	140 °F	
	POTABLE FLOW RATE AT DESIGN CONDITION :	0.8 GPM	
REQUIRED F	POTABLE FLOW FOR MINIMUM LIFT CONDITION :	3.5 GPM	
	PERFORMANCE SPEC	CIFICATIONS**	
	HEATING CAPACITY:	34,551 BTU/hr	·
	HEATING CAPACITY:	3 Tons	
	SUCTION TEMPERATURE:	30 °F	
	COOLING CAPACITY:	23,275 BTU/hr	·
	HEATING COP:	2.8	
	COOLING COP:	1.9	

**APPROXIMATE VALUES, SUBJECT TO CHANGE. VALUES BASED ON CONDITIONS SPECIFIED ABOVE. IF ACTUAL CONDITIONS DIFFER, PERFORMACE WILL ALSO DIFFER.

4.7

COMBINED COP:

INCLUDED OPTIONS : POLYESTER AIR FILTER, PLC **COMPRESSOR:** COPELAND ZR34K5E-PFV-160 **POTABLE PUMP:** GRUNDFOS UPS 15-55 x 1

NOTES:

Date Generated: 8/31/2018



CUSTOMER NAME :	Highmark	JOB NAME :	SCA
	NUMBER OF	UNITS : 1	
SALES CONTACT :	Bart Ransom		
	HPA	2 PLC	
		_	
	CABINET CONST	RUCTION	
	CABINET MATERIAL :	304 STAINLESS STEE	EL (S)
	FIN MATERIAL :	MICROCHANNE	L
	FAN TYPE :	PROP FAN	
	ELECTRICAL SPECI	FICATIONS*	
	VOLTAGE :	230V / 60Hz / 1P	Ph
	TOTAL PANEL AMPACITY (FLA) :	19.1 A	
	MINIMUM CIRCUIT AMPACITY (MCA) :	23.3 A	
	FEEDER WIRE GAUGE :	12 AWG	
	MAXIMUM OVERCURRENT PROTECTION (MOP) :	30 A	
	*APPROXIMATE VALUES, SU	BJECT TO CHANGE	
	OPERATING CO	NDITIONS	
	ENTERING AIR WET BULB TEMP :	78 °F	
	ENTERING POTABLE WATER TEMP :	50 °F	
	LEAVING POTABLE WATER TEMP :	140 °F	
	POTABLE FLOW RATE AT DESIGN CONDITION :	0.9 GPM	
REQUIRED F	POTABLE FLOW FOR MINIMUM LIFT CONDITION :	4.2 GPM	
	HEATING CAPACITY:	42,334 BTU/hr	
		4 IONS	
		42 F	
		31,140 010/11	
		2.5	
		2.5	

**APPROXIMATE VALUES, SUBJECT TO CHANGE. VALUES BASED ON CONDITIONS SPECIFIED ABOVE. IF ACTUAL CONDITIONS DIFFER, PERFORMACE WILL ALSO DIFFER.

6.0

COMBINED COP:

INCLUDED OPTIONS : POLYESTER AIR FILTER, PLC **COMPRESSOR:** COPELAND ZR34K5E-PFV-160 **POTABLE PUMP:** GRUNDFOS UPS 15-55 x 1

NOTES:

Date Generated: 8/31/2018





SUBMITTAL DRAWING FILE: 1010002-0007 DRAWING IS APPROXIMATE AND SUBJECT TO CHANGE



CUSTOMER NAME :	Highmark		JOB NAME :	SCA
		NUMBER OF UN	ITS : 1	
SALES CONTACT :	Bart Ransom			
	HP	4-PASP PLC	(SINGLE PASS)
			•	
ONSTRUCTION:				
	CABIN	ET MATERIAL :	304 STAINLESS STEE	EL (S)
	F	IN MATERIAL :	POLYCOAT (P)	
		FAN TYPE :	PROP FAN	
LECTRICAL SPECIFICATI	ONS*:			
		VOLTAGE :	230V / 60Hz / 1P	Ph
	TOTAL PANEL AN	1PACITY (FLA) :	29.7 A	
	MINIMUM CIRCUIT AMI	PACITY (MCA) :	35.6 A	
	FEEDER	WIRE GAUGE :	10 AWG	
MAXIN	MUM OVERCURRENT PROTE	CTION (MOP) :	50 A	
	*APPR	OXIMATE VALUES, SUE	JECT TO CHANGE	
PERATING CONDITION	IS:		60 hz Operatio	n: Optional VFD at:
	ENTERING AIR WE	T BULB TEMP :	42 °F	45 hz
	ENTERING POTABLE	WATER TEMP :	50 °F	
	LEAVING POTABLE	WATER TEMP :	140 °F	
POT	ABLE FLOW RATE AT DESIG	N CONDITION :	0.9 GPM	0.6 GPM
REQUIRED POTA	BLE FLOW AT MINIMUM LIF	T CONDITION :	3.9 GPM	2.6 GPM
ERFORMANCE SPECIFIC	CATIONS**:			
	HEA	TING CAPACITY:	39,359 BTU/hr	26,391 BTU/h
	HEA	TING CAPACITY:	3 Tons	2.2 Tons
	SUCTION	TEMPERATURE:	27 °F	
	CO0	LING CAPACITY:	28,197 BTU/hr	21,148 BTU/h
		HEATING COP:	3.2	5.0
		COOLING COP:	2.3	4.0
			54	9.1
	(5.1	5.1

INCLUDED OPTIONS :

POLYESTER AIR FILTER, PLC

COMPRESSOR: COPELAND ZR61KCE-PFV-250 **POTABLE PUMP:** GRUNDFOS UPS 26-150 x 1

Date Generated: 8/31/2018

NOTES:



CUSTOMER NAME :	Highmark		JOB NAME :	SCA
		NUMBER OF UN	ITS: 1	
SALES CONTACT :	Bart Ransom			
	НРА	4-PASP PLC	(SINGLE PASS)	
ONSTRUCTION:				
	CABINE	T MATERIAL :	304 STAINLESS STEEL (S)	
	F	N MATERIAL :	POLYCOAT (P)	
		FAN TYPE :	PROP FAN	
LECTRICAL SPECIFICATI	ONS*:			
		VOLTAGE :	230V / 60Hz / 1Ph	
	TOTAL PANEL AM	PACITY (FLA) :	29.7 A	
	MINIMUM CIRCUIT AMP	ACITY (MCA) :	35.6 A	
	FEEDER	WIRE GAUGE :	10 AWG	
MAXIN	MUM OVERCURRENT PROTEC	CTION (MOP) :	50 A	
	*APPRC	XIMATE VALUES, SUB	IECT TO CHANGE	
PERATING CONDITION	IS:		60 hz Operation:	Optional VFD at:
	ENTERING AIR WET	BULB TEMP :	59 °F	45 hz
	ENTERING POTABLE V	VATER TEMP :	50 °F	
	LEAVING POTABLE V	VATER TEMP :	140 °F	
POT	ABLE FLOW RATE AT DESIGN	I CONDITION :	1.1 GPM	0.8 GPM
REQUIRED POTA	BLE FLOW AT MINIMUM LIFT	CONDITION :	5.2 GPM	3.5 GPM
ERFORMANCE SPECIFIC	CATIONS**:			
	HEAT	ING CAPACITY:	51,534 BTU/hr	35,427 BTU/h
	HEAT	ING CAPACITY:	4 Tons	3.0 Tons
	SUCTION 1	EMPERATURE:	40 °F	
	COOL	ING CAPACITY:	40,085 BTU/hr	30,063 BTU/h
		HEATING COP:	4.1	6.6
		COOLING COP:	3.2	5.6
			7.0	12.2
	C	OMBINED COP:	1.2	12.2

INCLUDED OPTIONS :

POLYESTER AIR FILTER, PLC

COMPRESSOR: COPELAND ZR61KCE-PFV-250 **POTABLE PUMP:** GRUNDFOS UPS 26-150 x 1

Date Generated: 8/31/2018

NOTES:



CUSTOMER NAME :	Highmark		JOB NAME :	SCA
		NUMBER OF UN	ITS : 1	
SALES CONTACT :	Bart Ransom			
	HP	A4-PASP PLC	(SINGLE PASS)	
			, ,	
ONSTRUCTION:				
	CABIN	IET MATERIAL :	304 STAINLESS STEEL (S)
		FIN MATERIAL :	POLYCOAT (P)	
		FAN TYPE :	PROP FAN	
ECTRICAL SPECIFICATI	ONS*:			
		VOLTAGE :	230V / 60Hz / 1Ph	
	TOTAL PANEL AM	/IPACITY (FLA) :	29.7 A	
	MINIMUM CIRCUIT AM	PACITY (MCA) :	35.6 A	
	FEEDER	WIRE GAUGE :	10 AWG	
MAXIN	UM OVERCURRENT PROTE	CTION (MOP) :	50 A	
	*APPF	OXIMATE VALUES, SUB	JECT TO CHANGE	
PERATING CONDITION	S:		60 hz Operation:	Optional VFD at:
	ENTERING AIR WE	T BULB TEMP :	78 °F	45 hz
	ENTERING POTABLE	WATER TEMP :	50 °F	
	LEAVING POTABLE	WATER TEMP :	140 °F	
POT	ABLE FLOW RATE AT DESIG	N CONDITION :	1.6 GPM	1.1 GPM
REQUIRED POTA	BLE FLOW AT MINIMUM LIF	T CONDITION :	7.0 GPM	4.9 GPM
ERFORMANCE SPECIFIC	CATIONS**:			
	HEA	TING CAPACITY:	69,991 BTU/hr	49,127 BTU/h
	HEA	TING CAPACITY:	6 Tons	4.1 Tons
	SUCTION	TEMPERATURE:	59 °F	
	COC	LING CAPACITY:	58,106 BTU/hr	43,580 BTU/h
		HEATING COP:	5.3	8.9
		COOLING COP:	4.4	7.9
			97	16.7
		LOMBINED COP:	5.7	

INCLUDED OPTIONS :

POLYESTER AIR FILTER, PLC

COMPRESSOR: COPELAND ZR61KCE-PFV-250 **POTABLE PUMP:** GRUNDFOS UPS 26-150 x 1

Date Generated: 8/31/2018

NOTES:





SUBMITTAL DRAWING FILE: 1010004-0018 DRAWING IS APPROXIMATE AND SUBJECT TO CHANGE



Cold Climate Heat Pump Water Heater

ccHPWH Series

80 Hartford Avenue, Mount Vernon, NY 10553 Tel: 877-ICE-AIR-1 (877-423-2471) Main: 914-668-4700 Fax: 914-668-5643 email: sales@ice-air.com www.ice-air.com

Ice Air's cold climate heat pump water heaters capture the free energy in the environment and convert it to hot water. These commercial water heater are designed to provide domestic hot water to large buildings on the coldest days.

- Industry leading performance
 - Lower cost of operation and maintenance compared to condensing gas-fired water heaters
- 4x more efficient compared to electric resistance heaters
- Multiple independent circuits provide built-in redundancy
- Double wall heat exchangers ensure occupant safety
- Optional single wall heat exchangers (for glycol applications)
- Freeze protection standard
- Optional heat-trace powered by building emergency power
- Clean out ports to remove sediment or lime deposits





	Model Num	bers	ccHPWH275-S	ccHPWH275-D	ccHPWH550-S	ccHPWH550-D
	Heat Exchange	ег Туре	Single Wall Brazed Plate HXR	Double Wall Brazed Plate HXR	Single Wall Brazed Plate HXR	Double Wall Brazed Plate HXR
	Input F	Power	208-230V/3PH/60Hz	208-230V/3PH/60Hz	208-230V/3PH/60Hz	208-230V/3PH/60Hz
	Refrigerar	nt Circuits	2	2	4	4
	Refrigerant	: / Quantity	R410A (30.8 Lbs / 15.4 Lbs per circuit)	R410A (30.8 Lbs / 15.4 Lbs per circuit)	R410A (70.8 Lbs / 17.7 Lbs per circuit)	R410A (70.8 Lbs / 17.7 Lbs per circuit)
	Max H/W Te	emperature	140°F	140°F	140°F	140°F
	Dry Bulb Temperature (68°F)	Heating Capacity (Btu/H)	341,263	327,246	563,003	532,287
	Wet Bulb Temperature (59°F) Inlet Water Temperature (59°F)	Input Power (kW)	22.2	22.7	37	37.3
Pe	Outlet Water Temperature (131°F)	СОР	4.41	4.23	4.42	4.18
prform	Dry Bulb Temperature (45°F)	Heating Capacity (Btu/H)	270,645	262,360	495,600	470,820
lance	Wet Bulb Temperature (43°F) Inlet Water Temperature (48°F)	Input Power (kW)	18.6	21.7	39.2	44.8
Spec	Outlet Water Temperature (131°F)	COP	3.70	3.54	3.71	3.48
ificat	Dry Bulb Temperature (10°F)	Heating Capacity (Btu/H)	175,396	170,027	304,500	289,275
ions	Wet Bulb Temperature (7°F) Inlet Water Temperature (43°F)	Input Power (kW)	17.3	20.3	37.8	43.2
	Outlet Water Temperature (131°F)	COP	2.57	2.46	2.36	2.22
	Minimum Ambient Oper	rating Temperature (°F)	-13	-13	-13	-13
	Max. Input I	Power (kW)	29.8	29.8	62	62
	FLA	(A)	85.1	85.1	170.2	170.2
	MCA	A (A)	93.7	93.7	187.2	187.2
	MOC	P (A)	127.7	27.7 127.7		255.4
	Sound Le	vel (dBA)	≤71	≤71	≤76	≤76
	Water Side Pres	sure Loss (psig)	8.1	16.51	7.25	13.0
_	Rated Water	Rated Water Flow (GPM)		58.9	129.6	122.5
Vater	Single pass delta	a-T (F) (average)	9.30	10.60	9.36	9.36
Data	Max Working F	Pressure (psig)	230	230	230	230
μ.	Piping Position (Refer to t	the electric box as front)	Rear	Rear	Right Hand	Right Hand
	Piping	Sizes	2"	2"	3"	3"
	Overall Dimensions [L x	W x H] (inches)	81 x 39 x 89	81 x 39 x 89	95 x 51 x 89	95 x 51 x 89
	Net Weight ((Lbs)	1,500	1,555	2,850	2,950



Due to Ice Air's ongoing product development programs, the information in this document is subject to change without notice.

Appendix E:

Deleted

Appendix F:

Energy Analysis Calculations

Energy Analysis Using Hybrid Heat Pumps

	Existing Conditions											
				Heating	Storage							
				Capacity	Capacity							
School	Manufacturer	Heater Model	Tank Model	(Btu)	(gal)	Efficiency						
A	Lochinvar	CWN399PM	RGA0318	399,000	318	82%						
В	Lochinvar	CWN0986PM	RGA0700H	986,000	700	819						
С	AO Smith	BTR2	75118	275,000	100	80%						
D	Lochinvar	CWN0497PM	ST175	495,000	175	81%						

l											
	School	Daily Consumption (gal)	Daily Water Heating Energy (kBtu)	Daily Water Heating Energy (therm)	Daily Gas Heating Energy Input (therm)	Annual Water Heating Energy (kBtu)	Annual Gas Heating Energy (therm)	Energy Cost		School	Daily Consump (gal)
ľ	A	162	87.6	0.876	1.069	31,989	390	\$487.63		A	(3. 7
ľ	В	436	235.1	2.351	2.903	85,817	1,059	\$1,324.33	1	В	
I	С	255	137.7	1.377	1.721	50,252	628	\$785.18		С	

	Option 1: Electric Heat Pump Operation												
School	Daily Consumption (gal)	Daily Water Heating Energy (kBtu)	Daily Water Heating Energy (kWh)	Daily Electric Heating Energy Input (kWh) (Heat Pump WH)	Annual Water Heating Energy (kBtu)	Annual Electric Heating Energy (kWh)							
A	162	87.6	25.686	8.562	31,989	3,125							
В	436	235.1	68.908	22.969	85,817	8,384							
С	255	137.7	40.351	13.450	50,252	4,909							
		1		COP = 3.0									

	Option 1: PV System												
		Heating											
	Annual	Energy						Energy Cost					
	Electric	Covered by			Roof Area			Savings @		Annual CO2			
	Heating	PV System	Size of PV	Number of	Required		Energy Cost	100% PV	Incremental	Emissions			
School	Energy (kWh)	(kWh)	System (kW)	PV Panels	(sqft)	\$/kWh	(\$/yr)	(\$/yr)	Costs (\$)	Avoided (lbs)			
A	3,125	3,125	3	9	189.50		\$0.00	\$487.63	\$66,750	4,558			
В	8,384	8,384	8	23	484.27	\$0.27	\$0.00	\$1,324.33	\$103,375	12,379			
С	4,909	4,909	5	15	315.83		\$0.00	\$785.18	\$80,250	7,340			

	Option 2: Solar Thermal System with Electric Heat Pump Auxiliary												
			Heating										
			Energy	Auxiliary	Auxiliary	Auxiliary							
	Annual Gas		Covered by	Heating	Heating	Heating	Solar						
	Heating		Solar Thermal	Energy	Energy	Energy Input,	Thermal	Roof Area					Annual CO2
	Energy	Solar Fraction	System	Required	Required	Elec Heat	Number of	Required		Energy Cost	Energy Cost	Incremental	Emissions
School	(therm)	(%)	(therm)	(therm)	(kBtu)	Pump (kWh)	Collectors	(sqft)	\$/kWh	(\$/yr)	Savings (\$/yr)	Costs (\$)	Avoided (lbs)
A	320	53.4%	171	149	14,907	1,456	6	162.12		\$393.20	\$94.43	\$127,753	3,632
В	858	52.3%	449	409	40,935	3,999	12	324.24	\$0.27	\$1,079.75	\$244.58	\$153,253	9,837
С	503	51.4%	258	244	24.422	2.386	8	216.16		\$644.20	\$140.98	\$146,265	5,823

	Option 3: Solar Thermal System with Gas-Fired Heater Auxiliary													
			Heating			Auxiliary								
			Energy	Auxiliary	Auxiliary	Heating								
	Annual Gas		Covered by	Heating	Heating	Energy	Solar							
	Heating		Solar Thermal	Energy	Energy	Covered by	Thermal	Roof Area					Annual CO2	
	Energy	Solar Fraction	System	Required	Required	Gas Boiler	Number of	Required		Energy Cost	Energy Cost	Incremental	Emissions	
School	(therm)	(%)	(therm)	(therm)	(kBtu)	(therm)	Collectors	(sqft)	\$/therm	(\$/yr)	Savings (\$/yr)	Costs (\$)	Avoided (lbs)	
A	320	53.4%	171	149	14,907	182	6	162.12		\$227.24	\$260.40	\$96,253	2,434	
В	858	52.3%	449	409	40,935	505	12	324.24	\$1.25	\$631.71	\$692.63	\$112,503	6,474	
С	503	51.4%	258	244	24,422	305	8	216.16		\$381.60	\$403.58	\$107,265	3,773	

	Option 4: Hybrid Solar Thermal System and PV System with Electric Heat Pump																	
			Heating															
			Energy	Auxiliary	Auxiliary	Auxiliary												
	Annual Gas		Covered by	Heating	Heating	Heating					Solar Thermal	Total Roof				Energy		
	Heating		Solar Thermal	Energy	Energy	Energy Input,			PV Roof Area	Solar Thermal	Roof Area	Area				Cost		Annual CO2
	Energy	Solar Fraction	System	Required	Required	Elec Heat	Size of PV	Number of	Required	Number of	Required	Required			Energy	Savings	Incremental	Emissions
School	(therm)	(%)	(therm)	(therm)	(kBtu)	Pump (kWh)	System (kW)	PV Panels	(sqft)	Collectors	(sqft)	(sqft)	\$/kWh	\$/therm	Cost (\$)	(\$/yr)	Costs (\$)	Avoided (lbs)
A	320	53.4%	171	149	14,907	1,456	2	6	126.33	6	162.12	288.45			\$0.00	\$487.63	\$153,003	4,558
В	858	52.3%	449	409	40,935	3,999	4	12	252.66	12	324.24	576.9	\$0.27	\$1.25	\$0.00	\$1,324.33	\$225,578	12,379
С	503	51.4%	258	244	24,422	2,386	3	9	189.50	8	216.16	405.66			\$0.00	\$785.18	\$172,515	7,340

From DOE	0.0053 Met	ric tons of CO2/therm
eGrid	635.8 lbs (CO2/MW

Energy Analysis Using Commercial Heat Pumps for School A and B

	Existing Conditions											
				Heating	Storage							
				Capacity	Capacity							
School	Manufacturer	Heater Model	Tank Model	(Btu)	(gal)	Efficiency						
A	Lochinvar	CWN399PM	RGA0318	399,000	318	82%						
В	Lochinvar	CWN0986PM	RGA0700H	986,000	700	81%						
С	AO Smith	BTR2	75118	275,000	100	80%						
D	Lochinvar	CWN0497PM	ST175	495,000	175	81%						

	Existing Operation (Gas)												
	Daily Consumption	Daily Water Heating	Daily Water Heating Energy	Daily Gas Heating Energy Input	Annual Water Heating Energy	Annual Gas Heating Energy	Energy Cost						
School	(gal)	Energy (KBtu)	(tnerm)	(therm)	(KBtu)	(tnerm)	(\$/yr)						
A	162	87.6	0.876	1.069	31,989	390	\$487.63						
В	436 235.1 2.351 2.903 85,817 1,059 \$1,324.3												

		Option 1: Electr	ic Heat Pump	Operation							
School	Daily Consumption (gal)	Daily Water Heating Energy (kBtu)	Daily Water Heating Energy (kWh)	Daily Electric Heating Energy Input (kWh) (Heat Pump WH)	Annual Water Heating Energy (kBtu)	Annual Electric Heating Energy (kWh)					
A	162	87.6	25.686	7.784	31,989	2,841					
В	B 436 235.1 68.908 20.881 85,817 7,622										
				COP = 3.3							

Option 1: PV System												
		Heating										
	Annual	Energy						Energy Cost				
	Electric	Covered by			Roof Area			Savings @		Annual CO2		
	Heating	PV System	Size of PV	Number of	Required		Energy Cost	100% PV	Incremental	Emissions		
School	Energy (kWh)	(kWh)	System (kW)	PV Panels	(sqft)	\$/kWh	(\$/yr)	(\$/yr)	Costs (\$)	Avoided (lbs)		
A	2,841	2,841	3	9	189.50	¢0.27	\$0.00	\$487.63	\$80,250	4,558		
В	7,622	7,622	8	23	484.27	φυ.27	\$0.00	\$1,324.33	\$136,625	12,379		

	Option 2: Solar Thermal System with Electric Heat Pump Auxiliary														
			Heating												
			Energy	Auxiliary	Auxiliary	Auxiliary									
	Annual Gas		Covered by	Heating	Heating	Heating	Solar								
	Heating		Solar Thermal	Energy	Energy	Energy Input,	Thermal	Roof Area					Annual CO2		
	Energy	Solar Fraction	System	Required	Required	Elec Heat	Number of	Required		Energy Cost	Energy Cost	Incremental	Emissions		
School	(therm)	(%)	(therm)	(therm)	(kBtu)	Pump (kWh)	Collectors	(sqft)	\$/kWh	(\$/yr)	Savings (\$/yr)	Costs (\$)	Avoided (lbs)		
A	320	53.4%	171	149	14,907	1,324	6	162.12	¢0.27	\$357.46	\$130.18	\$141,253	3,716		
В	858	52.3%	449	409	40,935	3,636	12	324.24	φ0.27	\$981.59	\$342.74	\$153,253	10,068		

	Option 3: Solar Thermal System with Gas-Fired Heater Auxiliary														
			Heating			Auxiliary									
			Energy	Auxiliary	Auxiliary	Heating									
	Annual Gas		Covered by	Heating	Heating	Energy	Solar								
	Heating		Solar Thermal	Energy	Energy	Covered by	Thermal	Roof Area					Annual CO2		
	Energy	Solar Fraction	System	Required	Required	Gas Boiler	Number of	Required		Energy Cost	Energy Cost	Incremental	Emissions		
School	(therm)	(%)	(therm)	(therm)	(kBtu)	(therm)	Collectors	(sqft)	\$/therm	(\$/yr)	Savings (\$/yr)	Costs (\$)	Avoided (lbs)		
A	320	53.4%	171	149	14,907	182	6	162.12	¢1.25	\$227.24	\$260.40	\$96,253	2,434		
В	858	52.3%	449	409	40,935	505	12	324.24	φ1.25	\$631.71	\$692.63	\$112,503	6,474		

	Option 4: Hybrid Solar Thermal System and PV System with Electric Heat Pump																	
			Heating															
			Energy	Auxiliary	Auxiliary	Auxiliary												
	Annual Gas		Covered by	Heating	Heating	Heating					Solar Thermal	Total Roof				Energy		
	Heating		Solar Thermal	Energy	Energy	Energy Input,			PV Roof Area	Solar Thermal	Roof Area	Area				Cost		Annual CO2
	Energy	Solar Fraction	System	Required	Required	Elec Heat	Size of PV	Number of	Required	Number of	Required	Required			Energy	Savings	Incremental	Emissions
School	(therm)	(%)	(therm)	(therm)	(kBtu)	Pump (kWh)	System (kW)	PV Panels	(sqft)	Collectors	(sqft)	(sqft)	\$/kWh	\$/therm	Cost (\$)	(\$/yr)	Costs (\$)	Avoided (lbs)
A	320	53.4%	171	149	14,907	1,324	2	6	126.33	6	162.12	288.45	¢0.27	¢1.25	\$0.00	\$487.63	\$166,503	4,558
В	858	52.3%	449	409	40,935	3,636	4	12	252.66	12	324.24	576.9	φ0.2 <i>1</i>	φ1.25	\$0.00	\$1,324.33	\$225,578	12,379

From DOE 0.0053 Metric tons of CO2/therm eGrid 635.8 lbs CO2/MW

Energy Analysis Using Commercial Heat Pump and Gas-Fired Supplemental Heater for School B

	Existing Conditions											
Heating Storage												
				Capacity	Capacity							
School	Manufacturer	Heater Model	Tank Model	(Btu)	(gal)	Efficiency						
В	Lochinvar	CWN0986PM	RGA0700H	986,000	700	81%						

			Existing Ope	eration (Gas)							Option 1: Electr	ic Heat Pump	Operation		
	Daily Consumption	Daily Water Heating	Daily Water Heating Energy	Daily Gas Heating Energy Input	Annual Water Heating Energy	Annual Gas Heating Energy	Energy Cost			Daily Consumption	Daily Water Heating	Daily Water Heating Energy	Daily Electric Heating Energy Input (kWh) (Heat	Annual Water Heating Energy	Annual Electric Heating Energy
School	(gal)	Energy (kBtu)	(therm)	(therm)	(kBtu)	(therm)	(\$/yr)		School	(gal)	Energy (kBtu)	(kWh)	Pump WH)	(kBtu)	(kWh)
В	436 235.1 2.351 2.903 85,817 1,059 \$1,324								В	436	235.1	68.908	22.969	85,817	8,384
													COP = 3.0		

				PV Syste	an with Gas-FI	led heater				
		Heating								
	Annual	Energy						Energy Cost		
	Electric	Covered by			Roof Area			Savings @		Annual CO2
	Heating	PV System	Size of PV	Number of	Required		Energy Cost	100% PV	Incremental	Emissions
School	Energy (kWh)	(kWh)	System (kW)	PV Panels	(sqft)	\$/therm	(\$/yr)	(\$/yr)	Costs (\$)	Avoided (lbs)
В	8,384	8,384	8	23	484.27	\$1.25	\$185.41	\$1,138.93	\$117,875	10,646

From DOE 0.0053 Metric tons of CO2/therm eGrid 635.8 lbs CO2/MW

School: B	Site Visits: 2/1/18							
		Existing Condit	ions					
				Storage Capacity				
Manufacturer	Heater Model	Tank Model	Heating Capacity (Btu)	(gal)	Efficiency			
Lochinvar	CWN0986PM	RGA0700H	986,000	700	81.0%			

		Exis	ting DHW System vs Op	tion 1: Solar PV and	Heat Pump vs Optio	on 5: Point of Use Electr	ic				
		Daily Energy	Annual Energy	Percent of Total	Annualized	Annual Gas Heating	Annual Electric	Annual	Annual CO ₂		
	Consumption	Consumption / Load	Consumption / Load	Annual Heating	Heating System	Energy @ 81% Eff	Energy Input	Energy Cost	Emissions	DHW Site	DHW Source
System Component	(gal)	(kBtu)	(kBtu)	Energy	Efficiency	(therm)	(kWh)	(\$)	(lbs/year)	kBtu/ft ²	kBtu/ft ²
DHW Heating Load	436	235.1	85,817	64%	52%	1,059	0	\$ 1,176	12,379	0.59	0.62
DHWR Piping Losses	0	112.4	41,040	31%		507	0	\$ 562	5,920	0.28	0.30
DHW Storage Tank	0	17.2	6,271	5%	-	77	0	\$ 86	905	0.04	0.05
DHW Heating Total	436	364.7	133,127	100%	-	1,644	0	\$ 1,824	19,204	0.91	0.96
DHW Recirculation Pumps	0	27.1	9,900	0		0	2,902	\$ 158	1,848	0.05	0.14
Ex. DHW System Total	436	392	143,027	100%	-	1,644	2,902	\$ 1,982	21,052	0.97	1.10
Chronomite Model M-20L/120											
Electric Tankless Water Heater	436	235.1	85,817	100%	99%	0	25,406	\$ 10,331	16,185	0.48	1.23
Savings	0	156.7	57,210	-	-	1,644	-22,504	\$ (8,349)	4,868	0.49	-0.13
Option 1: Solar PV and Heat Pump	436	235.1	85,817	-	-	0	7,622	-	4,855	0.14	0.37
DHWR Piping Losses	0	112.4	41,040	-	-	0	3,645	-	2,322	0.07	0.18
DHW Storage Tank	0	17.2	6,271	-		0	557	-	355	0.01	0.03
DHW Recirculation Pumps	0	27.1	9,900	-	-	0	2,902	-	1,848	0.05	0.14
Option 1 System Total	436	392	143,027	-	-	0	14,725	-	9,381	0.28	0.71
Savings	0	0	0	-	-	1,644	-11,823	-	11,672	0.69	0.39
										0.69	

Demand Charg	ges
3.07	peak gpm per 15 minute period
65	delta T
99,901	Btu/h
100.9	kBtu
29.6	peak kW
\$ 8,946	annual demand charge
\$ 1,385	annual energy charge
\$ 10.331	annual electricity charge

DHW System Heat Loss Calcs

DHWR Piping

Floor	Length (LF)
First	1301
Second	168
Third	488
Fourth	28
Roof Penthouse	30
Total	2015
Btu/LF 3/4" pipe	4.7
Total BTU/h	9,370
Daily kBtu	112

 DHW Storage Tank

 U-value
 0.077

 Surface Area (ft)
 143.2

 Delta T
 65

 Total Heat Loss (Bt)
 715.8

 Daily kBtu
 17.2

 Annual KBtu
 6,271

 Annual Therms
 62.7

DHW Recirculation Pumps				
0.666	hp			
0.497	kW output			
0.662	kW input			
4380	run hours			
2,902	annual kWh in	iput		
9,900	annual kBtu in	put		
\$ 158.13	annual pump	energy cost		
27.1	daily kbtu			

1.9 gpm

10/17/2019

Appendix G:

Schematic Diagrams and Sketches



	OLA Consulting Engineers50 Broadway, Hawthorne, New York 10532 91.747.280012 East 49th Street, 11th Flr. New York, NY 10017 646.849.4110olace.com
	Key Standard Stress NEW YORK CITY School construction Authority Sharon L. Greenberger, MCP, President & CEO Board of Trustees Chancellor Joel I. Klein, Chairman Stanley E. Grayson, Trustee Lilliam Barrios-Paoli, Trustee
Image: Solution of Size OR REVISION DATE Image: No. Issue OR REVISION DATE	
No. ISSUE OR REVISION DATE No. ISSUE OR REVISION DATE No. ISSUE or reproduction or dissemination may be made of this drawing and the concepts set forth without the prior written consent of OLA Consulting Engineers, PC. Copyright © PROJECT TITLE PROJECT TITLE SOLAR DHW STUDY	
	No. ISSUE OR REVISION DATE No use, reproduction or dissemination may be made of this drawing and the concepts set forth without the prior written consent of OLA Consulting Engineers, PC. Copyright © PROJECT TITLE SOLAR DHW STUDY
DRAWING TITLE OPTION 1 - PV SYSTEM FLOW DIAGRAM SEAL SEAL SEAL SEALE SCALE AS NOTED DRAWING NO. AP DRAWING NO. AP DRAWING NO. AP DRAWING NO. DRAWING NO. AP DRAWING NO. DRAWING	DRAWING TITLE OPTION 1 - PV SYSTEM FLOW DIAGRAM SEAL SEAL SCALE PROJECT NO. AS NOTED DRAWING NO. AP DRAWING NO.



1	OLA Consulting Engineers 50 Broadway, Hawthorne, New York 10532 914.747.2800 12 East 49th Street, 11th Flr. New York, NY 10017 646.849.4110 olace.com
	CLIENT NEW YORK CITY SCHOOL CONSTRUCTION AUTHORITY Sharon L. Greenberger, MCP, President & CEO Board of Trustees Chancellor Joel I. Klein, Chairman Stanley E. Grayson, Trustee Lilliam Barrios–Paoli, Trustee
SOLAR COLLECTORS	
COMBINATION TEMPERATURE AND PRESSURE GAUGE (TYP.)	
 DIFFERENTIAL TEMPERATURE CONTROLLER HTF RETURN TO SOLAR COLLECTOR 	
ELECTRICAL WIRING TO SOLAR STORAGE TANK SENSOR	No. ISSUE OR REVISION DATE
	No use, reproduction or dissemination may be made of this drawing and the concepts set forth without the prior written consent of OLA Consulting Engineers, PC. Copyright © PROJECT TITLE
PUMPING STATION	SOLAR DHW STUDY
 EXTERNAL HEAT EXCHANGER (CAN ALSO BE INSIDE SOLAR TANK) DRAIN VALVE PIPED TO NEAREST FLOOR DRAIN 	DRAWING TITLE OPTION 2 - SOLAR THERMAL SYSTEM WITH ELECTRIC HEAT PUMP FLOW DIAGRAM SEAL SCALE AS NOTED DRAWN BY AP CHECKED BY
	ка Р5.1 Дате 12/14/17

7	OLA Consulting Engineers50 Broadway, Hawthorne, New York 10532 914.747.280012 East 49th Street, 11th Flr. New York, NY 10017 646.849.4110olace.com
	NEW YORK CITY SCHOOL CONSTRUCTION AUTHORITYSharon L. Greenberger, MCP, President & CEOBoard of TrusteesChancellor Joel I. Klein, Chairman Stanley E. Grayson, Trustee Lilliam Barrios-Paoli, Trustee
SOLAR COLLECTOR	
COMBINATION TEMPERATURE AND PRESSURE GAUGE (TYP.)	
 DIFFERENTIAL TEMPERATURE CONTROLLER HTF RETURN TO SOLAR COLLECTOR 	
ELECTRICAL WIRING TO Solar storage tank Sensor	No. ISSUE OR REVISION
	No use, reproduction or dissemination may be made of this drawing and the concepts set forth without the prior written consent of OLA Consulting Engineers, PC. Copyright © PROJECT TITLE
PUMPING STATION	SOLAR DHW STUDY
EXTERNAL HEAT EXCHANGER (CAN ALSO BE INSIDE SOLAR TANK) DRAIN VALVE PIPED TO NEAREST FLOOR DRAIN	DRAWING TITLE OPTION 3 - SOLAR THERMAL SYSTEM WITH GAS-FIRED WATER HEATER FLOW DIAGRAM SEAL SCALE PROJECT NO. NSCA1002.00 DRAWN BY DRAWING NO.
	АР СНЕСКЕД ВУ КG DATE 12/14/17

	OLA Consulting Engineers 50 Broadway, Hawthorne, New York 10532 914.747.2800 12 East 49th Street, 11th Fl New York, NY 10017 646.849.4110 olace.com	r.
	CLIENT NEW YORK CITY SCHOOL CONSTRUCTI AUTHORITY Sharon L. Greenberger, MCP, President & CE Board of Trustees Chancellor Joel I. Klein, Chairman Stanley E. Grayson, Trustee Lilliam Barrios–Paoli, Trustee	EON
PV COLLECTOR ELECTRICAL INVERTERS		
ELECTRICAL POWER WIRING TO ELECTRICAL BUILDING PANEL		
ELECTRICAL BUILDING PANEL		
FROM BUILDING	No. ISSUE OR REVISION DAT	ſE
DISTRIBUTION	No use, reproduction or dissemination may be made of this draw and the concepts set forth without the prior written consent of OLA Consulting Engineers, PC. Copyright © PROJECT TITLE SOLAR DHW STUDY DRAWING TITLE OPTION 4 - HYBBID SOLAB	ving
	SYSTEM WITH ELECTRIC HEAT PUMP FLOW DIAGRAM SEAL SCALE AS NOTED PROJECT NO. NSCA1002.02	1
	DRAWN BY AP CHECKED BY KG DATE 12/14/17	1

NEW ELECTRICAL CONDUIT DOWN ELECTRICAL PANEL

NEW PV PANEL ARRAY —— 9 PANELS TOTAL

School A <u>– Solar</u> Thermal System Roof Sketch

NEW SOLAR THERMAL — PIPING DOWN THROUGH CHIMNEY TO BASEMENT BOILER ROOM

NEW SOLAR THERMAL TOTAL AND PV PANEL













NEW SOLAR THERMAL PANEL \longrightarrow ARRAY 8 PANELS TOTAL. PIPING DOWN TO BOILER ROOM







Appendix H:

Sample Design School #1 Schematic Diagrams



				COI		OLA Consulting 50 Broadway, New York 1053 914.747.2800 12 East 49th S New York, NY 646.849.4110 olace.com	g Engineers Hawthorne, 32 Street, 11th Flr. 10017
			 B	CLIENT SCHC 3 LC	NEW OOL CON 3030 TH ONG ISL	YORK C STRUCTION OMPSON A AND CITY,	ITY AUTHORITY VENUE NY 11101
			 C				
			 - D				
			 E				
			 F				
			 G				
		BB	 H				
			 J	3 2 1 No.	FINAL ISSUE ISSUED FOF ISSUED FOF ISSUE OR F	E R REVIEW R REVIEW REVISION	5/29/19 5/6/19 4/23/19 DATE
			 K	PROJECT	TITLE DESIC	HEAT PU	MP DHW
				DRAWING T	PLUMBI	NG ROOF	PLAN CXC-15
				SEAL		SCALE AS NOTED	PROJECT NO. NSCA1008.00
14	(15) (16)					CHECKED BY JK DATE 3/28/19	P2.1A



1		5 (1	6					
	+	5) (I	0				A Consulting Er	ngineers
						50 Ne) Broadway, Hav w York 10532	vthorne,
						914	4.747.2800	
						12 Ne	East 49th Stree w York, NY 100	et, 11th Flr.
					CONSULT	64	6.849.4110	
					ENGINEE	ers ola	ace.com	
 ·			<u></u>	(_A	CLIENT			
- +				— — — (B				v
					SCHOOL			
					303		MPSON AVE	NUE
					LONG	G ISLAI	ND CITY, NY	′ 11101
I								
				C				
- +				——————————————————————————————————————				
+				——————————————————————————————————————				
- +				——————————————————————————————————————				
			BB					
				— – – (H				
	_							
		/				AL /00:		
					3 FIN,	AL ISSUE		5/29/19
					2 ISS	ued for r	EVIEW	5/6/19
				— – –(J		ued for r	EVIEW	4/23/19
					No. ISS	ue or rev	SION	DATE
					No use, reproduce and the concept	ction or disse s set forth w	mination may be made	of this drawing consent of
					OLA Consulting E	Engineers, PC.	Copyright © 2019	
l					PROJECT TITLE			
				— – – (K	SCA	H	IEAT PUM	p dhw
						ESIGN	N SUPPOF	RT
+				——————————————————————————————————————				
					DRAWING TITLE			
					PI I	JMBIN	G ROOF P	
				\frown		N B: A	ERMEC NF	RK0300
			·	— — — (M				
				\bigcirc				
	l				SEAL		SCALE DD	DJECT NO
							AS NOTED	NSCA1008.00
							DRAWN BY DRA	AWING NO.
							CHECKED BY)) 1D
		5 4	6				DATE	∠.ID
(14	+) (1	\mathbf{o} (1	0)				3/28/19	



						HE		P WAIE	RHEATER		RAGE IAN	IK SCHE	DULE					
					PERFORMA	NCE DATA					E	LECTRICAL DA	TA					
WATER HEATER	LOCATION	EAT	FLUID	EWT	LWT	MIN/MAX FLOW (GPM)	HEATING CAPACITY (BTU/H)	MIN HEATING COP	MIN RECOVERY RATE (GPH) (50°F-140°F)	FLA	MOCP/MCA	PHASE	CYCLE	VOLTS	WEIGHT (LBS)	(DBA)) DIMENSIONS/WEIGHT/CAPACITY	, REMARKS
HPWH-1/2	ROOF	7℉ WB 7℉ DB	40% PROPYLENE GLYCOL	55°F	145°F	3.18/6.87	143,552 (11.96 TONS)	2.0	190	55	50 / 68	3	60	460	TBD	90.0	DIA. 40" X 110" (H)/982 LBS/449 GAL. STORAGE (ST#1) BRADFORD WHITE MODEL NH449JG5A	COLMAC CXC-15 AS BASIS OF DESIGN.
NOTES																		

INUIES:

1. PROVIDE ADJUSTABLE TXV, SIGHT GLASS, LIQUID LINE DRIER.

2. PROVIDE BRONZE DHW CIRCULATING PUMP 1/6 HP FOR POTABLE WATER. <u>CP-A</u>: 6.42 GPM, 25 FT. WC. BELL & GOSSETT MODEL PL-36B 115/1/60 OR EQUAL.

3. PROVIDE 40% PROPYLENE GLYCOL CIRCULATING PUMP 1/6 HP. <u>CP-B</u>: 6.87 GPM, 25 FT. WC. BELL & GOSSETT MODEL PL-36 115/1/60 OR EQUAL. 4. PROVIDE GLYCOL FILL PUMP GP: 50 WATT, 0.7 GPM, AXIOM MODEL MF300 DIAPHRAGM PUMP (PUMP ONLY) OR EQUAL. 115/1/60 PROVIDE 24 VDC 50 WATTS POWER SUPPLY. 5. PROVIDE UNIT MOUNTED MICROPROCESSOR CONTROLLER WITH BACNET INTERFACE.

6. SS 304 CABINET, ALUMINUM FINS.

7. ET-2: AMTROL AX-15(V) AS BASIS OF DESIGN.

8. PROVIDE INLINE AIR SEPARATOR <u>IAS-1</u>: BELL AND GOSSETT IAS- $1\frac{1}{2}$ AS BASIS OF DESIGN. 9. PROVIDE MOTOR STARTER AND DISCONNECT SWITCH FOR EACH PUMP.

PLATE AND EXCHANGEF	FRAME HEAT
DESIGNATION	HX-1
LOCATION	BOILER ROOM
SERVICE	DOMESTIC HOT WA
MODEL	AT190X-IG1-120/9
CAPACITY (MBH)	287.10
NUMBER OF PLATES	96
HEAT TRANSFER AREA (SF)	225.36
NUMBER OF PASSES	8
DIMENSIONS (LXWXH IN.)	31.08x15.6x37.
WORKING PRESSURE (PSI)	150.0
WEIGHT (LBS)	782
COLD SIDE:	
FLUID	WATER
GPM	6.42
E.W.T/L.W.T. (°F)	50°/140°
WATER P.D. (PSI)	3.95
CONNECTION SIZE (IN.)	2.5
HOT SIDE:	
FLUID	40% PROPYLENE GL
GPM	6.87
E.W.T./L.W.T. (°F)	145°/55°
WATER P.D. (PSI)	4.81
CONNECTION SIZE (IN.)	2.5
NOTES: 1. POTABLE WATER HEAT EX VENTED/DOUBLE WALL 0.4 M STEEL, PLATE AND FRAME, E 2. BASIS OF DESIGN BASED	CHANGER SHALL BE M AISI 316L, STAINLES PDM GASKET MATERIA ON AIC.

OLA	Consulting	Engineers



12 East 49th Street, 11th Flr. New York, NY 10017 646.849.4110

olace.com

CLIENT

-

CONSULTING ENGINEERS

SCHC 3 LC	NEW OOL CONS 8030 THOI ONG ISLAI	YORK CI TRUCTION MPSON AY ND CITY, I	ITY AUTH VENU NY 11	IORITY JE 101
3	FINAL ISSUE			5/29/19
2	ISSUED FOR R	EVIEW		5/6/19
1	ISSUED FOR R	EVIEW		4/23/19
No.	ISSUE OR REV	ISION		DATE
No use, re and the co OLA Consu	production or disse oncepts set forth w Iting Engineers, PC	mination may be n rithout the prior wr . Copyright © 2019	nade of t itten cons	his drawing sent of
PROJECT	DESIG	»س N SUPPC	》 DRT)
DRAWING PLUI OF WITH	MBING DE PTION A: I SPLIT I	TAILS & S COLMAC IEAT EX(SCHE CXC CHAI	DULE C-15 NGER
SEAL		SCALE AS NOTED	PROJEC NSC	t no. A1008.00
		DRAWN BY AP CHECKED BY JK DATE 3/28/10	DRAWING	^{3 NO.}
 L			I	

SCHEDULE HX-1 BOILER ROOM DOMESTIC HOT WATER AT190X-IG1-120/96-DW 287.10 96 225.36 8

31.08x15.6x37.2

150.0 782 WATER 6.42 50°/140° 3.95 2.5 40% PROPYLENE GLYCOL 6.87 145°/55° 4.81 2.5

HANGER SHALL BE 1 AISI 316L, STAINLESS PDM GASKET MATERIAL. N AIC.



							HEAT PUMP	WAIER	HEATER &	SIOR	AGE TANK	SCHED	ULE					
WATER HEATER LOCAT		PERFORMANCE DATA								ELECTRICAL DATA								
	LOCATION	EAT	FLUID	EWT	LWT	MIN/MAX FLOW (GPM)	HEATING CAPACITY (BTU/H)	MIN HEATING COP	MIN RECOVERY RATE (GPH) (50°F-140°F)	FLA	MOCP/MCA	PHASE	CYCLE	VOLTS	APPROX. WEIGHT (LBS)	(DBA)	DIMENSIONS/WEIGHT/CAPACITY	, REMARKS
HPWH-1/2	ROOF	8.1°F WB 9.9°F DB	40% PROPYLENE GLYCOL	128°F	145°F	20.9 / 41.8	165,015 (13.75 TONS)	1.66	220	34	76 / 59	3	60	460	1,741	85.4	DIA. 40" X 110" (H)/982 LBS/449 GAL. STORAGE (ST#1) BRADFORD WHITE MODEL NH449JG5A	AERMEC NRK0300 AS BASIS OF DESIGN
NOTES: 1. PROVIDE ADJUSTA 2. PROVIDE BRONZE 3. PROVIDE 40% PRO 4. PROVIDE GLYCOL F 5. PROVIDE UNIT MOU 6. SS 304 CABINET, 7. FT-2: AMTROL AX	BLE TXV, SIGHT DHW CIRCULATIN PYLENE GLYCOL FILL PUMP <u>GP</u> : JNTED MICROPR ALUMINUM FINS	GLASS, LIQUID LIN NG PUMP 1/6 HP . CIRCULATING PUN 50 WATT, 0.7 GPN OCESSOR CONTROL	NE DRIER. FOR POTABLE V 1P 3/4 HP. <u>CP-</u> 1, AXIOM MODEL LER WITH BACN	VATER. <u>CP—A</u> : <u>-B</u> : 41.8 GPM MF300 DIAP IET INTERFACI	: (7.38 GPM, 1, 25 FT. WC HRAGM PUMF E.	25 FT. WC.). BI . BELL & GOSSE ? (PUMP ONLY) (ELL & GOSSETT MODEL TT MODEL PD-37S 11 OR EQUAL. 115/1/60	- PL-36B 115/ 5/1/60 OR EQI PROVIDE 24 VD	'1/60 OR EQUAL UAL. DC 50 WATTS PC	DWER SUPPL	Y.						1 -	

7. EI = 2: AMTRUL AX = 15(V) AS BASIS OF DESIGN. 8. PROVIDE INLINE AIR SEPARATOR <u>IAS-1</u>: BELL AND GOSSETT IAS- $2\frac{1}{2}$ AS BASIS OF DESIGN. 9. PROVIDE MOTOR STARTER AND DISCONNECT SWITCH FOR EACH PUMP.

	FRAME HEAT
EXCHANGER	SCHEDULE
DESIGNATION	HX-1
LOCATION	BOILER ROOM
SERVICE	DOMESTIC HOT WATER
MODEL	AT140X-IG1-47/26-DW
CAPACITY (MBH)	330.03
NUMBER OF PLATES	26
HEAT TRANSFER AREA (SF)	38.75
NUMBER OF PASSES	1
DIMENSIONS (LxWxH IN.)	17.64x11.80x39.10
WORKING PRESSURE (PSI)	150.0
WEIGHT (LBS)	413
COLD SIDE:	
FLUID	WATER
GPM	7.38
E.W.T/L.W.T. (°F)	50°/140°
WATER P.D. (PSI)	0.27
CONNECTION SIZE (IN.)	2.0
HOT SIDE:	
FLUID	40% PROPYLENE GLYCOL
GPM	41.71
E.W.T./L.W.T. (°F)	145°/128°
WATER P.D. (PSI)	5.79
CONNECTION SIZE (IN.)	2.0
NOTES: 1. POTABLE WATER HEAT EXC VENTED/DOUBLE WALL 0.4 MI STEEL, PLATE AND FRAME, EF 2. BASIS OF DESIGN BASED (CHANGER SHALL BE M AISI 316L, STAINLESS PDM GASKET MATERIAL. DN AIC.

LEAT DUNAD WATED LEATED & STODAGE TANK SOLEDULE

OLA Consulting Engineers



12 East 49th Street, 11th Flr. New York, NY 10017 646.849.4110

olace.com

CLIENT

.

CONSULTING ENGINEERS

SCHC G	NEW Y OOL CONST 3030 THOM ONG ISLAM	ORK CI RUCTION MPSON A ND CITY, I	ITY AUTH VENU NY 11	IORITY JE 101
3	FINAL ISSUE			5/29/19
2	ISSUED FOR RE	EVIEW		5/6/19
1 No.	ISSUED FOR RE	EVIEW SION		4/23/19 DATE
No use, re	production or disser	nination may be n	nade of t	his drawing
OLA Consu PROJECT	Ilting Engineers, PC.	Copyright © 2019		
SCA	DESIGN	» N SUPPC	∍ DRT	٧
DRAWING PLUI OPT WITH	TITLE MBING DE TION B: A I SPLIT H	TAILS & S ERMEC I IEAT EX(SCHE NRK CHAI	DULE 0300 NGER
SEAL		SCALE AS NOTED	PROJEC NSC	t no. A1008.00
		DRAWN BY AP CHECKED BY JK DATE 3/28/19	P7	3 ΝΟ. 7.18

Appendix I:

Sample Design School #2 Floor Plan and Schematic Diagram





