ELECTRIC VEHICLE CHARGING INFRASTRUCTURE LOCAL LAW 130/2013 CRITERIA & REQUIREMENTS*

EFFECTIVE DATE: 12/17/2013



Provide capability for installation of electrical vehicle charging stations in accordance with the following:

Parking Garages

YES

-Electrical raceway to the electrical supply panel serving the garage shall be capable of providing 3.1 kW minimum electrical capacity to at least 20% of parking spaces of garage.

-Electrical room supplying garage must provide physical space for such electrical supply panel.

Open Parking Lots

-At least 20% of parking spaces shall be equipped with electrical raceway capable of providing 11.5kVA minimum supply to Electric Vehicle Supply Equipment from an electrical supply panel.
-Electrical supply panel serving such parking spaces must provide at least 3.1 kW of available capacity for each stall connected to it with raceway.

CRITERIA FOR LL130/13

CRITERIA INELIGIBLE FOR LL130/13

REQUIREMENT