60% DESIGN SUBMISSION NYC 2016 Green Schools Rating System

P.S. 347X Bronx Annex at PS33X & Lot 8 2400 Jerome Ave, Bronx, NY, 10468 LLW# 107340 Architect: Mitchell Giurgola Architects, LLP 7 May 2018, 15 June 2018 Revision, 18 September 2018 Revision, 15 October 2018 Revision



Street View without MTA massing

Contents

Minutes of	Meeting	5
Project Ch	ecklist	11
Credit Con	npliance Narratives	13
Site Cre	dits	13
S1.1P	Construction Activity Pollution Prevention	13
S1.2R	Site Selection	14
S1.3R	Sustainable Site & Building Layout	16
S1.4	Development Density & Community Connectivity	30
S1.5R	Joint Use of Facilities, Community Access	32
S1.6P	Site Assessment	34
S1.7	Brownfield Redevelopment	41
S2.1	Alternative Transportation, Public Transportation Access	42
S2.2	Alternative Transportation, Bicycle Storage & Changing Rooms	43
S2.3R	Alternative Transportation, Fuel-Efficient Vehicles/Parking	45
S3.1	Site Development, Protect or Restore Habitat	45
S3.2	Site Development, Maximize Open Space	48
S4.1	Stormwater Design, Quality Control	48
S5.1R	Heat Island Effect, Roof	49
S6.1	Light Pollution Reduction	50
Water C	redits	55
W1.1	Water Efficient Landscaping, Reduce by 50%	55
W1.2	Water Efficient Landscaping, Reduce by 100%	56
W2.1P	Water Use Reduction	57
W2.2R	Water Use Reduction, 30% Reduction	60
W2.3	Water Use Reduction, 35% Reduction	60
W2.4	Water Use Reduction, 40% Reduction	60
Energy.	· · · · · · · · · · · · · · · · · · ·	61
E1.1P	Fundamental Commissioning	61
E2.1P	Fundamental Refrigerant Management	61
E2.2	Enhanced Refrigerant Management	62
E3.1R	Measurement & Verification	64
E3.2R	Energy Management System Controls, HVAC and Hot Water	65
E4.1P	Minimum Energy Performance	66
E4.2R	HVAC System Sizing, Avoid Oversizing	72
E5.1R	Green Power	73
Material	s Credits	73
M1.1P	Storage & Collection of Recyclables	73
M1.2	Building Reuse, Maintain 75% of Existing Walls, Floors & Roof	74
M1.3	Building Reuse, Maintain 95% of Existing Walls, Floors & Roof	74
M1.4	Building Reuse, Maintain 50% of Interior Non-Structural Elements	74
M1.5R	Construction Waste Management, Divert 50% from Disposal	74
M1.6R	Construction Waste Management, Divert 75% from Disposal	75
M1.7	Construction Waste Management, Divert 95% from Disposal	75
M2.1R	Recycled Content, 10% (post-consumer + 1/2 pre-consumer)	75
M2.2	Recycled Content, 20% (post-consumer + 1/2 pre-consumer)	76

M2.3	Regional Materials, 10% Extracted, Processed & Manufactured Regionally	77
M2.4	Regional Materials, 20% Extracted, Processed & Manufactured Regionally	78
M2.5R	Wallboard & Roof Deck Products, Mold Resistance	78
Indoor	Environmental Quality Credits	78
Q1.1P	Minimum IAQ Performance	79
Q1.2R	Outdoor Air Delivery Monitoring	82
Q2.1R	Construction IAQ Management Plan, During Construction	82
Q2.2R	Construction IAQ Management Plan, Before Occupancy	83
Q3.1R	Low-Emitting Materials, Adhesives & Sealants	84
Q3.2R	Low-Emitting Materials, Paints & Coatings	84
Q3.3R	Low-Emitting Materials, Flooring Systems	85
Q3.4R	Low-Emitting Materials, Comp Wood & Agrifiber Products	85
Q4.1R	Indoor Chemical & Pollutant Source Control	86
Q4.2R	Electric Ignition Stoves	86
Q4.3R	Post Construction Indoor Air Quality	87
Q5.1R	Controllability of Systems, Lighting	87
Q5.2R	Controllability of Systems, Thermal Comfort	89
Q6.1R	Thermal Comfort, Design	90
Q7.1	Daylight & Views, Daylight 75% of Classrooms	91
Q7.2	Daylight & Views, Daylight 90% of Classrooms	99
Q7.3	Daylight & Views, Daylight for 75% of Other Spaces	99
Q7.4	Daylight & Views, Views	101
Q7.5R	Visual Performance, Direct-Indirect Lighting	110
Q8.1P	Minimum Acoustical Performance	110
Q8.2	Enhanced Acoustical Performance & Sound Isolation for Special Spaces	111
Q8.3	Acoustic Windows	112
Additio	nal Credits	113
A1.1R	LEED® Accredited Professional	113
A1.2	Innovation or Exemplary Performance	113
A1.3	Innovation or Exemplary Performance	113
A2.1	Heat Island Effect, Non-Roof	114
A2.2	Stormwater Design, Quantity Control	114
A2.3	Active Design in a School Environment	114
A3.1	Enhanced Commissioning	116
A3.2	Optimize Energy Performance	116
A3.3	On Site Renewable Energy	116
A3.4	Enhanced Energy Management System Controls, HVAC and Hot Water Systems	116
A4.1	Low-Emitting Materials, Ceiling and Wall Systems	116
A5.1	The School Building as a Teaching Tool	116
APPEND		117
Credit S	SI. IP: Soil Erosion and Sediment Control Plan	118
Credit S	56.1: Site Photometric Analysis & Plan	123
Credit I	21.1P: Specification Table of Contents modified for project	125
	24.1 & A3.2: Assessment of Energy Performance for Compliance with NYC SCA Green $C_{1,1}$ (100% $E_{2,2}$ $M_{1,1}$ $D_{2,2}$ $M_{1,1}$	n 121
School	Guide (100% Energy Model Report)	131
Credit I	24-2: Cooling and Heating Load Calculations	219

Credit Q1.1P: ASHRAE Outdoor Air Assessment	
Credit Q1.1P: CFD modeling	
Credit Q7.5R: Point-by-point lighting level (photometric) and LPD calculations for typica	al and non-
typical areas	
Credit Q8.1P & Q8.2: Acoustical 60% review.	
Acoustical 100% review:	
Acoustical Compliance Memo	
Q8.3: Window Acoustical Laboratory Test Report	

Project Checklist

							17									
								\mathbb{N}								
Project Ch	eckl	list	- page 1	l of 2			<u>SC</u>	A	School C	O	nst	ruc	tio	n Aı	ıthor	ity
									NYC Green S	cho	ols R	ating	Syste	em 2016		
											SD	DD	60%	100%	Const	
Project:	PS347	Brony	Annex	at PS33X				Sub	omission (Check or	ne):			X			1
Address Zip Code:	2424 J	erome	e Ave, Bi	ronx, NY, 1046	8				Submission Da	ate:	7Ma	y2018	B, rev	ised 21A	ug2018	
LLW #:	107340)					.									
Design #:	Mitcho				Reviewer :									If Anticipated, or		
Alchitect.	WITCHE	ii/Giu	ryoia			Review	wer Sign Oil.	-		GS				if Docum	ented: 3	redi
	_									de in				or leave	blank	sued al C
	60					1	F "			ipco	jects	-		if Not Fe	asible or	Purs
se	n ce Is 20	5	016			tion				ect z	Pro	ible	~	if Not Pu	rsued	Add F
Jam	fere	erer	0 20			d cip	ĔĔ			proje	rall	eas	dits	۵	_	e i Blar
di i	Scl	Ref	S			and				sck	5	1 1 1	- S	has	tion	ed: ible ued
å	D80	H PS	¥			adit	op-C			(ch	lired	lired	onal	L	e	Fill Fill
		Ū	-			5				RC	Sequ	Sequ	Dtic	Desiç	Cons	A of P
											_	-		-	0 -	
Site	SS Pr 1		27%	of I otal Po	Activity	Pollution	Brovention				ND	P		14 Crodit Ro	out of	19 firm Bureuit
	SS 1		S 1.2R	Site Selectio	n	Fonution	Flevenuon				1	•	1123	1	q u - con	
		1.1.7	S 1.3R	Sustainable \$	Site & B	uilding La	vout				NP	~	YES	Indicate	Pursuit	NO
Site Selection	SS 2		S 1.4	Development	t Density	y & Commi	unity Conne	ctiv	rity	RPC		4		4		
	SS 10	1.1.2	S 1.5R	Joint Use of F	Facilitie	s, Commur	nity Access				1			1		
	SS Pr 2		S 1.6P	Environment	al Site A	Assessment	t				NP	~	YES	Credit Re	q'd - Con	firm Pursuit
	SS 3		S 1.7	Brownfield R	edevelo	opment						1			NF	1
Transportation	SS 4.1		S 2.1	Alternative Transportation, Public Transportation Access					RPC		4		4			
Transportation	SS 4.3/4	.4	S 2.3R	Alternative Transportation, Elegicity of orlanging Rooms						2	1		2	-		
	SS 5.1		S 3.1	Site Development, Protect or Restore Habitat					RPC	_	1		_	NF	1	
Minimize Impact on Site	SS 5.2		S 3.2	Site Development, Maximize Open Space							1		NF		1	
Storm water Design	SS 6.2		S 4.1	Stormwater I	Design,	Quality Con	itrol					1		NF		1
Heat Island Effect	SS 7.2		S 5.1R	Heat Island E	ffect, Ro	oof					1			1		
Outdoor Lighting	SS 8		S 6.1	Light Pollutio	on Redu	ction		0:+	o Cotogon (Sub To	talı		1		NF		1
Water			4%	of Total Po	inte			SIL	e Calegory Sub-To	lai.	5	14 P	l oints:	14	out of	5 8
Water	WE 1.1		W 1.1	Water Efficie	nt Land	scaping, R	educe by 50	%				2		NF	out of	2
Outdoor Systems	WE 1.1		W 1.2	Water Efficie	nt Land	scaping, R	educe by 10	0%				2		NF		2
	WE Pr 1		W 2.1P	Minimum Water Use Reduction, 20% Reduction							NP	>	YES	Credit Re	q'd - Con	firm Pursuit
Indoor Systems	WE 3		W 2.2R	Enhanced Water Use Reduction, 30% Reduction							2			2		
	WE3		W 2.3	Enhanced Water Use Reduction, 35% Reduction								1		NF		1
	WE 3		VV 2.4	Water Category Sub-To						tal·	2	6		2		6
Energy			6%	of Total Po	ints		•	T ditt	si catogoly cas io	ton	-	P	oints:	- 3		5
Commissioning	EA Pr 1		E 1.1P	Fundamental	l Comm	issioning					NP	~	YES	Credit Re	q'd - Con	firm Pursuit
Refrigerant Management	EA Pr 3		E 2.1P	Fundamental	l Refrige	erant Mana	igement				NP	V	YES	Credit Re	q'd - Con	firm Pursuit
	EA 4		E 2.2	Enhanced Re	frigerar	nt Managei	ment					2		NF		2
Verification	EA 5	225	E 3.1R	Measuremen	t & Veri	fication	ontrolo LIV//		PLI W Svotoma		1		1/50	Indianta	1 Durquit	
	FA Pr 2	3.3.5	E 3.2R	Minimum Eng	aray Po	rformance			x n. w. Systems			V	YES	Credit Re	Pursuit	firm Pursuit
Energy Efficiency		3.1.2	E 4.2R	HVAC System	n Sizina	. Avoid Ove	rsizina				NP	 	YES	Indicate	Pursuit	
Power	EA 6		E 5.1R	Green Power	r J	,					2				2	
							Er	nerg	y Category Sub-To	tal:	3	2		0	3	2
Materials			13%	of Total Po	oints							P	oints:	7	out of	10
	MR Pr 1		M1.1P	Storage & Co	ollection	of Recycla	ables f Existing W/	allo	Floors & Boof		NP		YES	Credit R	≩q'd-Conf	irm Pursuit
	MR 1.1		M13	Building Reu	se, Mair	nan 15% 0	f Existing Wa	ans, alls	Floors & Roof	RPC		1			NF	1
Efficient Material Use	MR 1.2	-	M 1.4	Building Reu	se, Mair	ntain 50% of	f Interior Non	-Str	uctural Elements			1			NF	1
	MR 2	-	M1.5R	Construction	Waste I	Manageme	nt, Divert 50	% fr	rom Disposal		1				1	
	MR 2		M 1.6R	Construction	Waste I	Manageme	nt, Divert 75	% fr	rom Disposal		1				1	
	MR 2		M 1.7	Construction	Wastel	Manageme	nt, Divert 95	% fr	rom Disposal			1			1	
	MR 4		M2.1R	Recycled Cor	ntent, 10	0% (post-co	nsumer + 1/2	pre	-consumer)		1				1	
Queteinstite Med. 11	MR 4		M 2.2	Recycled Cor	ntent, 20)% (post-co	nsumer + 1/2	pre	-consumer)			1			1	
Sustainable Materials	MR 5		M 2.3	Regional Mat	terials, "	10% Extrac	ted, Process	ed of	& Manufactured			1			1	
	IVII V U	4,1.1	M 2.5R	Wallboard &	Roof De	ck Produc	ts. Mold Res	ista			NP	1	YES	Indicate	Pursvit	
See Notes on Page 2 of 2							Mate	erial	s Category Sub-To	tal:	3	7			7	3

					1.1	\sim								
Project Che	eck	list	- page 2	2 of 2	ŚĆ	AÌ	School (Ca	ons	tru	icti	on A	utho	rity
-					IIINYC		NYC Green S	cho	ols R	atino	ı Svst	em 2016	;	
											, . ,			
									SD	DD	60%	100%	Const	
Project:	PS347	Bronx	Annex	at PS33X	t PS33X Submission (Check or									
Address Zip Code:	2424 J	lerome	Ave, B	ronx, NY, 10468	nx, NY, 10468 Submission Da								ug2018	1
LLVV #: Design #:	10734	0			Reviewer:			чл						
Architect:	Mitchell/Giurgola Reviewer Sign Off:											If Anticipated, or		** *
			Ĭ					Ü ⊒.				Enter po	int value,	Cred,
		<u> </u>						ode	s			or leave	blank	rsue
	500 g		6		us tion			t zipc	ojec	- -		if Not Pu	rsued	điti Pu
mes	srence	renc	500		Men			oject	E E	asib	its 2			f No r Ad
it Na	Sch	Refe	ese		Desc and and own			sk pr	Fora	if Fe	Cred	ase	<u>io</u>	d:B Se o Se o
Cred	6 C	ST ST	ž		P-D dit [chea	red	per	nal	E E	La ct	Fille Poi easil
0		5	Z		Dro Gelevice			ŭ	inpe	quir	ptio	sign	onst	ot of P
					—			R	2	R	0	ā	ŭ≣	< z z z
Indoor Environmer	ntal Qu	uality	25%	of Total Points						P	oints:	13	out of	16
IAQ Post-occupancy	IEQ 1		Q 1.1P	Air Flow Stations, Ou	tside Air Intakes				NP 1	V	YES	Credit Re	eq'a - Cor	firm Pursun
	IEQ 3.1		Q 2.1R	Construction IAQ Mar	nagement Plan, During	Con	struction		. 1				1	
IAQ Pre-occupancy	IEQ 3.2		Q 2.2R	Construction IAQ Mar	nagement Plan, Before	e Occ	upancy		1				1	
	IEQ 4.1		Q 3.1R	Low-Emitting Materia	IIs, Adhesives & Sealan	ts ⁴			1				1	
Low-Emitting Materials	IEQ 4.2		Q 3.2R	Low-Emitting Materia	Low-Emitting Materials, Paints & Coatings 4								1	
	IEQ 4.3		Q 3.3R	Low-Emitting Materials, Flooring Systems ⁴					1				1	
	IEQ 4.4		Q 4.1R	Indoor Chemical & Pollutant Source Control								1	-	
Pollution Source Control		5.3.5	Q 4.2R	Electric Ignition Stove	es				NP		YES	Indicate Pursuit		NO
		6.2.4	Q 4.3R	Post Construction Indoor Air Quality					NP	Y	YES	Indicate	Pursuit	NO
Controllability of Systems	IEQ 6.1		Q 5.1R	Controllability of Systems, Lighting					1			1		
The sum of O and fairt	IEQ 6.2		Q 5.2R	Controllability of Syst	tems, Thermal Comfort				1			1		
Thermal Comfort	IEQ 7.1		071	Davlight & Views Dav	sign vlight 75% of Classroom	19			1	4		1		
	IEQ 8.1		Q 7.2	Daylight & Views, Daylight for 90% of Classrooms						1		NF		1
Lighting and Views	IEQ 8.1		Q 7.3	Daylight & Views, Daylight for 75% of Other Spaces						1		NF		1
	IEQ 8.2		Q 7.4	Daylight & Views, Views						1		NF		1
		5.2.1	Q 7.5R	Visual Performance, Artificial Direct-Indirect Lighting						2	YES	Indicate	Pursuit	NO
Acoustics	IEQ Pr 3	5.5.1	Q 8.1P	Minimum Acoustical Performance							YES	Credit Re	eq'd - Cor	firm Pursui
Acoustics	IEQ 9	SCA	Q 8.3R	Ennanced Acoustical Performance & Sound for Special Spaces						1	YES	1 Indicate	Pursuit	
	Į	1-0.1			tal:	11	5	120	7	6	3			
Regional			0%	of Total Points	Use pull-down menus 🍾		RPC Claimed			Р	oints:	0	out of	4
	RP 1.1		R 1.1	Regionally Defined C	redit Achieved		WEc2 (NF/SCA)			1		0		0
Regionally Appropriate ⁵	RP 1.2		R 1.2	Regionally Defined C	redit Achieved		Blank			1				1
	RP 1.3		R1.3	Regionally Defined C	realt Achieved		Blank			1				1
L			1		Reg	ional	Category Sub-To	tal:	0	4	0	0		3
Additional Credits			25%	of Total Points	For A 3.1	Usep	oull-down menu ↓			P	oints:	13	out of	33
	ID 2		A 1.1R	LEED [®] Accredited Pro	ofessional				1			1		
Innovation in Design	ID 1		A 1.2	Innovation or Exemp	lory Performance						1			1
	ID 1 SS 7 1		A 1.3	Innovation or Exemp	Iory Performance						1			1
Optional - Site Impact	SS 6.1		A 2.2	Stormwater Design.	Quantity Control			RPC			1			
	ID 1		A.2.3	Active Design in a Sc	hool Environment						1	1		1
	EA 3		A 3.1	Enhanced Commissio	oning						2			2
Optional - Energy	EA 1		A 3.2	Optimize Energy Per	formance ⁶ lew 20%, R	enov	vation 18%, 11 pt				16	11		5
	EA 2	225	A 3.3	On-Site Renewable Energy If NOT Approved, 0 pts					ND		7	Indiant	Burguit	7
Optional - IEQ	IEQ 4 6	3.3.3	A 4.1	Low-Emitting Matoria	Is Ceiling and Wall Sve	stem	α, ΠΥΛΟ α Π.ΨΥ. s ⁴	-	NP		1	mulcate	rursuit	
Optional - Education	ID 3		A 5.1	The School Building	as a Teaching Tool	Storn					1			1
					Additional C	redit	Category Sub-To	tal:	1		32	13	0	21
	Letter	prefix ir	ndicates	credit section (S, W, E,	M, Q, R, A)		Column Tota	als:	25	38	32	36	16	43
	First n	umber	indicates	the category within the	section		LEED [®] Equiv	/ale	ent Po	oint T	otal ⁷ :	52	out of	95
SCA Credit Name :	Secon	d numb	er indica	tes the specific credit w	ithin the section catego	ry	-							
	Suffix '	"P" is a	added for	credits that are LEED®	prerequisites and there	fore r	equired of all proje	ects	3					
	Suffix "R" is added for credits that are required of all projects													



Credit Compliance Narratives

Project: <u>34/X Bronx Annex at P.S. 33X Bronx Ann</u>	<u>nex</u> Date: <u>17 April 2018, 5 June 2018, Revised 18 Sept 2018</u> ,
15 October 2018 Revision	
Address: 2424 Jerome Ave, Bronx, NY, 10468	Architect: Mitchell/Giurgola
LLW #: <u>107340</u>	Submission: <u>60% Design</u>
Design #:	Reviewer:
-	Reviewer Sign Off:

Directions:

- Eleven of the Site narratives are submitted with the Schematic Submission as indicated below. All other required narratives are submitted with the Design Development submittal.
- Design Teams must submit narratives for all credits in the Site, Water, Energy, Materials and Indoor Environmental Quality sections. For the Additional Credits, all projects must include a narrative for credit A1.1R. Narratives for the other Additional Credits should only be provided when it has been determined with the SCA that the additional credit(s) are to be pursued for this project. Include explanation of why the additional credit is to be pursued on this project. For those credits subject to Regional Priority Credit, indicate whether based on the zip code that the credit is eligible to obtain the additional point.
- Narratives should summarize the design approach to credit compliance and identify the specific SCA standards (standard specifications and design requirements) to be incorporated into the design documents. Include any specific information requested under the "Credit Submittals" heading from the second page of credit text. Provide explanations and calculations where appropriate for credits that are determined to be "not feasible" for this project.

Site Credits

Site Selection
<u>S1.1P</u> Construction Activity Pollution Prevention
Credit anticipated

Due to the fact that the site area of disturbance that is contributory to a separate sewer system is expected to be less than one acre (**21,260sf including lot 8**), a NYS DEC SPDES General Permit (GP-0-15- 002) and preparation of a Storm Sewer Pollution Prevention Plan (SWPPP) is not anticipated to be required. However, as a Best Management Practice (BMP), a Soil Erosion and Sediment Control Plan shall be prepared and included in the Contract Documents.

This Soil Erosion and Sediment Control Plan will be created to satisfy the requirements of the SCA's NYC Green School Guide. The plan typically involves notes, descriptions, and details of the necessary controls. We

anticipate that dust control measures, silt fencing, storm drain inlet protection, protection of existing vegetation, and a gravel temporary construction entrance will be needed for this project. This Soil Erosion and Sediment Control Plan has been provided on drawing A043 **dated 9July2018 and A047 dated 9July2018** (see Appendix A) to satisfy the requirements of the SCA's NYC Green School Guide. The plan involves notes and descriptions of the necessary controls. Straw bale dike, storm drain inlet protection, and a temporary stabilized construction entrance is indicated for this project.

Applicable SCA Standard Specifications include:

- S01352 Sustainability Requirements
- S01900 Existing Premises Work
- 02200 Earthwork.

These specification sections included in 100% CD set dated 9July2018.

S1.2R Site Selection

NARRATIVE AT SCHEMATIC SUBM.

1. As can be seen in the Google Earth image below the project site was previously developed and thus meets the 1st requirement of this credit of previously undeveloped needing to be 5 ft above 100-yr flood.



2. The project site is Not identified as habitat for any species based on the following documents:

a. U.S. Department of the Interior, Fish and Wildlife Service map generated 13Apr2017 indicates there are no critical habitats within this project area.



Critical Habitat for Threatened & Endangered Species [USFWS]

U.S. Fish and Wildlife Service | NYC OpenData, State of New Jersey, Esri, HERE, Garmin, INCREMENT P, USGS, EPA, USDA

b. New York Natural Heritage Program website indicates no plants or animals identified, thus references Environmental Resource Mapper in item #3 below.

3. The New York State DEC Environmental Resource Map below indicates the land is NOT within 50 feet of any wetlands.

and that may require special management and protection.



- 4. The New York State DEC Environmental Resource Map above indicates the land is NOT within 100 feet of water body. In addition, the Google Earth image in S1.2R item #1 above indicates the project site was previously developed.
- 5. The project site is NOT public parkland as indicated in S1.2R item #1 above as per the included Google Earth image; the entire site consists of an existing public school.

S1.3R Sustainable Site & Building Layout Credit anticipated.

Credit Item #1: Identify viable locations on the roof(s) for potential renewable energy generation.

The design scheme has two areas on the South end of roof that has access to South sun and the potential for solar energy generation. The remainder of roof's southern exposure is blocked by mechanical equipment, building structure, and mechanical penthouses. If it is possible that the mechanical equipment on the Southeast portion of the roof move to a different location, the potential for solar power generation would increase significantly.





Progress Plan 23Oct2017, little change in plans received 20&29Nov2017, or dated 11Dec2017.

Credit Item #2: Plot shadow patterns from surrounding buildings onto project site to optimize access to daylight.



12pm



September 21st 9am



3pm



12pm





As can be seen from the above shadow plots the existing main school building does not shade the proposed addition. The neighboring 3-story buildings, along with the existing Southeast property line wall, to the Southeast will shade 1st and 2nd stories of the proposed building Southeast façade during the winter, spring, and fall in the morning.

Credit Item #3: Orient and compose the building to take advantage of natural daylighting.



The design maximizes the daylight access to regularly occupied spaces through exterior windows.

First Floor drawing dated 19Feb2018



Second Floor drawing dated 19Feb2018



Third Floor drawing dated 19Feb2018



Fourth Floor drawing dated 19Feb2018



North South Section dated 11Dec2017, little change in section dated 19Feb2018

PRE

+ THIRD FLOO

SECOND FLOOR



East West Section dated 11Dec2017, little change in section dated 19Feb2018

Credit Item #4: Plot shadow patterns from proposed building(s)/addition on adjacent properties and buildings and consider design options to address impact as necessary.

See above plotted shadow patterns for 9am, 12pm, and 3pm for June 21st, September 21st, and December 21st in credit Item #2 above.

As can be seen from the above shadow plots the proposed addition will shade the Northwest façade of the existing main school building during the fall, winter, and spring with part of the first floor during the summer for the afternoon. The proposed addition shades the residential buildings to the East during the afternoons for most of the year.

Credit Item #5: The following is a windrose diagram for the site:



Operable windows on the South, West, and East facades will allow for natural ventilation of the spaces adjacent to these windows which include classroom and administration. The existing building will partially shelter the proposed addition from the prevailing Northwest winter winds.

Credit Item #6: Take advantage of existing adjacent building and natural land formations and vegetation to provide shelter from extreme weather or to deflect unwanted noise.



The existing school building to the will provide partial protection from the winter's Northwest winds to the building exterior; see 3-D Google Earth image above.

Credit Item #7: Landscaping mitigation: There are a small amount of existing deciduous trees to the West along Jerome Avenue which will provide some spring/summer/fall shading to the lower floors while allowing the warm sun in the winter (See 3-D Google Earth image above in Credit Item #6.

<u>S1.4</u> Development Density & Community Connectivity NARRATIVE AT SCHEMATIC SUBM. Credit anticipated.

The project easily complies with Option 1, Community Connectivity; as seen below in the Google Earth image and a copy of the Development Density & Community Connectivity Form. There is a 38-unit residential building on a 0.18 acre site at 2410 Walton Ave and many services within ½ mile of the project.



DEVELOPN	IENT DENSI	TY &		ŚCA	Sch	ool Cor	struction	Authority						
COMMUNIT	TY CONNECT	IVITY FORM	1											
Credit S1.4					NYC	Green So	chools Rating S	system						
Project:	P.S. 33X Bron	ix Annex												
Address:	2424 Jerome	Ave, Bronx, NY, 1046	58		_	Architect:	Mitchell/Giurgola							
LLW #:	107340		Design #:		_	Preparer:	EME Group							
Date:	23-Oct-17					Telephone:	212-529-5969							
Fill in either Op	otion 1 or Option	2												
Option 1 - C	Community Co	onnectivity (Submi	t site plan with b	asic service lo	ocation	s noted ma	atching table n	umbering and						
separate pla	an verifying du	welling unites per a	acre)											
		Plan Kev		Rusinoss Nam										
		Identification	within 1/2 m	bilo (2 640 foo	t) radi	ucand	Sonvio							
					i rau	us anu	Servic	e Type						
			accessibi	e by pedestri	an ac	cess								
		1	C-T	own SuperMa	rkets		Grocery							
		2	Multi	cultural Music	Group		Music Center							
		3	Ustin	Hall Monroe C	College		College							
		4	lgles	ia Estrella de	Jacob		Place of Wors	hip						
		5	Bror	ix Dental Cent	er Inc		Dental Care							
		6	Diamon	ite Poblano Re	estaura	nt	Restaurant							
		7		Salon 25			Beauty Salon							
		8	S	ammy's Fashi	ion		Clothing Store	÷						
		9	Forh	am Road Phar	rmacy		Pharmacy							
		10	Br	ony Library Ce	nter		Library							

S1.5R Joint Use of Facilities, Community Access

Credit anticipated.

The community will have access to the school for various public programs, performances, and events. The proposed designs allow for controlled access from the Jerome Avenue entrance to the 1st floor cafeteria, parents/community room, and exercise room. Additionally, members of the community may have access to the library on the fifth floor via the staircase and elevators located to the left of the main entrance door.

Applicable SCA design requirements that will be complied with include Cafeteria PK-8 and HS DR1.3.5.1, Entrances and Exits DR1.3.4.1, Vestibules and Lobbies DR1.3.4.2, Corridors 1.3.4.3, Interior Stairs DR1.3.4.4, and Elevators DR1.3.4.5.



1st Fl 60% Received 9Apr2018



S1.6P Site Assessment

Credit anticipated.

A Phase I Environmental Site Assessment (ESA) was performed by AKRF Engineering, PC on 26Jan2017. The Phase I ESA indicates the possible presence onsite of ACM materials and historical fill from historic building demolition, suspect LBP identified on painted surfaces and potential PCB-containing buried fill.

Please see the following Executive Summary from the Phase I ESA report lots 14 and 20:

1.0 EXECUTIVE SUMMARY

At the request of the Industrial and Environmental Hygiene (IEH) Division of the New York City School Construction Authority (NYCSCA), AKRF Engineering, P.C. (AKRF) conducted a Phase I Environmental Site Assessment (ESA) of the property located at 2400-2424 Jerome Avenue in the Bronx, New York 10468 (hereafter referred to as the "Site"). The Site property is located on Tax Block 3188 and consists of the Public School (P.S.) 33X building (Lot 20), play area (Lot 14) and the off-site P.S. 33X Annex (Lot 8). Due diligence was completed for Lot 8 in 2014 and the use of this lot has remained the same (school annex building), therefore this Phase I ESA only includes Lots 20 and 14.

The legal description of the Site is Block 3188, Lots 14 and 20. The approximately 12,300-square foot (SF) Lot 14 consists of a play area paved with a synthetic surface. The approximately 40,000-SF Lot 20 is developed with a four-story building with a partial basement on an approximately 10,000-SF footprint, and surrounding paved and landscaped areas. The building, constructed as a public school in 1900, serves as the Timothy Dwight Elementary School, also identified as P.S. 33X, for pre-kindergarten through 5th grade. A one-story building with a partial basement, south-adjacent to the Site (Block 3188, Lot 8), is occupied by the P.S. 33X Annex (not considered part of the Site for the purpose of this assessment). The Site is located in an area primarily characterized by commercial, residential, and institutional (educational) uses with some auto-related uses. The on-site play area and the Annex are being considered for the construction of a new addition to the existing P.S. 33X building by the NYCSCA.

The northern portion of the Site was historically vacant, and developed with the existing P.S. 33X building in 1900. Two additions were constructed on the eastern side of this building in 1928. The southern portion of the Site was historically vacant and developed with seven commercial buildings with backyards between 1900 and 1945. The commercial buildings were demolished between 1954 and 1962 and replaced by the existing play area.

The Site is bounded to the north by commercial and residential buildings; to the south by the P.S. 33X Annex, Lot 8 (not considered part of the Site for the purpose of this assessment); to the east by Walton Avenue, residential properties, and a church; and to the west by Jerome Avenue and elevated subway tracks, followed by residential and commercial properties, a construction site, and an auto repair shop.

AKRF previously conducted several studies of the Annex, Lot 8 [a Phase I ESA in January 2012, an Indoor Air Quality (IAQ) survey in September 2011, a Phase I ESA Update in July 2013, and a Subsurface (Phase II) Investigation in August 2014], and a Vapor Intrusion (VI) Assessment of the existing P.S. 33X building in August 2014.

The main objective of the Phase I ESA is to identify recognized environmental conditions (RECs) and environmental concerns that may affect the suitability of the Site for use as a school. RECs are defined in ASTM International (ASTM) Standard Practice E 1527-13 as the presence or likely presence of any hazardous substances or petroleum products in, on, or at a property. Note that controlled recognized environmental conditions (CRECs) are considered to be RECs and are listed in the Executive Summary and Conclusions of this Phase I ESA. Additionally, vapor encroachment conditions (VECs) were evaluated as per ASTM E 2600-10.

Other environmental issues and conditions that, in the opinion of the *environmental professional* conducting the assessment, would not be considered *RECs* are identified in this assessment. These may include *historical RECs and/or de minimis conditions*. The Phase I ESA also includes a preliminary evaluation of specific potential environmental issues or conditions that are, according to ASTM E 1527-

13, considered non-scope considerations. These issues include radon, asbestos-containing material (ACM), polychlorinated biphenyl (PCB) - containing light ballasts and caulking materials, exterior leadbased paint (LBP), chemical storage, wetlands, regulatory compliance issues, dry cleaner and other industrial emissions, mold, biological agents, electromagnetic fields, and methane. The Phase I ESA included a review of federal, state, and local records, and historical documents; visual observation of the Site and adjoining properties; and interviews with selected Site representatives.

The assessment requested by the NYCSCA is intended to identify conditions that would have the potential to impact the value of the Site or the development and use of the Site as a public school facility. The assessment was also conducted for purposes of environmental due diligence in order to qualify for the innocent landowner, a bona fide prospective purchaser or a contiguous property owner defense under the Comprehensive Environmental Response, Compensation, and Liability Act (CERCLA). The Phase I ESA included evaluation of the following: current and historical Site usage; current and historical usage of adjoining properties; regulatory agency records review; on-site solid waste management and disposal practices; on-site hazardous materials and petroleum products management; chemical storage, ACM, PCBs and exterior LBP management; wetlands; regulatory compliance issues; dry cleaner and other industrial emissions; radon; mold and moisture intrusion; biological agents; electromagnetic fields; and potential for methane-generating materials.

AKRF has performed a Phase I ESA in conformance with the scope and limitations of ASTM Practice E 1527-13 and the requirements of NYCSCA. Any additions to, exceptions to, or deletions from this practice are described in Section 2.0 of this report.

This Phase I ESA has revealed the following RECs, CRECs, and/or VECs associated with the Site:
Summary of RECs, CRECs, VECs, and Environmental Concerns

On-Site RECs/CRECs/VECs:

- A Vapor Intrusion (VI) assessment of the original school building was conducted by AKRF in 2014, following the detection of elevated volatile organic compounds (VOCs) in sub-slab at the PS 33X Annex. VOCs associated with chlorinated solvents (TCE and PCE) were detected above their respective New York State Department of Health (NYSDOH) Air Guideline Values (AGVs) in one sub-slab vapor and one soil vapor sample. However, TCE and PCE concentrations were below their corresponding AGVs and published background levels in all indoor air samples collected in both the building basement and slab-on-grade areas, and indicated no evidence of vapor intrusion into the original P.S. 33X building.
- Historic fill material of unknown origin and potential buried debris associated with the demolition of historical buildings on Lot 14, which could include possible underground storage tanks (USTs).
- The original P.S. 33X school building on Lot 20 was associated with Spill No. 9300750, reported at the Site in April 1993, and closed by the New York State Department of Environmental Conservation (NYSDEC) in August 2008. The listing indicated that the spill involved No. 2 fuel oil floating on top of the groundwater table, which was discovered during an excavation at the school. The source of the spill was associated with a leaking 275-gallon aboveground storage tank (AST) at an adjacent building (2413 Walton Avenue). Remedial activities included the replacement of the leaking AST, and removal of contaminated soil and groundwater.
- Historically, Lot 14 was developed with commercial buildings between 1927 and 1956 which included a possible painter or printer, plumbing and heating supply, a sign shop, a laundry (potential dry cleaner), a vacuum cleaner service, an electrical appliance business and a sign manufacturer. This lot is situated between the two previously investigated Lots 8 and 20.

Off-Site RECs/CRECs/VECs:

- The south-adjacent PS 33X Annex site historically contained a sign shop and a potential watchmaker or repair shop. A 2014 subsurface investigation and vapor intrusion assessment conducted by AKRF identified VOCs associated with chlorinated solvents and petroleum at concentrations above NYSDOH AGVs and/or the range of anticipated background concentrations in several sub-slab vapor samples. However, all VOC concentrations in indoor air were below the AGVs and vapor intrusion was not a concern.
- Historical uses of the Site block and adjacent blocks included manufacturing, appliance repair, dry cleaning/dyeing, auto-related uses (auto repair, filling station), paint shops, printers, and an exterminator. The regulatory database identified one Brownfield Cleanup site, six Spills sites, nine PBS sites, five RCRA hazardous waste generator sites, two registered drycleaners, as well as multiple historical dry cleaners and auto station in close proximity to the Site.

This Phase IESA has revealed the following environmental concerns associated with the Site:

- Suspect ACM in building materials and potentially in buried fill materials associated with demolition of historical structures on Lot 14.
- Suspect LBP identified on painted surfaces and potentially in buried fill materials associated with demolition of historical structures on Lot 14.
- Potential PCB-containing electrical fixtures and light ballasts and potential PCBs in buried fill
 materials associated with demolition of historical structures on Lot 14.
- The P.S. 33X building reportedly experiences occasional water infiltration through walls. However, no evidence of mold was noted.

Recommendations:

Based on a February 15, 2017 Test Fit/Sketch Study prepared by NYCSCA, the proposed new Addition will consist of a stand-alone annex building occupying all of Lot 8 and only a minor portion of Lot 14. Given that the new building construction will require minimal excavation on Lot 14 and since no new RECs have occurred since the 2014 Vapor Intrusion assessment for Lot 20, additional investigation of the Site is not warranted at this time. Based on the findings of the 2014 Phase II ESI report for Lot 8, a vapor barrier and an active sub-slab depressurization system (SSDS) should be incorporated into the new building design. In addition, if design plans for the proposed addition change in the future such that its construction will require significant soil disturbance on Lots 14 and/or 20, a pre-design investigation should be conducted. AKRF also recommends that any ACM, LBP, and/or PCB-containing building components affected by any future demolition and/or construction activities at the Site property should be identified and properly managed during such activities in accordance with all applicable regulations and NYCSCA policies and procedures. Finally, stormwater infiltration through building walls in the main P.S. 33X school building should be properly addressed, in accordance with NYCSCA policies and procedures.

Please see the following Executive Summary from the Phase II ESA report for Lot 8 which is assumed to be same conditions at Lot 14:

PHASE II ENVIRONMENTAL SITE INVESTIGATION P.S. 33X ANNEX, 2392 JEROME AVENUE BRONX, NEW YORK 10468

EXECUTIVE SUMMARY

At the request of the New York City School Construction Authority (NYCSCA), AKRF Engineering, P.C. (AKRF) conducted a Phase II Environmental Site Investigation (ESI) at the P.S. 33X Annex, located at 2392 Jerome Avenue in the Bronx, New York 10468 (the "Site"). The legal description for the Site is defined as Block 3188, Lot 8. The Site consists of an approximately 10,000-square foot, one-story school building with a partial cellar. The NYCSCA is considering purchasing the Site, which they currently lease, and continuing to use it as a public school facility. The Site is located in an area that is primarily characterized by commercial, residential, and institutional (educational and playground) uses with some auto-related uses.

AKRF completed an Indoor Air Quality Survey for the Site on September 2011, a Phase I Environmental Site Assessment (ESA) in January 2012, and a Site Inspection and Regulatory Database Review in July 2013. The Indoor Air Quality Survey indicated that no volatile organic compounds (VOCs) were detected at concentrations above the range of anticipated background indoor air levels or comparison criteria. On-Site Recognized Environmental Conditions (RECs)/Vapor Encroachment Conditions (VECs) identified by the Phase I ESA included: historical site use as a sign manufacturer and potential buried structures from historical on-Site buildings that may contain underground storage tanks and/or historic fill of unknown origin. Off-Site RECs identified included: closed spills and a Petroleum Bulk Storage (PBS) listing at P.S. 33X north-northeast of the Site; a filling station with Resource Conservation and Recovery Act (RCRA), PBS and active spills listings; current and historical automotive-related facilities (auto repair shops, a car wash, and a filling station) with closed spills, PBS and/or RCRA listings; and sites with historical uses including an exterminator, known and suspected dry cleaners, paint and sign shops, printers, possible electric companies, and various manufacturers. The Site Inspection and Regulatory Agency Database Review did not identify any new RECs that were not present at the time of the January 2012 Phase I ESA.

The purpose of the Phase II ESI was to determine whether the RECs/VECs identified in the Phase I ESA Report have affected the suitability of the Site for acquisition and potential redevelopment by the NYCSCA. Initial Phase II ESI field activities were performed on June 17 and 21, 2014 and consisted of a geophysical survey and the completion of five soil borings, two temporary monitoring wells, and four sub-slab vapor sampling points. A total of five soil samples, two groundwater samples, and four sub-slab vapor samples were collected for laboratory analysis. Supplemental Phase II ESI activities were conducted on July 31, 2014, and consisted of a Vapor Intrusion (VI) Assessment, including a building inspection and a chemical inventory, and the collection and laboratory analysis of five (5) sub-slab vapor samples and five co-located indoor air samples from the annex building and one (1) ambient air sample from the adjacent play yard.

Based on the results of the Phase II ESI, AKRF concludes the following:

- Fill material, consisting of sand with silt, gravel, concrete, and asphalt, was observed to depths of approximately 3 to 5 feet below ground surface (bgs) in three of the soil borings. Apparent native material, consisting sand, silt, and gravel, was observed below the fill. Weathered bedrock was encountered between 1.5 and 15 feet below grade.
- Volatile organic compounds (VOCs) and semivolatile organic compounds (SVOCs) were detected in select soil samples at concentrations below New York State Department of Environmental Conservation (NYSDEC) Soil Cleanup Objectives (SCOs) for Unrestricted Use and CP-51 Supplemental SCOs. No detectable concentrations of polychlorinated biphenyls (PCBs) or gasoline-range total petroleum hydrocarbons (GRO-TPH) were present in the soil samples. Diesel range (DRO) TPH was present in each of the soil samples; however, there are no SCOs for TPH and the concentrations are not anticipated to impact potential soil disposal options.
- Pesticides (4,4-DDT and 4,4-DDE) and metals (chromium, lead, and zinc) were detected in select soil samples at concentrations exceeding the NYSDEC Unrestricted Use SCOs. The detections were not indicative of an on-Site release but are attributable to historic fill material.

Tetrachloroethene (PCE), trichloroethene (TCE), and petroleum-related compounds were
detected in sub-slab vapor samples at concentrations above the New York State Department of
Health (NYSDOH) Air Guideline Values (AGVs) and/or the range of anticipated background
concentrations during initial sampling on June 21, 2014. Results from subsequent Vapor
Intrusion Assessment on July 31, 2014 indicated that PCE and TCE were detected at
concentrations below the AGVs, and petroleum-related compounds were detected at
concentrations slightly above the anticipated range of background concentrations in sub-slab
vapor. All the VOC concentrations in both sub-slab vapor and indoor air were below the AGVs
and below levels that would warrant further monitoring or mitigation.

Based on these results, AKRF concludes that the Site is suitable for continued use as a public school facility in its current condition. If the on-Site building is substantially modified or demolished and replaced with a new building, AKRF recommends the following measures to make the Site suitable for use as a public school facility:

- If the on-Site building is replaced, consistent with NYCSCA standard practice, a soil vapor barrier should be incorporated into the new building design as a safeguard to prevent potential VOCs in soil vapor from entering the new school building. If substantial modifications are made to the existing building slab, consideration should be given to installing a sub-slab sheet membrane vapor barrier or a topically-applied vapor barrier (e.g., Aquafin).
- Water infiltration noted in the building basement during the July 2013 Site Inspection and Regulatory Agency Database Review should be properly addressed to prevent potential mold growth.
- All material excavated during construction activities should be properly characterized prior to transportation to an off-Site disposal facility. Results from the limited waste characterization sampling conducted during this investigation should not be used in lieu of data from a full Site characterization. Based on the results of the Phase II ESI, it is anticipated that material excavated from the Site would require handling as non-hazardous excavated material.
- Fill material should be evaluated for the presence of asbestos-containing materials (ACM). In
 addition, any suspect ACM, lead based paint (LBP) and polychlorinated biphenyl (PCB)containing materials affected by the proposed demolition or construction work should be
 identified prior to and properly managed during construction activities.
- Any dewatering required during construction should be minimized to mitigate influx of
 potentially contaminated water from off-Site sources toward the Site. Treatment to remove
 sediment and other potential contaminants from dewatering effluent may be required prior to
 discharge to the municipal sewer. The contract specifications should include requirements that
 the Contractor procure all appropriate permits and conduct any pre-treatment required to meet
 applicable sewer effluent limitations for discharge of the dewatering fluids.
- If exposed soil (landscaped areas) is incorporated into redevelopment plans for the Site, a
 minimum of two feet of environmentally clean fill should be placed over existing soil in these
 areas.

At the time of issuing this report no hazardous material remediation is expected to be needed.

A soil vapor barrier and sub-slab depressurization system will be integrated into the new building design as per drawings H201-H208 dated 9July2018. The project team has incorporated the specification Sections 02200,

Earthwork, 02220 Gas Vapor Barrier (Fluid Applied), 02221 Sub-slab Depressurization System, and 15880 Subslab Depressurization System Accessories into the construction documents dated 9July2018.

S1.7 Brownfield Redevelopment

Credit is not feasible.

See S1.6P above for the contamination status narrative and executive summary of the Phase I Environmental Site Assessment Report.

The site has not been defined as a Brownfield by a New York City, New York State, or federal government agency. The Phase I Environmental Site Assessment Report indicated that the databases and/or documentation of the following were evaluated:

- United States Environmental Protection Agency (USEPA)
- New York State Department of Environmental Conservation (NYSDEC)
- National Priorities Listing (NPL)
- Delisted NPL Site List
- Superfund Enterprise Management System (SEMS)
- Resource Conservation and Recovery Information System Treatment, Storage, or Disposal Facilities (RCRIS-TSD)/RCRIS Corrective Action Activity (CORRACTS)
- Federal Institutional Control/ Engineering Control Registries
- Emergency Response Notification System (ERNS)
- Toxic Release Inventory System (TRIS)
- New York State Inactive Hazardous Waste Disposal Sites (SHWS)
- Hazardous Substance Waste Disposal Site Inventory (HSWDS)
- Solid Waste Management Facilities (SWMF)
- Vapor Reopened
- New York State Spills Information Database (NY Spills)/Leaking Underground Storage Tanks (LTANKs)
- Petroleum Bulk Storage Tanks (USTs/ASTs)
- Chemical Bulk Storage Tanks (USTs/ASTs)
- New York State Voluntary and Brownfields Cleanup Program Sites
- Registered Dry Cleaners
- Manufactured Gas Plant Sites (Coal Gas)
- New York City E-Designation Site Listing
- EDR Historic Auto Station
- New York City Fire Department (FDNY)
- New York City Department of Buildings (NYCDOB)

In addition, TRC requested hazardous materials information from the following agencies:

- New York State Department of Health (NYSDOH)
- New York City Department of Health and Mental Hygiene (NYCDHMH)
- New York City Department of Environmental Protection (NYCDEP)

See S1.6P above for the executive summary of the Phase II Environmental Site Assessment Report. The Phase II Environmental Site Investigation performed by AKRF Engineering, PC from June 17, 2014 to June 21, 2014 would seem to indicate that the site does not contain hazardous materials in quantities that would deem the site

as contaminated. Thus, this credit would appear not to be feasible unless additional hazardous materials are found during excavation and construction.

A soil vapor barrier and sub-slab depressurization system will be integrated into the new building design as per drawings H201-H208 dated 9July2018. The project team has incorporated the specification Sections 02200, Earthwork, 02220 Gas Vapor Barrier (Fluid Applied), 02221 Sub-slab Depressurization System, and 15880 Sub-slab Depressurization System Accessories into the construction documents dated 9July2018.

Transportation

<u>S2.1</u> Alternative Transportation, Public Transportation Access NARRATIVE AT SCHEMATIC SUBM. Credit anticipated.

The project complies with Option 1, 1/2 mile to subway station; the following Google Map image indicates that the Fordham Road station for the 4 Subway line is within 1/2 mile of main building entrance; in addition, there are public buses and school buses that are in compliance with Option 2.

Option 1 walking distances are as follows:

• 0.2 miles to Fordham Road station for the 4 Subway line.



S2.2 Alternative Transportation, Bicycle Storage & Changing Rooms Credit anticipated.

The project design incorporates secure bicycle storage and changing rooms. The bicycle storage will be provided outside and within the building and on the site and will accommodate at least 5% of all building staff and students above third grade. The shower and changing facilities in the building will accommodate 0.5% of Full-time equivalent (FTE) staff.

The interior bike storage will be provided on the 1st floor, in the entrance vestibule of the West entrance. SCA's DR1.3.1. requires 1 bicycle/10,000sf resulting in a minimum of 5 bicycle spots at 15sf/bicycle. The 19Feb2018 plan indicates storage for 5 interior bicycles.

Full Time employees will be provided with a single unisex showers/changing room to the North of the bicycle storage on the 1st floor adjacent to the elevators and North stair.

Applicable SCA design requirements that will be complied with include DR 1.3.1.12 Bicycle Storage and DR 2.3.3 Bicycle Racks.

From 19Feb2018 Plans		
Building Area	0	From 11Dec2017 SD Report
		From 11Dec2017 SD Report, 19Feb2018 Plans, and DR
Total Students in Building	1,080	2.3.3
Number of students above 3rd grade	0	From 11Dec2017 SD Report, 19Feb2018 Plans, and DR 2.3.3
Number of FTE	63	From 11Dec2017 SD Report, 19Feb2018 Plans, DR 2.3.3, and 2Oct2017 Pre-schematic POR
Total students above 3rd grade & FTE	63	
Required Bicycle Spots for students above 3rd grade & FTE	4	5% but no less than 1. 5 required per DR 1.3.1.12 and zoning.
Required Shower & Changing Facilites for FTE	1	0.5% but no less than 1.
Provided Interior Bicycle Spots	5	From 19Feb2018 Final Plans, 5 required per DR 1.3.1.12 and zoning.
Provided Exterior Bicycle Spots	0	The 5 interior comply with the required 5 total spaces.
Provided Shower & Changing Facilites for FTE	1	From 19Feb2018 Final Plans

	1st	2nd	3rd	4th	5th	Building Total
Pre-K	0	3919				
			0	0	0	3,919
Kindergarten		1,936	4,865			6,801
Grade 1						
				5,626		5,626
Grade 2						
					3,164	3,164
Grade 3						
						0
Grade 4						
						0
Grade 5						
						0
CSD Space						
Fd					676	676
Pooding/Spo					010	0/0
ech/Res		530				530
		000				000
A+						0
AIL						0
Music						0
						_
Computer						0
Project Rm	Ļ		891			891
Iotal SF all G	brades	-				21,607
Total all Grad	le Students					1,080
Total SF Abo	ve 3rd Grad	le				
Total Above 3	Brd Grade S	tudents				0
1010171007010		Cadon to				0

DR 2.3.3 Student Calculations



1st Fl Plan dated 19Feb2018

Applicable SCA design requirements that will be complied with include DR 1.3.1.12 Bicycle Storage and specification 05700 Ornamental Metals have been incorporated into construction documents dated 9July2018.

S2.3R Alternative Transportation, Fuel-Efficient Vehicles/Parking

Credit anticipated.

Option 1, no new parking, will be pursued.

The project is an annex next to an existing building with the majority of the non-building site dedicated to the undersized play areas; no new parking is planned to be provided within the building or on the site.

A site plan is not applicable due to no new parking provided.

Minimize Impact on Site <u>S3.1</u> Site Development, Protect or Restore Habitat Credit is not feasible

As currently designed, the project will be unable to comply with the requirements of this credit; the project site is currently a school playground (Lot 14); the new building is going to be built almost to the full extent of the site and will have no open spaces other than a circulation path at the back; SCA will demolish the existing one-story building (Lot 8) south of the new school and make it the future playground which will be maximized for play area with little vegetation. The credit guidelines would require the project to include a minimum of **7,501** sf of

native or adapted vegetation which is not possible based on the site program. Currently, the site design contains approximately **369** sf of planted area and does not have a vegetated roof.

From 100% CDs		
Total Site Area (including sidewalk) for Lot 14 & 8	24,600	From Site Survey dated 25Oct2017
Building Footprint Proposed	9,598	From Z002 dated 9July2018
Site Area Minus Building Footprint	15,002	
50% of Site Area (excl. building footprint)	7,501	Required to use larger
20% of Total Site Area (incl. building footprint)	4,920	
Green Roof Space	0	
		Scaled from Site Plans dated 9July2018,
		assume 100% of street trees are
Vegetated Area (Existing Street Trees)	369	native/adaptive; includes existing sidewalk.



Site Plan Based on 100% CDs dated 9July2018

S3.2 Site Development, Maximize Open Space Credit is not feasible

In order to comply with this credit, the project must provide vegetated open space equal to at least 20% of the project's site area, excluding the building footprint. Since this project is located in an urban area and will be achieving S1.4, pedestrian-oriented hardscape can contribute to this credit if a minimum of 25% of the open space is vegetated.

As can be seen below, there is not enough vegetation for this credit to be earned; the project site is currently a school playground (Lot 14); the new building is going to be built almost to the full extent of the site and will have no open spaces other than a circulation path at the back; SCA will demolish the existing one-story building (Lot 8) south of the new school and make it the future playground which will be maximized for play area with little vegetation.

From 100% CDs		
Total Site Area (including sidewalk) for Lot 14 & 8	24,600	From Site Survey dated 25Oct2017
Building Footprint Proposed	9,598	From Z002 dated 9July2018
Site Area Minus Building Footprint	15,002	
20% of Site Area (excl. building footprint)	3,000	
25% of 20% Site Area Requiring Vegetation	750	
		Scaled from Site Plans dated 9July2018,
		assume 100% of street trees are
Open Space (Pedestrian & Vegetated)	16,096	native/adaptive; includes existing sidewalk.
Green Roof Space	0	
		Scaled from Site Plans dated 9July2018,
		assume 100% of street trees are
Vegetated Area (Existing Street Trees)	369	native/adaptive; includes existing sidewalk.

Applicable SCA design requirements that will be complied with include DR1.3.1.1 Building Layout and Orientation, and 1.3.1.2 Planning Guidelines for New Schools and Additions.

Stormwater Design

S4.1 Stormwater Design, Quality Control

Credit is not feasible.

Due to the fact that the site area of disturbance that is contributory to a combined sewer system and is 21,260 sf which is less than one acre, a New York State Department of Environmental Conservation (NYSDEC) State Pollutant Discharge Elimination System (SPDES) General Permit for Stormwater Discharges from Construction Activity (GP-0-15-002) and preparation of a Stormwater Pollution Prevention Plan (SWPPP) is not anticipated to be required.

Lot 14 (the site of the proposed annex building), will have a restricted flow to the combined sewer in Jerome Avenue of 0.25 cubic feet per second (cfs). Stormwater will be detained as a combination of permanent roof detention and site detention. The future play yard project at Lot 8 will have its own separate site detention system. The proposed systems are not designed treat 90% of average annual rainfall and remove 80% of TSS, thus this credit is not earned; AKRF's 31July2018 e-mail verified the stormwater systems will not comply with this credit.

Applicable SCA Design Requirements include:

6.1.11 Stormwater Management

Applicable SCA Standard Specifications Include: 02723 Stormwater Drainage Systems.

Heat Island Effect <u>S5.1R</u> Heat Island Effect, Roof Credit anticipated.

The top roof layer of roof paver ballast shall comply with SCA standard specification section 07560, Fluid applied Protected Membrane Roofing and have a SRI value of 78 for a minimum of 75% of the roof surface thus assuring compliance with this credit.

NARRATIVE AT DD SUBMISSION

Applicable SCA Design Requirements include:

6.1.11 Stormwater Management

Applicable SCA Standard Specifications Include: 07560 Fluid Applied Protected Membrane Roofing.

Gross Roof Area	9,598	Sq Ft	From Z002 dated 9July2018
Parapets	770	Sq Ft	Scaled from Plans dated 9July2018
Mechanical Equipment & Penthouses	2,698	Sq Ft	Scaled from Plans dated 9July2018
Net Roof Area Not Including Mechanical Equipment, & Parapets	6,130	Sq Ft	
Roof Area Covered by Compliant Roof Pavers	5,867	Sq Ft	Scaled from Plans dated 9July2018
% of Roof Covered by Compliant Roof Pavers	95.71%		



Bulkhead Roof dated 9July2018



<u>S6.1 Light Pollution Reduction</u> Credit is not feasible.

In the past SCA has directed that similar sites meet GSG's definition of "areas predominantly consisting of Residential zoning, Neighborhood business districts, Light industrial with limited nighttime use, and Residential mixed-use areas" Zone LZ2 requirements as directed by RCNY5000-01 of the New York City Energy Code for projects in R-districts and R-districts with C overlays and MX districts. It has been verified that the project is in an R7-1 Residential District with C2-4 Commercial Overlay District. LZ2 limits initial illuminance to 0.10 horizontal and vertical footcandles at the site boundary and 0.01 horizontal footcandles 10 feet beyond the site boundary.

Light pollution reduction design approach toward meeting this credit include:

- Luminaires will be high efficiency LED.
- All interior lighting shall automatically be controlled by a programmable Lighting Control Panel with integral clock except for the emergency lighting. The Lighting Control Panel shall be provided at the Electric Closet and to control all spaces that do not have automatic shutoff and/or Occupant sensors. This will meet this credit's requirement for control of interior lighting with direct line of site to the exterior.

- Instructional space: For spaces 2,000 SF or less in area, lighting shall be controlled by one ceiling mounted vacancy sensor/daylight sensor which will meet this credit's requirement for control of interior lighting with direct line of site to the exterior.
- Exterior/site/security lighting will be provided around the perimeter of the school for safe passage of students and staff and to deter theft and vandalism.
- Main Entrances and Walkways: 1.0 foot-candle minimum as per DR7.2.5 revised 29Sept2017. This, many times, is at odds with the credit requirements for maximum lighting at site boundary, but student safety and security will take precedence although every effort will be made to still earn this credit.
- Building Perimeter: 1.0 foot-candle (average) to a 20-foot depth. This, many times, is at odds with the credit requirements for maximum lighting at site boundary, but student safety and security will take precedence although every effort will be made to still earn this credit.
- Exterior Lighting levels will be achieved utilizing high efficiency LEDs which will be full cut-off Dark Sky compliant and shall have optional visors and shields to prevent light trespass.
- All fixtures will be suitable for exterior use with a hinged and gasketed diffuser/door.
- Diffusers will be mechanically affixed to the doorframe.
- Lighting Control: All site security lighting will be master controlled by the programmable lighting controller.

Applicable SCA Design Requirements include:

7.2.1 Interior Lighting7.2.3 Emergency Lighting7.2.5 Exterior / Site / Security Lighting

Applicable SCA Standard Specifications Include 16145 Lighting Control Devices 16502 LED Interior Building Lighting 16520 Illuminated Exit Sign and Emergency Lighting Fixtures 16530 LED Site/Security Lighting

Light Pollu	tion Reduction - For	n A		5		
Exterior Lig	ght Tresspass - Site L	umen Calculat	ion	ŚCA	School Construct	on Authority
Credit S6.1				INTC.	NYC Green Schools Rati	ng System - 2016
Project:	P.S. 347X Bronx An	nex at PS33X				
Address:	2424 Jerome Ave. Bronx					
	107340	, 111, 10400		Architect	Mitchell Giurgola Architects	IIP
Date:	6/25/2018			Preparer:	EME Group	,
				Telephone:	212-529-5969	
Site Lumer	Calculation					
Fixture Type						
		Quantity of Installed Luminaries	Initial Lamp Lumens per Luminaire	Total Lamp Lumens	Initial Lamp Lumens Above 90 degrees from Nadir	Total Lamp Lumens Above 90 degrees
Z1	Site	14	2,818	39,452	0	0
Z2	Roof	5	3,698	18,490	0	0
НЗ	Overhang	4	1,500	6,000	0	0
				0		0
[insert rows	as necessary]					
		Total I	_amp Lumens	63,942		
			Tot	al Lamp Lume	ens above 90 degrees	0
		Pe	rcentage of Si	te Lamp Lume	ens above 90 degrees	0%
lf P	ercentage of Site La	mp Lumens ab re	ove 90 degree ferenced for th	s is less than one select site L	or equal to the value Z then site complies.	Yes
				LZ1: 0%, LZ2:	2%, LZ3:5%, LZ4: 10%	

Light Pollutio	n Reduction - Form B					
Light Power [Density Calculations - Exterior Light	ng Only	ŚCA	School Con	struction Au	thority
Credit S6.1	Applicable for ASHRAE 90.1-2010			NYC Green Sch	nools Rating Sys	stem - 2016
Project:	P.S. 347X Bronx Annex at PS33X	1				
Address:	2424 Jerome Ave, Bronx, NY, 10468		Consulting Firm:	DVL Consulting Eng	gineers, Inc	
LLW:	107340		Preparer:	EME Group		
Date:	June 25, 2018		Telephone:	212-529-5969		

1. Exterior Building Lighting Power Allowance (Tradable Lighting Applications) - BASELINE BUDGET

Designer Note: Building Entrance, Canopy & Overhang and Other Exterior Lighting ONLY (No Façade Lighting to be included) Use this table to calculate the lighting power allowance for exterior lighting in tradable applications. <u>Identify</u> each of the tradable lighting applications listed in Table 9.4.5 that occur in the project, <u>select</u> the application type using the drop down menu (e.g. building entrance with canopy), the allowance is entered automatically, <u>enter</u> the linear feet **or** square feet as appropriate, the allowance times the area or length is automatically calculated, and entered in the Tradable Power Allowance column and summed in the cell shaded blue.

Exterior Lighting Applications (Identify each <u>project-specific</u> location)	Table 9.4.5 - Select Your Application (Apply 90.1-2010 Standard Description)	Allowance (W/ft or W/sf)	Area or Length (ft or sf)	Tradable Power (Watts)
Main school entrance	Bldg Entrances: Main entrances (W/ft of door width)	30.00	6	180
East Entrance	Bldg Entrances: Other doors (W/ft of door width)	20.00	6	120
Stair B Door	Bldg Entrances: Other doors (W/ft of door width)	20.00	6	120
Entrance Canopy	Canopies (free-standing & overhangs W/sf))	1.25	306	382.5
Refuse Door	Bldg Entrances: Other doors (W/ft of door width)	20.00	3	60
Receiving Doors	Bldg Entrances: Other doors (W/ft of door width)	20.00	3.5	70
Doors on Roof	Bldg Entrances: Other doors (W/ft of door width)	20.00	6	120
North Walkway	Bldg Grounds: Walkways < than 10 feet wide (W/lin-ft)	1.00	131	131
	Tradable BASELINE Allowance =			1183.5
Tradable B	ASELINE Allowance (less 20% per SCA req'ts) =			946.8

2. Exterior Building Lighting Power Allowance (NON-Tradable Lighting Applications) - BASELINE BUDGET Designer Note: Other Exterior Lighting ONLY (e.g. Façade Lighting to be included)

This table is identical to the previous table except that the non-tradable lighting applications, as listed in Table 9.4.5, are to be entered here.

Fixture ID	Applied Area Desc.	Table 9 (Apply	.4.5 - Selec 90.1-2010 Sta	ct Your App andard Desc	olication ription)	Allowance (W/ft or W/sf)	Area or Length (ft or sf)	Non- Tradable Power (Watts)
		<blank -="" td="" unuse<=""><td>d></td><td></td><td></td><td>0.15</td><td></td><td></td></blank>	d>			0.15		
		<blank -="" td="" unuse<=""><td>d></td><td></td><td></td><td></td><td></td><td></td></blank>	d>					
		<blank -="" td="" unuse<=""><td>d></td><td></td><td></td><td></td><td></td><td></td></blank>	d>					
		<blank -="" td="" unuse<=""><td colspan="4"> shank - unused></td><td></td><td></td></blank>	 shank - unused>					
		<blank -="" td="" unuse<=""><td>d></td><td></td><td></td><td></td><td></td><td></td></blank>	d>					
	•	NC	N-Tradable	BASELINE	Allowance =			
	NON-Tradable B	ASELINE Allo	owance (less	s 20% per \$	SCA req'ts) =			
	Exterior Lighting Applica	ations						
	(Identify each project-sp	ecific location	ו)					
3. Additional Un	restricted Exterior Ligh	ting Power	Allowance					
Designer Note: Th	is automatically adds 5%	6 to the BAS	ELINE					

The total power allowances from the preceding two tables are automatically manipulated to calculate the additional unrestricted exterior lighting power allowance. This value may be applied in the Exterior Lighting Compliance Test below.

[Tradable BASELINE Budget] (Watts)	+	[Non-Tradable BASELINE Budget] (Watts)	x	0.05	Additional Unrestricted Power
946.8	+		x	0.05	47.34

Light Power Den	sity Calcul	ations - Exte	erior Lightir	ng Only					
Project:	<u>P.S. 347X</u>	Bronx Anne	x at PS33X	-					
LLW:	<u>107340</u>								
4. Exterior Buildi	ng Lighting	g Power (Tr	adable Ligh	hting Applic	ations) - DI				
Designer Note: Bu Use this table to li	st the lightir	nce, Canopy ng equipment	& Overhang used for ex	and Other E terior lighting	used for tra	adable applica	tions as identifie	g to be included) d in Table 9.4.5.	
Fixture ID	Luminaire De	scription (inclue	ding number of of fi	lamp/fixture, W ixture.	′att/lamp, type	of ballast, type	# of Luminaire	W/Luminaire	Total Watts
Z1	LED Wall N	Nounted Full	Cut Off				14	18.4	257.6
Z2	LED Wall N	lounted Full	Cut Off (Root	f)			5	38	190
H3	LED Canop	y Mounted F	ull Cut Off				4	15.3	61.2
				Tra	adable DES	IGN CASE =			508.8
5. Exterior Buildi	ng Lighting	g Power (NC	DN-Tradable	e Lighting A	pplication	s) - DESIGN C	ASE		
Designer Note: Ot	her Exterior	Lighting ON	LY (e.g. ⊦aç	ade Lighting	to be includ	led)		. :	
because <u>each</u> of th	he non-trada	ceding table able applicati	except that to ons <u>must co</u>	the lighting a mply individu	pplication n <u>ially</u> .	eeds to be ide	entified along with	i its correspondi	ng iuminaires
Fixture ID	Luminaire De	scription (inclue	ling number of of fi	lamp/fixture, W ixture.	/att/lamp, type	of ballast, type	# of Luminaire	W/Luminaire	Total Watts
				NON-Tra	adable DES	IGN CASE =			
6. Exterior Lighti	ng Complia	ance Test							
Designer Note: The	e complianc	e form is fille	ed in automa	tically based	on your inp	outs above. If a	any portion of thi	s compliance te	st fails you
must aujust the de	sign accord	ingry to pass							
1) Each of the condition	ons in this table	e must be met f	or exterior light	ting systems to	comply. The t	radable exterior l	ighting applications	comply if the conne	ected lighting
pow er is no greater th	nan the total al	low ance. All or	a portion (or n	one) of the five	e percent addi	tional allow ance	can be used to achi	eve compliance.	
2) Connected lighting	pow er for eac	h of the non-tra	adable applicat	ions must be no	o greater than	their correspond	ling allow ances. He	re additional allow a	nce from the
five percent pool can	be applied to a	achieve complia	ince. The total	of additional allo	ow ances used	d for both the tra	dable and non-trada	ble applications mu	st be no greater
	aionesticted			vance.		Compliance tes	t 1		
		Tradable	e Pow er	Additional U	nrestricted	Must be	Tradable Conne	ected Lighting	
		Allow ance	e (Watts) +	Lighting Pov	ver (Watts)	≥ than	Pow er	(Watts)	
		54	0.0	47.	.5+	r as s	50		
						Compliance tes	t 2		
NON-tradable Ap	plication	NON-Tradable Pow er Additional Unrestricted Must be					NON-Tradable Co	nnected Lighting	
	,	Allowarice	e (Walls) +			≥ than Pass	Fow er	(waits)	
						Pass			
					Pass				
						rass			
						Compliance tes	t 3		
				Total Addition	al Allow ance	Must be	Additional Unres	tricted Lighting	
				Applied (Su	im) (Watts)	≤than Pass	Power Allowa	ance (Watts) 34	

There are no interior non-emergency luminaries with direct line of site to any exterior openings without automatic shut-off, thus a typical classroom plan indicating the angle of maximum candela is not needed. Occupancy and vacancy sensor details, and lighting control panel details are provided on drawing E703.00 dated 19Feb2018.

GSG requires that the exterior building mounted lighting fixtures produce a maximum initial illuminance value no greater than 0.10 horizontal and vertical foot-candles (fc) at the curb line & site boundary and 0.01 horizontal foot-candles at 10 feet beyond the curb & site boundary for Zone LZ2, but the lighting boundary can be the centerline of street when bordering a street. From the photometrics plans received 25Apr2018 and 25Jun2018, the exterior lighting is not in compliance with this requirement. The East property line has lighting levels exceeding 2 footcandles.



No additional lighting is being provided for lot 8 playground.

See Appendix A for full photometric site plan.

Water Credits

Outdoor Systems <u>W1.1</u> Water Efficient Landscaping, Reduce by 50% Credit is not feasible.

Consideration is being given to providing trees, shrubs, and plants that are low maintenance, low water, and drought resistant. Plantings that eliminate the need for permanent irrigation will be selected.

Temporary irrigation, if necessary, will be limited to up to one year after installation.

Any new street tree(s) shall comply with NYCDPR, NYCSCA, and NYCDOT standards and clearance requirements. Sorbus, Populus, Ailantus and Selix will be avoided. Trees that flower, require yearly spraying or that grow too wide for their location will be avoided.

Flowering shrubs will be avoided.

English Ivy (Hedera helix) is the preferred type cover (from DR2.5.1), especially in areas with leaves. Allegheny Pachysandra (Pachysandra procumbens) and Vinca minor which are also good ground cover and are native species that don't climb will also be considered. Ground cover in large areas will be avoided. Japanese Honeysuckle and Boston Ivy (Partenocissus tricuspidata) will be avoided.

369 sf proposed vegetated area (currently only at street trees) divided by the total project site area (including Lot **8)** of **24,600** sf, including the West sidewalk at Jerome Avenue, results in vegetation making up **1.5**% of the total site area. Credit is assumed to be not feasible as the vegetated area is less than 5% of the site area.

Applicable SCA Design Requirements include:

2.5.1 Trees, Shrubs, Ground Cover and Lawns

6.1.7 Wall Hydrant Requirements for Window Washing and General Maintenance

Applicable SCA Standard Specifications Include: 02900 Landscaping

Because the credit is not feasible due to the vegetated area being less than 5% of the site area, no water use calculations are required.

Site plans on A035 and A045 dated 9July2018 indicate only street trees being provided within the current GSG project boundary. Tree pit detail is provided on drawing A050. The street trees specified will be considered native and/or adaptive due to them being chosen from NYC Parks Department right-of-way trees list which are based on other trees in the area/what will work best at the specific site.

Permanent irrigation is not indicated in the current drawings and specifications.

W1.2 Water Efficient Landscaping, Reduce by 100% Credit is not feasible.

Consideration is being given to providing trees, shrubs, and plants that are low maintenance, low water, and drought resistant. Plantings that eliminate the need for permanent irrigation will be selected.

Temporary irrigation, if necessary, will be limited to up to one year after installation.

Any new street tree(s) shall comply with NYCDPR, NYCSCA, and NYCDOT standards and clearance requirements. Sorbus, Populus, Ailantus and Selix will be avoided. Trees that flower, require yearly spraying or that grow too wide for their location will be avoided.

Flowering shrubs will be avoided.

English Ivy (Hedera helix) is the preferred type cover (from DR2.5.1), especially in areas with leaves. Allegheny Pachysandra (Pachysandra procumbens) and Vinca minor which are also good ground cover and are native species that don't climb will also be considered. Ground cover in large areas will be avoided. Japanese Honeysuckle and Boston Ivy (Partenocissus tricuspidata) will be avoided.

369 sf proposed vegetated area (currently only at street trees) divided by the total project site **area (including Lot 8)** of **24,600** sf, including the West sidewalk at Jerome Avenue, results in vegetation making up **1.5%** of the total site area. Credit is assumed to be not feasible as the vegetated area is less than 5% of the site area.

Applicable SCA Design Requirements include:

- 2.5.1 Trees, Shrubs, Ground Cover and Lawns
- 6.1.7 Wall Hydrant Requirements for Window Washing and General Maintenance
- Applicable SCA Standard Specifications Include: 02900 Landscaping

Because the credit is not feasible due to the vegetated area being less than 5% of the site area, no water use calculations are required.

Site plan A035 and A045 dated 9July2018 indicate only street trees being provided within the current GSG project boundary. Tree pit detail is provided on drawing A050. The street trees specified will be considered native and/or adaptive due to them being chosen from NYC Parks Department right-of-way trees list which are based on other trees in the area/what will work best at the specific site.

Permanent irrigation is not indicated in the current drawings and specifications.

Indoor Systems W2.1P Water Use Reduction Credit anticipated.

As per SCA standard specification section 15440, the intended plumbing fixture flow rates are as follows:

Water closet flush valve: 1.28 gpf Urinal flush valve: 0.125 gpf Lavatory faucet: sensor-operated 0.125 gpc Kitchen lavatory faucet: sensor-operated 0.125 gpc Classroom sinks: 0.5 gpm. Art Room sink: 0.5 gpm. Science Lab sink: 0.5 gpm. Shower: 1.8 gpm.

Applicable SCA Design Requirements include: 6.1.16 Compliance with LL86/05

Applicable SCA Standard Specifications Include: 11400 Food Service Equipment 15440 Plumbing Fixtures

	•				tr-	(
		FORM			2	\sim			i i i i i i i i i i i i i i i i i i i
WATER					Ś	CA) Cok	aal Cane	truction	Authority
Credits W	2.1R, W 2.2R, W2	.3 & W2.4						truction /	Authority
						NYC	Green Schoo	is Rating Syst	em
Project:	P.S. 347X Bronx	Annex at PS33X							Page 1 of 2
Address:	2424 Jerome Ave	, Bronx, NY		Zip Code:	10468		Engineer:	DVL Consulting	Engineers, Inc
LLW:		107340					Preparer:	EME Group	
Date [.]		4/18/18					Telephone	212-529-5969	
Duito							reieprieriei	212 020 0000	
Seheel in	Eull Operation								
School III							Fill In Only th	a three lin	Fill In Only the one
							Fill III Only Li Shaded	le unee on-	Lin-Shaded Box
BASE CASE			9/ af				Shaueu	DOXES	OII-Silaueu Box
			% UI				Chudont	Occurrent	
D			Student	Delle		Duration	Student	Occupant	
Base Case			Population	Dally	Flow Rate	Duration	Population	Users	Sewage Generated
Flush Fixtu	ire Type		by Grade	Uses	[gpf]	[Flush]			[Gal]
Conventiona	al Water Closet	male 3-12	55%	1.00	1.6	1	N/A	130	207.7
Conventiona	al Urinal	male 3-12	55%	2.00	1.0	1	N/A	130	259.6
Conventiona	al Water Closet	female 3-12	55%	3	1.6	1	N/A	130	623.0
Conventiona	al Water Closet	male PK-2	45%	3.00	1.6	1	N/A	106	509.8
Conventiona	Water Closet	female PK-2	15%	3.00	1.6	1	NI/A	106	500.8
Conventiona	al Water Closet	Adult	-4370 N/Δ	3.00	1.0	1	N/A	63	302.4
Conventiona		Addit		5.00	1.0	I	IWA	00	502.4
Des a Ossa				Delle	Elaus Data	Duration	04	0	October of the second second
Base Case				Dally	Flow Rate	Duration	Student	Occupant	Sewage Generated
Flow Fixtur	re Type			Uses	0.05 / 1		Population	Users	[Gal]
Conventiona	al Lavatory (Student)			3	0.25 g/cycle	1 cycle	N/A	472	354.0
Conventiona	al Lavatory (Adult)			3	0.25 g/cycle	1 cycle	N/A	63	47.3
Show er				0.1	2.5 gpm	300 sec	N/A	63	78.8
Food Servic	e Hand Sink			4	0.25 g/cycle	1 cycle	472	5	4.7
				Ba	<u>ase Case</u> "Sch	ool In Full (Operation" Dail	y Volume [Gal]	2897.0
						Annual	Days School In	Full Operation	180
				Base Case	Annual "Sch	ool in Full (Operation" Tota	I Volume [Gal]	521.453
							-		
	ee.								
DESIGN CA	35		% of					1	
			% UI				DOD Student	Occurrent	
De siene Ose			Student	Delle		Duration	POR Student	Occupant	
Design Cas	se -		Population	Dally	Flow Rate	Duration	Population	Users	Sewage Generated
Flush Fixtu	ire Type		by Grade	Uses	[gpt]	[Flush]		100	[Gal]
High Efficien	ncy Water Closet	male 3-12	55%	1.00	1.28	1	N/A	130	166.1
High Efficien	ncy Urinal	male 3-12	55%	2.00	0.125	1	N/A	130	32.5
High Efficien	ncy Water Closet	temale 3-12	55%	3	1.28	1	N/A	130	498.4
High Efficien	ncy Water Closet	male PK-2	45%	3.00	1.28	1	N/A	106	407.8
High Efficien	ncy Water Closet	female PK-2	45%	3.00	1.28	1	N/A	106	407.8
High Efficien	ncy Water Closet	Adult	N/A	3.00	1.28	1	N/A	63	241.9
Design Cas	se			Daily	Flow Rate	Duration	Student	Occupant	Sewage Generated
Flow Fixtur	re Туре			Uses			Population	Users	[Gal]
Aerated Lav	atory with metering	device (Student)		3	0.125 g/cycle	1 cycle	N/A	472	177.0
Aerated Lav	atory with metering	device (Adult)		3	0 125 g/cycle	1 cvcle	N/A	63	23.6
Low Flow S	Show er	dorloo (Fidali)		0.1	1.8 gpm	300 sec	N/A	63	56.7
Eood Sorvio	o Hand Sink			4	0 125 g/cyclo	1 cyclo	472	5	2.4
				4	J. 120 groyole	- i cycle	772		2.4
				Desi	gn <u>Case</u> "Sch	ool In Full (Operation" Dail	y Volume [Gal]	2,014.2
						Annual	Days School In	Full Operation	180
				Desi	an Case "Sch	ool in Full (Operation" Tota	I Volume IGall	362 564 5
					<u></u>				002,004.0
				<u> </u>					
				Sub-In	tal·Wator IIco	Reduction	tor "School in F	()))))))))))))))))))))))))))))))))))))	-2/10/

						Fin						
WATER US	SE REDUCTION F	ORM										
Credits W 2	.1R, W 2.2, W2.3 8	& W2.4			NYC	<u>SCA</u> SC	hool Con	struction	Autr	Authority		
						NY	C Green Scho	ols Rating Sys	stem			
Project:	P.S. 347X Bronx A	nnex at PS33X								Page 2 of 2		
Address:	2424 Jerome Ave,	Bronx, NY		Zip Code:	10468		Engineer:	DVL Consulting	Engineer	s, Inc		
LLW:		107340					Preparer:	EME Group				
Date:		4/18/2018					Telephone:	212-529-5969				
Summer C	Deration		1									
							Fill In Only t	he three Un-	Fill In C	Only the one		
BASE CASE							Shaded	Boxes	Un-S	haded Box		
			% of									
			Student				POR Student	Occupant				
Base Case			Population	Daily	Flow Rate	Duration	Population	Users	Sewag	e Generated		
<u>Flush</u> Fixtur	е Туре		by Grade	Uses	[gpf]	[Flush]				[Gal]		
Conventional	Water Closet	male 3-12	55%	1.00	1.6	1	N/A	39		62.3		
Conventional	Urinal	male 3-12	55%	2.00	1.0	1	N/A	39		77.9		
Conventional	Water Closet	female 3-12	55%	3	1.6	1	N/A	39		186.9		
Conventional	Water Closet	male PK-2	45%	3.00	1.6	1	N/A	32		152.9		
Conventional	Water Closet	female PK-2	45%	3.00	1.6	1	N/A	32		152.9		
Conventional	Water Closet	Adult	N/A	3.00	1.6	1	N/A	19		90.7		
-	1											
Base Case				Daily	Flow Rate	Duration	POR Student	Occupant	Sewag	e Generated		
Flow Fixture	e Type			Uses			Population	Users		[Gal]		
Conventional	Lavatory (Student)			3	0.25 g/cycle	1 cycle	N/A	142		106.2		
Conventional	Lavatory (Adult)			3	0.25 g/cycle	1 cycle	N/A	19		14.2		
Show er				0.1	2.5/gpm	300 sec	N/A	19		23.6		
Food Service	Hand Sink			4	0.25 g/cycle	1 cycle	142	2		2.0		
					Base Ca	se "Summer C	peration" Dail	v Volume [Gal]		458.9		
						An	nual Davs Sum	mer Operation		30		
				Ra	se Case Annu	al "Summer (neration" Tota	I Volume [Gal]		13 768		
								, totallic [oul]		10,100		
	F											
DESIGN CAS	L		% of									
			Student				POR Student	Occupant				
Design Case	e		Population	Daily	Flow Rate	Duration	Population	Users	Sewag	e Generated		
Flush Fixtur	е Туре		by Grade	Uses	[gpf]	[Flush]			-	[Gal]		
High Efficienc	y Water Closet	male 3-12	55%	1.00	1.28	1	N/A	39		49.8		
High Efficienc	y Urinal	male 3-12	55%	2.00	0.125	1	N/A	39		9.7		
High Efficienc	y Water Closet	female 3-12	55%	3	1.28	1	N/A	39		149.5		
High Efficience	y Water Closet	male PK-2	45%	3.00	1.28	1	N/A	32		122.3		
High Efficience	y Water Closet	female PK-2	45%	3.00	1.28	1	N/A	32		122.3		
High Efficienc	y Water Closet	Adult	N/A	3.00	1.28	1	N/A	19		72.6		
Design Case	e			Daily	Flow Rate	Duration	POR Student	Occupant	Sewag	e Generated		
Flow Fixture	е Туре			Uses			Population	Users		[Gal]		
Aerated Lava	atory with metering de	evice (Student)		3	0.125 g/cycle	1 cycle	N/A	142		53.1		
Aerated Lava	atory with metering de	evice (Adult)		3	0.125 g/cycle	1 cycle	N/A	19		7.1		
Low Flow Sh	iow er			0.1	1.8 gpm	1 300 sec	N/A	19		17.0		
Food Service	Hand Sink			4	0.125 g/cycle	1 cycle	142	2		1.0		
					Decise Co) navatian" Dail	Volume [Coll		200.2		
					Design Ca	se summer c	peration Dali	y volume [Gal]		200.2		
							nual Days Sum	mer Operation		30		
					Design Cas	se "Summer O	peration" lotal	Volume [Gal]		8,406.5		
				5	Sub-Total: Wa	iter Use Redu	ction for "Sumn	ner Operation"		39%		
			Tota	I Base Cas	e "School In	Full Operatio	n & Summer Or	peration" [Gal]		535,220.4		
					_							
			Total	Design Cor	so "School In	Eull Operatio	n & Summar O	peration" [Coll		370 071 0		
			Total I	Joargii Uda		, an operatio	n a summer Op			570,971.0		
						Total	Water Use	Reduction	30%			

Notes:

1. Figures in shaded boxes are based on EPA 1992 as amended in 2005 with revisions as per LEED 2009 (base case), SCA standards (design case) or are calculated by this spreadsheet. No design team revision required.

2. Spreadsheet will calculate occupant users for water closets and urinals for design and base cases based on figures entered by Design Team for "Occupant Users" for "Conventional Lavaratory" for students and adults, along with "% of Student Population by Grade". Distribution of male and female "Occupant USers" are based on assumption of 50-50 ratio of male and female.

3. Methodology to determine student population: Use unadjusted capacity from POR Methodology to determine adult population: Follow DR 2.3.3.-Bicycle Racks

4. Figure entered by Design Team for occupant users for showers should include all physical education staff, potential adult bike users (GSG credit S 2.2) and for high schools with showers in the student locker rooms, all students.

5. Figure entered by Design Team to determine occupant users for "Food Service Hand Sinks" is based on 1 FTE for each 100 students. Student population based on unadjusted capacity from POR is to be entered. (Minimum of 2 kitchen staff is required).

6. For "Summer Operation", occupant users is anticipated to be 30% of "Full Operation Population". If program is known to be different, actual summer population should be entered.

7. For "Annual Days of Summer Operation", revise anticipated number of days for regular summer operation, excluding weekends and days when school is closed, if program is known to be different than the default value of 30.

8. Modernization projects should include the actual fixture flow rate of fixtures to remain in the design case calculations and indicate assumptions about percentage of occupant users who will use those existing fixtures to remain.

9. Percentage of Student Population by Grade should be based on number of students in classrooms with toilets located within the classrooms. Dedicated classroom toilets would be applicable to PK and K and to first and second grade classrooms as indicated in the POR. Single user toilets are typically provided for staff use. If first and second grade don't have toilets, include population in 3-12

10. For typical IS and HS, percentage of occupant users in the PK-2 row should be equal to zero.

11. For typical PS and PS/IS, percentage of occupant users in the PK-2 row should be based on occupants users in PK-2 grade classrooms that have dedicated toilets.

The above calculations indicate a 30% savings with pre-kindergarten and kindergarten classrooms only having toilets, thus earning this credit.

W2.2R Water Use Reduction, 30% Reduction Credit anticipated.

See narrative in W2.1P above.

The above calculations indicate a 30% savings with pre-kindergarten and kindergarten classrooms only having toilets, thus earning this credit.

W2.3 Water Use Reduction, 35% Reduction Credit is not feasible.

See narrative in W2.1P above.

The above calculations indicate a 30% savings with pre-kindergarten and kindergarten classrooms only having toilets, thus not earning this credit.

W2.4 Water Use Reduction, 40% Reduction Credit is not feasible in the **22**June2018 meeting minutes.

The fixtures indicated narrative in W2.1P above typically do not result in a 40% savings thus this credit is not feasible.

The above calculations indicate a 30% savings with pre-kindergarten and kindergarten classrooms only having toilets, thus not earning this credit.

Energy

Commissioning <u>E1.1P</u> Fundamental Commissioning Credit anticipated. Setty & Associates is CxA.

The Specification Table of Contents may require further revision when project materials and systems are further defined.

Applicable SCA Standard Specifications include:

- S01352 Sustainability
- S01650 Facility Start-up, Demonstration, and Training
- S01660 Supplemental Commissioning Requirements

SCA CxA, Setty & Associates, to review the Project Specifications Table of Contents, OPR (Owner's Project Requirements contained in the Program of Requirements and SCA's Design Requirements), and BOD (Basis of Design contained in the Schematic Design Report).

See Appendix A for Project Specifications Table of Contents.

Refrigerant Management E2.1P Fundamental Refrigerant Management Credit is being pursued.

The air-cooled chiller servicing the new building will utilize R-410A refrigerant; split heat pumps servicing MDF, IDF, and the elevator machine rooms will have R-410A refrigerant. No CFC-based refrigerants will be used on the project.

The one existing 1-story PS347X Annex on lot 8 is to be removed; all existing equipment in building being removed will not be re-used in the new addition.

A summary of the scope of work for removal of removed building's air conditioning systems is as follows:
DX cooling air conditioning rooftop unit and refrigerant piping with R-12 (CFC) or R-22 (HCFC) refrigerant.

All refrigerant from existing equipment will be recovered and recycled as required by city, state, and federal laws.

Applicable SCA Standard Specifications:

- 11400 Food Service Equipment
- 11450 Domestic Type Equipment
- 11452 Culinary Arts Lab Equipment
- 15660 Packaged Modular Outdoor Chillers

15783 Split Heat Pump System

E2.2 Enhanced Refrigerant Management

Credit is not feasible.

The air-cooled chiller servicing the new building will utilize R-410A refrigerant; split heat pumps servicing MDF, IDF, and the elevator machine rooms will have R-410A refrigerant. No CFC-based refrigerants will be used on the project. Architect's 25Apr2018 e-mail indicated there are no walk-in refrigerator or freezer in project.

The one existing 1-story PS347X Annex on lot 8 is to be removed; all existing equipment in building being removed will not be re-used in the new addition.

A summary of the scope of work for removal of removed building's air conditioning systems is as follows:
DX cooling air conditioning rooftop unit and refrigerant piping with R-12 (CFC) or R-22 (HCFC) refrigerant.

All refrigerant from existing equipment will be recovered and recycled as required by city, state, and federal laws.

Applicable SCA Standard Specifications:

11400 Food Service Equipment

11450 Domestic Type Equipment

11452 Culinary Arts Lab Equipment

15660 Packaged Modular Outdoor Chillers

15783 Split Heat Pump System

The following Refrigerant Impact Form indicates a Weighted Average Atmospheric Impact of 123 which is more than the maximum of 100 thus showing credit non-compliance.

REFRIGERANT I	MPAC		٨												
Credit E2.2		-								ś	A S	School (Constru	ction A	uthority
										нихон		NYC Greer	Schools F	Rating Syst	em
														5,	
Proiect:	P.S. 3	347X Br	onx An	nex at PS	533X		E	Inaineerir	na Firm:	DVL C	onsult	ina Enaine	ers. Inc.		
Address:	2424	Jerome	Ave, B	ronx, NY,	10468		-	Pr	eparer:	EME G	roup				
LLW #:		107340		Design #:				Tele	ephone:	212-52	9-5969)			
Date:	4/2	25/2018													
The matrix below	is to a	ssist in	calculat	ing the											
refrigerant impact	using	the follo	wing ca	Iculation:	LCGWP	+ LCO	DP x ′	100,000	is les	s than o	or equ	al to 100			
Maightad average	farm	ultinlan	iaaaa of												
weighted average		uitipie p	leces of		[Σ (LCG	WP + L	CODP	x 100,	000) x	Qunit]	/ Qtot	al is lessth	nan or equ	al to 100	
Innuta Eutenan										Colouis	tione		الم يبنال مماد		motically
Inputs - Enter pro	OJECT S	pecific	project	Informat		elow	1 :60	1.7	Ma	Calcula		- snaded ce			
	No	Q	Reing-	GWPr	ODPr	(lb/		(%)	(%)	U total			× 10000		
equinment	of	(Tons)	erant			ton)	(913)	(70)	(70)	Tone	Life	Try	× 10000		× 100000)
oquipinon	Units	(10110)				tony				10113	+Mr)	Rc/Life)		100000	x 100000)
											,	,			Qtotal
CH-1	1	133.9	R410a	1,890	0	2,6139	20	2.0%	10%	134	50%	123 5	0	123 5	16538
ACCU-1	1	2	R410a	1.890	0	3	15	2.0%	10%	2	40%	151.2	0	151.2	302
ACCU-2&3	2	2.85	R410a	1.890	0	2.1053	15	2.0%	10%	6	40%	106.1	0	106.1	605
				1,780	0.04	7.54	10	2.0%	10%	0	30%	402.6	90.48	493.1	0
										142				Subtotal =	17445
			Weig	hted Ave	rage At	mosphe	ric Im	pact [Σ	(LCG	WP + L	CODF	• x 100,000) x Qunit]	/ Qtotal =	123.2
Definitions:															
LCGW	P: Life	cycle Di	rect Glo	bal Warmi	ing Poter	ntial (lbC	FC11.	Ton-Ye	ar) = [(GWPr x	(Lr x	ife + Mr) x	Rc]/life		
LCODF	P: Lifec	ycle Oz	one Dep	letion Pot	ential (lb	CFC11.	Ton-Ye	ear) = [C	DPr x	(Lr x lif	e + M	r) x Rc]/life			
GWPr:	Globa	I Warmi	ng Pote	ntial of Re	frigerant	(0 to 12,	,000 lb	CO2/lbr). See	on follo	wing p	age.			
ODPr:	Ozone	Depleti	on Poter	ntial of Re	rigerant	(0 to .21		1/IDr). S	see on	tollowin	g page	Э.			
Q unit.		g capac Dofrigor	ant Char	n individual	F 0 lbo	of refrige	ration	unit in to	ons. Imaah	onical a	ooling	oonooitu()			
RC: AC		nt Life (ant Unar based or	ge (0.5 to	5.0 IDS (15 voor	rant pe	er ton or	mecn wiso d	lanicai-c	cound	capacity)			
	laipine	t Leakar	ne Rate	(0.5% to 2)	m type, ‰∶defai	It of 2%	unles	s othen	wise d	emonstr	ated)				
Mr. En	d-of-life	Refrige	erant Los	(0.0% to 2	10%: def	ault of 1	0% un	less of	nerwise	e demor	istrate	d)			
Q total	: Total	mechar	nical-coo	ling capac	ttv for a	aiven tvi	oe of ⊢	IVAC or	refria	eration u	init on	the project			
RAI: Re	efrigera	int Atmo	osheric li	mpact		3									
Ozone-	Refrig	gerant	-					OD	P	GW	/P	Com	mon Build	ling Appli	cation
depletion and	Chlor	ofluoro	carbon	s	(CFC-11		1.	0	4,6	80	Centrifuga	chillers		
global-					(CFC-12		1.	0	10,7	720	Refrigerato	ors, chillers		
warming					C	FC-114		0.9	94	9,8	00	Centrifuga	chillers		
potentials of					C	FC-500		0.6	05	7,9	00	Centrifuga	chillers, hu	umidifiers	
refrigerants					C	FC-502		0.2	21	4,6	00	Low-tempe	erature refriç	geration	
(100-yr values)	Нус	Irochlo	rofluroc	arbons	Н	CFC-22		0.0)4	1,7	80	Air conditi	oning, chille	ers,	
	<u> </u>				H	CFC-123		0.0)2	70	5 140	CFC-11 re	placement		
	Hydro	ofluoroo	carbons		ł	HFC-23		~	0	12,2	240	Ultra-low-to	emperature	refrigeratio	n
					H	-C-134a		~	0	1,3	20	CFC-12 or	HCFC-22 r	eplacemen	it
					H		1	~	0	1,0	20	Insulation	agent, cent	ritugai chili	ers
					HI	-C-404A		~	0	3,9	00	Low-tempe	erature refin	tugal chille	rs
						-C-407C		~	0	1,7	00	Low-tempe		jeration	
					HE	C-410A		~	0	3.0	00	Air conditi	oning		
	Natur	al Refr	igerants		Carbon	Dioxide	(CO2)	0	0	1	0		oning		
					Amm	ionia (Nł	(002) H3)	0)	0					
					F	ropane	,	0)	3					
Default	R	efriger	ant	10 Yea	r Life		15 Yea	ar Life		2	0 Yea	r Life	2	3 Year Lif	e
Maximum				(Room or		(Un	nitary, s	split and	1	(R	ecipro	cating	(Cen	trifugal Sc	rew &
Allowable				window A	.C &	packa	iged A	C and h	eat	compre	essors	& chillers)	Abs	sorption Ch	illers)
Equipment	<u> </u>	D 00		heat pum	ps)		pum	ips)				0		0.74	,
Refrigerant		R-22		0.5	50		0.0	04 80			0.6	ษ ว		0.71	
Charge (lb/ton)	┝───	R-123) D	1.0	52		1.0	50 R0			1.9	2		3 10	
		R-1048	a	2.0	26		2.0	30 30			3.0 3.0	2		4 02	
	<u> </u>	R-407	а С	1.2	95		2 2	20			2.3	5		2.41	
		R-410a	а	1.7	76		1.9	98			2.1	1		2.41	

Verification <u>E3.1R</u> Measurement & Verification Credit anticipated.

The control system will be a Direct Digital Control (DDC) system integrated into a Building Management System (BMS). Sub-meters will be installed to meter gas, electricity, domestic hot water and building hot water.

The school will be provided with a low pressure gas service with the gas meter rig located outside the building in the alleyway between the existing PS-33X school and new PS-347X schools. ConEdison will only be required to provide one gas meter since the service is a low gas pressure service Two (2) gas submeters (boilers and domestic water heater) will be required since the school will be provided with a low pressure gas service by ConEdison. NYC SCA Plumbing Design Guidelines only require for schools with low pressure gas service one (1) utility gas meter and two (2) gas sub-meters (for boilers and for domestic water heater). All gas submeters, as well as the main utility gas meters, will be pulse type meters connected to the BMS LonWorks network. Warming Kitchen gas usage can be calculated by subtracting the two sub-meters from the utility meter.

Lighting loads: as per SCA Standard Detail 1598515a, energy use will be measured by a watt meter.

Receptacle loads: as per SCA Standard Detail 1598515a, energy use will be measured by a watt meter.

Chiller: as per SCA Standard Detail 1598510a, energy use will be measured by a watt meter and chilled water by flow meter.

Rooftop AHU units: as per SCA Standard Details 1598508b&g energy use will be measured by watt meters.

Miscellaneous electrical loads: as per SCA Standard Detail 1598515b, energy use will be measured by watt meters.

Applicable SCA Design Requirements include:

6.2.20 Building Management Control System/Direct Digital Control BMS/DDC

Applicable SCA Standard Specifications include:

15416 Gas Piping System

15970 Temperature Control System (LonWorks BMS/DDC With School Operating Console)

15973 Facility Management Systems Integration

15985 Sequence of Operations

16420 Service Entrance Equipment

Applicable SCA Standard Details include: 15985 HVAC Standard Detail Series

The project team has incorporated applicable SCA Standard Specifications, including 15416, 15970, 15973, 15985, and 16420 into the construction documents dated 9July2018.

BMS control diagrams have also been incorporated into the construction documents on drawings M404 through M412.

The control system will be a Direct Digital Control (DDC) system integrated into a Building Management System (BMS). The protocol to be employed between the sensors and actuators will be the LONTALK Network System (LNS). All controllers that drive the valves, dampers, etc. will be LONMARK certified. LONMARK certified controllers will be interchangeable.

Applicable SCA Design Requirements include:

6.2.20 Building Management Control System / Direct Digital Control BMS/DDC

Applicable SCA Standard Specifications include:

15970 Temperature Control System (LonWorks BMS/DDC With School Operating Console)

15973 Facility Management Systems Integration

15985 Sequence of Operations

Applicable SCA Standard Details include:

15985 HVAC Standard Detail Series

Control system will utilize night setback settings. Winter temperature setpoints will be reset to 55°F from the 72°F day setting.

The School Construction Authority will use the services of a Facility Management Systems Integrator (FMSI) whose responsibilities will be to:

- Evaluate the control submissions made by the HVAC contractor's proposed Temperature Controls subcontractor. Systems Integrator will prepare a report if the proposed Temperature Controls Contractor is rejected by the Systems Integrator.
- Supervise the installation of the field level controls by the controls subcontractor.
- Commission the field level controls as installed by the controls subcontractor.
- Provide the LNS/WEB Server and UPS
- Provide the Cisco 3560 Switch
- Provide the School's Operator Console (SOC)
- Review of shop drawings for BMS/ATC system and all HVAC equipment that connects to the BMS LonWorks network.
- Provide the Graphic User Interface (GUI) front-end software and provide Pre-Schematic control graphics according to SCA Standard Details.
- Turn over all software routines, operation manuals and access codes.
- Provide 40 hours of training for the custodial staff in the operation of the control system.
- Connect the project school to the Department of Education Centralized Host Work Station located at the Department of Education Bureau of Supplies Building.

The project team has incorporated applicable SCA Standard Specifications, including 15970, 15973, and 15985, into the construction documents dated 9July2018.

BMS control diagrams have also been incorporated into the construction documents on drawings M404 through M412.

All FMSI 60% design comments have been addressed as noted in DVL's 6Jun2018 e-mail.

Energy Efficiency E4.1P Minimum Energy Performance Credit is being pursued.

The Project's goal is complete compliance with NYC Green Schools Guide (GSG) 2016 which will show compliance with NYC Local Law 86/05 amended by LL32/16. SCA has indicated that a project specific energy model will be completed to demonstrate compliance.

The building will be heated by two gas fired condensing boilers with an approximate heating output capacity of **1,584** MBH (each as per M002 dated **9July2018**); hot water to be used for perimeter heating (finned tube radiation, convectors, etc.) and hot water coils at Variable Air Volume AHU Units and Single Zone Variable Air Volume (SZVAV) AHU Units.

The primary 160°F maximum, resettable, nominal hot water loop serving the air handlings units shall utilize 30% propylene glycol. The secondary 140°F maximum resettable, nominal hot water loop serving the perimeter fin tube radiation units shall be non-glycol water. All hot water return water to the boilers shall be at nominally 120°F. The nominal 160°F maximum hot water supply temperature to the air handling units is to be provided on a design day. The primary loop and secondary loop hot water supply temperature shall be reset based on outside air temperature.

An Air cooled modular chiller will be provided for the new building; chilled water to be used for chilled water coils of VAV and SZVAV AHU units. The anticipated size of the chiller is **103.3** tons (as per M002 dated **9July2018**).

The chilled water cooling system will have one hydronic loop with 30% polypropylene glycol to service coils of VAV and SZVAV AHU units. The chiller plant shall provide 45°F chilled water to the central VAV air handling unit cooling coil to provide a 55°F discharge air temperature off of the cooling coil, thus providing indirect dehumidification.

Classrooms, Offices, other Non-Assembly areas and Corridor VAV boxes shall be provided with supply air from (VAV) central recirculating air handling units with energy recover wheels. The VAV air handling units' role is to temper the heating season ventilation air and provide all of the space cooling capacity. The fin tube radiation units located in each Classroom, Office and other Non-Assembly area shall provide the balance of the space heating capacity.

The VAV system will be designed with a Demand Control Ventilation (DCV) control sequence. The design documents will indicate occupied minimum, vacant standby minimum, and maximum air flows for each VAV box.

The cafeteria (public assembly space) and kitchen shall be served by Single Zone Variable Air Volume (SZVAV) air handling unit (AHU) without energy recovery wheel (as per M002 dated 30Apr2018). The SZVAV system shall have a decoupled heating system where the SZVAV units provide nominally 65°F ventilation air during the heating mode and the PA space will be equipped with terminal heating capability (recessed convectors and/or fin tube radiation). Kitchen terminal heating shall be accomplished by a reheat hot water coil located in the duct that serves the Kitchen. Units shall be coupled in cooling with a mixed variable air volume system (SZVAV). DCV is to be employed, so carbon dioxide sensors shall be located in each PA space to reduce the outside air intake when the spaces are not occupied. The Cafeteria and Kitchen minimum outside air intake ventilation rate that the carbon dioxide sensors can throttle the outside air intake rate down to in the non-cooking mode is the Cafeteria specific cfm per square foot requirements as defined in MC Table 403.3 of the 2014 NYC Mechanical Code times the Cafeteria square footage plus the cumulative Kitchen General

Exhaust, Can Wash Room and Staff Toilet exhaust make up requirements considering that ample make up air must always be provided for the Kitchen General Exhaust, Can Wash Room, and Staff Toilet.

Telecom rooms, food storage rooms, and elevator machine room will be provided with ductless spilt-type heat pump systems that will maintain the space temperatures 24 hours a day, seven days a week.

Wall recessed cabinet unit heaters and/or convectors will be used in stairways. Ceiling hung cabinet heaters may be used in lieu of wall recessed convectors in stairways if space is limited.

Toilets will be provided with ceiling mounted cabinet heaters for all toilets that are located on the perimeter of the building or any toilet room (interior or perimeter located) that is located on the top floor or on a slab on grade.

Entrance vestibules will be provided with hot water air curtains; hot water from the primary hot water heating loop (30% glycol) will be used to service the heating coil of the air curtains.

Hot water unit heaters will also be provided in equipment rooms, custodial storage rooms and other storage rooms.

Non-glycol hot water for perimeter building heating is to be provided by a plate to plate heat exchanger that is supplied by glycol hot water generated by high efficiency gas fired hot water condensing boilers located in a mechanical room on the roof.

The boiler room, all domestic water service rooms and the sprinkler booster pump room will be provided, in addition to the hot water unit heaters, with electric unit heaters that will prevent freeze ups of the room in case there is a failure of the hot water heating system.

The building will be provided with lighting fixtures that are in compliance with the NYC SCA's latest Electrical Design Requirements 7.2.1 for Interior Lighting, 7.2.3 for Emergency Lighting, 7.2.4 for Exit Signs, and 7.2.5 for Exterior/Site/Security Lighting. Daylight sensors will be provided for all spaces with windows.

Applicable SCA Design Requirements include:

4.2.1 Exterior Masonry Wall
6.2.0 General Overview of HVAC
6.2.3 Non-Assembly Spaces
6.2.4 Public Assembly Spaces
6.2.9 Convectors and Enclosures
6.2.20 BMS/DDC Controls
7.2.1 Interior Lighting
7.2.5 Exterior/Site/Security Lighting

Applicable SCA Standard Specifications include:

08413 Aluminum-Framed Entrance and Storefronts
08524 Aluminum Projected Windows
15540 HVAC Pumps
15565 Hot Water Condensing Boilers
15783 Split Heat Pump System
15853 Custom Packaged Rooftop Heating and Cooling Units (Variable Air Volume System)
15930 Variable Air Terminals
15935 Single Zone Variable Air Volume (SZVAV) Air Handling Units for Public Assembly Spaces
15970 Temperature Control System (LONWORKS BMS/DDC with School Operating Console)

15973 Facility Management Systems Integration15985 Sequence of Operations16145 Lighting Control Devices16502 LED Interior Building Lighting16530 Site/Security Lighting

Applicable SCA Standard Details include: 04200 Unit Masonry 15970 BMS Control Diagrams

The revised project specific **100**% energy model, located in Appendix A indicates there is a **20.7%** savings relative to GSG baseline (ASHRAE 90.1-10) and **22.4%** savings for LL86/05 as compared to ASHRAE 90.1-13; the minimum energy requirements have been met for the GSG and LL86/05.

LL 86 Input			PS33	X/107340						
				Projected						
LL86 Intake form Inputs	Base	eline	Design Case	Reductions						
Electric Use (Kwh/yr)		336059	283806	52253						
Electric Peak Demand (Kw)		181	144	38						
Monthly Electric Peak Demand (Kw/yr)		1424	1170	253						
Gas Use for Heating (therms/yr)		6467	4739	1728						
			Ì							
				Reduction	Reduction in	Reduction in	Reduction in	Reduction in Use	Reduction in	
			Energy Cost	in Electric	Sum of	Gas Used for	Gas Used for	of Purchased	the Use of #2	
	Incr	emental	Reduction	Use	Monthly	Heating from	Non-Heating	Steam from EEM	Oil from EEM	
EEM Description	Cost	t	per year	(Kwh/yr)	Electric Peak	EEM	from EEM	(Mlbs/yr)	(gals/yr)	Notes
Lighting Efficiency	\$	31,736	\$ 8,415	52728	193	-637	0	0	0	
Exterior Lighting	\$	8,768	\$ 345	7508	0	0	0	0	0	
Increased Insulation	\$	19,982	\$ 1,328	1798	9	718	0	0	0	
Condensing DHW Boiler	\$	3,768	\$ 31	0	0	0	27	0	0	
Boiler Efficiency	\$	32,775	\$ 813	-719	-2	801	0	0	0	
Energy Recovery Effectiveness	\$	3,671	\$ 2,630	1368	41	357	0	0	0	

EPA Target Finder Statement of Energy Design Intent (SEDI) signed and certified by the engineer is as follows:



ENERGY STAR[®] Statement of Energy Design Intent (SEDI)¹ P.S. 347X Bronx Annex at PS33X

93

Primary Property Type: K-12 School Gross Floor Area (ft²): 49,128 Estimated Date of Certification of Occupancy:

Date Generated: August 21, 2018

ENERGY STAR® Design Score²

1. This form is required when applying for Designed to Earn the ENERGY STAR recognition. It was generated from ENERGY STAR Portfolio Manager.

Manager. 2. The ENERGY STAR 1 – 100 Score is based on total annual Source Energy. To be eligible for Designed to Earn the ENERGY STAR recognition you must score at least 75.

Property & Contact Information for D	ocian Project	
	esign Frojeci	
Property Address P.S. 347X Bronx Annex at PS33X 2424 Jerome Ave Bronx, New York 10468	Project Architect John Doherty 630 Ninth Avenue Suite 711 New York, NY 10036 2126634000 Doherty@mitchellgiurgola.com	Owner Contact Jeremy R. M. Shannon 30-30 Thomson Avenue Long Island City, NY 11101 7184728765 jshannon@nycsca.org
Property ID: 6323921	Architect Of Record Mitchell Giurgola Architects 630 Ninth Avenue Suite 711 New York, NY 10036 ()	Property Owner NYC School Construction Authority 30-30 Thomson Avenue Long Island City, NY 11101 7184728561
Estimated Design Energy		
Fuel Type	Usage	Energy Rate (\$/Unit)
Electric - Grid	283,806 kWh (thousand Watt-hours)	\$ 0.21/kWh (thousand Watt-hours)
Natural Gas	6,547 therms	\$ 1.16/therms
Estimated Design Use Details		
☆ This Use Detail is used to calculate the 1-10	DENERGY STAR Score.	
K-12 School		
Number of Workers on Main Shift	37.83	
☆Percent That Can Be Cooled	90	
☆Number of Computers	85.97	
Gymnasium Floor Area	1,284 Sq. Ft.	
☆Number of Walk-in Refrigeration/Freezer Units	0	
☆Cooking Facilities	Yes	

🛧 Cooking Facilities	Yes
School District	
Student Seating Capacity	491.28 ← default value
★ Weekend Operation	No ← default value
☆ High School	No
☆Percent That Can Be Heated	90
🛧 Gross Floor Area	49 128 Sa Et

Page 1 of 3 Statement of Energy Design Intent (SEDI) for P.S. 347X Bronx Annex at PS33X Months in Use

12

Design Energy and Emission Results			
Metric	Design Project	Median Property	Estimated Savings
ENERGY STAR Score (1-100)	93	50	N/A
Energy Reduction (from Median)(%)	-43.2	0	N/A
Source Energy Use Intensity (kBtu/ft²/yr)	75	133	58
Site Energy Use Intensity (kBtu/ft²/yr)	33	58	25
Source Energy Use (kBtu/yr)	3,728,041	6,567,443	2,839,402
Site Energy Use (kBtu/yr)	1,623,046	2,859,212	1,236,166
Energy Costs (\$)	66,069	116,390	50,321
Total GHG Emissions (Metric Tons CO2e)	120	212	92
Designed to Earn the ENERGY STAR: Application	Checklist		
Designed to Earn the ENERGY OTAR. Application	Oneckiist		
This section is only required if you are using this documen	t to apply for Designed	to Earn the ENERGY	STAR All design projects
that achieve an EPA energy performance score of 75 or hi	aber are eligible for th	is certification	o ran. An design projects
and denieve an Er A chergy performance score of 75 of m	grier are engine for an	is certification.	
1) Does your property type match the function or use of a	property that's	X Yes	No/Not Sure
eligibility to receive an ENERGY STAR design score?			
If you are not sure your project is eligible for an EN	FRGY STAR design		
score please describe the property's major function	ns or use:		
source, piedoe describe the property simajor function	15 01 450.		
2) Is the design project at least 95% complete with constr	uction documents?	X Yes	

X Yes

No No

If no, please explain:		
	. <u></u>	. <u></u>
3) Is the property currently unoccupied and not yet generating energy bills?	X Yes	No No
4) Do energy calculations account for the whole building intended operations and all energy sources?	X Yes	No No
5) Is the Architect of Record (AOR) applying for ENERGY STAR partnership?	Yes	X No
6) Was the design record created in the owner's Portfolio Manager account?	Yes	X No
7) Are you seeking other qualifications for this design project?	X Yes	No No
If so, please select all that apply:		
AIA 2030 Commitment		
Architecture 2030 Challenge		
Federal, State or Local Disclosure Ordinance		
Green Globes		
LEED		
Other, please indicate: NYC GSG		
Other, please indicate: <u>NYC GSG</u>		

Professional Verification

Michael McNamara verify that the above information is true and correct to the best of my knowledge. Date: August 21, 2018 Signature: _

Verifying Professional

(212)529 - 5969 mmcnamara@emegroup.com Verifying Professional Stamp (if applicable)

OF

NEW

Note: When applying for the ENERGY STAR Designed to Earn, the signature of the Verifying Professional must match the stamp.

I agree to adhere to the ENERGY STAR Identity Guidelines when using the Designed to Earn the ENERGY STAR recognition graphic in association with this project.

Architect of Record Acknowledgement

As the Architect of Record representative, I confirm that the information on this SEDI is true and accurate to the best of my knowledge. It is our best estimate for all energy use of specified systems and processes but does not guarantee the operational performance of this building. Instead, this project has been specified to achieve Designed to Earn the ENERGY STAR recognition in an effort to assist the Owner/Developer in meeting their operational performance goal for the building to earn ENERGY STAR certification.

Signature: _____

Date:

Building Owner/Developer Acknowledgement

As the Building Owner/Developer representative, I concur that this project be nominated for Designed to Earn the ENERGY STAR recognition. Our organization understands the importance of measuring actual energy use in Portfolio Manager after receiving the Certificate of Occupancy to verify that this property is performing as intended. We understand that once the building earns an ENERGY STAR score of 75 or higher, it may be eligible for ENERGY STAR certification.

Signature:	<u>a</u>
Data:	

	5900-22	m	For	A	P	Ē
--	---------	---	-----	---	---	---

HVAC Optimization E4.2R HVAC System Sizing, Avoid Oversizing Credit anticipated.

The HVAC Systems for the building will be sized per SCA DR 6.2.13 Arrangement and Sizing of Equipment and 6.2.9 Heating and Cooling Design (Load Calculations) and not be oversized except when required to optimize energy efficiency operation of system. RTU's will be sized slightly above ventilation requirements to account for ductwork leakage.

Documentation demonstrating that cooling load calculations were performed for both the maximum dry-bulb and wet-bulb conditions will be submitted at 60%.

The project team has designed the HVAC system to not only efficiently handle peak and design load conditions, but to operate efficiently during a wide range of partial load conditions, which are the most common operating conditions.

The heating loads and cooling loads shall be calculated as per Design Requirements 6.2.9 and 6.2.13 as follows:

Heating and Cooling Systems shall be designed in accordance with Section MC 312 of the 2014 NYC Mechanical Code, Heating and Cooling Load Calculations, and shall be in accordance with 2005 ASHRAE Fundamentals Handbook. 2000 ASHRAE HVAC Systems and Equipment Handbook: and ANSI/ASHRAE/ACCA Standard 183 per Section C403.2.1 of the 2016 New York City Energy Conservation Code (NYCECC) and Section 6.4.2.1 of ASHRAE 90.1-2013. Per Section C403.2.1, heating and cooling loads shall be adjusted to account for load reductions that are achieved when energy recovery systems are utilized in the HVAC system in accordance with the ASHRAE Handbook - HVAC Systems and Equipment.

Heating Capacity:

All boilers (condensing) shall be provided with a reserve capacity equal to that as defined in the Engineering Criteria for Fuel Oil Burning Equipment of the NYC Department of Environmental Protection Bureau of Air Resources, July 1973 and SCA Standards. Reserve capacity shall be 25% to account for piping losses and pickup. Boiler capacity shall be based on total connected capacity.

Cooling Capacity:

The cooling capacity for roof top units shall be increased by 10% to account for duct losses (duct insulation losses, duct air leakage) and general building pull-down. The 10% term (i.e. 1.10 multiplier) shall be applied to all terms (transmission, infiltration, lighting loads, equipment loads, people loads, and solar loads). Cooling loads shall include the sensible loads and the latent dehumidification loads (as per Design Requirements 6.2.3 and 6.2.4).

Applicable SCA Design Requirements include:

6.2.9 Heating and Cooling Design Parameters (Load Calculations)

- 6.2.13 Arrangement and Sizing of Equipment
- 6.2.34 Verification of Air System Design

Applicable SCA Standard Specifications include:

15540 HVAC Pumps

15565 Hot Water Condensing Boilers

15660 Packaged Modular Outdoor Chillers

15783 Split Heat Pump System

15853 Custom Packaged Rooftop Heating and Cooling Units (Variable Air Volume System)
15935 Single Zone Variable Air Volume (SZVAV) Air Handling Units for Public Assembly Spaces

See Appendix A for cooling and heating load calculations.

Applicable design drawings can be found on M100 to M504 and the HVAC schedule can be found on M002 to M005 dated 9July2018.

PowerE5.1RGreen PowerCredit pursued.

The project will provide at least 35% of its electricity from renewable sources by engaging in at least a two-year renewable energy contract. The amount of energy required will be established from the project specific energy model (Option 1) related to credit E4.1R.

As stated in GSG Construction Phase Architect/PO Toolkit, Page 6, "New York City has stated that they are providing the requisite green power to meet this credit for all city projects, and thus by such fiat the credit can be initialed by the AOR.

The latest results from the **100% CD** Energy Model Report dated **17August2018** indicates the Design Case with Unregulated Loads will have an annual electrical energy consumption of **283,806 kWh**. Based on this estimate, **99,332 kWh** of green power will need to be purchased for each of the first two years of building operation to satisfy the 35% requirement.

Materials Credits

Efficient Material Use <u>M1.1P</u> Storage & Collection of Recyclables Credit anticipated.

The project space will have a dedicated area for the storage and collection of recyclables located on the ground floor with close access to the warming kitchen. The recyclable materials will include, at a minimum, paper, corrugated cardboard, glass, plastic, and metal. In addition to the recycling area on the ground floor, there will be designated bins in the cafeteria. In the warming kitchen, there will be two types of bins; one, to accommodate glass/plastic/metal and the other to accommodate paper/cardboard. There will also be recycling bins in the classroom and office spaces. The current area of the refuse and recycling room is 123 sqft.

Applicable SCA Design Requirements include:

- 1.3.1.2 Building Organization Space Relationships
- 1.3.1.8 Refuse and Recycling Storage
- 1.3.5.01 Cafeterias PK-8 and HS

Applicable SCA Standard Specifications include:

11172 Waste Handling Equipment

Room	Number of Rooms	Type of Recycling	Area of Recycling Type (sf)	Recycling Area Sub-total (sf)	
Refuse and Recycling		Recycling Storage			
Rm in New Building	1	(1/2 of room)	61.5	61.5	
Warming Kitchen in New Building	1	Bin	1.6	1.6	
Cafeteria in New Building	1	Bin	2.3	2.3	
Classrooms in New Building *1	25	Bins	1.6	40.0	1 bin in each classrm
Offices in New					
Building *2	7	Bins	1.6	11.2	1 bin in each office
		Total Recy	cling Area	116.6	
Footnote *1	includes s	pec ed, reading/spec	ach, and pr	oject room	
Footnote *2	includes s lunch4, ar	supervisory1&3, pare nd custodian5	ent commu	nity1, dietician's d	office1, nurse1, staff

Room recycling bin locations shown on drawings FF201-FF221 dated 9July2018.

M1.2 Building Reuse, Maintain 75% of Existing Walls, Floors & Roof Credit is not feasible.

The focus of this GSG project is the new addition so this credit would not be applicable and thus not feasible.

<u>M1.3</u> Building Reuse, Maintain 95% of Existing Walls, Floors & Roof Credit is not feasible.

The focus of this GSG project is the new addition so this credit would not be applicable and thus not feasible.

M1.4 Building Reuse, Maintain 50% of Interior Non-Structural Elements Credit is not feasible.

The focus of this GSG project is the new addition so this credit would not be applicable and thus not feasible.

<u>M1.5R</u> Construction Waste Management, Divert 50% from Disposal Credit anticipated.

This credit is assumed to be feasible: the project will follow SCA specifications to achieve waste management requirements.

As this building new construction, it is assumed that no building structure or non-structural items can be re-used. The materials from the demolished building on Lot 8 will be included in this credit's waste calculation.

Applicable SCA Specification Sections include: S01352 Sustainability Requirements S01524 Construction Waste Management 02060 Building Demolition 02070-Selective Removals and Demolition

The project team has incorporated the above SCA Standard Specifications into the construction documents dated 9July2018.

M1.6R Construction Waste Management, Divert 75% from Disposal Credit anticipated.

This credit is assumed to be feasible: the project will follow SCA specifications to achieve waste management requirements.

As this building new construction, it is assumed that no building structure or non-structural items can be re-used. The materials from the demolished building on Lot 8 will be included in this credit's waste calculation.

Applicable SCA Specification Sections include:

S01352 Sustainability Requirements S01524 Construction Waste Management 02060 Building Demolition 02070-Selective Removals and Demolition

The project team has incorporated the above SCA Standard Specifications into the construction documents dated 9July2018.

M1.7 Construction Waste Management, Divert 95% from Disposal Credit feasible.

This credit is assumed to be feasible although experience suggests unlikely: the project will follow SCA specifications to achieve waste management requirements.

As this building new construction, it is assumed that no building structure or non-structural items can be re-used. The materials from the demolished building on Lot 8 will be included in this credit's waste calculation.

Applicable SCA Specification Sections include: S01352 Sustainability Requirements S01524 Construction Waste Management 02060 Building Demolition 02070-Selective Removals and Demolition

The project team has incorporated the above SCA Standard Specifications into the construction documents dated 9July2018.

Sustainable Materials <u>M2.1R Recycled Content, 10% (post-consumer + ½ pre-consumer)</u> Credit anticipated.

When choosing materials, the project team will give preference to materials with a recycled content value in accordance with the SCA Standard Specifications.

This credit will be achieved by using materials with recycled content such that the sum of pos-consumer content plus on-half of pre-consumer recycling content constitutes at least 10% of the total value of the materials in the project. The recycled content value of a material assembly shall be determined by weight. The recycled fraction of the assembly is then multiplied by the cost of the assembly to determine the recycled content value. Recycled contents shall be defined in accordance with the International Organization for Standardization document, ISO 14021 – Environmental Labels and Declaration – Self-Declared Environmental Claims (Type II environmental labeling). Per the methodology for this credit in the current version of LEED, the typical value of materials on the project will be assumed to be 45% of the cost of divisions 2-10.

Applicable SCA Standard Specifications include:

S01352 Sustainability Requirements 02200 Earthwork 02513 Sidewalk and Street Paving 02521 Concrete Curbs and Pavements 03200 Concrete Reinforcement 03300 Cast-in-Place Concrete 04200 Unit Masonry 05120 Structural Steel 07211 Perimeter Foundation Insulation 07212 Miscellaneous Building Insulation 07560 Fluid-applied Protected Membrane Roofing 08110 Steel Doors and Frames 08330 Coiling Doors, Grilles and Shutters 08524 Aluminum Projected Windows 08921 Aluminum Storefront 09260 Gypsum Board Assemblies 09310 Ceramic Tile 09510 Acoustic Ceilings 09650 Resilient Flooring 10151 Toilet Compartments 10185 Plastic Shower and Dressing Compartments 10505 Metal Lockers

The project team has incorporated the above SCA Standard Specifications into the construction documents dated 9July2018.

M2.2 Recycled Content, 20% (post-consumer + ½ pre-consumer) Credit pursued.

When choosing materials, the project team will give preference to materials with a recycled content value in accordance with the SCA Standard Specifications.

This credit can be achieved by using materials with recycled content such that the sum of pos-consumer content plus on-half of pre-consumer recycling content constitutes at least 20% of the total value of the materials in the project. The recycled content value of a material assembly shall be determined by weight. The recycled fraction of the assembly is then multiplied by the cost of the assembly to determine the recycled content value. Recycled contents shall be defined in accordance with the International Organization for Standardization document, ISO 14021 – Environmental Labels and Declaration – Self-Declared Environmental Claims (Type II environmental labeling). Per the methodology for this credit in the current version of LEED, the typical value of materials on the project will be assumed to be 45% of the cost of divisions 2-10.

Applicable SCA Standard Specifications include: S01352 Sustainability Requirements 02200 Earthwork 02513 Sidewalk and Street Paving 02521 Concrete Curbs and Pavements 03200 Concrete Reinforcement 03300 Cast-in-Place Concrete 04200 Unit Masonry 05120 Structural Steel 07211 Perimeter Foundation Insulation 07212 Miscellaneous Building Insulation 07560 Fluid-applied Protected Membrane Roofing 08110 Steel Doors and Frames 08330 Coiling Doors, Grilles and Shutters 08524 Aluminum Projected Windows 08921 Aluminum Storefront 09260 Gypsum Board Assemblies 09310 Ceramic Tile 09510 Acoustic Ceilings 09650 Resilient Flooring 10151 Toilet Compartments 10185 Plastic Shower and Dressing Compartments 10505 Metal Lockers

The project team has incorporated the above SCA Standard Specifications into the construction documents dated 9July2018.

<u>M2.3</u> Regional Materials, 10% Extracted, Processed & Manufactured Regionally Credit anticipated.

The credit requirements will be met by verifying if the materials or products used for this project have been extracted, harvested or recovered, as well as manufactured, within 500 miles of the project site for a minimum of 10% of the total material value. Per the methodology of this credit in LEEDv3, the typical value of materials on the project can be assumed to be 45% of the cost of divisions 2-10.

Applicable SCA Standard Specifications include:

S01352 Sustainability Requirements

02200 Earthwork 05211 Asphaltic Concrete Paving 02513 Sidewalk and Street Paving 02521 Concrete Curbs and Pavements 03200 Concrete Reinforcement 03300 Cast-in-Place Concrete 04200 Unit Masonry 04435 Cast Stone 05120 Structural Steel 07211 Perimeter Foundation Insulation 07212 Miscellaneous Building Insulation 08524 Aluminum Projected Windows (standard SCA spec does not request local information) 09260 Gypsum Board Assemblies 09310 Ceramic Tile 09510 Acoustical Ceilings (standard SCA spec does not request local information)

The project team has incorporated the above SCA Standard Specifications into the construction documents dated 9July2018.

<u>M2.4</u> Regional Materials, 20% Extracted, Processed & Manufactured Regionally Credit pursued.

The credit requirements can be met by verifying if the materials or products used for this project have been extracted, harvested or recovered, as well as manufactured, within 500 miles of the project site for a minimum of 20% of the total material value. Per the methodology of this credit in LEEDv3, the typical value of materials on the project can be assumed to be 45% of the cost of divisions 2-10.

Applicable SCA Standard Specifications include:

S01352 Sustainability Requirements 02200 Earthwork 05211 Asphaltic Concrete Paving 02513 Sidewalk and Street Paving 02521 Concrete Curbs and Pavements 03200 Concrete Reinforcement 03300 Cast-in-Place Concrete 04200 Unit Masonry 04435 Cast Stone 05120 Structural Steel 07211 Perimeter Foundation Insulation 07212 Miscellaneous Building Insulation 08524 Aluminum Projected Windows (standard SCA spec does not request local information) 09260 Gypsum Board Assemblies 09310 Ceramic Tile 09510 Acoustical Ceilings (standard SCA spec does not request local information)

The project team has incorporated the above SCA Standard Specifications into the construction documents dated 9July2018.

<u>M2.5R</u> Wallboard & Roof Deck Products, Mold Resistance Credit anticipated.

When choosing materials, the project team will select materials for the interior and exterior envelope that are resistant to mold in accordance with the SCA Standard Specifications.

Applicable SCA Standard Specifications include: S01352 Sustainability Requirements 06100 Rough Carpentry 07212 Miscellaneous Building Insulation 09260 Gypsum Board Assemblies

The project team has incorporated the above SCA Standard Specifications into the construction documents dated 9July2018.

Indoor Environmental Quality Credits

The project will be designed as to establish minimum indoor air quality (IAQ) performance in accordance with the minimum requirements outlined in Sections 4 through 7 of ASHRAE 62.1-2007 Ventilation for Acceptable Indoor Air Quality (with errata but without addenda). The new building does not contain auditorium or gymnasium spaces; they remain in the existing building.

The proposed configuration of the ventilation system for the project includes the following components:

- The HVAC system for the Classrooms, Offices, other Non-Assembly areas and Corridors shall utilize Variable Air Volume (VAV) boxes. The general requirements for the VAV system are as follows:
 - Outside air will be introduced to classrooms, offices, other non-assembly spaces, and corridors through VAV central recirculating air handling units. The VAV air handling units' role is to temper the heating season ventilation air and provide all of the space cooling capacity.
 - The VAV system will be designed with a Demand Control Ventilation (DCV) control sequence. Each classroom will be provided, in addition to space temperature sensor, with an occupancy sensor in order to reset the minimum required ventilation air rate at the outside air intake of the central VAV AHU unit. The design documents will indicate occupied minimum, vacant standby minimum and maximum air flows for each VAV box.
 - The maximum air flow shall be that required to satisfy the thermal loads during the occupied scheduled time periods at the adjustable space temperature setpoint. Demand Controlled Ventilation (DCV) for each space will be provided in addition to utilizing an energy recovery wheel (ERW) in the central air handling unit.
 - The following required DCV logic shall be utilized: When classroom is actually occupied during scheduled occupied hours as determined by an occupancy sensor, the minimum ventilation rate shall be the sum of the space ventilation rates (cfm/SF * SF) plus the occupant ventilation rate (cfm/p * population), and when vacant during scheduled occupied hours as determined by an occupancy sensor, the minimum ventilation rate shall be the space ventilation rates (cfm/SF * SF). The space ventilation rate (cfm/SF) and occupancy ventilation rate (cfm/p) will be determined from MC Table 403.3.
 - These spaces should be hard ducted, as ceilings will not be used as return plenums.
- The cafeteria and kitchen shall be served by a Single Zone Variable Air Volume (SZVAV) air handling unit (AHU) with the following requirements:
 - The SZVAV system shall have a decoupled heating system where the SZVAV units provide nominally 65°F ventilation air during the heating mode. Units shall be coupled in cooling with a mixed variable air volume system (SZVAV).
 - O DCV is to be employed, so carbon dioxide sensors shall be located in each PA space to reduce the outside air intake when the spaces are not occupied. The control of the outside air intake for each public assembly space is as follows: For the Cafeteria and Kitchen the minimum outside air intake ventilation rate that the carbon dioxide sensors can throttle the outside air intake rate down to in the non-cooking mode is the Cafeteria specific cfm per square foot requirements as defined in MC Table 403.3 of the 2014 NYC Mechanical Code times the Cafeteria square footage plus the cumulative Kitchen General Exhaust, Can Wash Room and Staff Toilet exhaust make up requirements considering that ample make up air must always be provided for the Kitchen General Exhaust, Can Wash Room and Staff Toilet.

• All air intake units will have MERV 7 pre-filters and MERV 13 final-filters installed.

Applicable SCA Design Requirements include:

6.2.0 General Overview of Heating Ventilation and Air Conditioning Systems

6.2.1 HVAC Unit Centralization and Coordination

6.2.3 Non-Assembly Spaces (Classrooms, Offices, etc.)

6.2.4 Public Assembly Spaces

6.2.9 Heating and Cooling Design Parameters (Load Calculations)

Applicable SCA Standard Specifications include:

S01550 Indoor Air Quality Requirements

15853 Custom Packaged Rooftop Heating and Cooling Units (Variable Air Volume System)

15930 Variable Air Terminals

15935 Single Zone Variable Air Volume (SZVAV) Air Handling Units for Public Assembly Spaces

15985 Sequence of Operations

15992 Cleaning and Testing

15993 Balancing of Systems

See Appendix A for the IEH Outdoor Analysis Report (ASHRAE Outdoor Air Assessment) and the PS 347X – Outdoor Air Intake Quality for GSG Prerequisite Q1.1P and LEED v4 EQp1 DRAFT REPORT (CFD Modeling) from NYC SCA. The IEH Outdoor Analysis Report indicates moderate non-attainment for ozone. The Outdoor Air Intake Quality report indicates that no special filters are required to meet the outdoor air quality requirements of ASHRAE 62.1-2007 and the surrounding air meets the air quality requirements of Section 4 of ASHRAE 62.1-2007 and SHRAE 62.1-2010, necessary for GSG and LEED compliance.

Please note that LEED does not specifically require special filtration for areas with moderate non-attainment for ozone.

Calculations to show compliance with this credit and ASHRAE 62.1-2007 as applicable are provided below; NYCMC 2014 references ASHRAE 62.1-2007.

VENTILATION INDEX																
Zone	Name and Number	Occu	oancy Categor	y Zo Fi Are (so	one oor a Az q ft)	Are you default for : populo	u using value zone ation?	Zone Populati Pz (people	ion e)	Zone Air Distributio Effectivene Ez	r O on O ess A	Zone Outdoor Airflow Voz (cfm)	Zone Discharge Airflow Vdz (cfm)	Zone Primary Airflow Vpz (cfm)	Zone Secondary Recirculation Fraction Er	Zone Primary Air Fraction Ep
100 LOREY		Corridom		1	102	v.	A110-1	0		1.00		66	400	400	1.00	1.00
105 PAREN		Office sp	ace		65	N	••	1		1.00		15	160	160	1.00	1.00
	F	Office sp		1	50	N	<u> </u>	1		1.00		15	50	50	1.00	1.00
111C EXAM	ROOM	Office sp	ace		77	N	0 0	1		1.00		10	25	25	1.00	1.00
103 SUPEV	ISORY OFFICE	Office sp	ace	1	57	N	- 0	1		1.00		15	160	160	1.00	1.00
201 CORRI	DOR	Corridors		9	97	Ye	15	0		1.00		60	250	250	1.00	1.00
203 KINDE	PGARTEN	Davcare (through gae	4) 0	30	N	~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~	23		1.00		398	400	400	1.00	1.00
204 885 8		Davcare (through gae	4) 0	54	N	~	2.5		1.00		411	400	420	1.00	1.00
204 FRE-P		Davcare	through age	4) 0	17	IN N	-	24		1.00		705	420	420	1.00	1.00
200 FRE-P		Corridore	iniough ugo	·/ 9	97	IN V	0	25		1.00		595	400	250	1.00	1.00
307 BRO IE	CT. ROOM	Classroom	15 (0085 5-8)		30	N	~	27		1.00		342	400	400	1.00	1.00
ZOA KINDE		Daveare	through age	4) 0	50	IN N	-	25		1.00		342	400	400	1.00	1.00
304 KINDER	RGARTEN	Daycare	through age	4) 9	04 4-	IN	0	24	-	1.00		411	420	420	1.00	1.00
JUG KINDER	RGARTEN	Classroom		-) 9	70	IN	0	25	-	1.00		595	400	400	1.00	1.00
405 GRADE		Classroon	is (ages 5-8)	8	38	N	0	25		1.00		331	400	400	1.00	1.00
404 GRADE	. 1	Classroom	15 (dges 5-6)	8	04	N	0	21	_	1.00		307	420	420	1.00	1.00
406 GRADE		Classroon	is (ages 5-8)	/	61	N	0	19		1.00		281	400	400	1.00	1.00
408 GRADE	. 1	Classroom	15 (dges 5-8)	/	92	No		23	_	1.00		325	400	400	1.00	1.00
503 LIBRAF	RY	Classroom	ns (ages 5-8)	8	64	54 NO		23		1.00		334	480	480	1.00	1.00
504 GRADE	2	Classroon	ns (ages 5-8)	8	04	N	0	21		1.00		307	420	420	1.00	1.00
506 GRADE	2	Classroon	ns (ages 5-8)	7	56	N	0	19		1.00		281	400	400	1.00	1.00
508 GRADE	2	Classroon	ns (ages 5-8)	7	73	N	0	20		1.00		293	400	400	1.00	1.00
CO1_CORRU	DOR	Corridors		5	45	Ye	ARU-2	0		1.00		33	150	150	1.00	1.00
109 EXERC	ISE	Classroon	ns (aaes 5-8)	1	1.258		0	31		1.00		460	460	460	1.00	1.00
205 RESOL	IRCE ROOM	Davcare (through gae	4) 5	40	N	0	14		1.00		183	400	400	1.00	1.00
203 KESOG		Davcare (through age	4) 0	21	N	-	07		1.00		706	400	400	1.00	1.00
207 KINDE	KGARTEN	Daycare	through age	4) 0	21	No		25	_	1.00	396		400	400	1.00	1.00
200 FRE-P	<	Daycare	through age	4) 0	30	NO		23		1.00	396		400	400	1.00	1.00
210 FRE-F	VIEORY	Office sp	nce	+) 9	23	No		25		1.00	396		400	400	1.00	1.00
207 KINDE		Davcare	through age	4) 0	21	IN N	-	27		1.00	10		100	400	1.00	1.00
JOR KINDER		Daycare	through age	4) o	47	No		23		1.00		396	400	400	1.00	1.00
300 KINDER		Daycare	through age	4) o	7.0	No		23	_	1.00	396		400	400	1.00	1.00
401 CORDU		Corridore	ugn uge -	·/ 9	30 97	N V.	0	23	-+	1.00		290	400	400	1.00	1.00
405 STAFF	LUNCH	Office sp	ace	5	88	T 6 N	, s 0	3	-+	1.00		50	400	200	1.00	1.00
407 GRADE	- 1	Classroon	- 1s (aaes 5-8)	9	43	IN N	~	21	-+	1.00		311	400	400	1.00	1.00
410 GRADE	· ·	Classroon	(ages 5-8)		88	IN N	~	20	-+	1.00		295	400	400	1.00	1.00
412 ORADE	· ·	Classroon	ns (ages 5-8)		30	IN N	- -	20	-+	1.00		295	400	400	1.00	1.00
501 COPPU	DOR	Corridore	- (-9-0 0 -0)		97	N V		20		1.00		60	250	250	1.00	1.00
505 SPECU		Classroon	ns (ages 5-8)		37	N	~	16	-+	1.00		236	400	400	1.00	1.00
507 ORADS	2 2000A11011	Classroom	1s (ages 5-8)		43	IN N	~	21	-+	1.00		311	400	400	1.00	1.00
514 CUSTO	DIAN'S	Office sp	ace	1	60	IN N	0	1	\rightarrow	1.00		15	125	125	1.00	1.00
					50	D	AHU-3	5		1.00		19	120	120	1.00	1.00
102 CAFET	ERIA	Cafeteria		1,	960	N	0	140		1.00		1403	1,785	1,785	1.00	1.00
SUM														-	-	
System	System Type	All zones	Condition	System	Sy	stem	Outdo	or Air Ou		utdoor Air Oute		or air				
and	Name inc and t		included in Analyzed F the VRP			uiation people)	intake (reauir	Flow In red by		ake Flow rovided	intake provi	tiow ided				
Number cal		calculation?	alculation?			(People) (requir 6.2.1)) Vot (design)	meets	s or				
							(cf	m)	Vot (cfm)		exceeds	s Vot?				
A101 4	Multiple Zoncs	Ver	Heating	15040	+ .	7.1.7	EO			7455						
	Multiple Zones	Tes	Heating	1/726	-	286	50:	06		6595	T9 V-	13				
AHU-3	Multiple Zones	Yes	Heating	1960	1	140	14	03		1785	Ye	s				
				1000	1							-				

Q1.2R Outdoor Air Delivery Monitoring

Credit anticipated.

The central ventilation system (rooftop HVAC units) for the addition will be provided with air flow measuring stations at the outside air intakes in order to measure/monitor the outside air supplied to the school. Data for outside air measurement will be available for verification at the school level through the BMS system schools operating console in the Custodian's Office or through the DOE centralized host control station for Automatic Temperature Control of Schools in NYC.

The VAV system will be designed with a Demand Control Ventilation (DCV) control sequence. Each classroom will be provided, in addition to space temperature sensor, with an occupancy sensor in order to reset the minimum required ventilation air rate at the outside air intake of the central VAV AHU unit.

Applicable SCA Design Requirements include:

- 6.2.0 General Overview of Heating Ventilation and Air Conditioning Systems
- 6.2.1 HVAC Unit Centralization and Coordination
- 6.2.3 Non-Assembly Spaces (Classrooms, Offices, etc.)
- 6.2.4 Public Assembly Spaces
- 6.2.9 Heating and Cooling Design Parameters (Load Calculations)

Applicable SCA Standard Specifications Include:

15970 Temperature Control System (LonWorks BMS/DDC with School Operating Console) 15985 Sequence of Operations

- Applicable SCA Standard Details include:
 - 15985 HVAC Standard Detail Series

The project team has incorporated the above SCA Design Requirements into the HVAC drawings, the SCA Standard Details into drawings M404, M405, M406, and M407 and the above SCA Standard Specifications into the project Specifications.

IAQ Pre-occupancy

Q2.1R Construction IAQ Management Plan, During Construction credit anticipated.

The project specifications will require that the project contractor to develop an IAQ Construction Management Plan to be implemented during construction. The Plan will include requirements to meet or exceed the recommended Control Measures of the Sheet Metal and Air Conditioning Contractors National Association (SMACNA) IAQ Guidelines for Occupied Buildings Under Construction, 2nd Edition 2007, ANSI/SMACNA 008-2008 (Chapter 3). All absorptive materials that are stored on site or installed will be protected from moisture damage. A dust control plan will be developed and implemented. Whenever permanently installed air handlers are used, filtration media with a Minimum Efficiency Reporting Value (MERV) 8, as determined by ASHRAE 52.2-1999, will be used at each return air inlet. All filtration media will be replaced prior to occupancy. In addition, smoking will be prohibited inside the building and within 25' of building entrances. The Plan will also require that any materials that emit Volatile Organic Compounds (VOCs) or urea formaldehyde and do not comply with the low emissions criteria, as outlined in credits Q3.1R through Q3.4R, will be mechanically exhausted during installation and will continue to be ventilated for at least 72 hours after installation until emissions dissipate. Prior to substantial completion, all carpeted and soft surfaces will be vacuumed with a high-efficiency particulate arrestor (HEPA) vacuum. The Plan will also contain the following minimum requirements to be implemented during construction:

- Building materials, such as wood, porous insulation, paper, and fabric, will be kept dry to prevent the growth of mold or bacteria.
- Deliveries will be scheduled so that materials that are susceptible to mold growth are installed after the construction area is water tight.
- In the event that materials do experience water damage, they will begin being dried within 24 hours. If they are damp or wet for more than 48 hours, they may need to be discarded as determined by the SCA.
- Any materials showing signs of mold and/or mildew will be removed from the site and properly disposed of. The damaged materials will be replaced with new, undamaged materials.

In addition to all these requirements, the sequence of installation will be coordinated to install high VOCemitting products prior to the installation of porous or fibrous materials (i.e. carpet). In the event that this is not possible, porous materials will be protected with polyethylene vapor retarders. In addition, all carpeting will be installed after the spaces have been painted. With these efforts, the indoor air quality problems that typically result from the construction process will be minimized and the comfort and well-being of both the construction workers and building occupants will be sustained.

Applicable SCA Standard Specifications Include:

G01700 Project Closeout

S01550 Indoor Air Quality Requirements

S01560 Installation Sequence of Finish Materials

The project team has incorporated the above SCA Standard Specifications into the construction documents dated 9July2018.

<u>Q2.2R</u> Construction IAQ Management Plan, Before Occupancy Credit anticipated.

The IAQ Construction Management Plan that has been outlined in Q2.1R will also include requirements for building flush-out at the completion of construction. The Plan will require that all filtration media be replaced at the end of construction with new filters and that a full building flush-out is performed at the end of construction, but prior to occupancy. Prior to occupancy, a total air volume of 14,000 cubic foot of outdoor air per square foot of floor area will be supplied while maintaining an internal temperate of at least 60° F dry bulb and relative humidity no higher than 60%. In the event that there is not enough time to for a full flush-out prior to occupancy, the building will have to first be supplied with 3,500 cubic foot of outdoor air per square foot of floor area prior to occupancy and then, once occupied, the building will need to be ventilated at a rate of 0.3 cubic feet per minute per square foot of outside air or the design minimum outside air rate, as established in Q1.1R, whichever is greatest. During each day of the flush-out period, the ventilation will begin 3 hours prior to occupancy and continue during occupancy until a total of 14,000 cubic foot of outside air per square foot of floor area has been delivered to the space.

Applicable SCA Standard Specifications Include:

G01700 Project Closeout S01352 Sustainability Requirements S01550 Indoor Air Quality Requirements

The project team has incorporated the above SCA Standard Specifications into the construction documents dated 9July2018.

Low-Emitting Materials <u>Q3.1R</u> Low-Emitting Materials, Adhesives & Sealants Credit anticipated.

When choosing adhesives and sealants, the project team will choose products that comply with the requirements of South Coast Air Quality Management District (SCAQMD) Rule #1168 and, for aerosol adhesives, Green Seal Standard for Commercial Adhesives GS-36.

Applicable SCA Standard Specifications Include: S01352 Sustainability Requirements G01600 Material and Equipment 06100 Rough Carpentry 06200 Finish Carpentry 06410 Custom Casework 07900 Joint Sealers 08210 Wood Doors 08524 Aluminum Projected Windows 08800 Miscellaneous Glazing 08921 Aluminum Storefront 09260 Gypsum Board Assemblies 09310 Ceramic Tile 09510 Acoustical Ceilings 09626 Resilient Athletic Flooring 09650 Resilient Flooring 10100 Visual Display Boards 10400 Identifying Devices 10415 Bulletin Boards, Glazed Display Boards, Display Cabinets, and Cases 10830 Mirrors Div. 15 & 16 - All MEP & fire protection adhesives and sealers

The project team has incorporated the above SCA Standard Specifications into the construction documents dated 9July2018.

Q3.2R Low-Emitting Materials, Paints & Coatings Credit anticipated.

When choosing paints and coatings, the project team will choose products that comply with the requirements of the following when applied to Interior elements:

- Clear Wood Finishes, Floor Coating, Stains, Sealers and Shellacs: South Coast Air Quality Management District (SCAQMD) Rule #1113.
- Architectural Paints, Coatings and Primers: Green Seal Standard GS-11
- Anti-Corrosive and Anti-Rust Paints: Green Seal Standard GS-03.

Applicable SCA Standard Specifications Include:

S01352 Sustainability Requirements G01600 Material and Equipment 09675 Fluid-Applied Equipment Room Flooring 09860 Graffiti Resistant Coatings 09900 Painting Div. 15 & 16 - All MEP & fire protection paints and coatings The project team has incorporated the above SCA Standard Specifications into the construction documents dated 9July2018.

<u>Q3.3R</u> Low-Emitting Materials, Flooring Systems Credit anticipated.

When choosing flooring systems, all hard surface flooring, including vinyl, ceramic flooring, rubber/resilient flooring, wall base, and associated sundries, will be certified as compliant with the FloorScore (or California department of Public Health Standard Method for Testing and Evaluation of Volatile Organic Chemical Emissions from Indoor Sources Using Environmental Chambers, Version 1.1) standard by a third-party. Furthermore, all sealers, stains, finishes, tile setting adhesives, and grout will comply with the requirements outlined in Q3.1R and Q3.2R. Carpet will Green Label Plus compliant.

Applicable SCA Standard Specifications Include:

S01352 Sustainability Requirements G01600 Material and Equipment 09310 Ceramic Tile 09650 Resilient Flooring

The project team has incorporated the above SCA Standard Specifications into the construction documents dated 9July2018.

<u>Q3.4R</u> Low-Emitting Materials, Comp Wood & Agrifiber Products Credit anticipated.

When choosing composite wood and agrifiber products, the project team will choose products that contain no added urea formaldehyde. In addition, laminating adhesives used to fabricate on-site and shop-applied composite wood and agrifiber assemblies will contain no-added urea formaldehyde. Composite wood and agrifiber products include particleboard, medium density fiberboard, plywood, wheatboard, strawboard, panel substrates, and door cores.

Applicable SCA Standard Specifications Include:

S01352 Sustainability Requirements 06100 Rough Carpentry 06200 Finish Carpentry 06410 Custom Casework 08210 Wood Doors 10100 Visual Display Boards 10415 Bulletin Boards, Glazed Display Boards, Display Cabinets and cases

Applicable SCA Standard Details include: 06200 Finish Carpentry 06410 Custom Casework

The project team has incorporated the above SCA Standard Specifications into the construction documents. Because MEP systems may use wood material, such as for mounting of telephone terminal blocks in the main telecommunications room (MDF Room) and telecommunication closets (IDF Closets), and for roof curbs of fans, a statement has been added to the MEP specification sections 15301, 15401, 15501, and 16010 (revision received 1May2018) stating that any engineered wood used shall not have added urea-formaldehyde.

Pollution Source Control

Q4.1R Indoor Chemical & Pollutant Source Control Credit anticipated.

The project will be designed to reduce and control the presence of chemicals and pollutants in the building. This includes both the entry of these pollutants into the building as well as the cross-contamination of pollutants between regularly occupied spaces. All entryways that qualify as regular entry points for students and staff and that have a direct access to the outdoors will include permanent entryway systems at least 10 feet long in the primary direction of travel, such as permanently installed grates, grilles, or slotted systems that allow for cleaning underneath, to capture dirt and particulates.

All spaces where hazardous gases or chemicals may be present will be exhausted sufficiently to create negative air balance with respect to adjacent spaces with the doors to the room closed. Each of these spaces will have self-closing doors and deck-to-deck partitions or a hard-lid ceiling. The exhaust rate will provide for at least 0.50 cubic foot per square foot, with no air re-circulation. Any make-up air provided in the area will be a minimum of 10% less than the exhaust rate. Such spaces that require these measures include janitor's sink closets, copy/print rooms, ground equipment storerooms, any others where hazardous gases or chemicals are present.

Additionally, all occupied spaces will have air filtration media that provides at least a MERV of 13. Filtration will be applied to both return and outside air that is to be delivered as supply air. Containment for future off-site disposal will also be provided for the appropriate disposal of hazardous liquid wastes in places where water and chemical concentrate mixing occurs (the GSG states that the use of hazardous materials in schools is limited and a separate containment area will typically not need to be provided). With these various measures, the exposure of building occupants to hazardous particulates and chemical pollutants will be greatly reduced.

The spaces which may contain hazardous gases or chemicals include as follows:

• Janitor's Closet.

Designated entryways with 10' walk-off systems are located at the Jerome Avenue exterior entrance from the new lobby (shown on A441 dated **9July2018**) and playground exterior entrance (shown on A101 dated **9July2018**).

Applicable SCA Design Requirements include:

1.3.4.1 Entrances and Exits

6.2.0 General Overview of Heating Ventilation and Air Conditioning Systems

6.2.28 HVAC Design Requirements for Special Spaces

Applicable SCA Standard Specifications include:

12485 Foot Grilles

15853 Custom Packaged Rooftop Heating and Cooling Units (Variable Air Volume System

15935 Single Zone Variable Air Volume (SZVAV) Air Handling Units for Public Assembly Spaces

The project team has incorporated the above SCA Design Requirements and specifications into the construction documents. The filter ratings for the air handlers are indicated in specification sections 15853 and 15935 dated 9July2018. Dedicated exhaust has been provided for Janitor's Closets.

Q4.2R Electric Ignition Stoves Credit is not feasible.

The project has only a warming kitchen which does not include a stove; this credit cannot be earned.

Applicable SCA Design Requirements include:

7.3.13 Carbon Monoxide Detection and Alarm Systems

Applicable SCA Standard Specifications include: 11400 Food Service Equipment 15416 Gas Piping System

The project team has incorporated the above SCA Standard Specifications into the construction documents dated 9July2018.

Q4.3R Post Construction Indoor Air Quality Credit anticipated.

High Efficiency Particulate Arrestor (HEPA) vacuums shall be provided as part of the initial equipment for the school. Carpeted and other soft surface floors will be vacuumed with HEPA vacuums after construction is complete and prior to occupancy.

From:MENDEZ, DIANASent:Tuesday, March 04, 2008 5:57 PMTo:SHAH, ARTICc:MAJOR, NICOLESubject:RE: HEPA Vacuums and Recycling Bins

Arti:

The maintenance equipment list provided to new buildings is selected and approved by DOE/DSF, not F&E. The DOE/DSF approved list includes (2) HEPA vacuums. Please note there are other vacuums also provided (backpack vacuum and wet/dry vacuum).....

Diana Mendez Manager, Operations - F&E NYC School Construction Authority

Controllability of Systems <u>Q5.1R</u> Controllability of Systems, Lighting Credit anticipated.

The project will comply with the credit requirements. The project will provide individual lighting controls for at least 90% of the occupancy and low voltage lighting control switches for shared multi-occupants' spaces including classrooms.

Lighting Controls will be as follows:

- All interior lighting shall automatically be controlled by a programmable Relay Control Panel with integral clock except for the emergency lighting. The Relay Control Panel shall be provided at the Electric Closet and to control all spaces that do not have automatic shutoff and/or Occupant sensors.
- All stairs, locker/shower rooms and multi-user student toilet luminaries shall be set to 50% power level in the OFF position and use occupancy sensors (Auto-ON) to bring it up to 100% when occupied.
- Student Classroom Toilets: wall mounted vacancy sensor with low-voltage switch at door.

- Emergency lighting controlled from key operated switches located at the main entrance; non-emergency lighting luminaires to have built-in censor; all luminaires in stairs are emergency.
- Cafeteria/Lunch Room: key operated switches for emergency lights and occupancy sensor for nonemergency lights.
- Instructional space: For spaces 2,000 SF or less in area, lighting shall be controlled by one ceiling mounted vacancy sensor/Daylight harvesting Sensor and one control switch located by the classroom entrance door. Control switch to consist of one five-button switch for High, Low, 50%, 100% and Off control of lighting in each classroom.
- Corridor: emergency lighting controlled from key operated switches located at the main entrance; other lights controlled by built-in occupancy sensor in each luminaire.
- All sensors in corridors, student locker rooms, stair and bathrooms to be set for 15 minutes.
- Electrical Closet: toggle switch.
- Library: three-way switches at entrance and at librarian desk, and ceiling mounted vacancy sensors.
- Individual office: wall mounted vacancy/daylight sensor to automatically control lighting with an override switch. Provide daylight room controller to control both near window rows of light. Provide an over-ride three position push button switch set to off, 50% and 100%.
- Janitor's Closet: wall-mounted vacancy sensor.
- Mechanical Areas Service Areas: toggle switch.
- Staff Toilets: vacancy sensor and toggle switch.
- Storage: wall-mounted vacancy sensor and toggle switch.
- Staff Locker Room: vacancy sensor and toggle switch.
- Staff Lunchroom/Lounge: ceiling-mounted vacancy sensor and toggle switch.
- Waiting Area: ceiling mounted occupancy sensors.
- Clinic/Exam Areas of medical suites: push-button switch.

Applicable SCA Design Requirements include: 7.2.1 Interior Lighting

Applicable SCA Standard Specifications include: 16140 Wiring Devices 16145 Lighting Control Devices

Applicable SCA Standard Details include:

SCA Room Planning Standards (Standard Room Layouts)

Floor plans indicating the quantity of lighting fixtures, control switches for lights, and furniture layouts for every room have been submitted to the SCA and can be found on drawings E601 for lighting fixture schedule, A801 - A805 for reflected ceiling plans, FF101-FF221 for furniture layouts and E100-E105 for control switches.

Q5.2R Controllability of Systems, Thermal Comfort

Credit anticipated.

A thermal comfort control system will be designed to provide comfort controls for 50% of the building occupants in workspaces. Comfort control is defined by ASHRAE Standard 55-2004 as the control in the occupant's local environment of one or more of these primary factors: air temperature, radiant temperature asymmetry, air speed, and humidity. By following SCA standards, this credit will be achieved by providing thermal comfort control in shared group multi-occupancy spaces including, but not limited to, instructional rooms, exercise, administration, and cafeteria. By providing a thermal comfort control system, the productivity, comfort, and well-being of occupants will be greatly improved.

- Classroom: As per SCA design, room layout standards, a thermostat will be provided in each classroom along with operable windows.
- Special Ed Classroom: As per SCA design room layout standards, a thermostat will be provided in each classroom along with operable windows.
- Office: As per SCA design, room layout standards, thermostat will be provided along with operable windows.

Applicable SCA Design Requirements include:

- 6.2.0 General Overview of Heating Ventilation and Air Conditioning Systems
- 6.2.1 HVAC Unit Centralization and Coordination
- 6.2.3 Non-Assembly Spaces (Classrooms, Offices, etc.)
- 6.2.4 Public Assembly Spaces

Applicable SCA Standard Specifications include:

15970 Temperature Control System (LONWORKS BMS/DDC with School Operating Console) 15985 Sequence of Operations

Applicable SCA Standard Details include: 15985 HVAC Standard Detail Series

Additional applicable SCA Design Standards include: SCA Room Planning Standards (Standard Room Layouts)

Floor plans indicating the locations of temperature control devices are found on M101 to M105. The symbol "TS" for Temperature Sensors, "T" for Thermostat, "TL" for Lonworks Thermostat, and "H" for Humidity Sensor are indicated in applicable spaces; these devices provide manual control at the space and also are connected to the BMS system. Operable windows are indicated on elevation drawings A201 through A204 and the window schedule on A920-A921.

Thermal Comfort <u>Q6.1R</u> Thermal Comfort, Design Credit anticipated.

All HVAC systems will be designed to comply with ASHRAE Standard 55-2004, Thermal Environmental Conditions for Human Occupancy.

Inside ambient design parameter for heating: 72°F DB.

Inside ambient design parameter for cooling: 78°F DB, 50% RH, with the exception of the special education spaces which will be maintained at 75 °F.

No proposed departures from SCA standards are currently indicated.

Applicable SCA Design Requirements include:

6.2.0 General Overview of Heating Ventilation and Air Conditioning Systems
6.2.1 HVAC Unit Centralization and Coordination
6.2.3 Non-Assembly Spaces (Classrooms, Offices, etc.)
6.2.4 Public Assembly Spaces
6.2.9 Heating and Cooling Design Parameters (Load Calculations)
6.2.22 Kitchen Ventilation
6.2.28 HVAC Design Requirement for Special Spaces

Applicable SCA Standard Specifications include:

15970 Temperature Control System (LONWORKS BMS/DDC with School Operating Console) 15985 Sequence of Operations

The project team has incorporated the above SCA Standard Specifications into the construction documents dated 9July2018.

HVAC Design Parameters copied from M001 dated 9July2018:

HVAC DESIGN PARAMETERS											
INSIDE AMBIENT DESIGN PAR SUMMER: WINTER:	RAMETERS (ASSEMB 78*F(DB)/50% RH 72*F(DB)	LY AREAS):									
INSIDE AMBIENT DESIGN PARAMETERS (CLASSROOMS/OFFICES): SUMMER: 78°F(DB)/50% RH WINTER: 72°F(DB)											
OUTSIDE SUMMER AMBIENT DESIGN PARAMETERS FOR AIR HANDLERS: SUMMER: 89*F(DB)/73*F(WB)											
OUTSIDE WINTER AMBIENT DESIGN PARAMETERS: WINTER TEMP.: 11°F(DB) WIND VELOCITY: 15 MPH											
MAX ALLOWABLE "U-VALUES ROOF: WALLS: WHOLE WINDOW: SOLAR HEAT GAIN COEFFICIENT:	0.045 BTU/HRxFT ² x*F 0.06 BTU/HRxFT ² x*F 0.45 BTU/HRxFT ² x*F 0.38	From 26Apr2018 Load Calculations: Roof: 0.031 Walls: 0.056 Window: 0.42									
MINIMUM OUTDOOR AIR SUPPLY NUMBER OF OCCUPANTS BASED ON BUILDING CODE TABLE 1004.1.1. DISTRICT 75 SPECIAL EDUCATION SPACES SHALL BE MAINTAINED AT 75°F DURING THE COOLING SEASON DURING OCCUPIED PERIODS (IN LIEU OF THE STANDARD 78°F PROVIDED IN OTHER SPACES).											

Lighting and Views Q7.1 Daylight & Views, Daylight 75% of Classrooms Credit anticipated

Credit anticipated.

Although the site constrains the new building to an 83' by 122' shape at a Northeast to Southwest orientation it provides all the classrooms a perimeter exposure; each classroom has at least one full wall facing the exterior. As per SCA standards, all windows in classrooms will be provided with manually operated window shades for glare control.

The following updated (downloaded from SCA GSG website on 30Apr2018) Daylight Form below includes a breakdown of the day lighted and non-day lighted areas for each space with a result of 77.26% daylit with VLT of 0.67 (08524 spec updated Dec2017) which meets the credit requirement of 75%.

Excluded Spaces:

Classroom toilets and classroom closets are currently excluded from the calculations.

Applicable SCA Design Requirements include:

- 1.3.1.1 Building Location and Orientation
- 1.3.1.2 Planning Guidelines for New Schools and Additions
- 5.7.1 Window Shades and Draperies

Applicable SCA Standard Specifications include: 08524 Aluminum Projected Windows 08800 Miscellaneous Glazing 08921 Aluminum Storefront 12501 Chain and Clutch Operated Window Shades

The project team has incorporated the above SCA Standard Specifications into the construction documents dated **9July**2018.

DAYLIG	IT & VIEWS														ート								
Daylight	Calculation Form for	or Classro	oms												ŚCA	Schoo	Cons	struoti	on Autho	arity			
Credit Q	7.1, Q7.2																NYC Gr	een Scho	ool Rating Sy	stems			
Project:	P.S. 347X Bronx A	nnex at F	PS 33	x								_			Architect:	Mitchell G	iurgola	Architec	ts, LLP				
Address [.]	2424 Jerome Ave B	ronx NY	1046												Preparer:	FMF Grou	n						
	107340		1010			Design #:					-	-			Date	4/30/18	P				-		
	107040					Design #.					_				Dute.	4/00/10							
RM #	Room Name	Room Data					Windo	ow Data			Glazing	j Data	Transm V	ittance- LT	Daylig	ht Zone	WFR Factor	Dayligh Factor	t Zone	Daylight Area		Compliant Daylight Area	Compliant area %
		Room Area		Room Length	Effective Head Hgt	Sill Hgt	Daylight Hgt	Window Width/ Room	Window Area - wa		Glazing factor	Glass Area	Actual	Min	Daylight Zone Depth	Daylight Area	Actual	Actual/ Greatest	Required		Actual Daylight Zone Factor	Greatest Room Area Allowed	
204	Pre-K	945	SF	64.13	10.00	2.67	7.33	31.20	229	SF	0.87	199	0.67	0.67	20.00	1282.60	0.22	0.15	0.15 - 0.18	919	0.145	919	0.97
205	Readg/Speech	325	SF	19.61	10.00	2.67	7.33	11.75	86	SF	0.86	74	0.67	0.67	20.00	392.20	0.22	0.15	0.15 - 0.18	325	0.153	325	1.00
205	Over Daylit	79	SF	8.44	10.00	2.67	7.33	7.75	57	SF	0.86	49	0.67	0.67	20.00	168.80	0.22	0.15	0.15 - 0.18	79	0.414	0	1.00
206	Pre-K	898	SF	28.96	10.00	2.67	7.33	23.50	172	SF	0.86	148	0.67	0.67	20.00	579.20	0.22	0.15	0.15 - 0.18	684	0.145	684	0.76
207	Kindergarten	902	SF	29.47	10.00	2.67	7.33	19.35	142	SF	0.87	123	0.67	0.67	20.00	589.40	0.22	0.15	0.15 - 0.18	570	0.145	570	0.63
208	Pre-K	927	SF	28.96	10.00	2.67	7.33	23.50	172	SF	0.86	148	0.67	0.67	20.00	579.20	0.22	0.15	0.15 - 0.18	684	0.145	684	0.74
209	Kindergarten	914	SF	65.07	10.00	2.67	7.33	30.75	225	SF	0.87	196	0.67	0.67	20.00	1301.40	0.22	0.15	0.15 - 0.18	906	0.145	906	0.99
210	Pre-K	909	SF	29.45	10.00	2.67	7.33	23.50	172	SF	0.86	148	0.67	0.67	20.00	589.00	0.22	0.15	0.15 - 0.18	684	0.145	684	0.75
310	Kindergarten	909	SF	29.46	10.00	2.67	7.33	23.50	172	SF	0.86	148	0.67	0.67	20.00	589.20	0.22	0.15	0.15 - 0.18	684	0.145	684	0.75
303	Project Room	891	SF	64.82	10.00	2.67	7.33	26.49	194	SF	0.87	169	0.67	0.67	20.00	1296.40	0.22	0.15	0.15 - 0.18	780	0.145	780	0.88
304	Kindergarten	937	SF	64.13	10.00	2.67	7.33	31.20	229	SF	0.87	199	0.67	0.67	20.00	1282.60	0.22	0.15	0.15 - 0.18	919	0.145	919	0.98
306	Kindergarten	898	SF	28.96	10.00	2.67	7.33	23.50	172	SF	0.86	148	0.67	0.67	20.00	579.20	0.22	0.15	0.15 - 0.18	684	0.145	684	0.76
307	Kindergarten	902	SF	29.46	10.00	2.67	7.33	19.35	142	SF	0.87	123	0.67	0.67	20.00	589.20	0.22	0.15	0.15 - 0.18	570	0.145	570	0.63
308	Kindergarten	919	SF	28.96	10.00	2.67	7.33	23.50	1/2	SF	0.86	148	0.67	0.67	20.00	579.20	0.22	0.15	0.15 - 0.18	684	0.145	684	0.74
403	Grade 1	824	SF	64.63	10.00	2.67	7.33	26.67	195	SF	0.87	170	0.67	0.67	20.00	1292.60	0.22	0.15	0.15 - 0.18	785	0.145	785	0.95
404	Grade 1	779	SF	58.39	10.00	2.67	7.33	23.20	170	SF	0.87	148	0.67	0.67	20.00	1167.80	0.22	0.15	0.15 - 0.18	683	0.145	683	0.88
406	Grade 1	719	SF	22.97	10.00	2.67	7.33	15.50	114	SF	0.86	98	0.67	0.67	20.00	459.40	0.22	0.15	0.15 - 0.18	451	0.145	451	0.63
407	Grade 1	806	SF	29.46	10.00	2.67	7.33	19.35	142	SF	0.87	123	0.67	0.67	20.00	589.20	0.22	0.15	0.15 - 0.18	570	0.145	570	0.71
408	Grade 1	755	SF	22.97	10.00	2.67	7.33	15.50	114	SF	0.86	98	0.67	0.67	20.00	459.40	0.22	0.15	0.15 - 0.18	451	0.145	451	0.60
410	Grade 1	726	SF	22.97	10.00	2.67	7.33	15.50	114	SF	0.86	98	0.67	0.67	20.00	459.40	0.22	0.15	0.15 - 0.18	451	0.145	451	0.62
412 504	Grade 1	765	SF	23.72	10.00	2.67	7.33	15.50	114	5F 6F	0.86	98	0.67	0.67	20.00	4/4.40	0.22	0.15	0.15 - 0.18	451	0.145	451	0.59
504	CSD Special Education	619	SF	34.75	10.00	2.07	7.33	23.20	170	SF SE	0.87	140	0.07	0.67	20.00	1107.00	0.22	0.15	0.15 - 0.18	683	0.145	683	0.00
506	Grade 2	710	SF	22 07	10.00	2.07	7 33	15 50	11/2	SF	0.86	98	0.07	0.07	20.00	459.00	0.22	0.15	0.15-0.18	018 <u>4</u> 51	0.101	018 151	0.63
507	Grade 2	777	SF	29.46	10.00	2.67	7.33	19.35	142	SF	0.87	123	0.67	0.07	20.00	589.20	0.22	0.10	0.15 - 0.18	570	0.140	570	0.00
508	Grade 2	716	SF	23.59	10.00	2.67	7.33	15.50	114	SF	0.87	99	0.67	1.67	20.00	471.80	0.22	0.15	0.15 - 0.19	456	0.145	456	0.64
1	F OF AREA BEING EVALUATED FOR DAYLIGHT FACTOR:	20,338													SF	OF AREA	THAT AC	HIEVES	DAYLIGHT FACTOR: e Achieved:	15,713 77.26%			
Requirement to achieve credit Q7.1 is Daylight in 75% of classroom areas															Comp	olies? (Y/ N):	YES						
Requirement to achieve credit Q7.2 is Davlight in 90% of classroom areas																Com	lies? (Y/ N)	NO					
				,																			





Plan of 2^{nd} Fl Dated 19Feb2018.



Plan of 3rd Fl Dated 19Feb2018.





Plan of 5th Fl Dated 19Feb2018.

Q7.2 Daylight & Views, Daylight 90% of Classrooms

Credit is not feasible.

See narrative, calculations, plans, and applicable SCA standards above in Q7.1.

The updated (downloaded from SCA GSG website on 30Apr2018) Daylight Form above includes a breakdown of the day lighted and non-day lighted areas for each space with a result of 77% daylit with VLT of 0.67 (08524 spec updated Dec2017) which does not meet the credit requirement of 90%.

<u>Q7.3</u> Daylight & Views, Daylight for 75% of Other Spaces Credit is not feasible.

Although the site constrains the new building to an 83' by 122' shape at a Northeast to Southwest orientation it provides all the classrooms a perimeter exposure; most other spaces have at least one full wall facing the exterior. As per SCA standards, all windows will be provided with manually operated window shades for glare control.

The following updated (downloaded from SCA GSG website on 30Apr2018) Daylight Form below includes a breakdown of the day lighted and non-day lighted areas for each space with a result of 64.04% daylit with VLT of 0.67 (08524 spec updated Dec2017) which does not meet the credit requirement of 75%. This calculation was updated with glass block in cafeteria.

Excluded Spaces:

No regularly occupied spaces are currently excluded from the calculations.

Applicable SCA Design Requirements include:

- 1.3.1.1 Building Location and Orientation
- 1.3.1.2 Planning Guidelines for New Schools and Additions
- 5.7.1 Window Shades and Draperies

Applicable SCA Standard Specifications include:

- 08524 Aluminum Projected Windows
- 08800 Miscellaneous Glazing
- 08921 Aluminum Storefront
- 12501 Chain and Clutch Operated Window Shades

The project team has incorporated the above SCA Standard Specifications into the construction documents dated 30Apr2018.

See plans in Q7.1.

DAYLIGH	IT & VIEWS														حوآ								
Daylight	Calculation Fo	rm for Otl	her S	Spaces											sei	Saha	d Cons	truoti	an Autho	ritu			
Credit Q	7.3																NYC Gr	een Scho	ol Rating Sy	stems			
Project:	P.S. 347X Bro	nx Annex	atP	9S33X											Architect	Mitchell	Giurgola	Architec	ts, LLP				
Address:	2424 Jerome A	ve. Bronx.	NY.	10468											Preparer	EME Grou	<u> </u>						
LT W-	107340		,			Design #									Date	6/8/18	- F						
						Boolgit #1	-	-	<u>. </u>						Bato								
RM #	Room Name	Room Data					Winde	ow Data			Glazing	Data	Transm V	nittance- LT	Daylig	ht Zone	WFR Factor	Dayligh Factor	t Zone	Daylight Area		Compliant Daylight Area	Compliant area %
		Room Area		Room Length	Effective Head Hgt	Sill Hgt	Daylight Hgt	Window Width/ Room	Window Area - WA		Glazing factor	Glass Area	Actual	Min	Daylight Zone Depth	Daylight Area	Actual	Actual/ Greatest	Required		Actual Daylight Zone Factor	Greatest Room Area Allowed	
102	Cafeteria w/ glass block	1959	SF	93.81	10.00	2.67	7.33	58.75	431 S	ŝF	0.86	370	0.75	0.67	20.00	1876.20	0.19	0.15	0.15 - 0.18	1,915	0.145	1,915	0.98
112K	Servery	265	SF	10.84	10.00	2.67	7.33	7.75	57 S	6F	0.86	49	0.67	0.67	20.00	216.80	0.22	0.15	0.15 - 0.18	225	0.145	225	0.85
112 A,B,0	Warming Kit	574	SF	0.00	10.00	2.67	7.33	0.10	1 5	SF	0.87	1	0.67	0.67	20.00	0.00	0.22	0.15	0.15 - 0.18	2	0.214	0	0.00
112G	Dietician Office	84	SF	0.00	10.00	2.67	7.33	0.10	1 5	SF	0.87	1	0.67	0.67	20.00	0.00	0.22	0.15	0.15 - 0.18	2	0.214	0	0.02
109	Exercise Room	1251	SF	73.63	10.00	5.00	5.00	29.50	148 S	SF	0.87	128	0.67	0.67	20.00	1472.60	0.22	0.15	0.15 - 0.18	592	0.145	592	0.47
105	Parents Room	209	SF	15.59	10.00	5.00	5.00	11.75	59 S	ŝF	0.86	51	0.67	0.67	20.00	311.80	0.22	0.15	0.15 - 0.18	209	0.162	209	1.00
103	Supervisory Of	176	SF	17.67	10.00	2.67	7.33	11.75	86 S	βF	0.87	75	0.67	0.67	20.00	353.40	0.22	0.15	0.15 - 0.18	176	0.285	0	1.00
103 A,C	Medical Suite	194	SF	18.69	10.00	5.00	5.00	7.75	39 S	ŝF	0.86	33	0.67	0.67	20.00	373.80	0.22	0.15	0.15 - 0.18	153	0.146	153	0.79
305	Supervisory Of	177	SF	15.59	10.00	2.67	7.33	11.75	86 S	SF	0.87	75	0.67	0.67	20.00	311.80	0.22	0.15	0.15 - 0.18	177	0.284	0	1.00
503	Library	860) SF	65.40	10.00	2.67	7.33	23.26	170 S	SF	0.87	148	0.67	0.67	20.00	1308.00	0.22	0.15	0.15 - 0.18	685	0.145	685	0.80
514	Custodian Offic	152	2 SF	0.00	10.00	2.67	7.33	0.10	1 S	ŝF	0.87	1	0.67	0.67	20.00	0.00	0.22	0.15	0.15 - 0.18	2	0.214	0	0.01
																						1	
																							1
SF O EV DAYL	F AREA BEING ALUATED FOR IGHT FACTOR:	5,901													SF	OF AREA	THAT AC	HIEVES	DAYLIGHT FACTOR: e Achieved:	3,779 64.04%			
Requirer	nent to achieve	e credit Q	7.3 is	s Daylight ir	n 75% of	Other S	paces											Comp	lies? (Y/ N):	NO			

Q7.4 Daylight & Views, Views

The credit is not feasible.

Although the site constrains the new building to an 83' by 122' shape at a Northeast to Southwest orientation it provides all the classrooms a perimeter exposure; each classroom has at least one full wall facing the exterior.

Excluded Spaces:

Classroom toilets and classroom closets are currently excluded from the calculations.

Applicable SCA Design Requirements include:

- 1.3.1.1 Building Location and Orientation
- 1.3.1.2 Planning Guidelines for New Schools and Additions
- 5.7.1 Window Shades and Draperies

Applicable SCA Standard Specifications include:

08524 Aluminum Projected Windows

08800 Miscellaneous Glazing

08921 Aluminum Storefront

12501 Chain and Clutch Operated Window Shades

The project team has incorporated the above SCA Standard Specifications into the construction documents dated 9July2018.

The following Views Form below includes a breakdown of the area for each space with compliant views to the exterior resulting in **87.6%** (with glass block in cafeteria) views which does not meet the 90% requirement and thus **not** earn this credit.





Typical view section at 1st Fl Exercise Room

LEED Interpretation 10254, made on 10/1/2012, allows sloped view lines starting at 42 inches in IEQc8.2 (GSG Q7.4) and specifically states that the view line is not required to be horizontal: "To determine direct lines of sight in section, provide one or more representative sight lines from a point at eye height (42 inches) in the regularly occupied space to perimeter vision glazing between 30 inches and 90 inches above the finished floor of the building. The direct line of sight may be slope from 42 inches at the seated area to any unobstructed area of the vision glazing. The direct line of sight is not required to be horizontal at 42 inches only.

DAYLIGH	T & VIEWS			—————————————————————————————————————			
Views Ca	Iculation Form			ŚCA	School	Constructio	n Authority
Credit Q7	.4				NYC Green	Schools Rating S	ystem
Project:	P.S. 347X Bronx Annex at PS33X				Architect	Mitchell Giurgo	la Architects
Address:	2424 Jerome Ave, Bronx, NY, 10468				Preparer	EME Group	
LLVV #:	107340				Date	0/0/10	
Design #.				<u> </u>			
			Step 1: Horiz	zontal View at:			
		Total	•		Step 2: Calo	culated Area of	
RM #	RM NAME	Occupiable	36" for rooms used by	42" for rooms used by	Room that	Compliant	
		Area in SF	for PK-thru 5 grades	offices	Direct Lin Perimeter	le of Signt to	Area (sr)
				Unices	Fermeter	vision Glazing	
			Y/N/NA	Y/N/NA			
1ST FLO	DR						
101	Cafeteria	1896	Y	NA		1,896	0
101a	Servery	276	NA	Y		276	0
1015	Warming Kit	658	N	N		658	0
1010	Exercise Room	1217	N V	N NA		62	1 217
102	Parents Room	200	NA I	NA V		33	1,217
103	Supervisory Office	164	NA	Y Y		1	163
111	Medical Suite	194	NA	Ŷ		110	84
		4,676					1640
2ND FLO	OR						
210	Pre-K	909	Y	NA		1	908
208	Pre-K	927	Ŷ	NA		2	925
206	Pre-K	898	Y Y	NA		2	896
204	Pre-K Kindergerten	945	Ý V	NA		0	945
209	Reading/Speech	914	r v	NA NA		0	914
203	Kindergarten	902	r v	NA NA		0	902
201	rindolgarton	5,899	•	112			5894
		.,					
3RD FLO	OR						
310	Kindergarten	909	Y	NA		2	908
308	Kindergarten	919	Y	NA		2	917
306	Kindergarten	898	Y	NA		2	897
304	Kindergarten	937	Y Y	NA		0	937
307	Kindergarten	902	Ý V	NA		0	902
305	Supervisory Office	177	T NA	NA V	-	0	177
505	Supervisory Onice	5 633	116	1		.	5628
		0,000					0020
4TH FLO	DR						
412	Grade 1	765	Y	NA		6	760
410	Grade 1	726	Y	NA		9	717
408	Grade 1	755	Y	NA		5	750
406	Grade 1	719	Y	NA		7	712
404	Grade 1	779	Ŷ	NA		0	779
407	Grade 1	806	Y Y	NA		0	806
403	Grade 1	824 5 374	Y	NA		3	821 5345
		5,574					5545
5TH FLO	DR						
508	Grade 2	716	Y	NA		4	712
506	Grade 2	719	Y	NA		9	711
504	Grade 2	779	Y	NA		0	779
507	Grade 2	777	Y	NA		0	777
505	CSD Special Education	618	Y	NA		0	618
503	Library	860	Y N	NA		0	860
514	Custodian Office	152	NA	N		0	
		4,621					4457
SF OF		. 26 203			SF OF ARE		22 063
5, 5,		20,200			Percent	Access to Views	87.6%
Requiren	nent to achieve credit Q 7.4 is Views fo	r 90% of regular	ly occupied spaces		Co	omplies? (Y / N):	N





Plan of 2nd Fl Dated 19Feb2018.



Plan of 3rd Fl Dated 19Feb2018.



Plan of 4th Fl Dated 19Feb2018.


Plan of 5th Fl Dated 19Feb2018.

<u>Q7.5R</u> Visual Performance, Direct-Indirect Lighting Credit anticipated.

In all classrooms and instruction spaces there will be direct/indirect, ceiling pendant LED lamps with a minimum color-rendering index of 82. For typical classrooms measuring 29' by 26', lighting will consist of two rows of direct/indirect ceiling pendant fixtures spaced approximately 12' on center to produce optimum lighting. The total luminary efficiency of the light fixtures will be 90% or better. For non-conventional shaped instructional spaces, the quantity of pendant fixtures, rows of pendant fixtures, and their spacing will vary as necessary to provide the required foot-candle levels and lighting power density.

Per the SCA Design Requirements, mounting shall be such that the bottom of the luminaires shall not be lower than 8'-0" in Early Childhood Centers and Primary Schools with the optimum fixture to ceiling distance ranging from 14" to 24". This requirement is copied directly from the latest available DR 7.2.1 Rev 10-09/30/16 from the SCA website.

Applicable SCA Design Requirements include: 7.2.1 Interior Lighting

Applicable SCA Standard Specifications include: 16502 LED Interior Building Lighting

The project team has incorporated the above SCA Standard Specifications into the construction documents dated 9July2018.

The lighting fixture schedule can be found on drawing E601.

The reflected ceiling plans can be found on A801 to A805 and the lighting plans can be found on E100 to E105.

The point-by-point lighting level (photometric) calculations and plans for typical and non-typical areas can be found in Appendix A.

Acoustics <u>Q8.1P</u> Minimum Acoustical Performance Credit anticipated.

Following SCA Acoustical Design Standards, the project will be designed to provide classrooms and learning spaces that limit background noise from building HVAC systems and adjacent spaces.

All classrooms will be designed to achieve a maximum background sound level of 40 dB(A). All classroom ceilings will incorporate sufficient areas of acoustical ceiling meeting a minimum NRC of 0.70 such that speech blurring reverberation will be controlled to meet SCA requirements. Classroom-to-classroom partitions shall have a STC of at least 50. Corridor-to-classroom partitions shall have a minimum STC of 45.

Where possible, rooftop air handlers should be located over or adjacent to corridors to eliminate the radiated noise of duct drops over classrooms. Air handler fans should be specified with airfoil or backward-inclined blades; fans with forward-curved blades should be avoided. Duct drops and associated ductwork over classrooms many need to be enclosed. The HVAC design shall limit air velocities in ducts to assure that duct turbulence noised does not exceed NYC SCA standards. Fire dampers should be a style that ordinarily has no vanes or blades in the airstream. Volume dampers shall be kept 10-feet or more upstream of air terminals. If possible, symmetrical, naturally balancing duct layout will be used to minimize the need for volume dampers.

Diffusers and return grilles shall have no integral dampers and be sized to limit velocity. As the project team continues to develop the mechanical design, the acoustical consultant will carry out detailed mechanical system analyses and recommend noise control features needed to meet background sound level criteria.

Applicable SCA Design Requirements include:

1.3.1.9 Architectural Acoustic Standards5.4.1 Suspended Ceilings

6.2.25 HVAC Acoustical Standards

Applicable SCA Standard Specifications include:

09510 Acoustical Ceilings 15853 Custom Packaged Rooftop Heating and Cooling Units (Variable Air Volume System) 15891 Metal Ductwork 15910 Duct Accessories 15930 Variable Air Terminals 15935 Single Zone Variable Air Volume (SZVAV) Air Handling Units for Public Assembly Spaces 15993 Balancing of Systems

The project team has incorporated the above SCA Design Requirements and Standard Specifications into the construction documents dated 9July2018.

Applicable SCA Standard Details include: 0926010a Partition Details

The project team has incorporated the above Standard Details into the construction documents on drawing A701.

The acoustical consultant, AKRF, preliminary suggestions include consider a free-standing stud (i.e., no bracing back to elevator shear wall) with a minimum 1/2-to-1-inch air gap separating the elevator shaft wall from the metal stud when adjacent to reading/speech resource and CSD special Education, 2'x4' ceiling tile should be specified with minimum acoustic ratings of NRC 0.90 and CAC 40 with 3-inch thick 2.5 pcf density mineral wool loose laid over the top of the ceiling tile in the cafeteria, and minimum 3-inch thick 2.5 pcf density mineral wool batt insulation above acoustic ceiling tile for classrooms below boiler room.

The acoustical 60% review, 100% review, and acoustical compliance memo are in Appendix A.

<u>Q8.2</u> Enhanced Acoustical Performance & Sound Isolation for Special Spaces Credit anticipated.

Spaces with special acoustical needs, in addition to classrooms, are limited to the exercise room and cafeteria, but special vertical sound isolating constructions is assumed not to be needed. The Acoustical design issues that will be addressed for all spaces include room acoustics, sound isolating constructions between spaces, HVAC noise control, and community noise. The Acoustic consultant (AKRF) advised that mass back-up walls will be needed to reduce the noise impact from the nearby elevated subway rail. SCA has directed that the project should utilize CMU backup wall construction.

<u>Emergency Generator</u>: The Architectural Scheme that was selected by the SCA has all floors with areas less than 15,000 sq. ft. and is not a high-rise structure. Therefore, an emergency generator is not required.

Applicable SCA Design Requirements include:

1.3.1.9 Architectural Acoustic Standards

4.2.1 Exterior Masonry Walls
4.3.1 Window Types
5.1.1 Typical Room Finishes
5.2.2 Interior Partitions
5.3.1 Floor Types
5.5.1 Interior Doors and Frames
6.2.25 HVAC Acoustical Standards

The project team has incorporated the above SCA Design Requirements into the construction documents within the "A" series drawings and "M" series drawings.

Applicable SCA Standard Specifications include: 08524 Aluminum Projected Windows 09260 Gypsum Board Assemblies

The project team has incorporated the above SCA Design Requirements and Standard Specifications into the construction documents dated 9July2018

Applicable SCA Standard Details include: 0926010a Partition Details 0926010b Partition Details

The project team has incorporated the above Standard Details into the construction documents on drawing A701.

See Q8.1R for the description of the location and construction of each special separation.

The acoustical 60%, 100% review, and acoustical compliance memo are in Appendix A.

Q8.3 Acoustic Windows Credit anticipated.

SCA has noted that acoustic review is required to confirm performance against the nearby elevated subway rail. Acoustical windows are assumed to be needed. Mitchell Giurgola's 7June2018 e-mail indicated special IGU (OITC 37) will be specified on the front façade to meet acoustic performance due to noise level from nearby elevated subway rail.

Applicable SCA Design Requirements include: 1.3.1.9 Architectural Acoustic Standards

Applicable SCA Standard Specifications include: 08524 Aluminum Projected Windows

The acoustical 60%, 100% review, and acoustical compliance memo are in Appendix A.

The basis-of-design Window Acoustical Laboratory Test Report is in Appendix A.

Additional Credits

Required Support A1.1R LEED® Accredited Professional Credit anticipated.

William Jose Higgins, EME Consulting Engineers Group - Green Consultant



<u>A1.2</u> Innovation or Exemplary Performance Upon SCA request only.

A1.3 Innovation or Exemplary Performance Upon SCA request only.

Optional - Site Impact

A2.1 Heat Island Effect, Non-Roof

Upon SCA request only.

A2.2 Stormwater Design, Quantity Control Upon SCA request only.

A2.3 Active Design in a School Environment Credit anticipated.

SCA GSG Committee, at 8January2014 meeting, requested all projects from this date forward to pursue active design as an innovation credit.

Current design meets 7 of the 10 active design features and complies with the minimum requirement of 7; see Active Design chart below.

Acti Acti Cre Proje Addr LLW Date	ve Design in a Sch ve Design Workshe dit A 2.3 wct: P. S. 347X Bronx A ess: 2424 Jerome Ave, : 107340 : 5Feb2018, Revised 5	ool Environment eet and Credit Rep nnex at PS33X Bronx, NY, 10468 June2018	porting FormSC	A School Construction Authority NYC Green Schools Rating System - 2016 Architect: Mitchell Giurgola Architects, LLP Preparer: EME Group Phone: 212-529-5969		
#	ITEM	INTENT	DESIGN CASE	DOCUMENTATION METHOD	PROJECT COMPLIES?	
	PREREQUISITE				(400 (400)	
R	Minimum Accessible Floors	Make active modes of vertical circulation accessible to all users	Building must have at least 1 main stair that enables occupants to travel between the building entrance floors and common use floors.	Floor Plans indicating main entrance and stairs.	YES	
	Include seven (7) c	or more of the follo	owing features within the project.			
1	Floor re-entry	Make active modes of vertical circulation accessible at all floors	Classify regularly occupied floors for re- entry, allowing all building users to have access to and from these floors. Service floors do not need access for all users.	Floor plans indicating stairs.	Yes	
2	Stair visibility at all floors	Visual connection to active modes of vertical circulation	Make accessible stair visible from corridor by providing: •vision panels of 10 SF at each door •side light of 10 SF. •providing open stair.	Floor plan, door schedule and door elevation	No	
3	Stair connectivity to building occupants	Stair accessibility for building occupants	Provide access to at least one (1) open or interconnecting stair to 50% of occupied floors	Floor Plans indicating stairs.	Yes	
4	Stair visibility from main lobby	Visual connection to main lobby	Position at least one active mode of vertical circulation to be visible from main building lobby with 25 feet maximum travel from edge of lobby to entry of active vertical circulation. No turns should be required to reach stairs from the lobby.	Floor plans indicating travel distance from main lobby to stair.	No	
5	Location - visibility	Visual connection to active mode of vertical circulation	Position at least one active mode of vertical circulation within the field of vision for users when standing in front of motorized modes of vertical circulation.	Plan drawing showing stair immediately adjacent to elevator	Yes	
6	Lighting	Make active vertical circulation areas a desirable space through enhanced lighting	Provide level of lighting in staircase consistent with or better than that provided for the building corridor.	Photometrics for stair and adjacent corridor.	Yes	
7	Daylighting	Make active vertical circulation areas a desirable space through natural lighting	Provide windows/skylight of at least 8 SF at each floor level of the active circulation space.	Building elevation indicating window area at each floor @ stair.	Yes	
8	Signage prompt at active vertical circulation	Encourage active modes of vertical circulation over motorized modes of vertical circulation	Include permanent signage promoting stair use at elevator call area and at outside of stair door at each floor of the active vertical circulation.	Floor plans indicating sign locations and signage detail.	Yes	
9	Artwork	Make active vertical circulation areas a desirable space through the addition of artwork	Provide artwork in the active circulation area.	Artwork location	No	
10	Recreational space	Provide opportunities for on- site recreation	For projects with 10 classrooms or more, provide an on-site recreational space with exercise opportunities for both staff and children. Exercise space must be at least 400 SF and include exercise equipment for use by at least 5% of FTE occupants. Gardening activity can count as staff active recreation space and equipment	Floor plan showing exercise room with equipment layout, FTE calculation, and narrative. Site plan indicating garden area (if applicable).	Yes	

Optional - Energy

A3.1 Enhanced Commissioning Upon SCA request only.

A3.2 Optimize Energy Performance 11 points anticipated.

SCA has indicated that a project specific energy model will be completed to demonstrate compliance.

Based on the 100% CD Energy Model Report dated 17 August 2018, there is an energy cost savings of 20.7%, earning 11 points under this credit.

See E4.1P for further information.

A3.3 On Site Renewable Energy_ Upon SCA request only.

A3.4 Enhanced Energy Management System Controls, HVAC and Hot Water Systems Upon SCA request only.

Optional - IEQ

A4.1 Low-Emitting Materials, Ceiling and Wall Systems Upon SCA request only.

Optional – Education

A5.1 The School Building as a Teaching Tool

Upon SCA request only.

APPENDIX A

Credit S1.1P: Soil Erosion and Sediment Control Plan





LEGEND

PROPERTY LINE

EXISTING BUILDING

PROPOSED BUILDING

PROPOSED CONCRETE SIDEWALK/PAVEMENT

PROPOSED FULL DEPTH ASPHALT PAVEMENT

PROPOSED ASPHALT RESURFACING

PROPOSED CONCRETE CURB/WALL AND IRON PICKET FENCE

PROPOSED CONCRETE CURB/WALL AND CHAIN LINK FENCE

BUILDING ENTRANCE

PROPOSED STREET TREE AND 5'X10' TREE PIT

PROPOSED AREA DRAIN

PROPOSED DRAIN BASIN

PROPOSED CLEANOUT

PROPOSED STORM/SANITARY MANHOLE

PROPOSED GRATED STORM MANHOLE

PROPOSED ELECTRIC MANHOLE

PROPOSED LIMIT OF WORK

TEMPORARY STRAW BALE DIKE

TEMPORARY DRAINAGE INLET PROTECTION





NOTES:

- 1. FOR CURB INLET CATCH BASINS, INLET SEDIMENT CONTROL DEVICE SHALL BE DANDY CURB BY DANDY PRODUCTS, OR APPROVED EQUAL.
- 2. FOR NON-CURB INLET CATCH BASINS, INLET SEDIMENT CONTROL DEVICE SHALL BE DANDY BAG BY DANDY PRODUCTS, OR APPROVED EQUAL.
- 3. INLET SEDIMENT CONTROL DEVICE SHALL BE MAINTAINED AS PER THE STANDARDS AND SPECIFICATIONS OF THE NYSDEC STANDARDS FOR EROSION AND SEDIMENT CONTROL (BLUE BOOK).
- 4. ONCE THE CONTRIBUTING DRAINAGE AREA HAS BEEN COMPLETELY STABILIZED (GREATER THAN 75% VEGETATIVE COVER) THE INLET SEDIMENT CONTROL DEVICE SHALL BE CLEANED OUT AND REMOVED FROM THE STRUCTURE.







CONSTRUCTION ENTRANCE



- AS NEEDED.
- BALES SHALL BE REMOVED WHEN THEY HAVE SERVED THEIR USEFULNESS SO AS NOT 6. TO BLOCK OR IMPEDE STORM FLOW OR DRAINAGE.

STRAW	BALE	DIKE
	N.T.S.	

TEMPORARY WOODEN TREE GUARD N.T.S.

14'

GREATER THAN

30.

BOUND BALES PLACED ON CONTOUR

2 RE-BARS, STEEL PICKETS OR 2"X2" STAKES PLACED 1 1/2' TO 2' IN GROUND. DRIVE STAKES FLUSH WITH TOP OF BALE.



Calculation Summary							
Label	CalcType	Units	Avg	Max	Min	Avg/Min	Max/Min
CalcPts_1	Illuminance	Fc	1.04	8.74	0.00	N.A.	N.A.

								,	/
.65	1.61	1.51	1.33	1.09	0.86	0.71	0.51	0.39	
2.01	2.01	97	1.70	1.35	9 .00	0.72	0.56	0.40	
.86	Z1 1.8	1.92	1.70	1.40	¶.01	0.66	0.52	0.37	
		0.35	0.99	0.87	0.64	0.58	0.43	0.33	
		0.59	0.69	0.73	0.75	0.56	0.43	0.33	
		0.91	9 .00	0.80	0.89	0.65	0.48	0.36	
		1.23	1.31	1.41	¶.01	0.74	0.54	0.39	
		1.53	1.61	1.67	1 .18	0.82	0.58	0.42	
		1.65	2.60	1.90	1.32	0.89	0.62	0.45	
		2.97	2.79	2.06	1 .40	0.94	0.65	0.47	
		3/29	Ê.87 (2.₽L	A Y GF	10 [.] 0	0.67	0.48	\prec
		3.11	2.71 2.71	2.00	¶.38	0.96	0.68	0.49	п
Vatts	[MA	NUFAC]					BUG F	Rating	
	PHII	LIPS LIGH	TOLIER				N.A. B0-U0	Gl	
	1 mil	an o orao					00-00	00	



		II							11
		1.43	2.56	1.94	1.36	0.95	0.67	0.48	
		1 .51	2.43	1.89	1.34	0.92	0.65	0 .47	
		1.64	1.72	1.79	¶.26	0.88	0.62	0.45	
нз		4.12	2.49	1.33	1 .15	0.80	0.58	0.42	
6.95	6.73	5.12	2.73	1.24	1 .02	0.72	0.53	0.39	
6.85	9 .62	4.97	2.58	1 .08	0.66	0.63	0 .47	0.35	
H3 8.24 ●	6.99	4.29	1 .98	0.86	0.54	0.41	0.41	0.32	
5.65	4.58	2.73	1.35	0.63	0.44	0.34	0.35	0.28	
2.56	1.97	1.31	0.70	0.46	0.37	0.28	0.23	0.24	<u> </u>
0.71	0.59	0.43	0.33	0.32	0.29	0.23	9 .19	0.15	
0.18	0 .16	0.18	0.20	•22	\$0.21	0.18	0 .15	•11	。 。
0.12	0.10	0.11	0.14	0.15	0.15	0.14	0.12	0 .10	
0.09	0.07	0.07	0.09	0.10	0.10	0.10	0.09	0.08	
0.06	0.05	0.05	0.05	0.06	0.07	0.07	0.07	0.07	
0.04	0.04	0.03	0.03	9 .04	0.05	0.05	0.05	0.05	
<u>p.</u> 03	0.03	0.02	0.02	0.03	0.03	0.03	0.04	0.04	
0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.03	0.03	
0.02	0.02	0.02	0.01	0.01	0.01	0.02	0.02	0.02	

Credit E1.1P: Specification Table of Contents modified for project 07/09/18 (100% CD)

LLW NO.: 107340

NEW YORK CITY SCHOOL CONSTRUCTION AUTHORITY SPECIFICATIONS for PS347X

TABLE OF CONTENTS 07/09/18

VOLUME I

DIVISION 1 - GENERAL & SUPPLEMENTARY REQUIREMENTS

GENERAL REQUIREMENTS

G01000	-	SPECIFICATIONS FORMAT
G01015	-	MISCELLANEOUS PROVISIONS
G01200	-	PROJECT MEETINGS
G01600	-	MATERIAL AND EQUIPMENT
G01700	-	PROJECT CLOSEOUT
G01720	-	RECORD DOCUMENTS
G01740	-	GUARANTEES, WARRANTIES, & BONDS

SUPPLEMENTARY REQUIREMENTS

S01010	-	SUMMARY OF WORK
S01060	-	PERMITS, FEES, AND CERTIFICATES OF OCCUPANCY
S01300	-	SUBMITTALS
S01311	-	PROGRESS SCHEDULE
S01352	-	SUSTAINABILITY REQUIREMENTS
S01400	-	QUALITY CONTROL
S01426	-	SAMPLE CLASSROOM
S01500	-	TEMPORARY FACILITIES AND CONTROLS
S01524	-	CONSTRUCTION WASTE MANAGEMENT
S01535	-	SAFETY PROGRAM
S01550	-	INDOOR AIR QUALITY (IAQ) REQUIREMENTS
S01560	-	INSTALLATION SEQUENCE OF FINISH MATERIALS
S01630	-	PRODUCT SUBSTITUTIONS
S01650	-	FACILITY START-UP, DEMONSTRATION, AND TRAINING
S01660	-	SUPPLEMENTAL COMMISSIONING REQUIREMENTS
S01730	-	SYSTEMS OPERATION AND MAINTENANCE MANUALS
S01900	-	EXISTING PREMISES WORK

DIVISION 2 - SITEWORK

02010 - ENVIRONMENTAL SITE ASSESSMENT REPORTS 02060 - BUILDING DEMOLITION 02070 - SELECTIVE REMOVALS & DEMOLITION 02081 - ASBESTOS ABATEMENT 02082 - PCB-CONTAINING CAULK REMOVAL WORK

NYCSCA PS347X

1

02085	_	FXTERIOR PAINT REMOVAL
02001	_	STODAGE HANDLING TRANSPORTATION AND DISPOSAL OF
02091		DEEDOLEUM CONTANTNATED AND/OD UN7ADDOUG MAGTES
		PEIROLEOM CONTAMINATED AND/OR HAZARDOOS WASTES
02100	-	SITE PREPARATION
02200	-	EARTHWORK
02220	-	GAS VAPOR BARRIER FLUID APPLIED
02221	-	SUB-SLAB DEPRESSURIZATION SYSTEM
02511	-	ASPHALTIC CONCRETE PAVING
02513	-	SIDEWALK AND STREET PAVING
02521	-	CONCRETE CURBS AND PAVEMENTS
02531	-	RESILIENT SURFACING
02533	-	COLORED ATHLETIC WEARING SURFACE
02580	-	PLAYGROUND MARKINGS
02722	-	PRECAST CONCRETE MANHOLES
02723	-	STORM DRAINAGE SYSTEMS
02831	-	CHAIN LINK FENCES AND GATES
02860	-	EARLY CHILDHOOD PLAYGROUND EQUIPMENT
02862	-	OUTDOOR GAME EQUIPMENT
02870	-	SITE AND STREET FURNISHINGS

DIVISION 3 - CONCRETE

03100 - CONCRETE FORMWORK 03200 - CONCRETE REINFORCEMENT 03300 - CAST-IN-PLACE CONCRETE

DIVISION 4 - MASONRY

04200 - UNIT MASONRY 04270 - GLASS UNIT MASONRY 04420 - EXTERIOR CUT STONE 04435 - CAST STONE

DIVISION 5 - METALS

05120 - STRUCTURAL STEEL 05170 - SUPPORT SYSTEM FOR SUSPENDED CEILINGS 05500 - METAL FABRICATIONS 05700 - ORNAMENTAL METAL

DIVISION 6 - WOOD AND PLASTICS

06100 - ROUGH CARPENTRY 06200 - FINISH CARPENTRY 06410 - CUSTOM CASEWORK

NYCSCA	PS347X

2

DIVISION 7 - THERMAL AND MOISTURE PROTECTION

- 07115 SHEET MEMBRANE WATERPROOFING FOR FOUNDATIONS
- 07147 CRYSTALLINE WATERPROOFING
- 07211 PERIMETER FOUNDATION INSULATION
- 07212 MISCELLANEOUS BUILDING INSULATION
- 07270 FIRESTOPPING/SMOKE SEALS
- 07272 FLUID-APPLIED MEMBRANE AIR BARRIER, VAPOR RETARDING
- 07461 FIBER CEMENT RAINSCREEN CLADDING SYSTEM
- 07560 FLUID-APPLIED PROTECTED MEMBRANE ROOFING
- 07600 FLASHING AND SHEET METAL
- 07720 ROOF ACCESSORIES
- 07900 JOINT SEALERS

DIVISION 8 - DOORS AND WINDOWS

08110 - STEEL DOORS AND FRAMES 08210 - WOOD DOORS 08305 - ACCESS DOORS 08330 - COILING DOORS, GRILLES AND SHUTTERS 08524 - ALUMINUM PROJECTED WINDOWS 08710 - FINISH HARDWARE 08730 - THRESHOLDS, WEATHERSTRIPPING AND SEALS 08800 - MISCELLANEOUS GLAZING 08921 - ALUMINUM STOREFRONT

DIVISION 9 - FINISHES

09205	-	FURRING AND LATHING
09210	-	PLASTER
09260	-	GYPSUM BOARD ASSEMBLIES
09310	-	CERAMIC TILE
09410	-	PRECAST TERRAZZO
09510	-	ACOUSTICAL CEILINGS
09626	-	RESILIENT ATHLETIC FLOORING
09650	-	RESILIENT FLOORING
09675	-	FLUID-APPLIED EQUIPMENT ROOM FLOORING
09860	-	GRAFFITI RESISTANT COATINGS
09900	-	PAINTING

DIVISION 10 - SPECIALTIES

10100 - VISUAL DISPLAY BOARDS 10151 - TOILET COMPARTMENTS 10185 - PLASTIC SHOWER AND DRESSING COMPARTMENTS 10214 - STATIONARY METAL WALL LOUVERS 10350 - FLAGPOLE

NYCSCA PS347X

3

07/09/18 (100% CD)

LLW NO.: 107340

10400 - IDENTIFYING DEVICES 10415 - BULLETIN BOARDS, GLAZED DISPLAY BOARDS, DISPLAY CABINETS AND CASES 10505 - METAL LOCKERS 10522 - FIRE EXTINGUISHERS AND CABINETS 10675 - METAL STORAGE SHELVING 10810 - TOILET AND BATH ACCESSORIES 10830 - MIRRORS

10840 - GRAB BARS

DIVISION 11 - EQUIPMENT

11172 - WASTE HANDLING EQUIPMENT 11400 - FOOD SERVICE EQUIPMENT 11481 - EXERCISE ROOM PADDING

DIVISION 12 - FURNISHINGS

12485 - FOOT GRILLES 12501 - CHAIN AND CLUTCH OPERATED WINDOW SHADES

DIVISION 13 - SPECIAL CONSTRUCTION

NOT USED

DIVISION 14 - CONVEYING SYSTEMS

14211 - GEARED TRACTION PASSENGER ELEVATORS

VOLUME II

DIVISION 15 - MECHANICAL

FIRE PROTECTION

15301 - GENERAL PROVISIONS FOR FIRE PROTECTION SYSTEMS WORK 15332 - COMBINATION WET STANDPIPE/SPRINKLER SYSTEM 15333 - SPRINKLER BOOSTER PUMPS

PLUMBING AND DRAINAGE

15401 - GENERAL PROVISIONS FOR PLUMBING AND DRAINAGE WORK 15410 - PLUMBING PIPING

NYCSCA PS347X

4

15411 - HANGERS AND SUPPORTS 15412 - VALVES 15413 - INSULATION (P&D) 15414 - TESTS 15415 - DRAINAGE 15416 - GAS PIPING SYSTEM 15417 - COLD WATER SUPPLY 15418 - HOT WATER SUPPLY 15431 - TAGS, CHARTS AND IDENTIFICATION 15432 - MISCELLANEOUS 15440 - PLUMBING FIXTURES 15451 - WATER HEATERS 15453 - PUMPING APPARATUS AND TANKS

HEATING, VENTILATING AND AIR CONDITIONING

15501	-	GENERAL PROVISIONS FOR HEATING, VENTILATING AND AIR
		CONDITIONING WORK
15502	-	HVAC IDENTIFICATION
15504	-	VIBRATION ISOLATION
15510	-	HVAC PIPING
15511	-	VALVES (HVAC)
15512	-	PIPING INSULATION (HVAC)
15513	-	EQUIPMENT INSULATION (HVAC)
15514	-	DUCTWORK INSULATION
15515	-	HYDRONIC SPECIALTIES
15517	-	WATER TREATMENT FOR HYDRONIC SYSTEMS
15540	-	HVAC PUMPS
15565	-	HOT WATER CONDENSING BOILERS
15575	-	BREECHING, CHIMNEY AND STACKS
15596	-	NATURAL GAS LEAK DETECTION EQUIPMENT
15660	-	PACKAGED MODULAR OUTDOOR CHILLERS
15670	-	PLATE HEAT EXCHANGERS
15783	-	SPLIT HEAT PUMP SYSTEM
15792	-	COILS
15835	-	CONVECTORS
15836	-	UNIT HEATERS/CABINET HEATERS
15839	-	DOOR AIR CURTAINS
15853	-	CUSTOM PACKAGED ROOFTOP HEATING AND COOLING UNITS
		(VARIABLE AIR VOLUME SYSTEM)
15860	-	CENTRIFUGAL FANS
15880	-	SUB-SLAB DEPRESSURIZATION SYSTEM ACCESSORIES
15891	-	METAL DUCTWORK
15910	-	DUCT ACCESSORIES
15915	-	DAMPER ASSEMBLIES
15930	-	VARIABLE AIR TERMINALS
15935	-	SINGLE ZONE VARIABLE AIR VOLUME (SZVAV) AIR HANDLING
		UNITS FOR PUBLIC ASSEMBLY SPACES
15940	-	AIR OUTLETS AND INLETS

NYCSCA PS347X

5

07/09/18 (100% CD)

LLW NO.: 107340

- 15970 TEMPERATURE CONTROL SYSTEM (LONWORKS BMS/DDC WITH SCHOOL OPERATING CONSOLE)
- 15973 FACILITY MANAGEMENT SYSTEMS INTEGRATION
- 15980 THERMOMETERS AND GAUGES
- 15985 SEQUENCE OF OPERATIONS
- 15992 CLEANING AND TESTING
- 15993 BALANCING OF SYSTEMS

DIVISION 16 - ELECTRICAL

16010	-	GENERAL PROVISIONS FOR ELECTRICAL WORK
16120	-	WIRING SYSTEMS
16130	-	RACEWAYS, FITTINGS, SUPPORTING DEVICES, BOXES AND
		ACCESSORIES
16140	-	WIRING DEVICES
16145	-	LIGHTING CONTROL DEVICES
16289	-	SURGE SUPPRESSION DEVICES
16420	-	SERVICE ENTRANCE EQUIPMENT
16425	-	SWITCHBOARDS
16441	-	ENCLOSED SWITCHES
16450	-	GROUNDING AND BONDING
16470	-	PANELBOARDS
16475	-	OVERCURRENT PROTECTIVE DEVICES, CIRCUIT BREAKERS AND
		FUSES
16480	-	MOTORS, STARTERS AND CONTROL EQUIPMENT
16502	-	LED INTERIOR BUILDING LIGHTING
16520	-	ILLUMINATED EXIT SIGN AND EMERGENCY LIGHTING FIXTURES
16530	-	LED SITE/SECURITY LIGHTING
16670	-	LIGHTNING PROTECTION
16701	-	AUXILIARY SIGNAL SYSTEMS
16720	-	FIRE DETECTION AND ALARM SYSTEM WITH CENTRAL OFFICE
		CONNECTION
16724	-	INTRUSION ALARM SYSTEM
16725	-	TELEPHONE CABLING SYSTEM
16726	-	INTERCOM SYSTEM FOR FIRE RESCUE AREAS AND EMERGENCY
		TELEPHONE FOR ELEVATORS
16727	-	DATA CABLING SYSTEM
16728	-	FIBER OPTIC CABLING SYSTEM
16770	-	SOUND, INTERCOM AND TEACHER ACTIVATED SECURITY SYSTEM
16771	-	PROJECTION AND INTERACTIVE WHITEBOARD SYSTEMS
16775	-	AUDIO FREQUENCY INDUCTION LOOP SYSTEM (AFILS)
16785	-	INTERNET PROTOCOL DIGITAL VIDEO SURVEILLANCE SYSTEM
		(IPDVS) SYSTEM USING DIGITAL CAMERAS (CAPACITY PROJECTS)
16791	-	SELF-CORRECTIVE CLOCK SYSTEM

END OF TABLE OF CONTENTS

6

Credit E4.1 & A3.2: Assessment of Energy Performance for Compliance with NYC SCA Green School Guide (100% Energy Model Report)



NYC Public School PS347X Annex at PS33X

2400 Jerome Avenue

Bronx, NY 10468

Assessment of Energy Performance for Compliance with NYC SCA Green School Guide

August 17, 2018

Project Narrative

EME Consulting Engineering Group (EME Group) analyzed the energy performance of the New York City building for PS-33X. The Proposed Design is a five story (with an additional partial cellar square), 46,390 sq. ft. building. The building includes classrooms, offices and support spaces. The energy model is based on the 100% CD drawing set.

EME Group performed energy modeling for compliance with the NYC SCA Green School Guide System. NYC SCA GSG allows compliance using the Appendix G Method of ASHRAE/IESNA Standard 90.1-2010 (ASHRAE 90.1-10). In addition, EME Group analyzed the performance of the Proposed Design with respect to New York City Local Law 86 (LL86). LL86 mandates 20% regulated energy cost savings¹ for projects with more than \$12 Million construction cost. Compliance with LL86 is demonstrated against the Energy Cost Budget Method of ASHRAE/IESNA Standard 90.1-2013 (ASHRAE 90.1-13).

The results are summarized in Table 1 below. The project achieves **20.7%** savings in energy costs compared to the GSG baseline. The project complies with the minimum requirements of E4.1P – Minimum Energy Performance (E4.1P).

In addition, the project achieves **22.4%** savings in regulated energy costs compared with the LL86 Baseline. The project complies with the LL86 requirements.

The energy model was developed for the sole purpose of documenting compliance with the SCA GSG E4.1R requirements and should not be used for predicting the actual energy use of the building. Actual energy use and cost will be greater, since the modeling rules do not account for many real-life issues, such as quality of construction, equipment functionality, building operation and other factors. Please refer to the end of the report for details.

¹ Note: Regulated energy excludes the energy consumed by equipment that is typically plugged into receptacles: computers, printers, copiers, TVs, radios, electric clocks, etc. It also excludes energy used by elevators and escalators, cooking equipment and process equipment (such as industrial or laboratory equipment).

New York City Public School PS 33X Energy Model Report

Table 1	Energy Modeling Results for Proposed Design; GSG Baseline and Energy Efficiency
	Measures (EEMs)

Description	Annual Energy Cost (\$)	Energy Cost Savings (\$)	% Energy Cost Savings	NYC SCA GSG Compliance
SCA GSG Baseline ASHRAE 90.1-2010 Appendix G	\$82,028	-	-	-
Proposed Design	\$65,011	\$17,017	20.7%	Yes

Description	Electric Use (kWh)	Peak kW	Electric Cost (\$)	Gas Use (Therms)	Gas Cost (\$)
SCA GSG Baseline ASHRAE 90.1-2010 Appendix G	389,249	173	\$73,971	6,987	\$8,057
Proposed Design	283,806	144	\$58,464	5,636	\$6,547

Table 2Energy Modeling Results for Proposed Design; LL86 Baseline and Energy Efficiency
Measures (EEMs)

Description	Annual Energy Cost (\$)	Annual Regulated Energy Costs (\$)	Regulated Energy Cost Savings (\$)	% Regulated Energy Cost Savings	LL86 Compliance
NYC LL86 Baseline ASHRAE 90.1-2013 ECB	\$79,333	\$62,523	-	-	-
Proposed Design	\$65,011	\$48,543	\$13,980	22.4%	Yes

	LL86 Baseline	Proposed Design
Total Annual Electric Use (kWh)	336,059	283,806
Total Annual Electric Cost	\$70,764	\$58,464
Regulated Annual Electric Use (kWh)	258,648	206,395
Regulated Annual Electric Cost	\$54,471	\$42,517
Peak Total Demand (kW)	181	144
Peak Regulated Demand (kW)	161	123
Sum of Regulated Monthly Peak Demands (kW)	1,177	924
Total Gas Use (Therms)	7,446	5,636
Total Gas Cost	\$8,569	\$6,547
Regulated Gas Use (Therms)	6,997	5,187
Regulated Gas Cost (\$)	\$8,052	\$6,026

Details for Energy Simulation

EME Group used the computer software EQUEST to model the building design and evaluate energy efficiency measures. EQUEST is a computer program for detailed energy use analysis of residential and commercial buildings. It was developed James J. Hirsch, in collaboration with the U.S. Department of Energy and other research groups. EQUEST calculates the hour-by-hour energy use of a building based on information on the building's location, construction, HVAC systems, central plant, occupancy, and operation.

The project is located in Staten Island, NY, which is in ASHRAE Climate Zone 4A per ASHRAE 90.1 Table B-1. The design conditions per ASHRAE 90.1 Table D-1 are wet bulb temperature of 73°F, dry bulb temperature of 89°F, HDD65 of 4,910 and CDD50 of 3,547. The analysis was based on climatic data for John F. Kennedy Airport in New York City, using a TMY3 bin weather file. The envelope of the SCA GSG Baseline is modeled to meet the requirements prescribed in Table 5.5-4 of ASHRAE 90.1-2010.

The utility rates used for the SCA Baseline and Proposed Design are based on LL86 energy rates for FY 2012 published by Mayor's Office of Environmental Coordination (MOEC). The electricity rate for NYPA Electric Public Schools consists of a demand charge of \$30.64/kW and energy charge of \$0.091/kWh. The natural gas rate for Con Edison gas, Firm-heating is \$1.1117/therm.

B Building Energy Efficiency Measures included in Current Design

1. Reduced Interior Lighting Power

The Proposed Design interior lighting consists of LED fixtures. Based upon a count of the designed lights we have calculated that the current interior lighting design is 44% better than ASHRAE 90.1-2010 and 40% better than ASHRAE 90.1-2013 Table 9.6.1, using the space-by-space method.

2. Variable Frequency Drives (Pumps & Fans)

All hot water / chilled water pumps and fans are scheduled to be equipped with Variable Frequency Drives controls. VFD controls enable the motor's rotational speed to follow the flow rates. In this way the motor's power consumption will be less than standard damper configurations at partial load.

3. Condensing Boilers

Gas-fired condensing boilers are part of the Proposed Design allowing for significant energy savings relative to conventional boiler versions. The condensing boilers have 88% heating efficiency when operating in condensing mode.

4. High Performance Envelope

The proposed design includes exterior envelope and fenestration components that have thermal insulation superior to the baseline design.

5. High Performance Split Heat Pumps

The proposed design includes high efficiency split heat pumps.

- Heating Efficiency: 10.8 HSPF
- Cooling Efficiency: 14 SEER

6. High Efficiency Energy Recovery

The proposed design includes energy recovery on four of the air handling units with 75% recovery effectiveness.

7. High Efficiency Domestic Hot Water Boiler

The proposed design includes a high efficiency domestic hot water boiler with efficiency of 85%.

C Fan power in the Baseline Model

We took credit for fully ducted return and exhaust air systems, return and exhaust airflow control devices, MERV 13 filters on the supply, heat recovery, sound attenuation, and VAV boxes.

	Proposed Design	SCA GSG Baseline ASHRAE 90.1-2010 App. G	LL86 Baseline ASHRAE 90.1-2013 ECBM
Climate	Bronx, NY- ASHRAE Climate Zone 4A	ASHRAE Climate Zone 4A	ASHRAE Climate Zone 4A
Exterior Wall Construction	Masonry Wall (1 st Floor) 4" Face Brick 1 3/8" Air Space 3" Rigid insulation (R-15) Continuous Air/Vapor Barrier 8" CMU Interior Finish Partition U-factor _{unit} =0.06 BTU/Hr-ft ² -°F Fiber Cement Cladding (Floors 2-5) Fiber Cement Rainscreen Cladding 1 1/2" Air Space Aluminum Cladding 4" Rigid insulation (R-16) Continuous Air/Vapor Barrier 6" CMU Interior Finish Partition U-factor _{unit} =0.06 BTU/Hr-ft ² -°F	 Steel Framed Walls U-factor = 0.064 Btu/(h-ft²-F) 	Mass Walls • U-factor = 0.104 Btu/(h-ft ² -F)
Vertical Fenestration	 Vision Glass Area: 20.6% of Total Wall Area Type: Aluminum Window Assembly U-factor_{unit} = 0.45 Btu/h-ft²-F Solar Heat Gain Coefficient = 0.38 Shading Coefficient = 0.45 Visible Transmittance = 0.68 *Window U-value reported in LV-D account for both frame and glass. 	 Vision Glass Area: 20.6% of Total Wall Area Type: Metal Framing- All Other U-factor_{unit} =0.55 Solar Heat Gain Coefficient= 0.4 Shading Coefficient = 0.46 Visible Transmittance = 0.44 Type: Entrance Doors with >50% glazed area U-factor_{unit} = 0.85 Btu/h-ft²-F Solar Heat Gain Coefficient = 0.39 Visible Transmittance = 0.44 	 Vision Glass Area: 20.6% of Total Wall Area Type: Metal Framing, Fixed: U-factor_{unit} =0.42 Solar Heat Gain Coefficient= 0.4 Shading Coefficient = 0.46 Type: Metal Framing, Operable: U-factor_{unit} =0.50 Solar Heat Gain Coefficient= 0.4 Shading Coefficient = 0.46 Visible Transmittance = 0.44 *Weighted U-value average of windows used: 0.43

D Side-by-Side Comparison between Proposed Design, SCA GSG Baseline, and LL86

	Proposed Design	SCA GSG Baseline ASHRAE 90.1-2010 App. G	LL86 Baseline ASHRAE 90.1-2013 ECBM
	 Type: Entrance Doors with >50% glazed area U-factor_{unit} = 0.77 Btu/h-ft²-F Solar Heat Gain Coefficient = 0.39 Visible Transmittance = 0.68 Type: Glass Block* U-factor_{unit} = 0.51 Btu/h-ft²-F Solar Heat Gain Coefficient = 0.39 Visible Transmittance = 0.68 *Glass Block makes up less than 5% of total exterior wall area. 		 Type: Entrance Doors with >50% glazed area U-factor_{unit} = 0.77 Btu/h-ft²-F Solar Heat Gain Coefficient = 0.39 Visible Transmittance = 0.44
Below-Grade Wall Construction	 Below-Grade Walls 1'2" Cast-in Place Concrete 2" continuous rigid insulation C-factor_{unit} = 0.111 Btu/h-ft²-F 	 Below-Grade Walls C-factor = 1.140 Btu/(h-ft²-F) 	Below-Grade Walls • C-factor = 0.119 Btu/(h-ft ² -F)
Roof Construction	 Roof Insulation entirely above deck, R- 30.0 c.i 6" Insulation 6" Concrete Slab U-0.032 BTU/Hr-ft2-°F 	 Typical Roof Construction 2" Stone paver R-20 Continuous Insulation 10" Roof slab U-factor = 0.048 Btu/(h-ft²-F) 	 Typical Roof Construction 2" Stone paver R-30 Continuous Insulation 10" Roof slab U-factor = 0.032 Btu/(h-ft²-F)
Opaque Doors	Swinging Door • U-factor = 0.5 Btu/(h-ft ² -F)	Swinging Door • U-factor = 0.7 Btu/(h-ft ² -F)	Swinging Door • U-factor = 0.5 Btu/(h-ft ² -F)

	Proposed Design	A	SCA GS SHRAE 90	G Baseline .1-2010 App.	G	LL86 Baseline ASHRAE 90.1-2013 ECBM						
		Area	De	sign	GSG B	aseline	LL86	Baseline				
	Space Type	ft2	LPD [W/ft2]	Model LPD (with OS Credit)	LPD [W/ft2]	Model LPD (with OS Credit)	LPD [W/ft2]	Model LPD (with OS Credi				
	Electrical/Mechanical Room	4,342	0.49	0.49	0.53	0.53	0.42	0.42				
	Stairwell	4,227	0.28	0.23	0.69	0.69	0.69	0.62				
	Corridor/All Other	6,438	0.50	0.49	0.66	0.66	0.66	0.66				
	Gymnasium/Fitness Center/Playing Area	1,284	0.31	0.31	1.20	1.20	1.20	1.20				
	Restroom/ All Other	2,395	0.63	0.57	0.98	0.88	0.98	0.88				
Interior I ishting	Conference/Meeting/Multipurpose Room	218	1.27	1.14	1.23	1.11	1.23	1.11				
Interior Lighting	Classroom/Lecture Hall/Training Room	22,176	0.65	0.59	1.24	1.12	1.24	1.12				
	Office/Enclosed ≤250 sqft	400	1.14	1.14	1.11	1.00	1.11	1.00				
	Office/Enclosed \leq 250 sqft with windows	243	0.86	0.86	1.11	1.00	1.11	1.11				
	Storage Room/≥50 sqft and ≤1000 sqft	1,056	0.70	0.70	0.63	0.57	0.63	0.57				
	Dining Area/All Other	2,882	0.55	0.51	1.31	1.31	0.65	0.65				
	Storage Room/<50 sqft	49	0.99	0.99	0.63	0.63	1.24	1.12				
	Locker Room	165	0.26	0.23	0.75	0.68	0.75	0.68				
	Food Preperation Area	541	0.87	0.78	0.99	0.99	1.21	1.21				
	Library/Reading Area	1,370	0.60	0.54	1.06	1.06	1.06	1.06				
	Overall	47,786	0.58	0.53	1.01	0.95	0.97	0.89				

	Proposed Desi	Design SCA GS ASHRAE 90			G Baseline).1-2010 App. G			A	LL86 Baseline ASHRAE 90.1-2013 ECBM				
			De	sign			GSG Bas	eline			LL86 Ba	aseline	
	Space Type	Total Wattage	OS Wattage	DS	Modeled Wattage	Total Wattage	OS Wattage	DS	Modeled Wattage	Total Wattage	OS Wattage	DS	Modeled Wattage
	Electrical/Mechanical Room	2,112			2,112	2,301			2,301	1,823			1,823
	Stairwell	1,184	1,184		972	2,917	2,917		2,917	2,917	2,917		2,625
	Corridor/All Other	3,219			3,134	4,249			4,249	4,249			4,249
	Gymnasium/Fitness Center/Playing Area	398		Yes	400	1,540		Yes	1,540	1,540		Yes	1,540
	Restroom/ All Other	1,509	1,509		1,366	2,347	2,347		2,113	2,347	2,347		2,113
	Conference/Meeting/Multip urpose Room	276	276	Yes	248	268	268	Yes	241	268	268	Yes	241
	Classroom/Lecture Hall/Training Room	14,415	14,415	Yes	13,119	27,499	27,499	Yes	24,749	27,499	27,499	Yes	24,749
	Office/Enclosed ≤250 sqft	455	455		455	444	444		400	444	444		400
Interior Lighting Controls	Office/Enclosed ≤250 sqft with windows	210	210	Yes	210	270	270	Yes	243	270	270	Yes	270
Controls	Storage Room/≥50 sqft and ≤1000 sqft	739			737	665			599	665			599
	Dining Area/All Other	1,585			1,473	3,776			3,776	1,873			1,873
	Storage Room/<50 sqft	48			48	31			31	60			54
	Locker Room	43	43		39	124	124		111	124	124		111
	Food Preperation Area	471			422	536			536	655			655
	Library/Reading Area	822	822	Yes	738	1,452	1,452	Yes	1,452	1,452	1,452	Yes	1,452

	Proposed Design		SCA GSG Baseline ASHRAE 90.1-2010 App. G	LL86 Baseline ASHRAE 90.1-2013 ECBM						
Mandatory Lighting Controls	Vacancy sensors (manual on/automatic off) in offices, locker rooms, restrooms, classrooms.		Vacancy sensors (manual on/automatic off) in offices, locker rooms, restrooms, classrooms.		Vacancy sensors (manual on/automatic off) in offices, locker rooms, restrooms, classrooms.		Vacancy sensors (manual on/automatic off) in offices, locker rooms, restrooms, classrooms.		Vacancy sensors (manual on/automatic off) in all rooms are required per Section 9.4.1.2b ASHRAE 90.1-2010.	Vacancy sensors (manual on/automatic off) in all rooms are required per Section 9.4.1.1b,c ASHRAE 90.1 2013.
Daylight Dimming	Daylight dimming locate with windows	ed in all spaces	Daylight dimming controls as required by Section 9.4.1.5.	Daylight dimming controls as required by Section 9.4.1.1e						
Exterior Lighting	747 Watt exterior lightin	ng power	2,408 Watt exterior lighting allowance	2,408 Watt exterior lighting allowance						
Elevators	(2) elevators		(2) elevators	(2) elevators						
	Space Type	Equip. Power Density	Same as proposed design	Same as proposed design						
	Gymnasium	0.25 W/ft ²								
	Conference	1.25 W/ft ²								
	Classroom	0.25 W/ft ²								
	Office	1.25 W/ft ²								
	Dining	0.25 W/ft^2								
Equipmont Dowor	Kitchen	3.0 W/ft ²								
Equipment I ower	Library	0.5 W/ft ²								
	MDF/IDF	7.5 W/ft ²								
	Other Spaces	0 W/ft ²								

	Proposed Design	SCA GSG Baseline ASHRAE 90.1-2010 App. G	LL86 Baseline ASHRAE 90.1-2013 ECBM
HVAC System Description	 (2) Variable volume air handling units (AHU) supply ventilation, heating and cooling to classrooms, offices and corridors. (1) AHU unit serves the kitchen and cafeteria. Heating and cooling to these units is provided by 2 central boilers and a chiller. Classrooms, Offices, other non- assembly areas and corridor VAV boxes shall be provided with supply air from Variable Air Volume (VAV) central recirculating air handling units. The VAV air handling units provide tempered heating ventilation air (normally discharge air at 65 F°) and provide all of the space cooling capacity. The fin tube radiation units located in classrooms, offices, and other non-assembly areas provide the balance of the space heating capacity in order to heat ventilation air from 65 F° to space temperature set point of 72 F°. Kitchen/ Cafeteria Air Handling Unit provide all of the space cooling capacity. The fin tube radiation units located in classrooms, offices, and other non-assembly areas provide the balance of the space heating capacity in order to heat ventilation air from 65 F° to space temperature set point of 72 F°. Kitchen/ Cafeteria Air Handling Unit provides tempered heating ventilation air (normally discharge air at 65 F°) and provide all of the space cooling capacity. The fin tube radiation units located in each cafeteria area and reheat coil in kitchen area shall provide the balance of the space heating capacity in order to heat ventilation air from 65 F° to space temperature set point of 72 F°. 	Main systems are System #7: Rooftop Variable Air Volume (VAV), with those zones that fall under the exceptions to G3.1.1 modeled as PSZ-AC systems (System #3) per Tables G3.1.1A and B. Zones which are heated only are served by System 9 and System 10- Heating and Ventilation.	Main system is a System #4 – Packaged VAV with reheat provided by a central boiler. Zones served by the HW and electric unit heaters in the proposed case modeled as individual System #11 (Packaged Rooftop air conditioner with Fossil Fuel Furnace) and System #9 (packaged Rooftop Heat Pump) respectively.
	operating nighttime set-back mode (unoccupied mode) to maintain space		

New York City Public School PS 33X Energy Model Report

Proposed Design	SCA GSG Baseline ASHRAE 90.1-2010 App. G	LL86 Baseline ASHRAE 90.1-2013 ECBM
temperature at 55 F° (adj).		
Hot water unit heaters and water cabinet unit heaters serve minimally heated spaces such as the large mechanical rooms, stairs, and restrooms. Electric unit heaters provide additional heat to mechanical rooms.		
Air curtains serve the front and side vestibules.		
Hot water convectors provide added heat to corridors, locker rooms, restrooms, and can wash room.		
Split type heat pumps serve areas which may require cooling during unoccupied hours in the MDF Rooms, elevator machinery room, and storage room.		

	Proposed Design	SCA GSG Baseline ASHRAE 90.1-2010 App. G	LL86 Baseline ASHRAE 90.1-2013 ECBM		
HVAC Systems: Classrooms, offices, toilets, corridors, reading and exercise rooms	 AHU-1 Variable volume Supply Flow, Primary 11,900 CFM Max Outside Air Flow 11,900 CFM Min Outside Air Flow 7,140 CFM Max Return Flow 10,150 CFM Min Return Flow 5,390 CFM Supply fan 30 HP Relief fan 15 HP Cooling Capacity 528 MBH Heating Capacity 332 MBH Economizer with enthalpy controls Demand Controlled Ventilation Cooling: Chilled water, 30% glycol Heating: Preheat – HW coil, 30% glycol Supplemental CUHs in toilets Fin Tube Radiation Energy Recovery 75% energy recovery effectiveness AHU-2 Variable volume Supply Flow, Primary 11,000 CFM Max Outside Air Flow 11,000 CFM Max Return Flow 9,380 CFM Min Outside Air Flow 4,980 CFM Min Return Flow 4,980 CFM Supply fan 30 HP Relief fan 10 HP Cooling Capacity 493 MBH Heating Capacity 294 MBH Economizer with enthalpy controls Demand Controlled Ventilation 	Classroom Systems System #7 - VAV with reheat Hot water reheat coils on VAV boxes DX cooling coil No economizer 50% energy recovery effectiveness Fan Power Credits: (AHU 1 and AHU 2) Energy Recovery 1.15" MERV 13 0.90" Sound Attenuator 0.15" Cellar VAV (Cellar) Supply Flow 300 CFM Max Outside Air Flow 300 CFM Minimum Flow 150 CFM Return Flow 90% of supply Total Fan Power 0.6 kW Cooling capacity 12.5 kBtu/h Heating capacity 16.4 kBtu/h FL1 VAV (1 st Floor) Supply Flow 3,245 CFM Max Outside Air Flow 2,570 CFM Minimum Flow 1,281 CFM Return Flow 90% of supply Total Fan Power 5.6 kW Cooling capacity 136 kBtu/h Heating capacity 178 kBtu/h FL2 VAV (2 rd Floor) Supply Flow 6,212 CFM Max Outside Air Flow 5,160 CFM Minimum Flow 2,503 CFM Return Flow 90% of supply Total Fan Power 10.5 kW	Classroom System System #4: Packaged VAV with reheat Hot water reheat coils on VAV boxes DX cooling coil Economizer with fixed drybulb controls with high-limit of t(OA) > 65°F 50% energy recovery effectiveness Demand Controlled Ventilation Fan Power Credits: (AHU 1 and AHU 2) Energy Recovery 1.15" MERV 13 0.90" Sound Attenuator 0.15" AHU 1 Supply Flow 14,326 CFM Max Outside Air Flow 11,900 CFM Minimum Flow 5,372 CFM Total Fan Power 23.8 kW Cool capacity 583 kBtu/h Cooling Efficiency 9.8 EER Heating capacity 1,214 kBtu/h AHU 2 Supply Flow 13,025 CFM Max Outside Air Flow 11,012 CFM Minimum Flow 5,731 CFM Total Fan Power 21.7 kW Cool capacity 521 kBtu/h Cooling Efficiency 9.8 EER Heating capacity 1,055 kBtu/h 		

Proposed Design	SCA GSG Baseline ASHRAE 90.1-2010 App. G	LL86 Baseline ASHRAE 90.1-2013 ECBM
Proposed Design <u>Cooling:</u> • Chilled water, 30% glycol <u>Heating:</u> • Preheat – HW coil, 30% glycol • Supplemental CUHs in toilets • Fin Tube Radiation <u>Energy Recovery</u> 75% energy recovery effectiveness	SCA GSG Baseline ASHRAE 90.1-2010 App. G• Cooling capacity254 kBtu/h• Heating capacity340 kBtu/hFL3 VAV (3 rd Floor)•• Supply Flow5,709 CFM• Max Outside Air Flow 4,840 CFM• Minimum Flow2,272 CFM• Return Flow90% of supply• Total Fan Power9.6 kW• Cooling capacity234 kBtu/h• Heating capacity313 kBtu/hFL4 VAV (4 th Floor)•• Supply Flow6,269 CFM• Max Outside Air Flow 5,882 CFM• Minimum Flow2,864 CFM• Return Flow90% of supply	LL86 Baseline ASHRAE 90.1-2013 ECBM
	 Return Flow 90% of supply Total Fan Power 10.6 kW Cooling capacity 255 kBtu/h Heating capacity 344 kBtu/h FL5 VAV (5th Floor) Supply Flow 5,699 CFM Max Outside Air Flow 4,540 CFM Minimum Flow 2,228 CFM Return Flow 90% of supply Total Fan Power 9.6 kW Cooling capacity 174 kBtu/h Heating capacity 327 kBtu/h 	

	Proposed Design			SCA GSG Baseline ASHRAE 90.1-2010 App. G		LL86 Baseline ASHRAE 90.1-2013 ECBM			
HVAC Systems: Kitchen/Cafeteria	 AHU-3 Variable volume Supply Flow, Primary 3,920 CFM Max Outside Air Flow 3,920 CFM Min Outside Air Flow 2,000 CFM Return Flow 1,920 CFM Supply fan 10 HP Relief fan 1 HP Cooling Capacity 218 MBH Heating Capacity 187 MBH Economizer with enthalpy controls Demand Controlled Ventilation Cooling: Chilled water, 30% glycol Heating: Preheat – HW coil, 30% glycol Supplemental CUHs in toilets Hot Water Convectors 		Kitchen/Cafeteria System #7 VAV with reheat Hot water reheat coils on VAV boxes DX cooling coil No economizer Fan Power Credits: (AHU 3) MERV 13 0.90" Ducted Return 0.50" Sound Attenuator 0.15" Cafeteria/Kitchen PSZ Supply Flow 4,068 CFM Max Outside Air Flow3,490 CFM Return Flow 90% of supply Total Fan Power 4.8 kW Cooling capacity 138 kBtu/h Heating capacity 463 kBtu/h		 Kitchen/Cafeteria System #4: Packaged VAV with reheat Hot water reheat coils on VAV boxes DX cooling coil Economizer with fixed drybulb controls with high-limit of t(OA) > 65°F Demand Controlled Ventilation Fan Power Credits: (AHU 3) MERV 13 0.90" Ducted Return 0.50" Sound Attenuator 0.15" AHU-3 Supply Flow 4,565 CFM Max Outside Air Flow 3,870 CFM Minimum Flow 1,981 CFM Return Flow 90% of supply Total Fan Power 8 kW Cool capacity 412 kBtu/h Cooling Efficiency 9.8 EER Heating capacity 621 kBtu/h 				
	Air source heat pumps serve the elevator machine room, MDF room and 112J		System 3- PSZ		System 9- Packaged Roof top heat pump (Split unit)				
	storage roo	<u>m.</u>	CEED	AC-1	112J Storage	14.0	Unit	Service	SEER
HVAC Systems: Air source heat pumps		Service	SEER		319 Telecom	14.0	AC-1	112J Storage	14.0
	AC-1 112J Storage AC-2 319 Telecom (MDF) 602 Elevator	319 Telecom	14.0	AC-2	(MDF)	14.0	AC-2	(MDF)	14.0
		14.0	AC-3	602 Elevator Machine Room	14.0	AC-3	602 Elevator Machine Room	14.0	
	AC-3Machine Room14.0Heating via 10.8 HSPF heat pump in model (no heating demand).14.0			Heating from 80% efficient furnaces (no heating demand).		Heating from 9 HSPF split system heat pump (no heating demand).			
	Proposed Design	SCA GSG Baseline ASHRAE 90.1-2010 App. G	LL86 Baseline ASHRAE 90.1-2013 ECBM						
--	---	--	--						
HVAC Systems, Hot water /Water Cabinet unit heaters	WCUH/WUH unit heaters serve restrooms, stairs, mechanical rooms, and vestibules.	System 9- Heating & Ventilation Heating from 80% efficient furnaces	System 11- Packaged rooftop air conditioner. Heating from 80% efficient furnaces. No cooling provided.						
HVAC Systems, Electric Unit Heaters	Electric unit heaters serve the mechanical rooms.	System 9- Heating & Ventilation Heating from electric furnaces	System 9- Packaged rooftop heat pump. No cooling provided.						
Boiler Plant	 Two (2) gas-fired condensing boilers (One on stand-by) Reset based on outdoor temperature 1,584 MBH each (output capacity) 88.0% minimum efficiency 	 Two (2) gas-fired boilers 1,033 MBH (each) 80% thermal efficiency per Table 6.8.1F 	 Two (2) gas-fired boilers 2,010 MBH (each) 80% thermal efficiency per Table 6.8.1F 						
Chiller Plant	One (1) 103.3-ton modular air-cooled chiller (with 4 modules, each 25.8 tons) • FL: 10.16 EER • IPLV: 14.26 EER (<150 tons)	One (1) 91-ton water-cooled chiller • FL: 0.775 kW/ton • IPLV: 0.615 kW/ton	No chillers (all DX cooling).						
Domestic Hot Water	 One gas fired hot water heater 200 MBtu/h 85% estimated modeled efficiency 	 One gas fired hot water heater 200 MBtu/h 80% thermal efficiency per Table 7.8 	 One gas fired hot water heater 200 kBtu/h 80% thermal efficiency per Table 7.8 						

	Proposed Design	SCA GSG Baseline ASHRAE 90.1-2010 App. G	LL86 Baseline ASHRAE 90.1-2013 ECBM
Pumps	Primary Hot Water Pumps• Two pumps plus one standby• 101 GPM• 5 HP• Variable SpeedSecondary Hot Water Pump• One pump plus one standby• 110 GPM• 5 HP• Variable SpeedChilled Water Pump• One pump plus one standby• 263 GPM• 7.5 HP• Variable Speed	 <u>Hot Water Pumps</u> 19 W/gpm Constant speed, rides pump curve. 	 <u>Primary Hot Water Pumps</u> 19 W/gpm Constant speed, rides pump curve.
Equipment Sizing	• Equipment capacities based on mechanical schedule (actual sizes)	 Equipment capacities based on temperature difference of 20°F between supply air temperature and the temperature set point in the space. Cooling equipment oversized for 15% and heating equipment oversized by 25%. 	 Equipment capacities based on temperature difference of 20°F between supply air temperature and the temperature set point in the space. The equipment capacities are sized proportionally to the capacities in the Proposed Design based on sizing runs; i.e., the ratio between the capacities used in the annual simulations and the capacities determined by the sizing runs are the same as in the Proposed Design

	Proposed Design	SCA GSG Baseline ASHRAE 90.1-2010 App. G	LL86 Baseline ASHRAE 90.1-2013 ECBM
	Cooling Capacity • System Total = 1,332 MBH • Chiller = 1,240 MBH • Heat Pumps = 92.4 MBH Heating Capacity • System Total = 3,326 MBH • Boiler = 3,168 MBH	Cooling Capacity • System Total = 1,230 MBH • Chiller = 1,088 MBH • Packaged Units = 165 MBH Heating Capacity • System Total = 2,644 MBH • Boiler = 2,066 MBH	Cooling Capacity • System Total = 1,552 MBH • Chiller = 0 MBH • Heat Pumps = 21 MBH Heating Capacity • System Total = 4,118 MBH • Boiler = 4,020 MBH
	 Electric = 58.0 MBH Heat Pumps = 100 MBH 	 Furnace = 576 MBH Electric = 2 MBH 	 Furnace = 80 MBH Electric = 1.7 MBH Heat pumps = 16.3 MBH
HVAC Summary	 Fan Power VAV supply = 26,820 cfm VAV supply fan power = 70 HP VAV return fan power = 26 HP CV supply = 17,578 cfm CV fan power = 3.2 HP 	 Fan Power VAV supply = 27,434 cfm VAV supply fan power = 32.5 kW Return fan power = 13.9 KW CV supply = 6,989 cfm CV fan power = 6.1 kW 	 Fan Power VAV supply = 31,916 cfm VAV supply fan power = 37.4 kW VAV return fan power = 16.0 kW CV supply = 3,633 cfm CV fan power = 1.8 kW

		Proposed	Design		SCA GSG E ASHRAE 90.1-2	Baseline 2010 App. G	1 F	LL86 Baseline ASHRAE 90.1-2013 ECBM			
		Month	Peak kW		Month	Peak kW			Month	Peak kW	
		January	65		January	86			January	71	
		February	62		February	83			February	69	
		March	64		March	88			March	79	
		April	95		April	125			April	118	
		May	124		May	152			May	157	
Flactric usaga	June 144			June	173			June	181		
summary		July	126		July	144			July	146	
		August	121		August	135			August	140	
		September	135		September	168			September	172	
		October	99		October	132			October	130	
		November	73		November	96			November	90	
		December	64		December	85			December	71	
	Ann 283,	ual electric consun 806 kWh	nption =	Annual 389,249	electric consumpti 9 kWh	on =		Annual 336,059	electric consumpt 9 kWh	ion =	
Natural gas usage summary	e Annual gas consumption = 5,636 therms				gas consumption = herms	=	Annual gas consumption = 7,446 therms				

Note:

This report is developed for the purpose of calculating the energy performance per requirements ASHRAE 90.1-2010 Appendix G and ASHRAE 90.1-2013 Section 11. Actual energy use and cost will be greater, since the modeling rules do not account for many real-life issues, such as quality of construction, equipment functionality, building operation and other factors. Reasons include, but are not limited to the following:

- The ECBM Baseline assumes perfection, as noted in the bullets below, so the design model also must assume perfection:
 - The HVAC equipment is manufactured per standards. The design of the HVAC systems is such that the each individual piece of equipment performs optimally. The installation is flawless, and the operation optimum.
 - Lighting and lighting controls are perfectly manufactured/installed and function as such.
 - The insulation is installed perfectly. There are no gaps and no rips caused by pipes and wiring. The windows are put in place with perfect caulking.
- Certain real-life effects are not included in the baseline calculations, and therefore are not included in the design calculations either. For instance, the three-dimensional heat loss effect that occurs at the roof parapet
- Occupant behavior is idealized
- Other effects, such as uncertainties in equipment (plug load) operation.

Please refer to the Informative Note in ASHRAE 90.1-2013 Section 11.1: "The energy cost budget and the design energy cost calculations are applicable only for determining compliance with this standard. They are not predictions of actual energy consumption or costs of the proposed design after construction. Actual experience will differ from these calculations due to variations such as occupancy, building operation and maintenance, weather, energy use not covered by this standard, changes in energy rates between design of the building and occupancy, and precision of the calculation tool."

To fully comply with ASHRAE 90.1, Section 11 and/or Appendix G, the design must comply with all mandatory provisions of ASHRAE 90.1 Sections 5.4 (Building Envelope), 6.4 (HVAC Equipment), 7.4 (Service Water Heating), 8.4 (Power), 9.4 (Lighting) and 10.4 (Other Equipment). Compliance with these provisions is not part of EME Group's energy analysis. Typically, this compliance is certified by the Architect (Section 5.4) and the HVAC Engineer (Sections 6.4, 7.4, 8.4, 9.4 and 10.4).

APPENDIX A. SCHEDULE DETAILS

A1. SCHEDULE FOR TYPICAL SPACES





New York City Public School PS 33X Energy Model Report





New York City Public School PS 33X Energy Model Report

Schedule Name	Effective	12-1 am	1-2 am	2-3 am	3-4 am	4-5 am	5-6 am	6-7 am	7-8 am	8-9 am	9-10 am	10- 11 am	11- 12 pm	12-1 pm	1-2 pm	2-3 pm	3-4 pm	4-5 pm	5-6 pm	6-7 pm	7-8 pm	8-9 pm	9-10 pm	10- 11 pm	11- 12 am
]	Heati	ng Sc	hedul	es												
MER HEAT YR	Winter	55	55	55	55	55	55	55	60	60	60	60	60	60	60	60	60	60	60	55	55	55	55	55	55
IT HEAT YR	All Days	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20
Cafeteria Heating YR	Winter	55	55	55	55	55	55	55	55	55	55	72	72	72	72	72	72	55	55	55	55	55	55	55	55
General Heat Sch	Winter	55	55	55	55	55	55	72	72	72	72	72	72	72	72	72	72	72	72	72	55	55	55	55	55
	•	-		, ,					(Cooli	ng Sc	hedul	es						•	, ,			•		
MER COOL YR	Summer	95	95	95	95	95	95	95	95	95	95	95	95	95	95	95	95	95	95	95	95	95	95	95	95
IT COOL YR	All Days	80	80	80	80	80	80	80	80	80	80	80	80	80	80	80	80	80	80	80	80	80	80	80	80
Cafeteria Cooling YR	Summer	85	85	85	85	85	85	85	85	85	85	78	78	78	78	78	78	85	85	85	85	85	85	85	85
General Cool Sch	Summer	85	85	85	85	85	85	78	78	78	78	78	78	78	78	78	78	78	78	78	85	85	85	85	85
Lighting Schedules																									
ALL ON YR	All Days	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
MER LIGHT YR	All Days	0	0	0	0	0	0	0	0.2	0.35	0.35	0.35	0.35	0.35	0.35	0.35	0.35	0.35	0.35	0	0	0	0	0	0
SCHOOL LIGHT SUMMER	Summer	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.15	0.15	0.15	0.15	0.15	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05
SCHOOL LIGHT YR	Non Summer Days	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.3	0.85	0.95	0.95	0.95	0.8	0.8	0.8	0.7	0.5	0.5	0.35	0.35	0.35	0.3	0.05	0.05
Cafeteria Lighting YR	All Days	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.6	0.6	0.6	0.6	0.6	0.6	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05
				·				Occu	ipanc	y, Fai	n, and	Othe	r Sch	edules	5				-				-		
*Class Occup Sch Yr	Non Summer Days	0	0	0	0	0	0	0.1	0.9	0.9	0.9	0.8	0.8	0.9	0.9	0.2	0.2	0.2	0	0	0	0	0	0	0
*Class Occup Sch Summer	Summer	0	0	0	0	0	0	0	0.1	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0	0	0	0	0	0	0	0	0
Fan Schedule	All Days	0	0	0	0	0	0	1	1	1	1	1	1	1	1	1	1	1	1	1	0	0	0	0	0
Min OA- Yr	All Days	0	0	0	0	0	0	1	1	1	1	1	1	1	1	1	1	1	1	0	0	0	0	0	0
DHW Eqp NRes YR	All Days	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.1	0.34	0.6	0.63	0.72	0.79	0.83	0.61	0.65	0.1	0.1	0.19	0.25	0.22	0.22	0.12	0.09
INF YR	All Days	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
Cafeteria Fan Yr	All Days	0	0	0	0	0	0	0	0	0	0	1	1	1	1	1	1	0	0	0	0	0	0	0	0

*Office Occ yr	Non Summer Days	0	0	0	0	0	0	0	0.9	0.9	0.9	0.9	0.9	0.5	0.8	0.8	0.8	0.8	0.5	0	0	0	0	0	0
*Office Occ summer	Summer	0	0	0	0	0	0	0	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0	0	0	0	0	0	0
*gym occ yr	Non Summer Days	0	0	0	0	0	0	0	0	0.46	0.46	0.46	0.46	0.46	0.46	0.46	0.2	0.2	0.2	0	0	0	0	0	0
*gym occ summer	Summer	0	0	0	0	0	0	0	0	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0	0	0
*Cafeteria Occ Yr	Non Summer Days	0	0	0	0	0	0	0	1	0.1	0.1	0.1	1	1	1	0.1	0.1	0	0	0	0	0	0	0	0
*Cafeteria Occ summer	Summer	0	0	0	0	0	0	0	0.5	0.1	0.1	0.5	0.5	0.5	0.1	0.1	0	0	0	0	0	0	0	0	0
*Kitchen Occupancy yr	All Days	0	0	0	0	0	0	0	1	1	1	1	1	1	1	0	0	0	0	0	0	0	0	0	0

*Building Occupancy schedules are based on intermediate school occupancy schedules from SCA energy modeling use guide and experience with similar buildings.

APPENDIX B. ENERGY MODEL OUTPUT REPORTS

ASHRAE 90.1 APPENDIX G ENERGY MODEL FOR GSG COMPLIANCE (BASELINE):

PS	33X Jerome	e Ave 3							DOE-	2.2-48y	7/24/20)18 17 :	06:37 BI	LRUN 1
REI	ORT- BEPS	Building	Energy Pe	erformance	•					WE	ATHER FII	LE- NEW YC	RK LAGUAF	DI NY
		LIGHTS	TASK LIGHTS	MISC EQUIP	SPACE HEATING	SPACE COOLING	HEAT REJECT	PUMPS & AUX	VENT FANS	REFRIG DISPLAY	HT PUMP SUPPLEM	DOMEST HOT WTR	EXT USAGE	TOTAL
EM1	ELECTRIC MBTU	CITY 349.5	0.0	264.2	0.7	228.1	5.3	163.0	281.4	0.0	0.0	0.0	36.3	1328.5
FM1	NATURAL MBTU	-GAS 0.0 ======	0.0	44.9	600.7	0.0	0.0	0.0	0.0	0.0	0.0	53.2	0.0	698.7 ======
	MBTU	349.5	0.0	309.1	601.4	228.1	5.3	163.0	281.4	0.0	0.0	53.2	36.3	2027.2
		TOI TOI PER	CAL SITE F	ENERGY E ENERGY IOURS ANY	2027.24 4684.23 SYSTEM ZC	4 MBTU 3 MBTU ONE OUTSIE	41.5 KBT 95.8 KBT DE OF THRC	U/SQFT-YF U/SQFT-YF TTLING RA	C GROSS-AF C GROSS-AF	EA 41 EA 95 97	.5 KBTU/S 5.8 KBTU/S	SQFT-YR NE SQFT-YR NE	T-AREA T-AREA	
		PER	RCENT OF H IRS ANY ZO	NE ABOVE	PLANT LOA COOLING T	AD NOT SAI THROTTLING	ISFIED		= 0.	00 77				

HOURS ANY ZONE BELOW HEATING THROTTLING RANGE = 151

NOTE: ENERGY IS APPORTIONED HOURLY TO ALL END-USE CATEGORIES.

			New Y	ork City	Public Se	chool PS	5 33X En	ergy Mod	el Report				
PS 33X Jer	ome Ave 3							DOE-	2.2-48y	7/24/20	018 17:	:06:37 BD	LRUN 1
REPORT- BE	PU Building	Utility P	erforman	ce					WE	ATHER FII	LE- NEW YO	ORK LAGUAR	DI NY
	LIGHTS	TASK LIGHTS	MISC EQUIP	SPACE HEATING	SPACE COOLING	HEAT REJECT	PUMPS & AUX	VENT FANS	REFRIG DISPLAY	HT PUMP SUPPLEM	DOMEST HOT WTR	EXT USAGE	TOTAL
EM1 ELECT KWH	RICITY 102408.	0.	77411.	212.	66824.	1555.	47755.	82449.	0.	0.	0.	10635.	389249.
FM1 NATUR THERM	2 AL-GAS 0.	0.	449.	6007.	0.	0.	0.	0.	0.	0.	532.	0.	6987.
	TOTAL ELECT TOTAL NATUR	RICITY AL-GAS	389249. 6987.	KWH THERM	7.961 0.143	KWH THERM	/SQFT-YR /SQFT-YR	GROSS-AREA GROSS-AREA	A 7.961 A 0.143	KWH THERM	/SQFT-YR /SQFT-YR	NET-AREA NET-AREA	
	PERCENT OF PERCENT OF HOURS ANY Z HOURS ANY Z NOTE: ENER	HOURS ANY HOURS ANY ONE ABOVE ONE BELOW GY IS APP	SYSTEM S PLANT LA COOLING HEATING	ZONE OUTSI DAD NOT SA THROTTLIN THROTTLIN HOURLY TO	DE OF THE TISFIED G RANGE G RANGE	OTTLING	RANGE = = = = EGORIES.	2.97 0.00 77 151					
PS 33X Jer REPORT- ES	ome Ave 3 -D Energy Co	st Summar	У					DOE-	2.2-48y WE	7/24/2(ATHER FII	018 17: LE- NEW YC	:06:37 BD DRK LAGUAR	DL RUN 1 DI NY
UTILITY-RA	TE		RESO	JRCE	METE	IRS	U	METERED ENERGY NITS/YR		TOTAL CHARGE (\$)	VIRTUA RAJ (\$/UNIJ	AL FE RATE F) ALL Y	USED EAR?
ConEd SmGe	en SC-2 Non-T	OU Elec	ELEC	TRICITY	EM1		3892	49. KWH		73971.	0.190)0 YE	S
ConEd Gen	SC-2 Heating	Gas	NATU	RAL-GAS	FM1		69	87. THERM		8057.	1.153	31 YE	S
									====	===== 82028.			
						FNFDC	V COST/CE	OSS BLDC A	DEA.	1 68			

ENERGY COST/GROSS BLDG AREA: 1.68 ENERGY COST/NET BLDG AREA: 1.68

PS 33X Jerome Ave 3							DOE-2.2-4	8y	7/24/2018	17:06:37 BDL	RUN 1
REPORT- LV-B Summary of Spac	es							WEAT	THER FILE- NE	W YORK LAGUARD	I NY
NUMBER OF SPACES 112	EXTERIOR	76	INTER	RIOR 36	5						
				LIGHTS		EQUIP					
	SPACE*FLOOR	SPACE		(WATT /		(WATT /	INFILTRATION		AREA	VOLUME	
SPACE	MULTIPLIER	TYPE	AZIM	SQFT)	PEOPLE	SQFT)	METHOD	ACH	(SQFT)	(CUFT)	
Spaces on floor: C Below-Gra	de Flr										
C Gas Meter Room	1.0	INT	0.0	0.42	0.0	0.00	NO-INFILT.	0.00	414.8	4977.0	
C Mech Equipment Room	1.0	INT	-90.0	0.42	0.0	0.00	NO-INFILT.	0.00	281.2	3374.1	
C Stairs B	1.0	INT	0.0	0.69	0.0	0.00	NO-INFILT.	0.00	130.7	1568.6	
C Electrical Room	1.0	INT	0.0	0.42	0.0	0.00	NO-INFILT.	0.00	333.4	4000.8	
C water Service/Sewage Eject	or 1.0	INT	0.0	0.42	0.0	0.00	NO-INFILT.	0.00	336.7	4040.0	
C fievalors	1.0		0.0	0.00	0.0	0.00	NO-INFILI.	0.00	216 0	2240.5	
C Sprinkler Booster Dump	1.0	TNT	180 0	0.03	0.0	0.00	NO-INFILT.	0.00	310.0	4165 8	
C Corridor	1.0	INT	90.0	0.66	0.0	0.00	NO-INFILT.	0.00	758.3	9099.3	
Spaces on floor: FL1 Ground	Flr										
FL1 Exercise Room	1.0	EXT	0.0	0.72	74.4	0.25	AIR-CHANGE	0.31	1283.6	16686.3	
FL1 Stairs B	1.0	EXT	-90.0	0.69	0.0	0.00	AIR-CHANGE	0.31	432.5	5622.8	
FL1 Toilet/Shower/Lockers	1.0	INT	0.0	0.99	0.0	0.00	NO-INFILT.	0.00	188.3	2448.4	
FL1 Parents/Community	1.0	EXT	0.0	1.11	2.2	0.50	AIR-CHANGE	0.31	217.7	2830.7	
FL1 Toilet A	1.0	EXT	0.0	0.99	0.0	0.00	AIR-CHANGE	0.31	70.1	911.2	
FL1 Exam Room	1.0	EXT	0.0	1.12	4.0	0.00	AIR-CHANGE	0.31	91.2	1185.1	
FL1 Stairs A	1.0	EXT	0.0	0.69	0.0	0.00	AIR-CHANGE	0.31	362.8	4716.3	
FL1 Nurse's Office	1.0	INT	0.0	1.00	1.7	1.25	NO-INFILT.	0.00	166.9	2169.4	
FL1 Elevators	1.0	INT	0.0	0.00	0.0	0.00	NO-INFILT.	0.00	193.1	2510.6	
FLI Bike Storage	1.0	EXT	90.0	0.63	0.0	0.00	AIR-CHANGE	0.31	97.6	1268.8	
FLI Vestibule A	1.0	EXT	-90.0	0.66	0.0	1 25	AIR-CHANGE	0.31	118.4	1539.0	
FLI Supervisory Office	1.0	EAT	0.0	1.00	2.0	1.25	AIR-CHANGE	0.31	203.7	2048.3	
FLI Vestibule B	1.0	EAT	-90.0	0.00	0.0	0.00	AIR-CHANGE	0.31	152.2	85U.I 1002 2	
FLI Boys	1.0	EA1 EVT	190 0	0.99	110 1	0.00	AIR-CHANGE	0.31	1091 6	25760 2	
FLI Cirle	1.0	EA1 EVT	100.0	0.05	110.1	0.00	NO-TNETLT	0.31	125 4	1630 5	
FL1 Students	1.0	EXT	0.0	0.99	0.0	0.00	NO-INFILT.	0.00	64.2	834.1	
FL1 Electrical	1.0	EXT	0.0	0.42	0.0	0.00	NO-INFILT.	0.00	66.7	867.5	
FL1 Servery	1.0	ЕХТ	0.0	0.65	15.8	0.00	NO-INFILT.	0.00	284.8	3702.1	
FL1 Janitor's Closet	1.0	INT	0.0	1.24	0.0	0.00	NO-INFILT.	0.00	48.7	633.4	
FL1 Refuse Recycling	1.0	EXT	180.0	0.63	0.0	0.00	AIR-CHANGE	0.31	145.0	1885.3	
FL1 Can Wash	1.0	EXT	90.0	1.21	0.5	3.00	AIR-CHANGE	0.31	94.3	1226.5	
FL1 Dietition's Office	1.0	EXT	90.0	1.00	0.8	1.25	AIR-CHANGE	0.31	75.7	983.7	
FL1 Locker Rooms	1.0	EXT	90.0	0.99	0.0	0.00	AIR-CHANGE	0.31	164.7	2140.6	
FL1 Toilet B	1.0	EXT	0.0	0.99	0.0	0.00	AIR-CHANGE	0.31	74.2	965.1	
FL1 Pot Wash	1.0	EXT	0.0	1.21	0.8	3.00	NO-TNETLT.	0.00	168.4	2189.4	

TL Deprivating 1.0 EXT 0.0 1.1 2.7 3.0 0.0 0.0 1.0 0.0 1.1 2.7 3.0 0.0		New Yo	rk Cit	ty Publi	c Schoo	1 PS 33	X Energ	gy Model Re	port				
Pil Storage 1.0 EXT -90.0 0.66 0.0 NO-TEPTIT. 0.00 NIT-CHANGE 0.31 143.0 15376.8 Fil Storage 1.0 EXT 180.0 0.63 0.0 0.00 NIT-CHANGE 0.31 143.4 1022.1 Spaces on floor: FL2 Ground Fir Fil Storage 1.0 EXT 90.0 1.12 43.3 0.25 AIR-CHANGE 0.31 994.9 12933.2 P# 33X Jarome Ave 3 VEXTUE: NEW YOR LAUGHADI NY REPORT VEXTUE: NEW YOR LAUGHADI NY Fil Classroom B 1.0 EXT 90.0 1.12 42.7 0.25 AIR-CHANGE 0.31 933.0 12776.4 Fil Classroom B 1.0 EXT 90.0 0.12 42.7 0.25 AIR-CHANGE 0.31 933.0 13776.4 Fil Classroom B 1.0 EXT 90.0 0.0 0.00 NO-HTLL. 0.00 133.6 1736.3 Fil Classroom B 1.0 INT 0.0 0.99 0.0 0.00 NO-HTLL. 0.00 133.6 1736.3 Fil Classroom B 1.0 INT 0.0 0.99 0.0 0.00 NO-HTLL. <	FL1 Prep/Warming	1.0	EXT	0.0	1.21	2.7	3.00	NO-INFILT.	0.00	541.2	7036.1		
Pil Storage 1.0 EXT 10.0 EXT 10.0 EXT 10.0 EXT 10.0	FL1 Corridor	1.0	EXT	-90.0	0.66	0.0	0.00	NO-INFILT.	0.00	1183.0	15378.8		
Til Receiving 1.0 EXT 180.0 0.63 0.0 0.00 ATR-CHANGE 0.31 78.6 1022.1 Spaces on floor: FL2 Ground Flr FL2 Classroom A 1.0 EXT 90.0 1.12 43.3 0.25 AIR-CHANGE 0.31 994.9 12933.2 P6 33X Jerome Ave 3 DEF-2.2-48y 7/24/2018 17:06:37 BOL AUTOR 100 EXT 0.0 1.12 42.7 0.25 AIR-CHANGE 0.31 934.9 12933.2 VEL Classroom C 1.0 EXT 0.0 1.12 42.7 0.25 AIR-CHANGE 0.31 0.31 13166.9 FL2 Classroom C 1.0 EXT 0.0 1.12 41.3 0.25 AIR-CHANGE 0.31 103.0 13166.9 FL2 Classroom D 1.0 EXT 0.0 0.00 0.00 NO 1.14 43.3 125 11033.0 13166.9 122 1243.3 1233.5 122 1233.5 122 124.5 177.6 100.133.6 127.76.4 1233.5 122 124.5 100.0 100.0 100.0	FL1 Storage	1.0	EXT	180.0	0.63	0.0	0.00	ATR-CHANGE	0.31	124.9	1623.4		
Spaces on floor: FL2 Ground FLT FL2 Classroom A 1.0 EXT 90.0 1.12 43.3 0.25 ATR-CHANGE 0.31 994.9 12933.2 FS 3IX Jerome Ave 3 DEF-2.2-480 7/24/2018 17:06:37 EDL EUN 1 REFUGT: LV-5 Summary of Spaces MERITHER FILE- NEW YORK LAGUABOL NO FL2 Classroom B 1.0 EXT 90.0 1.12 42.7 0.25 AIR-CHANGE 0.31 993.0 12778.4 FL2 Classroom C 1.0 EXT 90.0 1.12 42.7 0.25 AIR-CHANGE 0.31 103.0 131.6 1.9 FL2 Classroom B 1.0 EXT 90.0 0.099 0.0 0.000 ND-INFILT. 0.00 133.6 1755.3 FL2 Stairs B 1.0 EXT 90.0 0.099 0.0 0.000 ND-INFILT. 0.00 133.6 1755.3 FL2 Stairs B 1.0 EXT 90.0 0.99 0.0 0.000 ND-INFILT. 0.00 84.1 1093.0 FL2 Stairs B 1.0 EXT 0.0 0.099 0.0 0.000 ND-INFILT. 0.00 84.1 1093.0 FL2 Stairs B 1.0 EXT 0.0 0.099 0.0 0.000 ND-INFILT. 0.00 84.1 1093.0 FL2 Stairs A 1.0 EXT 0.0 1.05 AIR-CHANGE 0.31 61.2 795.0 FL2 Collet D 1.0 EXT 0.0 1.00 0.00 0.0 0.00 ND-INFILT. 0.00 84.1 1093.0 FL2 Stairs A 1.0 EXT 0.0 1.00 0.00 0.0 0.00 ND-INFILT. 0.00 136.5 12554.0 FL2 Collet D 1.0 EXT 0.0 1.06 0.00 0.00 ND 0.0 ND-INFILT. 0.00 84.1 1093.0 FL2 Stairs A 1.0 EXT 90.0 1.12 43.3 0.25 AIR-CHANGE 0.31 1095.6 1405.3 FL2 Stairs A 1.0 EXT 90.0 1.12 43.3 0.25 AIR-CHANGE 0.31 1095.6 1405.3 FL2 Stairs A	FL1 Receiving	1.0	EXT	180.0	0.63	0.0	0.00	AIR-CHANGE	0.31	78.6	1022.1		
FIL2 Classroom A 1.0 EXT 90.0 1.12 43.3 0.25 AIR-CHANGE 0.31 99.9 1293.2 PG 3IX Jerome Ave 3 DEC-2.450 7/24/2018 17:06:37 EDL EUT 1 REPORT LV-B Summary of Spaces TE2 Classroom B 1.0 EXT 90.0 1.12 42.7 0.25 AIR-CHANGE 0.31 993.0 12778.4 FL2 Classroom C 1.0 EXT 90.0 1.12 42.7 0.25 AIR-CHANGE 0.31 993.0 12778.4 FL2 Classroom B 1.0 EXT 90.0 0.0 0.00 NO-INFTLT, 0.00 133.6 1376.3 FL2 Classroom D 1.12 42.7 0.25 AIR-CHANGE 0.31 193.0 13166.9 FL2 Classroom A 1.0 INT 0.0 0.99 0.0 0.00 NO-INFTLT, 0.00 143.1 1033.0 13166.9 FL2 Colspan="2">Colspan="2">FL2 Colspan="2">FL2 Colspan="2" FL2 Cols	Spaces on floor: FL2 Ground Flr												
P 3 3X Jerons Av 3 Dec. 2.402 7 /2/021 1:0:0:7 Dec. 2.101 REDORT: LV-B Jummary of Space Image: Dec. 2.101	FL2 Classroom A	1.0	EXT	90.0	1.12	43.3	0.25	AIR-CHANGE	0.31	994.9	12933.2		
Dependent of Spaces Dependent of Spaces URL CLASSECON B 1.0 EXT 90.0 1.12 42.0 2.0 <th co<="" td=""><td>PS 33X Jerome Ave 3</td><td></td><td></td><td></td><td></td><td></td><td></td><td>DOE-2.2-4</td><td>8y</td><td>7/24/2018</td><td>17:06:37 BDL RU</td><td>JN 1</td></th>	<td>PS 33X Jerome Ave 3</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td>DOE-2.2-4</td> <td>8y</td> <td>7/24/2018</td> <td>17:06:37 BDL RU</td> <td>JN 1</td>	PS 33X Jerome Ave 3							DOE-2.2-4	8y	7/24/2018	17:06:37 BDL RU	JN 1
The second B 1.0 EXT 00.0 1.12 42.7 0.25 AIR-CHANGE 0.31 103.0 13168.9 F12 Classroom C 1.0 EXT 0.0 1.12 44.0 0.25 AIR-CHANGE 0.31 103.0 13168.9 F12 Tollets A 1.0 INT 0.0 0.99 0.0 0.00 NO-INFILT 0.00 133.6 1735.3 F12 Tollets B 1.0 INT 0.0 0.99 0.0 0.00 NO-INFILT 0.00 133.449.1 4538.8 F12 Tollets C 1.0 INT 0.0 0.99 0.0 0.00 NO-INFILT 0.00 184.1 1093.0 F12 Staff 1.0 INT 0.0 0.99 0.0 0.00 NO-INFILT 0.00 84.1 1093.0 F12 Elevators 1.0 INT 0.0 0.99 0.0 0.00 AIR-CHANGE 0.31 61.2 795.0 F12 Reading / Speech Resource 1.0 INT 0.0 0.42 0.0 <td< td=""><td>REPORT- LV-B Summary of Spaces</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td>WEA:</td><td>THER FILE- NE</td><td>W YORK LAGUARDI N</td><td>1Y</td></td<>	REPORT- LV-B Summary of Spaces								WEA:	THER FILE- NE	W YORK LAGUARDI N	1Y	
PIZ Classroom C 1.0 EXT 0.0 1.12 44.0 0.25 ATR-CHANGE 0.31 0113.0 13168.9 PIZ Tollets A 1.0 INT 0.0 0.99 0.0 0.00 NO-INFILT. 0.00 133.6 1736.3 PIZ Tollets B 1.0 INT 0.0 0.99 0.0 0.00 NO-INFILT. 0.00 133.6 1736.3 PIZ Tollets B 1.0 EXT 0.0 0.12 41.3 0.22 ATR-CHANGE 0.31 391.1 4538.8 PIZ Stairs B 1.0 INT 0.0 0.69 0.0 0.00 NO-INFILT. 0.00 46.1 1031.0 1124.2 PIZ Tollets C 1.0 INT 0.0 0.99 0.0 0.00 NO-INFILT. 0.00 66.6 1126.2 PIZ Tollets 12 TOL 12 TOL 12	FI.2 Classroom B	1 0	 हथूम	90 0	1 12	42 7	0 25	ATR-CHANCE	0 31	983 0	(CONTINUED) 12778 4		
1.10 1.00 1.10 0.00 0.09 0.00 0.00 NO-INFILT. 0.00 133.6 1736.3 P12 Toilets B 1.0 1.0 0.0 0.99 0.0 0.00 NO-INFILT. 0.00 125.3 1629.3 P12 Classroom D 1.0 EXT 0.0 0.99 0.0 0.00 NO-INFILT. 0.00 125.3 1629.3 P12 Stairs B 1.0 EXT 0.0 0.99 0.0 0.00 NO-INFILT. 0.00 144.1 1093.0 P12 Staff 1.0 INT 0.0 0.42 0.0 0.00 NO-INFILT. 0.00 84.1 1093.0 P12 Staff 1.0 INT 0.0 0.42 0.0 0.00 NO-INFILT. 0.00 146.1 126.2 795.0 P12 Staff 1.0 INT 0.0 0.00 0.0 0.00 NO-INFILT. 0.00 146.1 122.9 122.3 1490.4 P12 Staff 1.0 INT 0.0 0.00	FL2 Classroom C	1 0	FYT	0.0	1 12	44 0	0.25	ATR-CHANGE	0 31	1013 0	13168 9		
Instructs m 1.0 Int 0.0 0.0 NO NO Int 0.0 1.0 Int 0.0 0.0 0.0 NO Int 0.0 1.0 Int 0.0 0.0 0.0 NO Int 1.0 Int 0.0 0.0 0.0 NO Int 1.0 Int 0.0 0.0 1.0 Int 0.0 1.0 Int 0.0 1.0 Int 0.0 <td>FL2 Toilets A</td> <td>1.0</td> <td>TNT</td> <td>0.0</td> <td>0 99</td> <td>0.0</td> <td>0.25</td> <td>NO-TNETLT</td> <td>0.01</td> <td>133 6</td> <td>1736 3</td> <td></td>	FL2 Toilets A	1.0	TNT	0.0	0 99	0.0	0.25	NO-TNETLT	0.01	133 6	1736 3		
TLZ Classroom D 1.0 EXT 90.0 1.12 41.3 0.25 AIR-CHANGE 0.31 949.2 12339.5 FLZ Stairs B 1.0 EXT 0.0 0.69 0.0 0.00 AIR-CHANGE 0.31 349.1 4538.8 FLZ Stairs B 1.0 INT 0.0 0.99 0.0 0.00 AIR-CHANGE 0.31 349.1 4538.8 FL2 Stairs B 1.0 INT 0.0 0.99 0.0 0.00 NO-INFILT. 0.00 84.1 1093.0 FL2 Comp / AV 1.0 INT 0.0 0.42 0.0 7.50 NO-INFILT. 0.00 86.6 1126.2 FL2 Collat D 1.0 EXT 0.0 0.42 0.0 0.00 AIR-CHANGE 0.31 640.1 229.9 FL2 Stairs A 1.0 EXT 0.0 1.12 41.1 0.0 1.22 AIR-CHANGE 0.31 946.1 12299.9 FL2 Stairs A 1.0 EXT 0.0 1.12 41.3 0.0 0.00 NO-INFILT. 0.00 61.8	FL2 Toilets B	1.0	TNT	0.0	0.99	0.0	0.00	NO-INFILT.	0.00	125.3	1629.3		
P12 Stairs B 1.0 EXT 0.0 0.12 0.12 0.11 0.12	FL2 Classroom D	1 0	FYT	90.0	1 12	41 3	0.00	ATR-CHANGE	0.00	949 2	12339 5		
International and the set of the se	FL2 Stairs B	1 0	FYT	0.0	0 69	0.0	0.00	ATR-CHANGE	0 31	349 1	4538 8		
First Staff 1.0 INT 0.0 0.00 NO INFILT. 0.00 RALL 1.03 1.14 1.093.0 F12 Camp / AV 1.0 INT 0.0 0.42 0.0 0.00 NO INFILT. 0.00 86.6 1126.2 F12 Callet D 1.0 EXT 0.0 0.42 0.0 0.00 AIR-CHANGE 0.31 61.2 795.0 F12 Reading / Speech Resource 1.0 EXT 0.0 1.06 8.1 0.50 AIR-CHANGE 0.31 459.0 6097.4 F12 Elevators 1.0 EXT 0.0 0.00 0.00 NO -INFILT. 0.00 130 469.0 6097.4 F12 Classroom E 1.0 EXT 0.0 0.00 NO -INFILT. 0.00 132.3 449.0 12299.9 F12 Classroom F 1.0 EXT 90.0 0.66 0.0 0.00 NO -INFILT. 0.00 61.8 803.3 F12 Classroom A 1.0 EXT 90.0 1.12 43.7 0.25 AIR-CHANGE 0.31 1005.6 13073.0	FL2 Toilets C	1 0	TNT	0.0	0.99	0.0	0.00	NO-INFILT	0 00	119 1	1548 9		
FL2 Comp / AV 1.0 INT 0.0 0.42 0.0 7.50 NO-INFILT. 0.00 81.6 1126.2 FL2 Comp / AV 1.0 EXT 0.0 0.99 0.0 0.00 AIR-CHANGE 0.31 61.2 795.0 FL2 Reading / Speech Resource 1.0 EXT 0.0 0.99 0.0 0.00 AIR-CHANGE 0.31 61.2 795.0 FL2 Stairs A 1.0 EXT 0.0 0.00 0.00 NO-INFILT. 0.00 196.5 2554.0 FL2 Classroom E 1.0 EXT 0.0 1.12 41.1 0.25 AIR-CHANGE 0.31 946.1 12299.9 FL2 Classroom F 1.0 INT 0.0 0.42 0.0 0.00 NO-INFILT. 0.00 61.8 803.3 FL2 Classroom F 1.0 EXT 90.0 1.12 43.7 0.25 AIR-CHANGE 0.31 1005.6 13073.0 Spaces on floor: FL3 Ground Flr I.0 EXT 90.0 1.12 43.7 0.25 AIR-CHANGE 0.31 013.0	FL2 Staff	1.0	TNT	0.0	0.99	0.0	0.00	NO-INFILT.	0.00	84.1	1093.0		
File Condy J, M. 110 EXT 0.0 0.12 0.0 N. H. CHANGE 0.31 61.2 795.0 File Reading / Speech Resource 1.0 EXT 0.0 1.06 8.1 0.50 AIR-CHANGE 0.31 61.2 795.0 File Reading / Speech Resource 1.0 EXT 0.0 1.06 8.1 0.50 AIR-CHANGE 0.31 61.2 795.0 File Reading / Speech Resource 1.0 EXT 0.0 0.00 0.00 NTFLT. 0.00 1.31 322.3 4190.4 File Classroom E 1.0 EXT 0.0 0.42 0.0 0.00 NO-INFILT. 0.00 62.6 814.1 File Constrom 1.0 EXT 90.0 0.42 0.0 0.00 NO-INFILT. 0.00 61.8 803.3 File Constrom 1.0 EXT 90.0 1.12 43.7 0.25 AIR-CHANGE 0.31 1005.6 13073.0 Spaces on floor: FI3 Ground Flr Fi2 Classroom A 1.0 EXT 90.0 1.12 43.7 0.2	FL2 Comp / AV	1 0	TNT	0.0	0 42	0.0	7 50	NO-INFILT	0 00	86.6	1126 2		
FL2 Reading / Speech Resource 1.0 EXT 0.0 1.06 8.1 0.50 ATR-CHANGE 0.31 469.0 6097.4 FL2 Elevators 1.0 INT 0.0 0.00 0.00 NO-INFILT 0.00 196.5 2554.0 FL2 Stairs A 1.0 EXT 0.0 1.12 41.1 0.25 ATR-CHANGE 0.31 242.3 4190.4 FL2 Classroom E 1.0 INT 0.0 0.42 0.0 0.00 NO-INFILT 0.00 62.6 814.1 FL2 Elec 1.0 INT 0.0 0.42 0.0 0.00 NO-INFILT 0.00 62.6 814.1 FL2 Classroom F 1.0 EXT 90.0 1.12 43.7 0.25 ATR-CHANGE 0.31 1005.6 13073.0 Spaces on floor: FL3 Ground Flr FL3 Classroom A 1.0 EXT 90.0 1.12 42.7 0.25 ATR-CHANGE 0.31 103.6 12778.4 FL3 Classroom C 1.0 EXT 90.0 1.12 42.7 0.25 ATR-CHANGE	FL2 Toilet D	1.0	EXT	0.0	0.99	0.0	0.00	ATR-CHANGE	0.31	61.2	795.0		
FL2 Elevators 1.0 INT 0.0 0.0 0.0 NO-INFILT 0.00 196.5 2554.0 FL2 Elevators 1.0 EXT 0.0 0.69 0.0 0.00 ARC-CHANGE 0.31 322.3 4190.4 FL2 Classroom E 1.0 INT 0.0 0.99 0.0 0.00 NO-INFILT 0.00 62.6 814.1 FL2 FL2 Elec 1.0 INT 0.0 0.99 0.0 0.00 NO-INFILT 0.00 62.6 814.1 FL2 Classroom F 1.0 EXT 90.0 0.66 0.0 0.00 AIR-CHANGE 0.31 1089.6 14165.3 FL2 Classroom F 1.0 EXT 90.0 1.12 43.7 0.25 AIR-CHANGE 0.31 1005.6 13073.0 Spaces on floor: FL3 Ground Flr FL3 Classroom A 1.0 EXT 90.0 1.12 43.7 0.25 AIR-CHANGE 0.31 904.9 12933.2 FL3 Classroom A 1.0 EXT 90.0 1.12 42.7 0.25 AIR-CHANGE 0.3	FL2 Reading / Speech Resource	1.0	EXT	0.0	1.06	8.1	0.50	ATR-CHANGE	0.31	469.0	6097.4		
FL2 Stairs A 1.0 EXT 0.0 0.00 0.00 ATR-CHANGE 0.01 122.3 4130.4 FL2 Stairs A 1.0 EXT 0.0 1.12 41.1 0.25 ATR-CHANGE 0.31 946.1 12299.9 FL2 Toilet E 1.0 INT 0.0 0.42 0.0 0.00 NO-INFILT. 0.00 62.6 814.1 FL2 Classroom F 1.0 EXT 90.0 0.66 0.00 NO-INFILT. 0.00 61.8 803.3 FL2 Classroom F 1.0 EXT 90.0 1.12 43.7 0.25 AIR-CHANGE 0.31 1005.6 13073.0 Spaces on floor: FL3 Ground Flr I.0 EXT 90.0 1.12 43.7 0.25 AIR-CHANGE 0.31 994.9 12933.2 FL3 Classroom A 1.0 EXT 90.0 1.12 43.7 0.25 AIR-CHANGE 0.31 994.9 12933.2 FL3 Classroom C 1.0 EXT 90.0 1.12 42.7 0.25 AIR-CHANGE 0.31 1013.0 13168.9	FL2 Elevators	1.0	TNT	0.0	0.00	0.0	0.00	NO-INFILT.	0.00	196.5	2554.0		
FL2 Classroom E 1.0 EXT 0.0 0.12 41.1 0.25 AIR-CHANGE 0.01 946.1 12299.9 FL2 Toilet E 1.0 INT 0.0 0.99 0.0 0.00 NO-INFILT. 0.00 62.6 814.1 FL2 Elec 1.0 INT 0.0 0.42 0.0 0.00 NO-INFILT. 0.00 62.6 814.1 FL2 Classroom F 1.0 EXT 90.0 0.66 0.0 0.00 NO-INFILT. 0.00 61.8 803.3 FL2 Classroom F 1.0 EXT 90.0 1.12 43.7 0.25 AIR-CHANGE 0.31 1005.6 13073.0 Spaces on floor: FL3 Ground Flr FL3 Classroom A 1.0 EXT 90.0 1.12 42.7 0.25 AIR-CHANGE 0.31 1013.0 136.9 FL3 Classroom B 1.0 INT 0.0 0.99 0.0 0.00 NO-INFILT. 0.00 131.0 1316.9 FL3 Toilets A 1.0 INT 0.0 0.99 0.0 0.00 NO-INFILT.<	FL2 Stairs A	1.0	EXT	0.0	0.69	0.0	0.00	ATR-CHANGE	0.31	322.3	4190.4		
FL2 Toilet E 1.0 INT 0.0 0.99 0.0 0.00 NO-INFILT. 0.00 62.6 814.1 FL2 Elec 1.0 INT 0.0 0.42 0.0 0.00 NO-INFILT. 0.00 61.6 803.3 FL2 Corridor 1.0 EXT 90.0 0.66 0.00 NO-INFILT. 0.00 61.6 803.3 FL2 Classroom F 1.0 EXT 90.0 1.12 43.7 0.25 AIR-CHANGE 0.31 1005.6 13073.0 Spaces on floor: FL3 Ground Flr FL3 Classroom B 1.0 EXT 90.0 1.12 43.7 0.25 AIR-CHANGE 0.31 994.9 12933.2 FL3 Classroom A 1.0 EXT 90.0 1.12 42.7 0.25 AIR-CHANGE 0.31 101.0 136.8 1736.3 FL3 Toilets A 1.0 INT 0.0 0.99 0.0 0.00 NO-INFILT. 0.00 133.6 1736.3 FL3 Toilets B 1.0 INT 0.0 0.99 0.0 0.00 NO-INFILT.	FL2 Classroom E	1.0	EXT	0.0	1.12	41.1	0.25	ATR-CHANGE	0.31	946.1	12299.9		
FL2 Elec 1.0 INT 0.0 0.42 0.0 NO-INFILT. 0.00 AIR-CHANGE 0.31 1089.6 14165.3 FL2 Classroom F 1.0 EXT 90.0 1.12 43.7 0.25 AIR-CHANGE 0.31 1005.6 13073.0 Spaces on floor: FL3 Ground Flr FL3 Classroom A 1.0 EXT 90.0 1.12 43.7 0.25 AIR-CHANGE 0.31 1005.6 13073.0 FL3 Classroom A 1.0 EXT 90.0 1.12 43.7 0.25 AIR-CHANGE 0.31 994.9 12933.2 FL3 Classroom B 1.0 EXT 90.0 1.12 42.7 0.25 AIR-CHANGE 0.31 983.0 12778.4 FL3 Classroom C 1.0 EXT 90.0 1.12 44.0 0.25 AIR-CHANGE 0.31 103.0 13168.9 FL3 Toilets B 1.0 INT 0.0 0.99 0.0 0.00 NO-INFILT. 0.00 132.4 1629.3 FL3 Toilets B 1.0 INT 0.0 0.99 0.0 0.00 NO	FL2 Toilet E	1.0	TNT	0.0	0.99	0.0	0.00	NO-INFILT.	0.00	62.6	814.1		
FL2 Corridor 1.0 EXT 90.0 0.66 0.0 0.00 ART-CHANGE 0.31 1089.6 14165.3 FL2 Classroom F 1.0 EXT 90.0 1.12 43.7 0.25 AIR-CHANGE 0.31 1089.6 14165.3 Spaces on floor: FL3 Ground Flr FL3 Classroom A 1.0 EXT 90.0 1.12 43.3 0.25 AIR-CHANGE 0.31 994.9 12933.2 FL3 Classroom B 1.0 EXT 90.0 1.12 42.7 0.25 AIR-CHANGE 0.31 1013.0 1368.9 FL3 Classroom C 1.0 EXT 0.0 1.12 44.0 0.25 AIR-CHANGE 0.31 1013.0 1368.9 FL3 Toilets A 1.0 INT 0.0 0.99 0.0 0.00 NO-INFILT. 0.00 125.3 1629.3 FL3 Toilets B 1.0 INT 0.0 0.99 0.0 0.00 AIR-CHANGE 0.31 349.1 4538.8 FL3 Toilet C 1.0 INT 0.0 0.99 0.0 0.00 AIR-CHANGE </td <td>FL2 Elec</td> <td>1.0</td> <td>TNT</td> <td>0.0</td> <td>0.42</td> <td>0.0</td> <td>0.00</td> <td>NO-INFILT.</td> <td>0.00</td> <td>61.8</td> <td>803.3</td> <td></td>	FL2 Elec	1.0	TNT	0.0	0.42	0.0	0.00	NO-INFILT.	0.00	61.8	803.3		
FL2 Classroom F 1.0 Ext 90.0 1.12 43.7 0.25 AIR-CHANGE 0.31 1005.6 13073.0 Spaces on floor: FL3 Ground Flr FL3 Classroom A 1.0 EXT 90.0 1.12 43.7 0.25 AIR-CHANGE 0.31 994.9 12933.2 FL3 Classroom B 1.0 EXT 90.0 1.12 42.7 0.25 AIR-CHANGE 0.31 994.9 12933.2 FL3 Classroom C 1.0 EXT 90.0 1.12 42.7 0.25 AIR-CHANGE 0.31 983.0 12778.4 FL3 Classroom C 1.0 EXT 90.0 1.12 44.0 0.25 AIR-CHANGE 0.31 1013.0 13168.9 FL3 Toilets A 1.0 INT 0.0 0.99 0.0 0.00 NO-INFILT. 0.00 125.3 1622.3 FL3 Toilets B 1.0 INT 0.0 0.99 0.0 0.00 NO-INFILT. 0.00 11.1 43.8 FL3 Toilet C 1.0 INT 0.0 0.99 0.0 0.00 NO-INFILT. 0.00 13.949.1 4538.8 FL3 Toilet D 1.0 INT 0.0 0.99 0.0<	FL2 Corridor	1.0	EXT	90.0	0.66	0.0	0.00	ATR-CHANGE	0.31	1089.6	14165.3		
Spaces on floor: FL3 Ground Flr FL3 Classroom A 1.0 EXT 90.0 1.12 43.3 0.25 AIR-CHANGE 0.31 994.9 12933.2 FL3 Classroom B 1.0 EXT 90.0 1.12 42.7 0.25 AIR-CHANGE 0.31 998.0 12778.4 FL3 Classroom C 1.0 EXT 0.0 1.12 44.0 0.25 AIR-CHANGE 0.31 1013.0 13168.9 FL3 Toilets A 1.0 INT 0.0 0.99 0.0 0.00 NO-INFILT. 0.00 125.3 1629.3 FL3 Toilets B 1.0 INT 0.0 0.99 0.0 0.00 NO-INFILT. 0.00 125.3 1629.3 FL3 Toilets B 1.0 EXT 90.0 1.2 41.3 0.25 AIR-CHANGE 0.31 349.1 4538.8 FL3 Toilet C 1.0 INT 0.0 0.99 0.0 0.00 NO-INFILT. 0.00 119.1 1548.9 FL3 Toilet D 1.0 INT 0.0 0.99 0.0 0.00 NO-INFILT.	FL2 Classroom F	1.0	EXT	90.0	1.12	43.7	0.25	AIR-CHANGE	0.31	1005.6	13073.0		
FL3 Classroom A1.0EXT90.01.1243.30.25AIR-CHANGE0.31994.912933.2FL3 Classroom B1.0EXT90.01.1242.70.25AIR-CHANGE0.31983.012778.4FL3 Classroom C1.0EXT0.01.1244.00.25AIR-CHANGE0.311013.013168.9FL3 Toilets A1.0INT0.00.990.00.00NO-INFILT.0.00133.61776.3FL3 Toilets B1.0INT0.00.990.00.00NO-INFILT.0.00125.31629.3FL3 Stairs B1.0EXT90.01.1241.30.25AIR-CHANGE0.31949.212339.5FL3 Toilet C1.0INT0.00.990.00.00NO-INFILT.0.00119.11548.9FL3 Toilet C1.0INT0.00.990.00.00NO-INFILT.0.0084.11093.0FL3 Blevators1.0INT0.00.990.00.00NO-INFILT.0.0084.11093.0FL3 Stairs A1.0EXT0.00.420.07.50AIR-CHANGE0.31358.74662.7FL3 Stairs A1.0INT0.00.690.00.00AIR-CHANGE0.31196.52554.0FL3 Stairs A1.0INT0.00.690.00.00AIR-CHANGE0.31358.74662.7FL3 Stairs A1.0 <td>Spaces on floor: FL3 Ground Flr</td> <td></td>	Spaces on floor: FL3 Ground Flr												
FL3 Classroom B 1.0 EAT 90.0 1.12 42.7 0.25 AIR CHANGE 0.31 983.0 12778.4 FL3 Classroom C 1.0 EXT 0.0 1.12 44.0 0.25 AIR-CHANGE 0.31 983.0 12778.4 FL3 Classroom C 1.0 EXT 0.0 1.12 44.0 0.25 AIR-CHANGE 0.31 983.0 12778.4 FL3 Classroom C 1.0 INT 0.0 0.99 0.0 0.00 NO-INFILT. 0.00 133.6 1736.3 FL3 Classroom D 1.0 INT 0.0 0.99 0.0 0.00 NO-INFILT. 0.00 125.3 1629.3 FL3 Classroom D 1.0 INT 0.0 0.99 0.0 0.00 NO-INFILT. 0.00 125.3 1629.3 FL3 Toilet C 1.0 INT 0.0 0.99 0.0 0.00 NO-INFILT. 0.00 119.1 1548.9 FL3 Toilet D 1.0 INT 0.0 0.99 0.0 0.00 NO-INFILT. 0.00 119.1 1548.9	FI.3 Classroom A	1 0	FXT	90.0	1 12	43 3	0 25	ATR-CHANCE	0 31	994 9	12933 2		
FL3 Classroom C 1.0 1.1 1.11 </td <td>FL3 Classroom B</td> <td>1 0</td> <td>FYT</td> <td>90.0</td> <td>1 12</td> <td>42 7</td> <td>0.25</td> <td>ATR-CHANGE</td> <td>0 31</td> <td>983 0</td> <td>12778 4</td> <td></td>	FL3 Classroom B	1 0	FYT	90.0	1 12	42 7	0.25	ATR-CHANGE	0 31	983 0	12778 4		
FL3 Toilets A 1.0 INT 0.0 0.99 0.0 0.00 NO-INFILT. 0.00 133.6 1736.3 FL3 Toilets B 1.0 INT 0.0 0.99 0.0 0.00 NO-INFILT. 0.00 125.3 1629.3 FL3 Classroom D 1.0 EXT 90.0 1.12 41.3 0.25 AIR-CHANGE 0.31 949.2 12339.5 FL3 Toilet B 1.0 EXT 90.0 1.12 41.3 0.25 AIR-CHANGE 0.31 349.1 4538.8 FL3 Toilet C 1.0 INT 0.0 0.99 0.0 0.00 NO-INFILT. 0.00 119.1 1548.9 FL3 Toilet C 1.0 INT 0.0 0.99 0.0 0.00 NO-INFILT. 0.00 84.1 1093.0 FL3 MDF 1.0 EXT 0.0 0.42 0.0 7.50 AIR-CHANGE 0.31 358.7 4662.7 FL3 Stairs A 1.0 EXT 0.0 0.69 0.0 0.00 AIR-CHANGE 0.31 322.3 4190.4	FL3 Classroom C	1.0	EXT	0.0	1.12	44.0	0.25	ATR-CHANGE	0.31	1013.0	13168.9		
FL3 Toilets B 1.0 INT 0.0 0.99 0.0 0.00 NO-INFILT. 0.00 125.3 1629.3 FL3 Classroom D 1.0 EXT 90.0 1.12 41.3 0.25 AIR-CHANGE 0.31 949.2 12339.5 FL3 Stairs B 1.0 EXT 0.0 0.69 0.0 0.00 NO-INFILT. 0.00 119.1 4538.8 FL3 Toilet C 1.0 INT 0.0 0.99 0.0 0.00 NO-INFILT. 0.00 119.1 1548.9 FL3 Toilet D 1.0 INT 0.0 0.99 0.0 0.00 NO-INFILT. 0.00 119.1 1548.9 FL3 Toilet D 1.0 INT 0.0 0.99 0.0 0.00 NO-INFILT. 0.00 84.1 1093.0 FL3 Elevators 1.0 INT 0.0 0.00 0.00 AIR-CHANGE 0.31 358.7 4662.7 FL3 Stairs A 1.0 INT 0.0 0.00 0.00 AIR-CHANGE 0.31 322.3 4190.4 FL3 Classroom E <td< td=""><td>FL3 Toilets A</td><td>1.0</td><td>TNT</td><td>0.0</td><td>0.99</td><td>0.0</td><td>0.00</td><td>NO-INFILT.</td><td>0.00</td><td>133.6</td><td>1736.3</td><td></td></td<>	FL3 Toilets A	1.0	TNT	0.0	0.99	0.0	0.00	NO-INFILT.	0.00	133.6	1736.3		
FL3 Classroom D 1.0 EXT 90.0 1.12 41.3 0.25 AIR-CHANGE 0.31 949.2 12339.5 FL3 Stairs B 1.0 EXT 90.0 1.12 41.3 0.25 AIR-CHANGE 0.31 349.1 4538.8 FL3 Toilet C 1.0 INT 0.0 0.99 0.0 0.00 NO-INFILT. 0.00 119.1 1548.9 FL3 Toilet D 1.0 INT 0.0 0.99 0.0 0.00 NO-INFILT. 0.00 84.1 1093.0 FL3 MDF 1.0 EXT 0.0 0.42 0.0 7.50 AIR-CHANGE 0.31 358.7 4662.7 FL3 Elevators 1.0 INT 0.0 0.00 0.00 AIR-CHANGE 0.31 322.3 4190.4 FL3 Elevators 1.0 INT 0.0 0.69 0.0 0.00 AIR-CHANGE 0.31 322.3 4190.4 FL3 Toilet E 1.0 INT 0.0 0.42 0.0 0.00 NO	FL3 Toilets B	1.0	TNT	0.0	0.99	0.0	0.00	NO-INFILT.	0.00	125.3	1629.3		
FL3 Classform B 1.0 EXT 0.0 0.112 11.15 0.125 MAR CHARGE 0.011 14538.8 FL3 Stairs B 1.0 EXT 0.0 0.69 0.0 0.00 AIR-CHARGE 0.31 349.1 4538.8 FL3 Toilet C 1.0 INT 0.0 0.99 0.0 0.00 NO-INFILT. 0.00 119.1 1548.9 FL3 Toilet D 1.0 INT 0.0 0.99 0.0 0.00 NO-INFILT. 0.00 84.1 1093.0 FL3 MDF 1.0 EXT 0.0 0.42 0.0 7.50 AIR-CHANGE 0.31 358.7 4662.7 FL3 Elevators 1.0 INT 0.0 0.00 0.00 AIR-CHANGE 0.31 322.3 4190.4 FL3 Stairs A 1.0 EXT 0.0 1.12 41.1 0.25 AIR-CHANGE 0.31 322.3 4190.4 FL3 Classroom E 1.0 INT 0.0 0.42 0.0 0.00 NO-INFILT.	FL3 Classroom D	1 0	FYT	90.0	1 12	41 3	0 25	ATR-CHANGE	0 31	949 2	12339 5		
FL3 Dial Dia Dial Dial <	FL3 Stairs B	1 0	FYT	0.0	0 69	0.0	0.00	ATR-CHANGE	0 31	349 1	4538 8		
FL3 Toilet D 1.0 INT 0.0 0.99 0.0 0.00 NO INFILT 0.00 110 111 1093.0 FL3 Toilet D 1.0 INT 0.0 0.99 0.0 0.00 NO INFILT 0.00 84.1 1093.0 FL3 MDF 1.0 EXT 0.0 0.42 0.0 7.50 AIR-CHANGE 0.31 358.7 4662.7 FL3 Elevators 1.0 INT 0.0 0.00 0.00 AIR-CHANGE 0.31 322.3 4190.4 FL3 Classroom E 1.0 EXT 0.0 0.69 0.0 0.00 AIR-CHANGE 0.31 322.3 4190.4 FL3 Classroom E 1.0 EXT 0.0 1.12 41.1 0.25 AIR-CHANGE 0.31 322.3 4190.4 FL3 Classroom E 1.0 INT 0.0 0.99 0.0 0.00 NO-INFILT 0.00 62.6 814.1 FL3 Classroom F 1.0 INT 0.0 0.42 0.0 0.00 NO-INFILT 0.00 61.8 803.3 F	FL3 Toilet C	1 0	TNT	0.0	0.99	0.0	0.00	NO-INFILT	0 00	119 1	1548 9		
FL3 NDF 1.0 EXT 0.0 0.00 0.00 NO FATHER 0.00 0.00 0.00 0.00 0.00 0.00 0.00 0.00 0.00 0.00 0.00 0.01 196.5 2554.0 FL3 Stairs A 1.0 EXT 0.0 0.69 0.0 0.00 AIR-CHANGE 0.31 322.3 4190.4 FL3 Classroom E 1.0 EXT 0.0 0.69 0.0 0.00 AIR-CHANGE 0.31 322.3 4190.4 FL3 Classroom E 1.0 EXT 0.0 1.12 41.1 0.25 AIR-CHANGE 0.31 946.1 12299.9 FL3 Toilet E 1.0 INT 0.0 0.99 0.0 0.00 NO-INFILT. 0.00 62.6 814.1 FL3 Elec 1.0 INT 0.0 0.42 0.0 0.00 NO-INFILT. 0.00 61.8 803.3 FL3 Corridor 1.0 EXT 90.0 0.66 0.00 AIR-CHANGE 0.31 1093.1 14209.7 FL3 Comp / AV 1.0 INT 0.0 0	FL3 Toilet D	1 0	TNT	0.0	0.99	0.0	0.00	NO-INFILT	0.00	84 1	1093 0		
FL3 Elevators 1.0 INT 0.0 0.0 0.0 AIR-CHANGE 0.31 196.5 2554.0 FL3 Elevators 1.0 INT 0.0 0.69 0.0 AIR-CHANGE 0.31 196.5 2554.0 FL3 Stairs A 1.0 EXT 0.0 0.69 0.0 AIR-CHANGE 0.31 322.3 4190.4 FL3 Classroom E 1.0 EXT 0.0 1.12 41.1 0.25 AIR-CHANGE 0.31 946.1 12299.9 FL3 Toilet E 1.0 INT 0.0 0.99 0.0 0.00 NO-INFILT. 0.00 62.6 814.1 FL3 Elec 1.0 INT 0.0 0.42 0.0 0.00 NO-INFILT. 0.00 61.8 803.3 FL3 Corridor 1.0 EXT 90.0 0.66 0.0 0.00 AIR-CHANGE 0.31 1093.1 14209.7 FL3 Comp / AV 1.0 INT 0.0 0.42 0.0 7.50 NO-INFILT. 0.00 <td< td=""><td>FL3 MDF</td><td>1 0</td><td>FYT</td><td>0.0</td><td>0.42</td><td>0.0</td><td>7 50</td><td>ATR-CHANGE</td><td>0.00</td><td>358 7</td><td>4662 7</td><td></td></td<>	FL3 MDF	1 0	FYT	0.0	0.42	0.0	7 50	ATR-CHANGE	0.00	358 7	4662 7		
FL3 Stairs A 1.0 EXT 0.0 0.69 0.0 0.00 AIR-CHANGE 0.31 322.3 4190.4 FL3 Classroom E 1.0 EXT 0.0 1.12 41.1 0.25 AIR-CHANGE 0.31 322.3 4190.4 FL3 Classroom E 1.0 EXT 0.0 1.12 41.1 0.25 AIR-CHANGE 0.31 322.3 4190.4 FL3 Classroom E 1.0 EXT 0.0 1.12 41.1 0.25 AIR-CHANGE 0.31 322.3 4190.4 FL3 Toilet E 1.0 INT 0.0 0.99 0.0 0.00 NO-INFILT. 0.00 62.6 814.1 FL3 Elec 1.0 INT 0.0 0.42 0.0 0.00 NO-INFILT. 0.00 61.8 803.3 FL3 Corridor 1.0 EXT 90.0 0.66 0.0 0.00 AIR-CHANGE 0.31 1093.1 14209.7 FL3 Comp / AV 1.0 INT 0.0 0.42 0.0 <td< td=""><td>FL3 Elevators</td><td>1 0</td><td>TNT</td><td>0.0</td><td>0.12</td><td>0.0</td><td>0.00</td><td>ATR-CHANGE</td><td>0 31</td><td>196 5</td><td>2554 0</td><td></td></td<>	FL3 Elevators	1 0	TNT	0.0	0.12	0.0	0.00	ATR-CHANGE	0 31	196 5	2554 0		
FL3 Classroom E 1.0 EXT 0.0 1.12 41.1 0.25 AIR-CHANGE 0.31 946.1 12299.9 FL3 Toilet E 1.0 INT 0.0 0.99 0.0 0.00 NO-INFILT. 0.00 62.6 814.1 FL3 Toilet E 1.0 INT 0.0 0.42 0.0 0.00 NO-INFILT. 0.00 61.8 803.3 FL3 Corridor 1.0 EXT 90.0 0.66 0.00 AIR-CHANGE 0.31 1093.1 14209.7 FL3 Comp / AV 1.0 INT 0.0 0.42 0.0 750 NO-INFILT. 0.00 59.2 769.6 FL3 Supervisory 1.0 EXT 0.0 1.00 2.0 1.25 AIR-CHANGE 0.31 195.8 2544.8 FL3 Classroom F 1.0 EXT 90.0 1.12 43.7 0.25 AIR-CHANGE 0.31 1905.6 13073.0	FL3 Staire A	1 0	<u>тит</u>	0.0	0 69	0.0	0 00	ATR-CHANGE	0 31	322 3	4190 4		
FL3 Collected 1.0 INT 0.0 0.99 0.0 0.00 NO-INFILT. 0.00 62.6 814.1 FL3 Toilet E 1.0 INT 0.0 0.99 0.0 0.00 NO-INFILT. 0.00 62.6 814.1 FL3 Elec 1.0 INT 0.0 0.42 0.0 0.00 NO-INFILT. 0.00 61.8 803.3 FL3 Corridor 1.0 EXT 90.0 0.66 0.0 0.00 AIR-CHANGE 0.31 1093.1 14209.7 FL3 Comp / AV 1.0 INT 0.0 0.42 0.0 7.50 NO-INFILT. 0.00 59.2 769.6 FL3 Supervisory 1.0 EXT 0.0 1.00 2.0 1.25 AIR-CHANGE 0.31 195.8 2544.8 FL3 Classroom F 1.0 EXT 90.0 1.12 43.7 0.25 AIR-CHANGE 0.31 1905.6 13073.0	FL3 Classroom E	1 0	EXT	0.0	1 12	41 1	0.25	ATR-CHANCE	0.31	946 1	12299 9		
FL3 For the first	FL3 Toilet E	1.0	TNT	0.0	0.99	0.0	0.00	NO-TNETLT	0.00	62 6	814.1		
FL3 Corridor 1.0 EXT 90.0 0.66 0.00 AIR-CHANGE 0.31 1093.1 14209.7 FL3 Corridor 1.0 INT 0.0 0.42 0.0 7.50 NO-INFILT. 0.00 59.2 769.6 FL3 Supervisory 1.0 EXT 0.0 1.00 2.0 1.25 AIR-CHANGE 0.31 195.8 2544.8 FL3 Classroom F 1.0 EXT 90.0 1.12 43.7 0.25 AIR-CHANGE 0.31 1005.6 13073.0	FL3 Elec	1.0	TNT	0.0	0.42	0.0	0.00	NO-TNETLT	0.00	61 8	803.3		
FL3 Comp / AV 1.0 INT 0.0 0.00 0.00 NO-INFILT. 0.00 59.2 769.6 FL3 Supervisory 1.0 EXT 0.0 1.00 2.0 1.25 AIR-CHANGE 0.31 195.8 2544.8 FL3 Classroom F 1.0 EXT 90.0 1.12 43.7 0.25 AIR-CHANGE 0.31 1005.6 13073.0	FL3 Corridor	1.0	EXT	90.0	0.66	0.0	0.00	ATR-CHANCE	0.31	1093 1	14209.7		
FL3 Supervisory 1.0 EXT 0.0 1.0 2.0 1.25 AIR-CHANGE 0.31 195.8 2544.8 FL3 Classroom F 1.0 EXT 90.0 1.12 43.7 0.25 AIR-CHANGE 0.31 1005.6 13073.0	FL3 Comp / AV	1 0	TNT	0 0	0 42	0.0	7 50	NO-TNETT.T	0.00	50 2	769 6		
FL3 Classroom F 1.0 EXT 90.0 1.12 43.7 0.25 ATR-CHANGE 0.31 1005.6 13073.0	FI.3 Supervisory	1 0	2191 2191	0.0	1 00	2 0	1 25	ATR-CUANCE	0.00	105 0	2544 Q		
	FL3 Classroom F	1.0	EXT	90.0	1,12	43.7	0.25	AIR-CHANGE	0.31	1005.6	13073.0		

Spaces on floor: FL4 Ground Flr

FL4 Classroom B 1.0 EXT 90.0 1.12 64.4 0.25 AIR-CHANGE 0.31 1480.3 19 FL4 Classroom C 1.0 EXT 0.0 1.12 46.8 0.25 AIR-CHANGE 0.31 1077.2 14	9244.5 4003.1 2339.5 4538.8
FL4 Classroom C 1.0 EXT 0.0 1.12 46.8 0.25 AIR-CHANGE 0.31 1077.2 14	4003.1 2339.5 4538.8
	2339.5 1538.8
FL4 Classroom D 1.0 EXT 90.0 1.12 41.3 0.25 AIR-CHANGE 0.31 949.2 12	4538.8
FL4 Stairs B 1.0 EXT 0.0 0.69 0.0 0.00 AIR-CHANGE 0.31 349.1 4	1548 9
FL4 Toilet C 1.0 INT 0.0 0.99 0.0 0.00 NO-INFILT. 0.00 119.1 1	1940.9
FL4 Comp / AV 1.0 INT 0.0 0.42 0.0 7.50 NO-INFILT. 0.00 67.2	873.1
FL4 Staff Lunch / Conf 1.0 EXT -90.0 0.65 34.2 0.00 AIR-CHANGE 0.31 615.8 8	3005.2
FL4 Elevators 1.0 INT 0.0 0.00 0.00 NO-INFILT. 0.00 196.5 2	2554.0
FL4 Stairs A 1.0 EXT 0.0 0.69 0.0 0.00 AIR-CHANGE 0.31 322.3 4	1190.4
FL4 Classroom E 1.0 EXT 0.0 1.12 39.2 0.25 AIR-CHANGE 0.31 901.1 11	L713.8
FL4 Toilet D 1.0 INT 0.0 0.99 0.0 0.00 NO-INFILT. 0.00 107.7 1	L400.3
FL4 Elec 1.0 INT 0.0 0.42 0.0 0.00 NO-INFILT. 0.00 61.8	803.3
FL4 Corridor 1.0 EXT 90.0 0.66 0.0 0.00 AIR-CHANGE 0.31 1032.4 13	3421.4

PS 33X Jerome Ave 3

DOE-2.2-48y 7/24/2018 17:06:37 BDL RUN 1

REPORT- LV-B Summary of Spaces								WEAT	HER FILE- NEW	YORK LAGUARDI NY
FL4 Staff	1.0	INT	0.0	0.99	0.0	0.00	NO-INFILT.	0.00	76.1	989.5
FL4 Classroom F	1.0	EXT	90.0	1.12	35.5	0.25	AIR-CHANGE	0.31	817.3	10624.6
Spaces on floor: FL5 Ground Flr										
FL5 Classroom A	1.0	EXT	0.0	1.12	33.7	0.25	AIR-CHANGE	0.27	775.0	11624.8
FL5 Classroom B	1.0	EXT	90.0	1.12	41.3	0.25	AIR-CHANGE	0.27	949.2	14237.9
FL5 Stairs B	1.0	EXT	0.0	0.69	0.0	0.00	AIR-CHANGE	0.27	349.1	5237.1
FL5 Toilet A	1.0	EXT	0.0	0.99	0.0	0.00	NO-INFILT.	0.00	119.1	1787.2
FL5 Toilet B	1.0	EXT	0.0	0.99	0.0	0.00	NO-INFILT.	0.00	79.6	1194.0
FL5 Classroom C	1.0	EXT	-90.0	1.12	29.5	0.25	AIR-CHANGE	0.27	679.5	10192.0
FL5 Elevators	1.0	INT	0.0	0.00	0.0	0.00	NO-INFILT.	0.00	196.5	2946.9
FL5 Stairs A	1.0	EXT	0.0	0.69	0.0	0.00	AIR-CHANGE	0.27	322.3	4835.0
FL5 Library	1.0	EXT	0.0	1.06	15.5	0.50	AIR-CHANGE	0.27	901.1	13515.9
FL5 Toilet C	1.0	EXT	0.0	0.99	0.0	0.00	NO-INFILT.	0.00	107.7	1615.7
FL5 Elec	1.0	EXT	0.0	0.42	0.0	0.00	NO-INFILT.	0.00	61.8	926.9
FL5 Corridor	1.0	EXT	90.0	0.66	0.0	0.00	AIR-CHANGE	0.27	1032.4	15486.3
FL5 Classroom D	1.0	EXT	180.0	1.12	78.1	0.25	AIR-CHANGE	0.27	1795.3	26929.1
FL5 Boiler Room	1.0	EXT	90.0	0.42	0.0	0.00	AIR-CHANGE	0.27	1339.7	20096.0
FL5 Closets	1.0	EXT	0.0	0.63	0.0	0.00	NO-INFILT.	0.00	347.1	5206.7
Spaces on floor: R Ground Flr										
R Elevator Machine Room	1.0	EXT	180.0	0.42	0.0	0.00	AIR-CHANGE	0.34	403.0	4836.5
R Elevators	1.0	EXT	0.0	0.00	0.0	0.00	AIR-CHANGE	0.34	178.1	2137.1
R Corridor	1.0	EXT	90.0	0.66	0.0	0.00	AIR-CHANGE	0.34	65.5	786.5
R Stairs A	1.0	EXT	90.0	0.69	0.0	0.00	AIR-CHANGE	0.34	298.7	3584.4
BUILDING TOTALS					1234.9				49128.7	652732.6

Page 160 of 310

REPORT- LV-D Details of Exterior Surfaces

WEATHER FILE- NEW YORK LAGUARDI NY

MEATINER FINE- NEW TORK LAGOARDI NI

NUMBER OF EXTERIOR SURFACES 182 (U-VALUE INCLUDES OUTSIDE FILM; WINDOW INCLUDES FRAME AND CURB, IF DEFINED)

	W I N D O W	s	W A L L		-WALL+WIN	DOWS-	
SURFACE	U-VALUE	AREA	U-VALUE	AREA	U-VALUE	AREA	AZIMUTH
	(BTU/HR-SQFT-F)	(SQFT)	(BTU/HR-SQFT-F)	(SQFT)	(BTU/HR-SQFT-F)	(SQFT)	
FL1 NE Wall (G.NNE1.E2)	0.551	45.00	0.064	62.90	0.267	107.90	NORTH-EAST
in space: FL1 Exercise Room							
FL1 NE Wall (G.NNE1.E4)	0.000	0.00	0.064	473.20	0.064	473.20	NORTH-EAST
in space: FL1 Exercise Room							
FL1 NE Wall (G.NNW10.E11)	0.000	0.00	0.064	42.90	0.064	42.90	NORTH-EAST
in space: FL1 Bike Storage							
FL1 NE Wall (G.E22.E24)	0.000	0.00	0.064	120.25	0.064	120.25	NORTH-EAST
in space: FL1 Can Wash							
FL1 NE Wall (G.NE23.E26)	0.000	0.00	0.064	68.90	0.064	68.90	NORTH-EAST
in space: FL1 Dietition's Office	1						
FL1 NE Wall (G.NE24.E27)	0.000	0.00	0.064	180.05	0.064	180.05	NORTH-EAST
in space: FL1 Locker Rooms							
FL1 NE Wall (G.NNE25.E29)	0.000	0.00	0.064	95.55	0.064	95.55	NORTH-EAST
in space: FL1 Toilet B							
FL2 NE Wall (G.E1.E1)	0.000	0.00	0.064	462.15	0.064	462.15	NORTH-EAST
in space: FL2 Classroom A							
FL2 NE Wall (G.N6.E8)	0.000	0.00	0.064	473.20	0.064	473.20	NORTH-EAST
in space: FL2 Classroom D							
FL2 NE Wall (G.W15.E19)	0.000	0.00	0.064	113.75	0.064	113.75	NORTH-EAST
in space: FL2 Classroom E							
FL2 NE Wall (G.C18.E20)	0.551	45.00	0.064	65.50	0.263	110.50	NORTH-EAST
in space: FL2 Corridor							
FL3 NE Wall (G.E1.E1)	0.000	0.00	0.064	462.15	0.064	462.15	NORTH-EAST
in space: FL3 Classroom A							
FL3 NE Wall (G.N6.E8)	0.000	0.00	0.064	473.20	0.064	473.20	NORTH-EAST
in space: FL3 Classroom D							
FL3 NE Wall (G.W13.E18)	0.000	0.00	0.064	113.75	0.064	113.75	NORTH-EAST
in space: FL3 Classroom E							
FL3 NE Wall (G.C16.E19)	0.551	45.00	0.064	65.50	0.263	110.50	NORTH-EAST
in space: FL3 Corridor							
FL4 NE Wall (G.E1.E1)	0.000	0.00	0.064	462.15	0.064	462.15	NORTH-EAST
in space: FL4 Classroom A							
FL4 NE Wall (G.N6.E8)	0.000	0.00	0.064	473.20	0.064	473.20	NORTH-EAST
in space: FL4 Classroom D							
FL4 NE Wall (G.W13.E18)	0.000	0.00	0.064	113.75	0.064	113.75	NORTH-EAST
in space: FL4 Classroom E							
FL4 NE Wall (G.NE16.E19)	0.551	45.00	0.064	65.50	0.263	110.50	NORTH-EAST

FL4 Corridor							
(G.N2.E5)	0.000	0.00	0.064	546.00	0.064	546.00	NORTH-EAST
FL5 Classroom B							
(G.W9.E22)	0.000	0.00	0.064	131.25	0.064	131.25	NORTH-EAST
FL5 Library							
(G.NE12.E26)	0.551	45.00	0.064	82.50	0.236	127.50	NORTH-EAST
FL5 Corridor							
(G.E14.E31)	0.000	0.00	0.064	533.25	0.064	533.25	NORTH-EAST
FL5 Boiler Room							
G.E1.E2)	0.000	0.00	0.064	235.20	0.064	235.20	NORTH-EAST
R Elevator Machine Room							
•	FL4 Corridor (G.N2.E5) FL5 Classroom B (G.W9.E22) FL5 Library (G.NE12.E26) FL5 Corridor (G.E14.E31) FL5 Boiler Room G.E1.E2) R Elevator Machine Room	FL4 Corridor (G.N2.E5) 0.000 FL5 Classroom B 0.000 FL5 Library 0.000 FL5 Library 0.551 FL5 Corridor 0.000 FL5 Eoiler Room 0.000 FL5 Eoiler Room 0.000 R Elevator Machine Room 0.000	FL4 Corridor (G.N2.E5) 0.000 0.00 FL5 Classroom B 0.000 0.00 (G.W9.E22) 0.000 0.00 FL5 Library 0.551 45.00 (G.NE12.E26) 0.551 45.00 FL5 Corridor 0.000 0.00 FL5 Boiler Room 0.000 0.00 G.E1.E2) 0.000 0.00 R Elevator Machine Room 0.000 0.00	FL4 Corridor (G.N2.E5) 0.000 0.000 0.064 FL5 Classroom B 0.000 0.000 0.064 (G.W9.E22) 0.000 0.000 0.064 FL5 Library 0.551 45.00 0.064 FL5 Corridor 0.000 0.000 0.064 FL5 Eoiler Room 0.000 0.000 0.064 FL5 Eoiler Room 0.000 0.000 0.064 R Elevator Machine Room 0.000 0.000 0.064	FL4 Corridor (G.N2.E5) 0.000 0.00 0.064 546.00 FL5 Classroom B 0.000 0.000 0.064 131.25 (G.W9.E22) 0.000 0.000 0.064 131.25 FL5 Library 0.551 45.00 0.064 82.50 FL5 Corridor 0.000 0.000 0.064 533.25 FL5 Boiler Room 0.000 0.000 0.064 235.20 R Elevator Machine Room 0.000 0.000 0.064 235.20	FL4 Corridor (G.N2.E5) 0.000 0.00 0.064 546.00 0.064 FL5 Classroom B 0.000 0.000 0.064 131.25 0.064 (G.W9.E22) 0.000 0.000 0.064 131.25 0.064 FL5 Library (G.NE12.E26) 0.551 45.00 0.064 82.50 0.236 FL5 Corridor (G.E14.E31) 0.000 0.000 0.064 533.25 0.064 FL5 Boiler Room G.E1.E2) 0.000 0.000 0.064 235.20 0.064	FL4 Corridor (G.N2.E5) 0.000 0.000 0.064 546.00 0.064 546.00 FL5 Classroom B (G.W9.E22) 0.000 0.000 0.064 131.25 0.064 131.25 FL5 Library (G.NE12.E26) 0.551 45.00 0.064 82.50 0.236 127.50 FL5 Corridor (G.E14.E31) 0.000 0.000 0.064 533.25 0.064 533.25 FL5 Boiler Room G.E1.E2) 0.000 0.000 0.064 235.20 0.064 235.20

PS 33X Jerome Ave 3

REPORT- LV-D Details of Exterior Sur	faces				WEATHER FIL	E- NEW YORK LA	GUARDI NY
R NE Wall (G.W4.E11)	0.000	0.00	0.064	197.40	0.064	197.40	NORTH-EAST
Exterior Wall 145	0.551	180.00	0.064	212.60	0.288	392.60	SOUTH-EAST
Exterior Wall 149	0.000	0.00	0.064	0.65	0.064	0.65	SOUTH-EAST
Exterior Wall 150	0.000	0.00	0.064	0.65	0.064	0.65	SOUTH-EAST
FLI SE Wall (G.SE21.E23)	0.551	21.00	0.064	219.50	0.107	240.50	SOUTH-EAST
FL3 SE Wall (G.SE2.E4)	0.551	180.00	0.064	200.25	0.295	380.25	SOUTH-EAST
Exterior Wall 152	0.000	0.00	0.064	0.65	0.064	0.65	SOUTH-EAST
Exterior Wall 153	0.000	0.00	0.064	0.65	0.064	0.65	SOUTH-EAST
Exterior Wall 154	0.000	0.00	0.064	0.65	0.064	0.65	SOUTH-EAST
FL3 SE Wall (G.S3.E7)	0.551	180.00	0.064	213.90	0.287	393.90	SOUTH-EAST
Exterior Wall 143	0.000	0.00	0.064	175.50	0.064	175.50	SOUTH-EAST
FL3 SE Wall (G.N6.E11)	0.000	0.00	0.064	40.95	0.064	40.95	SOUTH-EAST
FL3 SE Wall (G.W13.E17)	0.000	0.00	0.064	33.15	0.064	33.15	SOUTH-EAST
Exterior Wall 144	0.551	21.00	0.064	89.50	0.157	110.50	SOUTH-EAST
FLI SE Wall (G.NNE1.E3)	0.000	0.00	0.064	40.95	0.064	40.95	SOUTH-EAST
Exterior Wall 151	0.551	180.00	0.064	212.60	0.288	392.60	SOUTH-EAST
Exterior Wall 155	0.000	0.00	0.064	0.65	0.064	0.65	SOUTH-EAST
Exterior Wall 156	0.000	0.00	0.064	0.65	0.064	0.65	SOUTH-EAST
in space: FL3 Classroom F FL2 SE Wall (G.SE2.E4)	0.000	0.00	0.064	0.65	0.064	0.65	SOUTH-EAST

	<u>New York City</u>	Public Schoo	l PS 33X End	ergy Model R	eport		
in space: FL2 Classroom B							
FL4 SE Wall (G.SE2.E4)	0.551	210.00	0.064	330.15	0.254	540.15	SOUTH-EAST
in space: FL4 Classroom B							
Exterior Wall 158	0.000	0.00	0.064	0.65	0.064	0.65	SOUTH-EAST
in space: FL4 Classroom B							
Exterior Wall 159	0.000	0.00	0.064	0.65	0.064	0.65	SOUTH-EAST
in space: FL4 Classroom B							
Exterior Wall 160	0.000	0.00	0.064	0.65	0.064	0.65	SOUTH-EAST
in space: FL4 Classroom B							
FL4 SE Wall (G.S3.E7)	0.551	150.00	0.064	243.90	0.250	393.90	SOUTH-EAST
in space: FL4 Classroom C							
Exterior Wall 146	0.551	180.00	0.064	200.25	0.295	380.25	SOUTH-EAST
in space: FL2 Classroom B							
FL4 SE Wall (G.N6.E11)	0.000	0.00	0.064	40.95	0.064	40.95	SOUTH-EAST
in space: FL4 Classroom D							
FL4 SE Wall (G.W13.E17)	0.000	0.00	0.064	33.15	0.064	33.15	SOUTH-EAST
in space: FL4 Classroom E							
Exterior Wall 147	0.000	0.00	0.064	0.65	0.064	0.65	SOUTH-EAST
in space: FL2 Classroom B							
Exterior Wall 148	0.000	0.00	0.064	0.65	0.064	0.65	SOUTH-EAST
in space: FL2 Classroom B							

REPORT- LV-D Details of Exterior Surf	faces				WEATHER FIL	E- NEW YORK LA	GUARDI NY
Exterior Wall 157	0.551	120.00	0.064	177.70	0.261	297.70	SOUTH-EAST
in space: FL4 Classroom F							
Exterior Wall 161	0.000	0.00	0.064	0.65	0.064	0.65	SOUTH-EAST
in space: FL4 Classroom F							
Exterior Wall 162	0.000	0.00	0.064	0.65	0.064	0.65	SOUTH-EAST
in space: FL4 Classroom F							
FL5 SE Wall (G.SSW1.E3)	0.551	120.00	0.064	207.00	0.243	327.00	SOUTH-EAST
in space: FL5 Classroom A							
FL2 SE Wall (G.S3.E7)	0.551	180.00	0.064	213.90	0.287	393.90	SOUTH-EAST
in space: FL2 Classroom C							
FL5 SE Wall (G.N2.E8)	0.000	0.00	0.064	47.25	0.064	47.25	SOUTH-EAST
in space: FL5 Classroom B							
FL5 SE Wall (G.W9.E21)	0.000	0.00	0.064	38.25	0.064	38.25	SOUTH-EAST
in space: FL5 Library							
FL1 SE Wall (G.E22.E25)	0.000	0.00	0.064	132.60	0.064	132.60	SOUTH-EAST
in space: FL1 Can Wash							
FL2 SE Wall (G.N6.E11)	0.000	0.00	0.064	40.95	0.064	40.95	SOUTH-EAST
in space: FL2 Classroom D							
FL5 SE Wall (G.SE13.E29)	0.551	240.00	0.064	517.50	0.219	757.50	SOUTH-EAST
in space: FL5 Classroom D							
FL2 SE Wall (G.W15.E18)	0.000	0.00	0.064	33.15	0.064	33.15	SOUTH-EAST
in space: FL2 Classroom E							
FL5 SE Wall (G.E14.E33)	0.551	240.00	0.064	471.75	0.229	711.75	SOUTH-EAST
in space: FL5 Boiler Room							
R SE Wall (G.E1.E1)	0.000	0.00	0.064	355.80	0.064	355.80	SOUTH-EAST
in space: R Elevator Machine Room							
FL1 SE Wall (G.WSW12.E17)	0.000	0.00	0.064	33.15	0.064	33.15	SOUTH-EAST

in space: FL1 Supervisory Office							
R SE Wall (G.SSE3.E9)	0.000	0.00	0.064	140.40	0.064	140.40	SOUTH-EAST
in space: R Corridor							
FL1 SE Wall (G.SSE15.E21)	0.551	277.50	0.064	626.00	0.214	903.50	SOUTH-EAST
in space: FL1 Cafeteria							
FL2 SE Wall (G.E1.E3)	0.551	180.00	0.064	206.75	0.291	386.75	SOUTH-EAST
in space: FL2 Classroom A							
FL3 SE Wall (G.E1.E3)	0.551	180.00	0.064	206.75	0.291	386.75	SOUTH-EAST
in space: FL3 Classroom A							
FL4 SE Wall (G.E1.E3)	0.551	120.00	0.064	201.10	0.246	321.10	SOUTH-EAST
in space: FL4 Classroom A							
R SW Wall (G.W4.E13)	0.000	0.00	0.064	309.01	0.064	309.01	SOUTH
in space: R Stairs A							
FL1 SW Wall (G.WSW14.E20)	0.000	0.00	0.064	139.13	0.064	139.13	SOUTH
in space: FL1 Boys							
FL4 SW Wall (G.NE16.E20)	0.551	30.00	0.064	74.00	0.205	104.00	SOUTH-WEST
in space: FL4 Corridor							
FL1 SW Wall (G.C28.E30)	0.000	0.00	0.064	12.35	0.064	12.35	SOUTH-WEST
in space: FL1 Corridor							
FL1 SW Wall (G.SW13.E18)	0.000	0.00	0.064	104.00	0.064	104.00	SOUTH-WEST
in space: FL1 Vestibule B							
FL1 SW Wall (G.W11.E13)	0.000	0.00	0.064	150.15	0.064	150.15	SOUTH-WEST
in space: FL1 Vestibule A							
FL5 SW Wall (G.SSW1.E2)	0.551	30.00	0.064	503.25	0.092	533.25	SOUTH-WEST
in space: FL5 Classroom A							
FL3 SW Wall (G.S3.E6)	0.551	30.00	0.064	432.15	0.096	462.15	SOUTH-WEST
in space: FL3 Classroom C							
FL2 SW Wall (G.C18.E21)	0.551	30.00	0.064	74.00	0.205	104.00	SOUTH-WEST
in space: FL2 Corridor							
FL5 SW Wall (G.N2.E7)	0.000	0.00	0.064	131.25	0.064	131.25	SOUTH-WEST
in space: FL5 Classroom B							

PS 33X Jerome Ave 3

REPORT- LV-	D Details of Exterior Surfa	ces				WEATHER FILE	- NEW YORK LA	GUARDI NY
FL2 SW Wall	(G.S3.E6)	0.551	30.00	0.064	432.15	0.096	462.15	SOUTH-WEST
in space:	FL2 Classroom C							
FL5 SW Wall	(G.W9.E20)	0.551	90.00	0.064	463.50	0.143	553.50	SOUTH-WEST
in space:	FL5 Library							
FL3 SW Wall	(G.N6.E10)	0.000	0.00	0.064	113.75	0.064	113.75	SOUTH-WEST
in space:	FL3 Classroom D							
FL1 SW Wall	(G.WSW12.E16)	0.551	90.00	0.064	156.35	0.242	246.35	SOUTH-WEST
in space:	FL1 Supervisory Office							
FL4 SW Wall	(G.S3.E6)	0.551	30.00	0.064	432.15	0.096	462.15	SOUTH-WEST
in space:	FL4 Classroom C							
FL5 SW Wall	(G.NE12.E27)	0.551	30.00	0.064	90.00	0.186	120.00	SOUTH-WEST
in space:	FL5 Corridor							
FL3 SW Wall	(G.W13.E16)	0.551	60.00	0.064	419.70	0.125	479.70	SOUTH-WEST
in space:	FL3 Classroom E							
FL1 SW Wall	(G.SSE15.E22)	0.551	52.50	0.064	271.20	0.143	323.70	SOUTH-WEST
in space:	FL1 Cafeteria							
FL4 SW Wall	(G.N6.E10)	0.000	0.00	0.064	113.75	0.064	113.75	SOUTH-WEST

in space:	FL4 Classroom D							
FL2 SW Wall	(G.N6.E10)	0.000	0.00	0.064	113.75	0.064	113.75	SOUTH-WEST
in space:	FL2 Classroom D							
FL4 SW Wall	(G.W13.E16)	0.551	60.00	0.064	419.70	0.125	479.70	SOUTH-WEST
in space:	FL4 Classroom E							
R SW Wall (0	G.E1.E4)	0.000	0.00	0.064	55.80	0.064	55.80	SOUTH-WEST
in space:	R Elevator Machine Room							
FL1 SW Wall	(G.W2.E5)	0.000	0.00	0.064	113.10	0.064	113.10	SOUTH-WEST
in space:	FL1 Stairs B							
FL3 SW Wall	(G.C16.E20)	0.551	30.00	0.064	74.00	0.205	104.00	SOUTH-WEST
in space:	FL3 Corridor							
FL2 SW Wall	(G.W15.E17)	0.551	90.00	0.064	389.70	0.156	479.70	SOUTH-WEST
in space:	FL2 Classroom E							
R SW Wall (0	G.SSE3.E8)	0.000	0.00	0.064	67.84	0.064	67.84	SOUTH-WEST
in space:	R Corridor							
FL3 NW Wall	(G.N6.E9)	0.551	150.00	0.064	231.55	0.256	381.55	NORTH-WEST
in space:	FL3 Classroom D							
FL4 NW Wall	(G.NW7.E12)	0.551	36.00	0.064	128.45	0.171	164.45	NORTH-WEST
in space:	FL4 Stairs B							
FL4 NW Wall	(G.NW10.E13)	0.551	120.00	0.064	355.80	0.187	475.80	NORTH-WEST
in space:	FL4 Staff Lunch / Conf							
FL4 NW Wall	(G.NW12.E14)	0.551	36.00	0.064	116.10	0.180	152.10	NORTH-WEST
in space:	FL4 Stairs A							
FL4 NW Wall	(G.W13.E15)	0.551	150.00	0.064	232.85	0.255	382.85	NORTH-WEST
in space:	FL4 Classroom E							
FL2 NW Wall	(G.W15.E16)	0.551	150.00	0.064	232.85	0.255	382.85	NORTH-WEST
in space:	FL2 Classroom E							
FL2 NW Wall	(G.E1.E2)	0.000	0.00	0.064	40.95	0.064	40.95	NORTH-WEST
in space:	FL2 Classroom A							
FL3 NW Wall	(G.NW7.E12)	0.551	36.00	0.064	128.45	0.171	164.45	NORTH-WEST
in space:	FL3 Stairs B							
FL3 NW Wall	(G.NW10.E13)	0.551	60.00	0.064	201.95	0.176	261.95	NORTH-WEST
in space:	FL3 MDF							
FL3 NW Wall	(G.NW12.E14)	0.551	36.00	0.064	116.10	0.180	152.10	NORTH-WEST
in space:	FL3 Stairs A							
FL3 NW Wall	(G.W13.E15)	0.551	150.00	0.064	232.85	0.255	382.85	NORTH-WEST
in space:	FL3 Classroom E							
FL1 NW Wall	(G.W11.E14)	0.551	50.00	0.064	83.25	0.247	133.25	NORTH-WEST
in space:	FL1 Vestibule A							
FL1 NW Wall	(G.WSW12.E15)	0.000	0.00	0.064	139.75	0.064	139.75	NORTH-WEST
in space:	FL1 Supervisory Office							

PS 33X Jerome Ave 3

REPORT- LV-I) Details of Exterior Surfa	ces				WEATHER FIL	E- NEW YORK LA	GUARDI NY
							(CONTIN	UED)
FL5 NW Wall	(G.SSW1.E1)	0.000	0.00	0.064	38.25	0.064	38.25	NORTH-WEST
in space:	FL5 Classroom A							
FL1 NW Wall	(G.NW4.E7)	0.551	30.00	0.064	195.55	0.129	225.55	NORTH-WEST
in space:	FL1 Parents/Community							
FL1 NW Wall	(G.NW5.E8)	0.000	0.00	0.064	105.95	0.064	105.95	NORTH-WEST
in space:	FL1 Toilet A							
FL1 NW Wall	(G.NNE25.E28)	0.000	0.00	0.064	40.95	0.064	40.95	NORTH-WEST

in space:	FL1 Toilet B	0 551	150 00	0.064	200 25	0 0 0 0	440.05	NODELL MEGE
FL5 NW Wall	(G.NZ.ED) ELE Claggroom P	0.551	150.00	0.064	290.25	0.230	440.25	NORTH-WEST
TI Space:	(C MW18 F21)	0 551	90 00	0 064	123 85	0 269	213 85	
in space:	FL3 Supervisory	0.551	50.00	0.001	123.05	0.209	213.03	NORTH MEDI
FL2 NW Wall	(G.S3,E5)	0.000	0.00	0.064	33,15	0.064	33,15	NORTH-WEST
in space:	FL2 Classroom C		0.00	0.001	55115	0.001	55115	NORTH ADDI
FL5 NW Wall	(G.NW3.E10)	0.551	36.00	0.064	153.75	0.157	189.75	NORTH-WEST
in space:	FL5 Stairs B					••=•		
FL5 NW Wall	(G.NW6.E14)	0.551	180.00	0.064	369.00	0.224	549.00	NORTH-WEST
in space:	FL5 Classroom C							
FL5 NW Wall	(G.NW8.E17)	0.551	36.00	0.064	139.50	0.164	175.50	NORTH-WEST
in space:	FL5 Stairs A							
FL5 NW Wall	(G.W9.E19)	0.551	150.00	0.064	291.75	0.230	441.75	NORTH-WEST
in space:	FL5 Library							
FL1 NW Wall	(G.NW6.E9)	0.551	60.00	0.064	77.80	0.276	137.80	NORTH-WEST
in space:	FL1 Exam Room							
FL1 NW Wall	(G.NW7.E10)	0.000	0.00	0.064	169.65	0.064	169.65	NORTH-WEST
in space:	FL1 Stairs A							
FL3 NW Wall	(G.E1.E2)	0.000	0.00	0.064	40.95	0.064	40.95	NORTH-WEST
in space:	FL3 Classroom A							
FL4 NW Wall	(G.E1.E2)	0.000	0.00	0.064	40.95	0.064	40.95	NORTH-WEST
in space:	FL4 Classroom A							
FL1 NW Wall	(G.NNE1.E1)	0.551	180.00	0.064	200.90	0.294	380.90	NORTH-WEST
in space:	FLI Exercise Room		1 = 0 0 0		001 55			
FL2 NW Wall	(G.N6.E9)	0.551	150.00	0.064	231.55	0.256	381.55	NORTH-WEST
in space:	FLZ Classroom D	0 000	0.00	0.064	100 05	0.004	100 05	
FLI NW Wall	ELL Bike Chemage	0.000	0.00	0.064	109.85	0.064	109.85	NORTH-WEST
III Space:	(C E14 E22)	0 000	0.00	0 064	47 25	0 064	47 25	
in anado.	ELE Poilor Poom	0.000	0.00	0.004	47.25	0.004	4/.25	NORTH-WEST
FI.1 NW Wall	(G W2 F6)	0 000	0 00	0 064	154 05	0 064	154 05	NORTH-WEST
in space:	FL1 Stairs B	0.000	0.00	0.001	134.05	0.001	131.03	NORTH MEDI
FL2 NW Wall	(G.NW7.E12)	0.551	18.00	0.064	146.45	0.118	164.45	NORTH-WEST
in space:	FL2 Stairs B							
FL4 NW Wall	(G.S3.E5)	0.000	0.00	0.064	33.15	0.064	33.15	NORTH-WEST
in space:	FL4 Classroom C							
R NW Wall (G.E1.E3)	0.000	0.00	0.064	126.00	0.064	126.00	NORTH-WEST
in space:	R Elevator Machine Room							
FL3 NW Wall	(G.S3.E5)	0.000	0.00	0.064	33.15	0.064	33.15	NORTH-WEST
in space:	FL3 Classroom C							
R NW Wall (G.NW2.E6)	0.000	0.00	0.064	229.80	0.064	229.80	NORTH-WEST
in space:	R Elevators							
FL2 NW Wall	(G.NW11.E13)	0.551	37.50	0.064	60.65	0.250	98.15	NORTH-WEST
in space:	FL2 Toilet D							
FL2 NW Wall	(G.NW12.E14)	0.551	142.50	0.064	235.15	0.248	377.65	NORTH-WEST
in space:	FL2 Reading / Speech Resource	0 ==1			001 55	0.056		
FL4 NW Wall	(G.N6.E9)	0.551	150.00	0.064	231.55	0.256	381.55	NORTH-WEST
in space:	FL4 CLASSTOOM D	0 000	0.00	0.004	140 40	0.004	140 40	NODELL MECE
K NW Wall (G.W4.ELZ)	0.000	0.00	0.064	140.40	0.064	140.40	NORTH-WEST
In space:	A DUGILS A							

PS 33X Jerome Ave 3

New	York	Citv	Public	School	I PS	33X	Energy	/ Model	Ren	ort
1 . .	1 0111	C10,	1 000110	001100.			DITELS,	11100001	1.00	

REPORT- LV-D Details of Exterior Surf	aces				WEATHER FII	LE- NEW YORK LA	GUARDI NY
FL2 NW Wall (G.NW14.E15) in space: FL2 Stairs A	0.551	36.00	0.064	116.10	0.180	152.10	NORTH-WEST
FL1 NW Wall (G.WSW14.E19)	0.000	0.00	0.064	33.15	0.064	33.15	NORTH-WEST
Exterior Wall 175	0.000	0.00	0.055	94.35	0.055	94.35	FLOOR
Exterior Wall 168	0.000	0.00	0.055	153.25	0.055	153.25	FLOOR
Exterior Wall 176	0.000	0.00	0.055	75.67	0.055	75.67	FLOOR
IN Space: FLI Dietition's Office Exterior Wall 166	0.000	0.00	0.055	203.71	0.055	203.71	FLOOR
IN Space: FLI Supervisory Office Exterior Wall 177	0.000	0.00	0.055	164.66	0.055	164.66	FLOOR
in space: FL1 Locker Rooms Exterior Wall 163	0.000	0.00	0.055	1283.56	0.055	1283.56	FLOOR
in space: FL1 Exercise Room Exterior Wall 169	0.000	0.00	0.055	1981.56	0.055	1981.56	FLOOR
in space: FL1 Cafeteria Exterior Wall 178	0.000	0.00	0.055	74.24	0.055	74.24	FLOOR
in space: FL1 Toilet B Exterior Wall 179	0.000	0.00	0.055	168.42	0.055	168.42	FLOOR
in space: FL1 Pot Wash Exterior Wall 180	0.000	0.00	0.055	541.24	0.055	541.24	FLOOR
in space: FL1 Prep/Warming Exterior Wall 170	0.000	0.00	0.055	125.43	0.055	125.43	FLOOR
in space: FL1 Girls Exterior Wall 181	0.000	0.00	0.055	1182.98	0.055	1182.98	FLOOR
in space: FL1 Corridor Exterior Wall 171	0.000	0.00	0.055	64.16	0.055	64.16	FLOOR
in space: FL1 Students Exterior Wall 182	0.000	0.00	0.055	124.88	0.055	124.88	FLOOR
in space: FL1 Storage Exterior Wall 172	0.000	0.00	0.055	66.73	0.055	66.73	FLOOR
in space: FL1 Electrical Exterior Wall 183	0.000	0.00	0.055	78.62	0.055	78.62	FLOOR
in space: FL1 Receiving Exterior Wall 173	0.000	0.00	0.055	284.78	0.055	284.78	FLOOR
in space: FL1 Servery Exterior Wall 167	0.000	0.00	0.055	65.40	0.055	65.40	FLOOR
in space: FL1 Vestibule B Exterior Wall 174	0.000	0.00	0.055	145.02	0.055	145.02	FLOOR
in space: FL1 Refuse Recycling Exterior Wall 164	0.000	0.00	0.055	97.60	0.055	97.60	FLOOR
in space: FL1 Bike Storage Exterior Wall 165	0.000	0.00	0.055	118.39	0.055	118.39	FLOOR
in space: FL1 Vestibule A Exterior Wall 142	0.000	0.00	0.048	103.10	0.048	103.10	ROOF
in space: FL1 Stairs B FL5 Roof (G.NW3.E11)	0.000	0.00	0.048	349.14	0.048	349.14	ROOF
in space: FL5 Stairs B FL5 Roof (G.C4.E12)	0.000	0.00	0.048	119.15	0.048	119.15	ROOF
in space: FL5 Toilet A							

New York City Public School PS 33X Energy Model Report											
FL5 Roof (G.E14.E34)	0.000	0.00	0.048	1339.73	0.048	1339.73	ROOF				
In space: FL5 Boller Room FL5 Roof (G.C15.E35)	0.000	0.00	0.048	347.11	0.048	347.11	ROOF				
in space: FL5 Closets FL5 Roof (G.C5.E13)	0.000	0.00	0.048	79.60	0.048	79.60	ROOF				
in space: FL5 Toilet B											

DOE-2.2-48y 7/24/2018 17:06:37 BDL RUN 1

REPORT- LV-D Details of Exterior Surfaces WEATHER FILE- NEW YORK LAGUAR									
				001 06		(CONTIN	UED)		
in grade, EL5 Library	0.000	0.00	0.040	901.00	0.040	901.00	ROOF		
FL5 Roof $(G,C10,E24)$	0.000	0.00	0.048	107.72	0.048	107.72	ROOF		
in space: FL5 Toilet C		0.00	0.010	2071/2	0.010	20/1/2	1001		
FL5 Roof (G.C11.E25)	0.000	0.00	0.048	61.79	0.048	61.79	ROOF		
in space: FL5 Elec				0_000		•=•••			
R Roof (G.E1.E5)	0.000	0.00	0.048	403.05	0.048	403.05	ROOF		
in space: R Elevator Machine Room									
FL5 Roof (G.SSW1.E4)	0.000	0.00	0.048	774.99	0.048	774.99	ROOF		
in space: FL5 Classroom A									
R Roof (G.NW2.E7)	0.000	0.00	0.048	178.10	0.048	178.10	ROOF		
in space: R Elevators									
FL5 Roof (G.NW6.E15)	0.000	0.00	0.048	679.47	0.048	679.47	ROOF		
in space: FL5 Classroom C									
FL5 Roof (G.NE12.E28)	0.000	0.00	0.048	430.18	0.048	430.18	ROOF		
in space: FL5 Corridor									
R Roof (G.SSE3.E10)	0.000	0.00	0.048	65.54	0.048	65.54	ROOF		
in space: R Corridor									
Exterior Wall 141	0.000	0.00	0.048	298.98	0.048	298.98	ROOF		
in space: FL5 Corridor									
FL5 Roof (G.N2.E9)	0.000	0.00	0.048	949.20	0.048	949.20	ROOF		
in space: FL5 Classroom B									
FL5 Roof (G.SE13.E30)	0.000	0.00	0.048	1795.27	0.048	1795.27	ROOF		
in space: FL5 Classroom D									
R Roof (G.W4.E14)	0.000	0.00	0.048	298.70	0.048	298.70	ROOF		
in space: R Stairs A									
C Flr (B.NNE1.U1)	0.000	0.00	0.010	414.75	0.010	414.75	UNDERGRND		
in space: C Gas Meter Room									
C NW Wall (B.NNE1.U2)	0.000	0.00	0.058	142.20	0.058	142.20	UNDERGRND		
in space: C Gas Meter Room									
C NE Wall (B.NNE1.U3)	0.000	0.00	0.058	420.00	0.058	420.00	UNDERGRND		
in space: C Gas Meter Room									
C Flr (B.W2.U4)	0.000	0.00	0.010	281.18	0.010	281.18	UNDERGRND		
in space: C Mech Equipment Room									
C SW Wall (B.W2.U5)	0.000	0.00	0.058	104.40	0.058	104.40	UNDERGRND		
in space: C Mech Equipment Room									
C NW Wall (B.W2.U6)	0.000	0.00	0.058	127.80	0.058	127.80	UNDERGRND		
in space: C Mech Equipment Room									
C Flr (B.C3.U7)	0.000	0.00	0.010	130.72	0.010	130.72	UNDERGRND		
in space: C Stairs B									
C Flr (B.NW4.U8)	0.000	0.00	0.010	333.40	0.010	333.40	UNDERGRND		

in space: C Electrical Room

	<u>New York City Publ</u>	<u>1c Schoo</u>	<u>l PS 33X Energy</u>	<u>Model Rep</u>	oort		
C NW Wall (B.NW4.U9)	0.000	0.00	0.058	200.40	0.058	200.40	UNDERGRND
in space: C Electrical Room							
C Flr (B.NW5.U10)	0.000	0.00	0.010	336.67	0.010	336.67	UNDERGRND
in space: C Water Service/Sewa	age Ejector						
C NW Wall (B.NW5.U11)	0.000	0.00	0.058	238.80	0.058	238.80	UNDERGRND
in space: C Water Service/Sewa	age Ejector						
C Flr (B.C6.U12)	0.000	0.00	0.010	186.71	0.010	186.71	UNDERGRND
in space: C Elevators							
C Flr (B.W7.U13)	0.000	0.00	0.010	316.82	0.010	316.82	UNDERGRND
in space: C Stairs A	0.000			110 60		115 60	
C SW Wall (B.W7.014)	0.000	0.00	0.058	117.60	0.058	117.60	UNDERGRND
in space: C Stairs A	0.000	0 00	0.059	120.00	0 050	120 00	
in apage: C Stairs)	0.000	0.00	0.058	138.00	0.058	138.00	UNDERGRND
III space: C Statts A C Elr (B SW8 II16)	0 000	0 00	0 010	347 15	0 010	347 15	
in space. C Sprinkler Booster	Pump	0.00	0.010	547.15	0.010	517.15	UNDERGRID
C SE Wall (B.SW8.U17)	0.000	0.00	0.058	157.20	0.058	157.20	UNDERGRND
in space: C Sprinkler Booster	Pump						011221101112
PS 33X Jerome Ave 3				DOE-2.2-48	By 7/24/2018	17:06:37	BDL RUN 1
REPORT- LV-D Details of Exterior	r Surfaces				WEATHER FILE- N	NEW YORK LAC	JUARDI NY
						(CONTIN	JED)
	W I N D O W S	3	W A L L		-WALL+WIN	DOWS-	
SURFACE	U-VALUE	AREA	U-VALUE	AREA	U-VALUE	AREA	AZIMUTH
	(BTU/HR-SQFT-F)	(SQFT)	(BTU/HR-SQFT-F)	(SQFT) ((BTU/HR-SQFT-F)	(SQFT)	
C NW Wall (B.SW8.U18)	0.000	0.00	0.058	157 20	0 0 0 0		
				157.20	0.058	157.20	UNDERGRND
in space: C Sprinkler Booster	Pump			157.20	0.058	157.20	UNDERGRND
in space: C Sprinkler Booster C SW Wall (B.SW8.U19)	Pump 0.000	0.00	0.058	318.00	0.058	157.20 318.00	UNDERGRND UNDERGRND
<pre>in space: C Sprinkler Booster C SW Wall (B.SW8.U19) in space: C Sprinkler Booster C The (P GPD U20)</pre>	Pump 0.000 Pump	0.00	0.058	318.00	0.058	157.20 318.00	UNDERGRND
<pre>in space: C Sprinkler Booster C SW Wall (B.SW8.U19) in space: C Sprinkler Booster C Flr (B.SE9.U20) in space: C Corridor</pre>	Pump 0.000 Pump 0.000	0.00	0.058	318.00 758.28	0.058	157.20 318.00 758.28	UNDERGRND UNDERGRND UNDERGRND
<pre>in space: C Sprinkler Booster C SW Wall (B.SW8.U19) in space: C Sprinkler Booster C Flr (B.SE9.U20) in space: C Corridor C NE Wall (B SE9 U21)</pre>	Pump 0.000 Pump 0.000	0.00	0.058	318.00 758.28	0.058	157.20 318.00 758.28	UNDERGRND UNDERGRND UNDERGRND
<pre>in space: C Sprinkler Booster C SW Wall (B.SW8.U19) in space: C Sprinkler Booster C Flr (B.SE9.U20) in space: C Corridor C NE Wall (B.SE9.U21) in space: C Corridor</pre>	Pump 0.000 Pump 0.000 0.000	0.00 0.00 0.00	0.058 0.010 0.058	318.00 758.28 120.00	0.058 0.010 0.058	157.20 318.00 758.28 120.00	UNDERGRND UNDERGRND UNDERGRND UNDERGRND
<pre>in space: C Sprinkler Booster C SW Wall (B.SW8.U19) in space: C Sprinkler Booster C Flr (B.SE9.U20) in space: C Corridor C NE Wall (B.SE9.U21) in space: C Corridor C SE Wall (B.SE9.U22)</pre>	Pump 0.000 Pump 0.000 0.000	0.00 0.00 0.00	0.058 0.010 0.058 0.058	318.00 758.28 120.00 847.20	0.058 0.010 0.058 0.058	157.20 318.00 758.28 120.00 847.20	UNDERGRND UNDERGRND UNDERGRND UNDERGRND
<pre>in space: C Sprinkler Booster C SW Wall (B.SW8.U19) in space: C Sprinkler Booster C Flr (B.SE9.U20) in space: C Corridor C NE Wall (B.SE9.U21) in space: C Corridor C SE Wall (B.SE9.U22) in space: C Corridor</pre>	Pump 0.000 Pump 0.000 0.000 0.000	0.00 0.00 0.00 0.00	0.058 0.010 0.058 0.058	318.00 758.28 120.00 847.20	0.058 0.010 0.058 0.058	157.20 318.00 758.28 120.00 847.20	UNDERGRND UNDERGRND UNDERGRND UNDERGRND UNDERGRND
<pre>in space: C Sprinkler Booster C SW Wall (B.SW8.U19) in space: C Sprinkler Booster C Flr (B.SE9.U20) in space: C Corridor C NE Wall (B.SE9.U21) in space: C Corridor C SE Wall (B.SE9.U22) in space: C Corridor</pre>	Pump 0.000 Pump 0.000 0.000 0.000	0.00 0.00 0.00 0.00	0.058 0.010 0.058 0.058	318.00 758.28 120.00 847.20	0.058 0.010 0.058 0.058	157.20 318.00 758.28 120.00 847.20	UNDERGRND UNDERGRND UNDERGRND UNDERGRND UNDERGRND
<pre>in space: C Sprinkler Booster C SW Wall (B.SW8.U19) in space: C Sprinkler Booster C Flr (B.SE9.U20) in space: C Corridor C NE Wall (B.SE9.U21) in space: C Corridor C SE Wall (B.SE9.U22) in space: C Corridor</pre>	Pump 0.000 Pump 0.000 0.000 0.000	0.00 0.00 0.00	0.058 0.010 0.058 0.058	318.00 758.28 120.00 847.20	0.058 0.010 0.058 0.058	157.20 318.00 758.28 120.00 847.20	UNDERGRND UNDERGRND UNDERGRND UNDERGRND UNDERGRND
<pre>in space: C Sprinkler Booster C SW Wall (B.SW8.U19) in space: C Sprinkler Booster C Flr (B.SE9.U20) in space: C Corridor C NE Wall (B.SE9.U21) in space: C Corridor C SE Wall (B.SE9.U22) in space: C Corridor</pre>	Pump 0.000 Pump 0.000 0.000 0.000	0.00 0.00 0.00	0.058 0.010 0.058 0.058	318.00 758.28 120.00 847.20	0.058 0.010 0.058 0.058	157.20 318.00 758.28 120.00 847.20	UNDERGRND UNDERGRND UNDERGRND UNDERGRND UNDERGRND

REPORT-	LV-D Details	of Exterior	Surfaces			1	WEATHER	FILE-	NEW YO	RK LAGUARDI	NY
									(C	ONIINOED)	
		AVERAGE		AVERAGE	AVERAGE U-VALUE	WINDOW		VAT.T.		WTNDOW+WA	т.т.
	t	-VALUE/WINDO BTU/HR-SQFT	วพร เ -F) (1	J-VALUE/WALLS BTU/HR-SQFT-F)	WALLS+WINDOWS (BTU/HR-SQFT-F)	AREA (SQFT)	2	AREA (SQFT)		AREA (SQFT)	

NORTH-EAST	0.551	0.064	0.082	225.00	6113.15	6338.15
SOUTH-EAST	0.551	0.064	0.226	2959.50	5947.05	8906.55
SOUTH	0.000	0.064	0.064	0.00	448.14	448.14
SOUTH-WEST	0.551	0.064	0.121	682.50	5207.59	5890.09
NORTH-WEST	0.551	0.064	0.197	2420.00	6481.35	8901.35
FLOOR	0.000	0.055	0.055	0.00	7094.64	7094.64
ROOF	0.000	0.048	0.048	0.00	9281.85	9281.85
ALL WALLS	0.551	0.064	0.165	6287.00	24197.28	30484.29
WALLS+ROOFS	0.551	0.060	0.138	6287.00	33479.14	39766.14
UNDERGRND	0.000	0.034	0.034	0.00	6194.48	6194.48
BUILDING	0.551	0.056	0.114	6287.00	46768.24	53055.24

PS 33X Jerome Ave 3

DOE-2.2-48y 7/24/2018 17:06:37 BDL RUN 1

REPORT- LV-H Details of Windows WEATHER FILE- NEW YORK LAGUARDI NY

NUMBER OF WINDOWS 123

(Note: u-values include outside air film)

					LOCATION OF	7 ORIGIN				
		GLASS	GLASS	GLASS	IN	SURFACE	FRAME	CURB	FRAME	CURB
WINDOW		AREA	HEIGHT	WIDTH	COOF	RDINATES	AR	EA	U-VA	LUE
NAME	MULTIPLIER	(SQFT)	(FT)	(FT)	X (FT)	Y (FT)	(SQF	т)	(BTU/HR-	SQFT-F)
Window 1	1.0	90.00	7.50	12.00	2.50	2.50	0.00	0.00	0.384	0.000
Window 2	1.0	90.00	7.50	12.00	17.30	2.50	0.00	0.00	0.384	0.000
Window 121	1.0	45.00	7.50	6.00	1.00	2.50	0.00	0.00	0.384	0.000
Window 5	1.0	30.00	7.50	4.00	11.00	2.50	0.00	0.00	0.384	0.000
Window 3	1.0	60.00	7.50	8.00	0.00	2.50	0.00	0.00	0.384	0.000
Window 7	1.0	50.00	8.00	6.25	0.00	0.00	0.00	0.00	0.384	0.000
Window 75	1.0	90.00	7.50	12.00	2.50	2.50	0.00	0.00	0.384	0.000
Window 77	1.0	52.50	7.50	7.00	3.75	2.50	0.00	0.00	0.384	0.000
Window 78	1.0	52.50	7.50	7.00	17.75	2.50	0.00	0.00	0.384	0.000
Window 79	1.0	52.50	7.50	7.00	32.75	2.50	0.00	0.00	0.384	0.000
Window 80	1.0	52.50	7.50	7.00	46.75	2.50	0.00	0.00	0.384	0.000
Window 81	1.0	67.50	7.50	9.00	58.75	2.50	0.00	0.00	0.384	0.000
Window 76	1.0	52.50	7.50	7.00	1.00	2.50	0.00	0.00	0.384	0.000

	New York Ci	ty Public S	chool]	PS 33X	Energy Mo	del Repo	rt			
Window 82	1 0	21 00	7 00	3 00	14 00	0 00	0 00	0 00	0 384	0 000
Window 126	1.0	21.00	7 00	3.00	1 00	0.00	0.00	0.00	0.384	0.000
Window 90	1.0	90.00	7 50	12 00	2 00	2 50	0.00	0.00	0.384	0.000
Window 91	1.0	90.00	7 50	12.00	17 00	2.50	0.00	0.00	0.384	0.000
Window 131	1.0	90.00	7 50	12.00	2 75	2.50	0.00	0.00	0.384	0.000
Window 132	1.0	90.00	7.50	12.00	16 75	2.50	0.00	0.00	0.304	0.000
Window 132	1.0	30.00	7.50	1 00	2 50	2.50	0.00	0.00	0.384	0.000
Window 94	1.0	90.00	7.50	12 00	2.50	2.50	0.00	0.00	0.384	0.000
Window 85	1.0	90.00	7.50	12.00	17 75	2.50	0.00	0.00	0.384	0.000
Window 85	1.0	30.00	7.50	1 00	2 50	2.50	0.00	0.00	0.384	0.000
Window 9	1.0	60.00	7 50	8 00	10 50	2.50	0.00	0.00	0.384	0.000
Window 10	1.0	60.00	7.50	8 00	21 25	2.50	0.00	0.00	0.304	0.000
Window 10	1.0	18 00	2 00	6.00	21.35	10 00	0.00	0.00	0.384	0.000
Window 11	1.0	27 50	7 50	5.00	2 55	2 50	0.00	0.00	0.384	0.000
Window 12	1.0	52 50	7.50	7 00	2.55	2.50	0.00	0.00	0.384	0.000
Window 13	1.0	90.00	7 50	12 00	11 00	2.50	0.00	0.00	0.384	0.000
Window 51	1.0	18 00	3 00	6 00	3 00	2.50	0.00	0.00	0.384	0.000
Window 51	1.0	18 00	3.00	6.00	3.00	10.00	0.00	0.00	0.304	0.000
Window 14	1.0	10.00	7 50	8.00	3.00	2 50	0.00	0.00	0.384	0.000
Window 15	1.0	60.00	7.50	8.00	12 50	2.50	0.00	0.00	0.384	0.000
Window 15	1.0	30.00	7.50	4 00	24 50	2.50	0.00	0.00	0.384	0.000
Window 62	1.0	60.00	7 50	8 00	24.50	2.50	0.00	0.00	0.384	0.000
Window 66	1.0	30.00	7 50	4 00	30.00	2.50	0.00	0.00	0.384	0.000
Window 122	1.0	45 00	7 50	5.00	1 00	2.50	0.00	0.00	0.384	0.000
Window 70	1.0	30.00	7 50	4 00	2 00	2.50	0.00	0.00	0.384	0.000
Window 127	1.0	90.00	7 50	12 00	2.00	2.50	0.00	0.00	0.384	0.000
Window 128	1.0	90.00	7 50	12.00	16 75	2.50	0.00	0.00	0.384	0.000
Window 98	1 0	90.00	7 50	12.00	2 00	2.50	0.00	0.00	0.384	0 000
Window 99	1 0	90.00	7 50	12.00	17 00	2.50	0.00	0.00	0.384	0 000
Window 94	1 0	90.00	7 50	12.00	2 75	2.50	0.00	0.00	0.384	0.000
Window 95	1.0	90.00	7 50	12.00	16 75	2.50	0.00	0.00	0.384	0.000
Window 73	1.0	30.00	7 50	4 00	2 50	2.50	0.00	0.00	0.384	0.000
Window 92	1.0	90.00	7 50	12 00	3 75	2.50	0.00	0.00	0.384	0.000
Window 93	1 0	90.00	7 50	12.00	17 75	2.50	0.00	0.00	0 384	0.000
Window 17	1.0	60.00	7.50	8.00	2.50	2.50	0.00	0.00	0.384	0.000
Window 18	1.0	60.00	7 50	8 00	14 50	2.50	0.00	0.00	0 384	0.000
MILITON TO	1.0	00.00	1.50	0.00	14.50	2.50	0.00	0.00	0.304	0.000

DOE-2.2-48y 7/24/2018 17:06:37 BDL RUN 1

REPORT- LV-H Details of Windows

WEATHER FILE- NEW YORK LAGUARDI NY ------ (CONTINUED)------

(Note: u-values include outside air film)

	LOCATION OF ORIGIN											
		GLASS	GLASS	GLASS	IN	SURFACE	FRAME	CURB	FRAME	CURB		
WINDOW		AREA	HEIGHT	WIDTH	COOF	RDINATES	AR	EA	U-VA	LUE		
NAME	MULTIPLIER	(SQFT)	(FT)	(FT)	X (FT)	Y (FT)	(SQF	т)	(BTU/HR-	SQFT-F)		
Window 19	1.0	30.00	7.50	4.00	24.50	2.50	0.00	0.00	0.384	0.000		
Window 45	1.0	18.00	3.00	6.00	3.00	10.00	0.00	0.00	0.384	0.000		
Window 49	1.0	18.00	3.00	6.00	3.00	0.00	0.00	0.00	0.384	0.000		
Window 27	1.0	30.00	7.50	4.00	2.50	2.50	0.00	0.00	0.384	0.000		

	<u>New York Ci</u>	ty Public S	School]	PS 33X	Energy Mo	del Repo	ort			
Window 28	1.0	30.00	7.50	4.00	10.50	2.50	0.00	0.00	0.384	0.000
Window 52	1.0	18.00	3.00	6.00	3.00	0.00	0.00	0.00	0.384	0.000
Window 57	1.0	18.00	3.00	6.00	3.00	10.00	0.00	0.00	0.384	0.000
Window 29	1.0	60.00	7.50	8.00	0.00	2.50	0.00	0.00	0.384	0.000
Window 30	1.0	30.00	7.50	4.00	12.50	2.50	0.00	0.00	0.384	0.000
Window 31	1.0	60.00	7.50	8.00	20.50	2.50	0.00	0.00	0.384	0.000
Window 61	1.0	30.00	7.50	4.00	0.00	2.50	0.00	0.00	0.384	0.000
Window 65	1.0	30.00	7.50	4.00	30.00	2.50	0.00	0.00	0.384	0.000
Window 123	1.0	45.00	7.50	6.00	1.00	2.50	0.00	0.00	0.384	0.000
Window 69	1.0	30.00	7.50	4.00	2.00	2.50	0.00	0.00	0.384	0.000
Window 26	1.0	90.00	7.50	12.00	2.50	2.50	0.00	0.00	0.384	0.000
Window 129	1.0	90.00	7.50	12.00	2.75	2.50	0.00	0.00	0.384	0.000
Window 130	1.0	90.00	7.50	12.00	16.75	2.50	0.00	0.00	0.384	0.000
Window 109	1.0	60.00	7.50	8.00	2.00	2.50	0.00	0.00	0.384	0.000
Window 110	1.0	60.00	7.50	8.00	14.00	2.50	0.00	0.00	0.384	0.000
Window 103	1.0	30.00	7.50	4.00	0.00	2.50	0.00	0.00	0.384	0.000
Window 104	1.0	60.00	7.50	8.00	6.00	2.50	0.00	0.00	0.384	0.000
Window 105	1.0	60.00	7.50	8.00	19.00	2.50	0.00	0.00	0.384	0.000
Window 135	1.0	60.00	7.50	8.00	30.00	2.50	0.00	0.00	0.384	0.000
Window 72	1.0	30.00	7.50	4.00	2.50	2.50	0.00	0.00	0.384	0.000
Window 100	1.0	60.00	7.50	8.00	3.80	2.50	0.00	0.00	0.384	0.000
Window 101	1.0	60.00	7.50	8.00	13.80	2.50	0.00	0.00	0.384	0.000
Window 102	1.0	30.00	7.50	4.00	26.30	2.50	0.00	0.00	0.384	0.000
Window 20	1.0	60.00	7.50	8.00	2.50	2.50	0.00	0.00	0.384	0.000
Window 21	1.0	60.00	7.50	8.00	14.50	2.50	0.00	0.00	0.384	0.000
Window 22	1.0	30.00	7.50	4.00	24.50	2.50	0.00	0.00	0.384	0.000
Window 46	1.0	18.00	3.00	6.00	3.00	10.00	0.00	0.00	0.384	0.000
Window 50	1.0	18.00	3.00	6.00	3.00	0.00	0.00	0.00	0.384	0.000
Window 38	1.0	30.00	7.50	4.00	2.50	2.50	0.00	0.00	0.384	0.000
Window 39	1.0	30.00	7.50	4.00	10.50	2.50	0.00	0.00	0.384	0.000
Window 40	1.0	30.00	7.50	4.00	18.50	2.50	0.00	0.00	0.384	0.000
Window 41	1.0	30.00	7.50	4.00	26.50	2.50	0.00	0.00	0.384	0.000
Window 53	1.0	18.00	3.00	6.00	3.00	0.00	0.00	0.00	0.384	0.000
Window 56	1.0	18.00	3.00	6.00	3.00	10.00	0.00	0.00	0.384	0.000
Window 32	1.0	30.00	7.50	4.00	0.00	2.50	0.00	0.00	0.384	0.000
Window 33	1.0	60.00	7.50	8.00	8.50	2.50	0.00	0.00	0.384	0.000
Window 34	1.0	60.00	7.50	8.00	20.50	2.50	0.00	0.00	0.384	0.000
Window 60	1.0	30.00	7.50	4.00	0.00	2.50	0.00	0.00	0.384	0.000
Window 64	1.0	30.00	7.50	4.00	30.00	2.50	0.00	0.00	0.384	0.000
Window 124	1.0	45.00	7.50	6.00	1.00	2.50	0.00	0.00	0.384	0.000
Window 68	1.0	30.00	7.50	4.00	2.00	2.50	0.00	0.00	0.384	0.000
Window 133	1.0	60.00	7.50	8.00	1.00	2.50	0.00	0.00	0.384	0.000
Window 134	1.0	60.00	7.50	8.00	11.00	2.50	0.00	0.00	0.384	0.000
Window 71	1.0	30.00	7.50	4.00	2.50	2.50	0.00	0.00	0.384	0.000
Window 111	1.0	60.00	7.50	8.00	3.80	2.50	0.00	0.00	0.384	0.000
Window 112	1.0	60.00	7.50	8.00	13.80	2.50	0.00	0.00	0.384	0.000
Window 23	1.0	30.00	7.50	4.00	2.50	2.50	0.00	0.00	0.384	0.000
Window 24	1.0	60.00	7.50	8.00	10.50	2.50	0.00	0.00	0.384	0.000

DOE-2.2-48y 7/24/2018 17:06:37 BDL RUN 1

WEATHER FILE- NEW YORK LAGUARDI NY

(Note: u-values include outside air film)

					LOCATION OF	ORIGIN				
		GLASS	GLASS	GLASS	IN S	SURFACE	FRAME	CURB	FRAME	CURB
WINDOW		AREA	HEIGHT	WIDTH	COORI	DINATES	AI	REA	U-VA	LUE
NAME	MULTIPLIER	(SQFT)	(FT)	(FT)	X (FT)	Y (FT)	(SQI	T)	(BTU/HR-	SQFT-F)
Window 25	1.0	60.00	7.50	8.00	21.35	2.50	0.00	0.00	0.384	0.000
Window 47	1.0	18.00	3.00	6.00	3.00	10.00	0.00	0.00	0.384	0.000
Window 48	1.0	18.00	3.00	6.00	3.00	0.00	0.00	0.00	0.384	0.000
Window 42	1.0	90.00	7.50	12.00	2.50	2.50	0.00	0.00	0.384	0.000
Window 43	1.0	90.00	7.50	12.00	18.50	2.50	0.00	0.00	0.384	0.000
Window 54	1.0	18.00	3.00	6.00	3.00	0.00	0.00	0.00	0.384	0.000
Window 55	1.0	18.00	3.00	6.00	3.00	10.00	0.00	0.00	0.384	0.000
Window 35	1.0	60.00	7.50	8.00	0.00	2.50	0.00	0.00	0.384	0.000
Window 36	1.0	60.00	7.50	8.00	12.50	2.50	0.00	0.00	0.384	0.000
Window 37	1.0	30.00	7.50	4.00	24.50	2.50	0.00	0.00	0.384	0.000
Window 59	1.0	60.00	7.50	8.00	0.00	2.50	0.00	0.00	0.384	0.000
Window 63	1.0	30.00	7.50	4.00	30.00	2.50	0.00	0.00	0.384	0.000
Window 125	1.0	45.00	7.50	6.00	1.00	2.50	0.00	0.00	0.384	0.000
Window 67	1.0	30.00	7.50	4.00	2.00	2.50	0.00	0.00	0.384	0.000
Window 113	1.0	60.00	7.50	8.00	4.50	2.50	0.00	0.00	0.384	0.000
Window 114	1.0	60.00	7.50	8.00	14.50	2.50	0.00	0.00	0.384	0.000
Window 115	1.0	60.00	7.50	8.00	26.50	2.50	0.00	0.00	0.384	0.000
Window 116	1.0	60.00	7.50	8.00	36.50	2.50	0.00	0.00	0.384	0.000
Window 117	1.0	60.00	7.50	8.00	0.00	2.50	0.00	0.00	0.384	0.000
Window 118	1.0	60.00	7.50	8.00	10.00	2.50	0.00	0.00	0.384	0.000
Window 119	1.0	60.00	7.50	8.00	24.00	2.50	0.00	0.00	0.384	0.000
Window 120	1.0	60.00	7.50	8.00	36.00	2.50	0.00	0.00	0.384	0.000
		GLASS	NUMBE	R	CENTER-OF	7-	GLASS	GLASS	SURFAC	E TO
WINDOW	SETBACK	SHADING	C)F	GLASS U-VALU	JE V	ISIBLE	SOLAR	ROUGH	OPEN
NAME	(FT)	COEFF	PANE	IS (BTU/HR-SQFT-I	?)	TRANS	TRANS	AREA R	ATIO
Window 1	0.00	0.46		1	0.55	51	0.440	0.878	1.00	0
Window 2	0.00	0.46		1	0.55	51	0.440	0.878	1.00	0
Window 121	0.00	0.46		1	0.55	51	0.440	0.878	1.00	0
Window 5	0.00	0.46		1	0.55	51	0.440	0.878	1.00	0
Window 3	0.00	0.46		1	0.55	51	0.440	0.878	1.00	0
Window 7	0.00	0.46		1	0.55	51	0.440	0.878	1.00	0
Window 75	0.00	0.46		1	0.55	51	0.440	0.878	1.00	0
Window 77	0.00	0.46		1	0.55	51	0.440	0.878	1.00	0
Window 78	0.00	0.46		1	0.55	51	0.440	0.878	1.00	0
Window 79	0.00	0.46		1	0.55	51	0.440	0.878	1.00	0
Window 80	0.00	0.46		1	0.55	51	0.440	0.878	1.00	0
Window 81	0.00	0.46		1	0.55	51	0.440	0.878	1.00	0
Window 76	0.00	0.46		1	0.55	51	0.440	0.878	1.00	0
Window 82	0.00	0.46		1	0.5	51	0.440	0.878	1.00	0
Window 126	0.00	0.46		1	0.5	51	0.440	0.878	1.00	0
Window 90	0.00	0.46		-	0.5	51	0.440	0.878	1.00	0
Window 91	0.00	0.46		1	0.5	51	0.440	0.878	1.00	0
Window 131	0.00	0.46		1	0.5	51	0.440	0.878	1.00	0
Window 132	0.00	0.46		1	0.55	51	0.440	0.878	1.00	0
··	3.00			_						-

	New York C	New York City Public School PS 33X Energy Model Report										
Window 74	0.00	0.46	1	0.551	0.440	0.878	1.000					
Window 84	0.00	0.46	1	0.551	0.440	0.878	1.000					
Window 85	0.00	0.46	1	0.551	0.440	0.878	1.000					
Window 8	0.00	0.46	1	0.551	0.440	0.878	1.000					
Window 9	0.00	0.46	1	0.551	0.440	0.878	1.000					

DOE-2.2-48y 7/24/2018 17:06:37 BDL RUN 1

REPORT- LV-H Details of Windows

WEATHER FILE- NEW YORK LAGUARDI NY ------(CONTINUED)------

WINDOW NAME	SETBACK (FT)	GLASS SHADING COEFF	NUMBER OF PANES	CENTER-OF- GLASS U-VALUE (BTU/HR-SQFT-F)	GLASS VISIBLE TRANS	GLASS SOLAR TRANS	SURFACE TO ROUGH OPEN AREA RATIO
Window 10	0.00	0.46	1	0.551	0.440	0.878	1.000
Window 44	0.00	0.46	1	0.551	0.440	0.878	1.000
Window 11	0.00	0.46	1	0.551	0.440	0.878	1.000
Window 12	0.00	0.46	1	0.551	0.440	0.878	1.000
Window 13	0.00	0.46	1	0.551	0.440	0.878	1.000
Window 51	0.00	0.46	1	0.551	0.440	0.878	1.000
Window 58	0.00	0.46	1	0.551	0.440	0.878	1.000
Window 14	0.00	0.46	1	0.551	0.440	0.878	1.000
Window 15	0.00	0.46	1	0.551	0.440	0.878	1.000
Window 16	0.00	0.46	1	0.551	0.440	0.878	1.000
Window 62	0.00	0.46	1	0.551	0.440	0.878	1.000
Window 66	0.00	0.46	1	0.551	0.440	0.878	1.000
Window 122	0.00	0.46	1	0.551	0.440	0.878	1.000
Window 70	0.00	0.46	1	0.551	0.440	0.878	1.000
Window 127	0.00	0.46	1	0.551	0.440	0.878	1.000
Window 128	0.00	0.46	1	0.551	0.440	0.878	1.000
Window 98	0.00	0.46	1	0.551	0.440	0.878	1.000
Window 99	0.00	0.46	1	0.551	0.440	0.878	1.000
Window 94	0.00	0.46	1	0.551	0.440	0.878	1.000
Window 95	0.00	0.46	1	0.551	0.440	0.878	1.000
Window 73	0.00	0.46	1	0.551	0.440	0.878	1.000
Window 92	0.00	0.46	1	0.551	0.440	0.878	1.000
Window 93	0.00	0.46	1	0.551	0.440	0.878	1.000
Window 17	0.00	0.46	1	0.551	0.440	0.878	1.000
Window 18	0.00	0.46	1	0.551	0.440	0.878	1.000
Window 19	0.00	0.46	1	0.551	0.440	0.878	1.000
Window 45	0.00	0.46	1	0.551	0.440	0.878	1.000
Window 49	0.00	0.46	1	0.551	0.440	0.878	1.000
Window 27	0.00	0.46	1	0.551	0.440	0.878	1.000
Window 28	0.00	0.46	1	0.551	0.440	0.878	1.000
Window 52	0.00	0.46	1	0.551	0.440	0.878	1.000
Window 57	0.00	0.46	1	0.551	0.440	0.878	1.000
Window 29	0.00	0.46	1	0.551	0.440	0.878	1.000
Window 30	0.00	0.46	1	0.551	0.440	0.878	1.000
Window 31	0.00	0.46	1	0.551	0.440	0.878	1.000
Window 61	0.00	0.46	1	0.551	0.440	0.878	1.000
Window 65	0.00	0.46	1	0.551	0.440	0.878	1.000

Page 174 of 310

	New York C	ity Public Sc	hool PS 33X	Energy Model R	<u>leport</u>					
Window 123	0.00	0.46	1	0.551	0.440	0.878	1.000			
Window 69	0.00	0.46	1	0.551	0.440	0.878	1.000			
Window 26	0.00	0.46	1	0.551	0.440	0.878	1.000			
Window 129	0.00	0.46	1	0.551	0.440	0.878	1.000			
Window 130	0.00	0.46	1	0.551	0.440	0.878	1.000			
Window 109	0.00	0.46	1	0.551	0.440	0.878	1.000			
Window 110	0.00	0.46	1	0.551	0.440	0.878	1.000			
Window 103	0.00	0.46	1	0.551	0.440	0.878	1.000			
Window 104	0.00	0.46	1	0.551	0.440	0.878	1.000			
Window 105	0.00	0.46	1	0.551	0.440	0.878	1.000			
Window 135	0.00	0.46	1	0.551	0.440	0.878	1.000			
Window 72	0.00	0.46	1	0.551	0.440	0.878	1.000			
Window 100	0.00	0.46	1	0.551	0.440	0.878	1.000			
Window 101	0.00	0.46	1	0.551	0.440	0.878	1.000			
Window 102	0.00	0.46	1	0.551	0.440	0.878	1.000			
Window 20	0.00	0.46	1	0.551	0.440	0.878	1.000			
Window 21	0.00	0.46	1	0.551	0.440	0.878	1.000			

DOE-2.2-48y 7/24/2018 17:06:37 BDL RUN 1

REPORT- LV-H Details of Windows

WEATHER FILE- NEW YORK LAGUARDI NY

------(CONTINUED)------

			GLASS	NUMBER	CENTER-OF-	GLASS	GLASS	SURFACE TO
WINDOW	7	SETBACK	SHADING	OF	GLASS U-VALUE	VISIBLE	SOLAR	ROUGH OPEN
NAME		(FT)	COEFF	PANES	(BTU/HR-SQFT-F)	TRANS	TRANS	AREA RATIO
Window	7 22	0.00	0.46	1	0.551	0.440	0.878	1.000
Window	7 46	0.00	0.46	1	0.551	0.440	0.878	1.000
Window	7 50	0.00	0.46	1	0.551	0.440	0.878	1.000
Window	7 38	0.00	0.46	1	0.551	0.440	0.878	1.000
Window	7 39	0.00	0.46	1	0.551	0.440	0.878	1.000
Window	v 40	0.00	0.46	1	0.551	0.440	0.878	1.000
Window	7 41	0.00	0.46	1	0.551	0.440	0.878	1.000
Window	7 53	0.00	0.46	1	0.551	0.440	0.878	1.000
Window	756	0.00	0.46	1	0.551	0.440	0.878	1.000
Window	7 32	0.00	0.46	1	0.551	0.440	0.878	1.000
Window	7 33	0.00	0.46	1	0.551	0.440	0.878	1.000
Window	7 34	0.00	0.46	1	0.551	0.440	0.878	1.000
Window	7 60	0.00	0.46	1	0.551	0.440	0.878	1.000
Window	764	0.00	0.46	1	0.551	0.440	0.878	1.000
Window	124	0.00	0.46	1	0.551	0.440	0.878	1.000
Window	7 68	0.00	0.46	1	0.551	0.440	0.878	1.000
Window	/ 133	0.00	0.46	1	0.551	0.440	0.878	1.000
Window	134	0.00	0.46	1	0.551	0.440	0.878	1.000
Window	71	0.00	0.46	1	0.551	0.440	0.878	1.000
Window	7 111	0.00	0.46	1	0.551	0.440	0.878	1.000
Window	/ 112	0.00	0.46	1	0.551	0.440	0.878	1.000
Window	7 23	0.00	0.46	1	0.551	0.440	0.878	1.000
Window	7 24	0.00	0.46	1	0.551	0.440	0.878	1.000
Window	7 25	0.00	0.46	1	0.551	0.440	0.878	1.000
Window	7 47	0.00	0.46	1	0.551	0.440	0.878	1.000

	<u>New York Ci</u>	<u>c City Public School PS 33X Energy Model Report</u>							
Window 48	0.00	0.46	1	0.551	0.440	0.878	1.000		
Window 42	0.00	0.46	1	0.551	0.440	0.878	1.000		
Window 43	0.00	0.46	1	0.551	0.440	0.878	1.000		
Window 54	0.00	0.46	1	0.551	0.440	0.878	1.000		
Window 55	0.00	0.46	1	0.551	0.440	0.878	1.000		
Window 35	0.00	0.46	1	0.551	0.440	0.878	1.000		
Window 36	0.00	0.46	1	0.551	0.440	0.878	1.000		
Window 37	0.00	0.46	1	0.551	0.440	0.878	1.000		
Window 59	0.00	0.46	1	0.551	0.440	0.878	1.000		
Window 63	0.00	0.46	1	0.551	0.440	0.878	1.000		
Window 125	0.00	0.46	1	0.551	0.440	0.878	1.000		
Window 67	0.00	0.46	1	0.551	0.440	0.878	1.000		
Window 113	0.00	0.46	1	0.551	0.440	0.878	1.000		
Window 114	0.00	0.46	1	0.551	0.440	0.878	1.000		
Window 115	0.00	0.46	1	0.551	0.440	0.878	1.000		
Window 116	0.00	0.46	1	0.551	0.440	0.878	1.000		
Window 117	0.00	0.46	1	0.551	0.440	0.878	1.000		
Window 118	0.00	0.46	1	0.551	0.440	0.878	1.000		
Window 119	0.00	0.46	1	0.551	0.440	0.878	1.000		
Window 120	0.00	0.46	1	0.551	0.440	0.878	1.000		

DOE-2.2-48y 7/24/2018 17:06:37 BDL RUN 1

REPORT- LV-I Details of Constructions _____

NUMBER OF CONSTRUCTIONS 10 DELAYED 8 QUICK 2

CONSTRUCTION	U-VALUE	SURFACE	SURFACE ROUGHNESS	SURFACE	NUMBER OF RESPONSE
NAME	(BTU/HR-SQFT-F)	ABSORPTANCE	INDEX	TYPE	FACTORS
C EWall Construction	0.066	0.70	3	QUICK	0
C Ceilg Construction	0.141	0.70	3	DELAYED	4
C IWall Construction	0.141	0.70	3	DELAYED	4
C IFlr Construction	0.813	0.70	3	DELAYED	5
C IF1SP Construction	0.813	0.70	3	DELAYED	5
FL1 GFlr Construction	0.056	0.70	3	DELAYED	23
FL1 GFISP Construction	0.056	0.70	3	DELAYED	23
FL5 Roof Construction	0.049	0.60	1	QUICK	0
C UFCons (B.NNE1.U2)	0.010	0.70	3	DELAYED	52
C UWCons (B.NNE1.U2)	0.058	0.70	3	DELAYED	40

Page 176 of 310

WEATHER FILE- NEW YORK LAGUARDI NY

ASHRAE 90.1 SECTION 11 ENERGY MODEL FOR LL86 COMPLIANCE (BASELINE):

PS 3	33X Jerome	e Ave 3							DOE-	2.2-48y	7/24/20	18 17:	17:21 BD	LRUN 1
REPO	EPORT- BEPS Building Energy Performance WEATHER FILE- NEW YORK LAGUARDI NY											DI NY		
		LIGHTS	TASK LIGHTS	MISC EQUIP	SPACE HEATING	SPACE COOLING	HEAT REJECT	PUMPS & AUX	VENT FANS	REFRIG DISPLAY	HT PUMP SUPPLEM	DOMEST HOT WTR	EXT USAGE	TOTAL
EM1	ELECTRIC MBTU	21TY 318.1	0.0	264.2	2.1	257.2	0.0	27.6	241.4	0.0	0.0	0.0	36.3	1147.0
FM1	NATURAL- MBTU	-GAS 0.0	0.0	44.9	646.7	0.0	0.0	0.0	0.0	0.0	0.0	53.0	0.0	744.6
												======		
	MBTU	318.1	0.0	309.1	648.8	257.2	0.0	27.6	241.4	0.0	0.0	53.0	36.3	1891.6
TOTAL SITE ENERGY1891.57 METU38.7 KBTU/SQFT-YR GROSS-AREA38.7 KBTU/SQFT-YR NET-AREATOTAL SOURCE ENERGY4185.50 MBTU85.6 KBTU/SQFT-YR GROSS-AREA85.6 KBTU/SQFT-YR NET-AREAPERCENT OF HOURS ANY SYSTEM ZONE OUTSIDE OF THROTTLING RANGE =3.76PERCENT OF HOURS ANY PLANT LOAD NOT SATISFIED=0.00HOURS ANY ZONE ABOVE COOLING THROTTLING RANGE=0HOURS ANY ZONE BELOW HEATING THROTTLING RANGE=234														

NOTE: ENERGY IS APPORTIONED HOURLY TO ALL END-USE CATEGORIES.

	New York City	Public School	PS 33X Ene	rgy Mode	el Report				
PS 33X Jerome Ave 3				DOE-	2.2-48y	7/24/20)18 17:	17:21 BD	L RUN 1
REPORT- BEPU Building Utility Pe	rformance				WE	ATHER FII	LE- NEW YO	RK LAGUAR	DI NY
TASK LIGHTS LIGHTS	MISC SPACE EQUIP HEATING	SPACE HE COOLING REJI	AT PUMPS SCT & AUX	VENT FANS	REFRIG DISPLAY	HT PUMP SUPPLEM	DOMEST HOT WTR	EXT USAGE	TOTAL
EM1 ELECTRICITY KWH 93216. 0.	77411. 623.	75346.	0. 8081.	70739.	0.	0.	0.	10644.	336059.
FM1 NATURAL-GAS THERM 0. 0.	449. 6467.	0.	0. 0.	0.	0.	0.	530.	0.	7446.
TOTAL ELECTRICITY TOTAL NATURAL-GAS	336059. KWH 7446. THERM	6.873 KWH 0.152 THERM	/SQFT-YR (/SQFT-YR (FROSS-AREA FROSS-AREA	6.873 0.152	KWH THERM	/SQFT-YR /SQFT-YR	NET-AREA NET-AREA	
PERCENT OF HOURS ANY PERCENT OF HOURS ANY HOURS ANY ZONE ABOVE HOURS ANY ZONE BELOW	SYSTEM ZONE OUTSI PLANT LOAD NOT SA COOLING THROTTLIN HEATING THROTTLIN	DE OF THROTTLIN TISFIED G RANGE G RANGE	NG RANGE = 3 = 0 = =	3.76).00 0 234					
NOTE: ENERGY IS APPO	RTIONED HOURLY TO	ALL END-USE CA	ATEGORIES.						
PS 33X Jerome Ave 3				DOE-	2.2-48y	7/24/20)18 17:	17:21 BD	LRUN 1
REPORT- ES-D Energy Cost Summary					WE	ATHER FII	LE- NEW YO	RK LAGUAR	DI NY
UTILITY-RATE	RESOURCE	METERS	ע אַט	METERED ENERGY NITS/YR		TOTAL CHARGE (\$)	VIRTUA RAT (\$/UNIT	L E RATE) ALL Y	USED EAR?
ConEd SmGen SC-2 Non-TOU Elec	ELECTRICITY	EM1	33605	59. KWH		70764.	0.210	6 YE	s
ConEd Gen SC-2 Heating Gas	NATURAL-GAS	FM1	744	46. THERM		8569.	1.150	8 YE	S
						===== 79334.			
		ENI	ERGY COST/GRO	SS BLDG A	REA:	1.62			

ENERGY COST/NET BLDG AREA: 1.62

PS 33X Jerome Ave 3							DOE-2.2-4	8y	7/24/2018	17:17:21 BDI	RUN 1	
REPORT- LV-B Summary of Spaces						WEATHER FILE- NEW YORK LAGUAR						
NUMBER OF SPACES 112	EXTERIOR	76	INTER	RIOR 36	5							
				LIGHTS		EQUIP						
	SPACE*FLOOR	SPACE		(WATT /		(WATT /	INFILTRATION		AREA	VOLUME		
SPACE	MULTIPLIER	TYPE	AZIM	SQFT)	PEOPLE	SQFT)	METHOD	ACH	(SQFT)	(CUFT)		
Spaces on floor: C Below-Gra	de Flr											
C Gas Meter Room	1.0	INT	0.0	0.42	0.0	0.00	NO-INFILT.	0.00	414.8	4977.0		
C Mech Equipment Room	1.0	INT	-90.0	0.42	0.0	0.00	NO-INFILT.	0.00	281.2	3374.1		
C Stairs B	1.0	INT	0.0	0.63	0.0	0.00	NO-INFILT.	0.00	130.7	1568.6		
C Electrical Room	1.0	INT	0.0	0.42	0.0	0.00	NO-INFILT.	0.00	333.4	4000.8		
C Water Service/Sewage Eject	or 1.0	INT	0.0	0.42	0.0	0.00	NO-INFILT.	0.00	336.7	4040.0		
C Elevators	1.0	INT	0.0	0.00	0.0	0.00	NO-INFILT.	0.00	186.7	2240.5		
C Stairs A	1.0	TNL	-90.0	0.63	0.0	0.00	NO-INFILT.	0.00	316.8	3801.9		
C Sprinkler Booster Pump	1.0	INT	180.0	0.42	0.0	0.00	NO-INFILT.	0.00	34/.2	4105.8		
C Corridor	1.0	TNT	90.0	0.59	0.0	0.00	NO-INFILT.	0.00	/58.3	9099.3		
Spaces on floor: FL1 Ground	Flr											
FL1 Exercise Room	1.0	EXT	0.0	0.72	74.4	0.25	AIR-CHANGE	0.31	1283.6	16686.3		
FL1 Stairs B	1.0	EXT	-90.0	0.63	0.0	0.00	AIR-CHANGE	0.31	432.5	5622.8		
FL1 Toilet/Shower/Lockers	1.0	INT	0.0	0.88	0.0	0.00	NO-INFILT.	0.00	188.3	2448.4		
FL1 Parents/Community	1.0	EXT	0.0	1.11	2.2	0.50	AIR-CHANGE	0.31	217.7	2830.7		
FL1 Toilet A	1.0	EXT	0.0	0.88	0.0	0.00	AIR-CHANGE	0.31	70.1	911.2		
FL1 Exam Room	1.0	EXT	0.0	1.12	4.0	0.00	AIR-CHANGE	0.31	91.2	1185.1		
FL1 Stairs A	1.0	EXT	0.0	0.63	0.0	0.00	AIR-CHANGE	0.31	362.8	4716.3		
FL1 Nurse's Office	1.0	INT	0.0	1.00	1.7	1.25	NO-INFILT.	0.00	166.9	2169.4		
FLI Elevators	1.0	TNT	0.0	0.00	0.0	0.00	NO-INFILT.	0.00	193.1	2510.6		
FLI Bike Storage	1.0	EAT	90.0	0.63	0.0	0.00	AIR-CHANGE	0.31	9/.0	1530.0		
FLI Vescibule A	1.0	EA1 EVT	-90.0	1 00	2 0	1 25	AIR-CHANGE	0.31	202 7	2649 2		
FIL Mostibulo P	1.0	EA1 EVT	_90.0	1.00	2.0	1.25	AIR-CHANGE	0.31	203.7	2040.3		
FLI Bove	1.0	EXT	-90.0	0.39	0.0	0.00	AIR-CHANGE	0.31	153.2	1002 2		
FL1 Cafeteria	1.0	EXT	180 0	0.00	110 1	0.00	AIR-CHANGE	0.31	1981 6	25760 2		
FL1 Girls	1.0	EXT	0.0	0.88	0.0	0.00	NO-INFILT.	0.00	125.4	1630.5		
FL1 Students	1.0	EXT	0.0	0.88	0.0	0.00	NO-INFILT.	0.00	64.2	834.1		
FL1 Electrical	1.0	EXT	0.0	0.42	0.0	0.00	NO-INFILT.	0.00	66.7	867.5		
FL1 Servery	1.0	EXT	0.0	0.65	15.8	0.00	NO-INFILT.	0.00	284.8	3702.1		
FL1 Janitor's Closet	1.0	INT	0.0	1.24	0.0	0.00	NO-INFILT.	0.00	48.7	633.4		
FL1 Refuse Recycling	1.0	EXT	180.0	0.63	0.0	0.00	AIR-CHANGE	0.31	145.0	1885.3		
FL1 Can Wash	1.0	EXT	90.0	1.21	0.5	3.00	AIR-CHANGE	0.31	94.3	1226.5		
FL1 Dietition's Office	1.0	EXT	90.0	1.00	0.8	1.25	AIR-CHANGE	0.31	75.7	983.7		
FL1 Locker Rooms	1.0	EXT	90.0	0.88	0.0	0.00	AIR-CHANGE	0.31	164.7	2140.6		
FL1 Toilet B	1.0	EXT	0.0	0.88	0.0	0.00	AIR-CHANGE	0.31	74.2	965.1		
FL1 Pot Wash	1.0	EXT	0.0	1.21	0.8	3.00	NO-INFILT.	0.00	168.4	2189.4		

	New Yo	rk Cit	ty Publi	c School	1 PS 332	X Energ	y Model Rep	port			
FL1 Prep/Warming	1.0	EXT	0.0	1.21	2.7	3.00	NO-INFILT.	0.00	541.2	7036.1	
FL1 Corridor	1.0	EXT	-90.0	0.59	0.0	0.00	NO-INFILT.	0.00	1183.0	15378.8	
FL1 Storage	1.0	EXT	180.0	0.63	0.0	0.00	AIR-CHANGE	0.31	124.9	1623.4	
FL1 Receiving	1.0	EXT	180.0	0.63	0.0	0.00	AIR-CHANGE	0.31	78.6	1022.1	
Spaces on floor: FL2 Ground Flr											
FL2 Classroom A	1.0	EXT	90.0	1.12	43.3	0.25	AIR-CHANGE	0.31	994.9	12933.2	
PS 33X Jerome Ave 3							DOE-2.2-4	8y	7/24/2018	17:17:21 BDL RUN 3	1
REPORT- LV-B Summary of Spaces								WEA	THER FILE- NE	EW YORK LAGUARDI NY	
										(CONTINUED)	-
FL2 Classroom B	1.0	EXT	90.0	1.12	42.7	0.25	AIR-CHANGE	0.31	983.0	12778.4	
FL2 Classroom C	1.0	EXT	0.0	1.12	44.0	0.25	AIR-CHANGE	0.31	1013.0	13168.9	
FL2 Toilets A	1.0	INT	0.0	0.88	0.0	0.00	NO-INFILT.	0.00	133.6	1736.3	
FL2 Toilets B	1.0	INT	0.0	0.88	0.0	0.00	NO-INFILT.	0.00	125.3	1629.3	
FL2 Classroom D	1.0	EXT	90.0	1.12	41.3	0.25	AIR-CHANGE	0.31	949.2	12339.5	
FL2 Stairs B	1.0	EXT	0.0	0.63	0.0	0.00	AIR-CHANGE	0.31	349.1	4538.8	
FL2 Tollets C	1.0	TNL	0.0	0.88	0.0	0.00	NO-INFILT.	0.00	119.1	1548.9	
FL2 Starr	1.0	INT	0.0	0.88	0.0	0.00	NO-INFILT.	0.00	84.1	1093.0	
FL2 Comp / AV	1.0	TNL	0.0	0.42	0.0	7.50	NO-INFILT.	0.00	86.6	1126.2	
FL2 Toilet D	1.0	EXT	0.0	0.88	0.0	0.00	AIR-CHANGE	0.31	61.2	795.0	
FL2 Reading / Speech Resource	1.0	EXT	0.0	0.95	8.1	0.50	AIR-CHANGE	0.31	469.0	6097.4	
FL2 Elevators	1.0	TNL	0.0	0.00	0.0	0.00	NO-INFILT.	0.00	196.5	2554.0	
FL2 Stairs A	1.0	EXT	0.0	0.63	0.0	0.00	AIR-CHANGE	0.31	322.3	4190.4	
FL2 Classroom E	1.0	EXT	0.0	1.12	41.1	0.25	AIR-CHANGE	0.31	946.1	12299.9	
FL2 Toilet E	1.0	INT	0.0	0.88	0.0	0.00	NO-INFILT.	0.00	62.6	814.1	
FL2 Elec	1.0	INT	0.0	0.42	0.0	0.00	NO-INFILT.	0.00	61.8	803.3	
FL2 Corridor	1.0	EXT	90.0	0.59	0.0	0.00	AIR-CHANGE	0.31	1089.6	14165.3	
FL2 Classroom F	1.0	EXT	90.0	1.12	43.7	0.25	AIR-CHANGE	0.31	1005.6	13073.0	
Spaces on floor: FL3 Ground Flr											
FL3 Classroom A	1.0	EXT	90.0	1.12	43.3	0.25	AIR-CHANGE	0.31	994.9	12933.2	
FL3 Classroom B	1.0	EXT	90.0	1.12	42.7	0.25	AIR-CHANGE	0.31	983.0	12778.4	
FL3 Classroom C	1.0	EXT	0.0	1.12	44.0	0.25	AIR-CHANGE	0.31	1013.0	13168.9	
FL3 Toilets A	1.0	INT	0.0	0.88	0.0	0.00	NO-INFILT.	0.00	133.6	1736.3	
FL3 Toilets B	1.0	INT	0.0	0.88	0.0	0.00	NO-INFILT.	0.00	125.3	1629.3	
FL3 Classroom D	1.0	EXT	90.0	1.12	41.3	0.25	AIR-CHANGE	0.31	949.2	12339.5	
FL3 Stairs B	1.0	EXT	0.0	0.63	0.0	0.00	AIR-CHANGE	0.31	349.1	4538.8	
FL3 Toilet C	1.0	INT	0.0	0.88	0.0	0.00	NO-INFILT.	0.00	119.1	1548.9	
FL3 Toilet D	1.0	INT	0.0	0.88	0.0	0.00	NO-INFILT.	0.00	84.1	1093.0	
FL3 MDF	1.0	EXT	0.0	0.42	0.0	7.50	AIR-CHANGE	0.31	358.7	4662.7	
FL3 Elevators	1.0	INT	0.0	0.00	0.0	0.00	AIR-CHANGE	0.31	196.5	2554.0	
FL3 Stairs A	1.0	EXT	0.0	0.63	0.0	0.00	AIR-CHANGE	0.31	322.3	4190.4	
FL3 Classroom E	1.0	EXT	0.0	1.12	41.1	0.25	AIR-CHANGE	0.31	946.1	12299.9	
FL3 Toilet E	1.0	INT	0.0	0.88	0.0	0.00	NO-INFILT.	0.00	62.6	814.1	
FL3 Elec	1.0	INT	0.0	0.42	0.0	0.00	NO-INFILT.	0.00	61.8	803.3	
FL3 Corridor	1.0	EXT	90.0	0.59	0.0	0.00	AIR-CHANGE	0.31	1093.1	14209.7	
FL3 Comp / AV	1.0	INT	0.0	0.42	0.0	7.50	NO-INFILT.	0.00	59.2	769.6	
FL3 Supervisory	1.0	EXT	0.0	1.00	2.0	1.25	AIR-CHANGE	0.31	195.8	2544.8	
FL3 Classroom F	1.0	EXT	90.0	1.12	43.7	0.25	AIR-CHANGE	0.31	1005.6	13073.0	
Spaces on floor: FL4 Ground Flr

FL4	Classroom A	1.0	EXT	90.0	1.12	38.2	0.25	AIR-CHANGE	0.31	877.5	11407.1
FL4	Classroom B	1.0	EXT	90.0	1.12	64.4	0.25	AIR-CHANGE	0.31	1480.3	19244.5
FL4	Classroom C	1.0	EXT	0.0	1.12	46.8	0.25	AIR-CHANGE	0.31	1077.2	14003.1
FL4	Classroom D	1.0	EXT	90.0	1.12	41.3	0.25	AIR-CHANGE	0.31	949.2	12339.5
FL4	Stairs B	1.0	EXT	0.0	0.63	0.0	0.00	AIR-CHANGE	0.31	349.1	4538.8
FL4	Toilet C	1.0	INT	0.0	0.88	0.0	0.00	NO-INFILT.	0.00	119.1	1548.9
FL4	Comp / AV	1.0	INT	0.0	0.42	0.0	7.50	NO-INFILT.	0.00	67.2	873.1
FL4	Staff Lunch / Conf	1.0	EXT	-90.0	0.65	34.2	0.00	AIR-CHANGE	0.31	615.8	8005.2
FL4	Elevators	1.0	INT	0.0	0.00	0.0	0.00	NO-INFILT.	0.00	196.5	2554.0
FL4	Stairs A	1.0	EXT	0.0	0.63	0.0	0.00	AIR-CHANGE	0.31	322.3	4190.4
FL4	Classroom E	1.0	EXT	0.0	1.12	39.2	0.25	AIR-CHANGE	0.31	901.1	11713.8
FL4	Toilet D	1.0	INT	0.0	0.88	0.0	0.00	NO-INFILT.	0.00	107.7	1400.3
FL4	Elec	1.0	INT	0.0	0.42	0.0	0.00	NO-INFILT.	0.00	61.8	803.3
FL4	Corridor	1.0	EXT	90.0	0.59	0.0	0.00	AIR-CHANGE	0.31	1032.4	13421.4

PS 33X Jerome Ave 3

REPORT- LV-B Summary of Spaces								WEATH	HER FILE- NEW	YORK LAGUARDI NY
FL4 Staff	 1.0	INT	0.0	0.88	0.0	0.00	NO-INFILT.	0.00		-(CONTINUED) 989.5
FL4 Classroom F	1.0	EXT	90.0	1.12	35.5	0.25	AIR-CHANGE	0.31	817.3	10624.6
Spaces on floor: FL5 Ground Flr										
FL5 Classroom A	1.0	EXT	0.0	1.12	33.7	0.25	AIR-CHANGE	0.27	775.0	11624.8
FL5 Classroom B	1.0	EXT	90.0	1.12	41.3	0.25	AIR-CHANGE	0.27	949.2	14237.9
FL5 Stairs B	1.0	EXT	0.0	0.63	0.0	0.00	AIR-CHANGE	0.27	349.1	5237.1
FL5 Toilet A	1.0	EXT	0.0	0.88	0.0	0.00	NO-INFILT.	0.00	119.1	1787.2
FL5 Toilet B	1.0	EXT	0.0	0.88	0.0	0.00	NO-INFILT.	0.00	79.6	1194.0
FL5 Classroom C	1.0	EXT	-90.0	1.12	29.5	0.25	AIR-CHANGE	0.27	679.5	10192.0
FL5 Elevators	1.0	INT	0.0	0.00	0.0	0.00	NO-INFILT.	0.00	196.5	2946.9
FL5 Stairs A	1.0	EXT	0.0	0.63	0.0	0.00	AIR-CHANGE	0.27	322.3	4835.0
FL5 Library	1.0	EXT	0.0	0.95	15.5	0.50	AIR-CHANGE	0.27	901.1	13515.9
FL5 Toilet C	1.0	EXT	0.0	0.88	0.0	0.00	NO-INFILT.	0.00	107.7	1615.7
FL5 Elec	1.0	EXT	0.0	0.42	0.0	0.00	NO-INFILT.	0.00	61.8	926.9
FL5 Corridor	1.0	EXT	90.0	0.59	0.0	0.00	AIR-CHANGE	0.27	1032.4	15486.3
FL5 Classroom D	1.0	EXT	180.0	1.12	78.1	0.25	AIR-CHANGE	0.27	1795.3	26929.1
FL5 Boiler Room	1.0	EXT	90.0	0.42	0.0	0.00	AIR-CHANGE	0.27	1339.7	20096.0
FL5 Closets	1.0	EXT	0.0	0.63	0.0	0.00	NO-INFILT.	0.00	347.1	5206.7
Spaces on floor: R Ground Flr										
R Elevator Machine Room	1.0	EXT	180.0	0.42	0.0	0.00	AIR-CHANGE	0.34	403.0	4836.5
R Elevators	1.0	EXT	0.0	0.00	0.0	0.00	AIR-CHANGE	0.34	178.1	2137.1
R Corridor	1.0	EXT	90.0	0.59	0.0	0.00	AIR-CHANGE	0.34	65.5	786.5
R Stairs A	1.0	EXT	90.0	0.63	0.0	0.00	AIR-CHANGE	0.34	298.7	3584.4
BUILDING TOTALS					 1234.9				49128.7	652732.6

DOE-2.2-48y 7/24/2018 17:17:21 BDL RUN 1

REPORT- LV-D Details of Exterior Surfaces

WEATHER FILE- NEW YORK LAGUARDI NY

NUMBER OF EXTERIOR SURFACES 182

(U-VALUE INCLUDES OUTSIDE FILM; WINDOW INCLUDES FRAME AND CURB, IF DEFINED)

	W I N D O W	s	W A L L		-WALL+WIN	DOWS-	
SURFACE	U-VALUE	AREA	U-VALUE	AREA	U-VALUE	AREA	AZIMUTH
	(BTU/HR-SQFT-F)	(SQFT)	(BTU/HR-SQFT-F)	(SQFT)	(BTU/HR-SQFT-F)	(SQFT)	
FL1 NE Wall (G.NNE1.E2)	0.441	45.00	0.104	62.90	0.245	107.90	NORTH-EAST
in space: FL1 Exercise Room							
FL1 NE Wall (G.NNE1.E4)	0.000	0.00	0.104	473.20	0.104	473.20	NORTH-EAST
in space: FL1 Exercise Room							
FL1 NE Wall (G.NNW10.E11)	0.000	0.00	0.104	42.90	0.104	42.90	NORTH-EAST
in space: FL1 Bike Storage							
FL1 NE Wall (G.E22.E24)	0.000	0.00	0.104	120.25	0.104	120.25	NORTH-EAST
in space: FL1 Can Wash							
FL1 NE Wall (G.NE23.E26)	0.000	0.00	0.104	68.90	0.104	68.90	NORTH-EAST
in space: FL1 Dietition's Office	e						
FL1 NE Wall (G.NE24.E27)	0.000	0.00	0.104	180.05	0.104	180.05	NORTH-EAST
in space: FL1 Locker Rooms							
FL1 NE Wall (G.NNE25.E29)	0.000	0.00	0.104	95.55	0.104	95.55	NORTH-EAST
in space: FL1 Toilet B							
FL2 NE Wall (G.E1.E1)	0.000	0.00	0.104	462.15	0.104	462.15	NORTH-EAST
in space: FL2 Classroom A							
FL2 NE Wall (G.N6.E8)	0.000	0.00	0.104	473.20	0.104	473.20	NORTH-EAST
in space: FL2 Classroom D							
FL2 NE Wall (G.W15.E19)	0.000	0.00	0.104	113.75	0.104	113.75	NORTH-EAST
in space: FL2 Classroom E							
FL2 NE Wall (G.C18.E20)	0.441	45.00	0.104	65.50	0.242	110.50	NORTH-EAST
in space: FL2 Corridor							
FL3 NE Wall (G.E1.E1)	0.000	0.00	0.104	462.15	0.104	462.15	NORTH-EAST
in space: FL3 Classroom A	0.000		0 104	482.00	0 104	482.00	
FL3 NE Wall (G.N6.E8)	0.000	0.00	0.104	473.20	0.104	473.20	NORTH-EAST
in space: FL3 Classroom D	0.000		0 104	112 85	0 104	110 85	
FL3 NE Wall (G.WI3.E18)	0.000	0.00	0.104	113.75	0.104	113.75	NORTH-EAST
IN SPACE: FL3 CLASSFOOM E	0 441	45 00	0 104	65 50	0 242	110 50	
in grade. EL2 Corridor	0.441	45.00	0.104	05.50	0.242	110.50	NORTH-EAST
FLA NE Wall (G E1 E1)	0 000	0 00	0 104	462 15	0 104	462 15	NODTU-FACT
in grade: EL4 Classroom A	0.000	0.00	0.104	402.13	0.101	102.13	NOKIII-EASI
FLA NE Wall (C N6 E8)	0 000	0 00	0 104	473 20	0 104	473 20	NODTU-FACT
in space: FL4 Classroom D	0.000	0.00	0.104	1/5.20	0.101	1/5.20	NORTH MADI
FL4 NE Wall ($G_{\rm W}13_{\rm F}18$)	0.000	0.00	0.104	113.75	0.104	113.75	NORTH-EAST
in space: FL4 Classroom E					**=*=		
FL4 NE Wall (G.NE16.E19)	0.441	45.00	0.104	65.50	0.242	110.50	NORTH-EAST
in space: FL4 Corridor							
FL5 NE Wall (G.N2.E5)	0.000	0.00	0.104	546.00	0.104	546.00	NORTH-EAST
FL5 NE Wall (G.N2.E5)	0.000	0.00	0.104	546.00	0.104	546.00	NORTH-EAST

in space:	FL5 Classroom B							
FL5 NE Wall	(G.W9.E22)	0.000	0.00	0.104	131.25	0.104	131.25	NORTH-EAST
in space:	FL5 Library							
FL5 NE Wall	(G.NE12.E26)	0.441	45.00	0.104	82.50	0.223	127.50	NORTH-EAST
in space:	FL5 Corridor							
FL5 NE Wall	(G.E14.E31)	0.000	0.00	0.104	533.25	0.104	533.25	NORTH-EAST
in space:	FL5 Boiler Room							
R NE Wall (G	.E1.E2)	0.000	0.00	0.104	235.20	0.104	235.20	NORTH-EAST
in space:	R Elevator Machine Room							

PS 33X Jerome Ave 3

REPORT- LV-D Details of Exterior Sur	faces				WEATHER FIL	E- NEW YORK LA	GUARDI NY
				107 40		(CONTIN	UED)
R NE Wall (G.W4.Ell)	0.000	0.00	0.104	197.40	0.104	197.40	NORTH-EAST
in space: R Stairs A	0 441	190 00	0 104	212 60	0 250	202 60	
in grade. EL2 Claggroom E	0.441	100.00	0.104	212.00	0.259	392.00	SOUTH-EAST
Fraterior Wall 149	0 000	0 00	0 104	0 65	0 1 0 4	0 65	COULT L- FACT
in grade, EL2 Classroom E	0.000	0.00	0.104	0.05	0.104	0.05	SOUTH-EAST
Exterior Wall 150	0 000	0 00	0 104	0 65	0 1 0 4	0 65	SOUTH-FAST
in grade, EL2 Classroom E	0.000	0.00	0.104	0.05	0.104	0.05	SOOTH-EAST
FIL SF Wall (C SF21 F23)	0 441	21 00	0 104	219 50	0 134	240 50	SOUTH-FAST
in space: FL1 Refuse Recycling	0.111	21.00	0.101	219.50	0.134	210.50	DODIN HADI
FL3 SE Wall (G.SE2.E4)	0.441	180.00	0.104	200.25	0.264	380.25	SOUTH-EAST
in space: FL3 Classroom B		100.00	01101	200125	01201	500125	
Exterior Wall 152	0.000	0.00	0.104	0.65	0.104	0.65	SOUTH-EAST
in space: FL3 Classroom B							
Exterior Wall 153	0.000	0.00	0.104	0.65	0.104	0.65	SOUTH-EAST
in space: FL3 Classroom B							
Exterior Wall 154	0.000	0.00	0.104	0.65	0.104	0.65	SOUTH-EAST
in space: FL3 Classroom B							
FL3 SE Wall (G.S3.E7)	0.441	180.00	0.104	213.90	0.258	393.90	SOUTH-EAST
in space: FL3 Classroom C							
Exterior Wall 143	0.000	0.00	0.104	175.50	0.104	175.50	SOUTH-EAST
in space: FL1 Storage							
FL3 SE Wall (G.N6.E11)	0.000	0.00	0.104	40.95	0.104	40.95	SOUTH-EAST
in space: FL3 Classroom D							
FL3 SE Wall (G.W13.E17)	0.000	0.00	0.104	33.15	0.104	33.15	SOUTH-EAST
in space: FL3 Classroom E							
Exterior Wall 144	0.441	21.00	0.104	89.50	0.168	110.50	SOUTH-EAST
in space: FL1 Receiving							
FL1 SE Wall (G.NNE1.E3)	0.000	0.00	0.104	40.95	0.104	40.95	SOUTH-EAST
in space: FL1 Exercise Room							
Exterior Wall 151	0.441	180.00	0.104	212.60	0.259	392.60	SOUTH-EAST
in space: FL3 Classroom F							
Exterior Wall 155	0.000	0.00	0.104	0.65	0.104	0.65	SOUTH-EAST
in space: FL3 Classroom F							
Exterior Wall 156	0.000	0.00	0.104	0.65	0.104	0.65	SOUTH-EAST
in space: FL3 Classroom F							
FLZ SE WALL (G.SEZ.E4)	0.000	0.00	0.104	0.65	0.104	0.65	SOUTH-EAST
in space: FL2 Classroom B	0 441	010 00	0 104	220 15	0 005	F40 15	
FL4 SE WAII (G.SE2.E4)	0.441	210.00	0.104	330.15	0.235	540.15	SOUTH-EAST

	New York City Public School PS 33X Energy Model Report									
in space: FL4 Classroom B				0.65		0.65				
in space: FL4 Classroom B	0.000	0.00	0.104	0.65	0.104	0.65	SOUTH-EAST			
Exterior Wall 159	0.000	0.00	0.104	0.65	0.104	0.65	SOUTH-EAST			
in space: FL4 Classroom B										
Exterior Wall 160	0.000	0.00	0.104	0.65	0.104	0.65	SOUTH-EAST			
in space: FL4 Classroom B	0 441	1 - 0 0 0	0 104	040.00		202.00				
in space. FL4 Classroom C	0.441	150.00	0.104	243.90	0.233	393.90	SOUTH-EAST			
Exterior Wall 146	0.441	180.00	0.104	200.25	0.264	380.25	SOUTH-EAST			
in space: FL2 Classroom B										
FL4 SE Wall (G.N6.E11)	0.000	0.00	0.104	40.95	0.104	40.95	SOUTH-EAST			
in space: FL4 Classroom D	0 000	0.00	0 104	22.15	0 104	22.15				
in space: FL4 Classroom E	0.000	0.00	0.104	33.15	0.104	33.15	SOUTH-EAST			
Exterior Wall 147	0.000	0.00	0.104	0.65	0.104	0.65	SOUTH-EAST			
in space: FL2 Classroom B										
Exterior Wall 148	0.000	0.00	0.104	0.65	0.104	0.65	SOUTH-EAST			
in space: FL2 Classroom B										

REPORT- LV-D Details of Exterior Surfa	ces				WEATHER FIL	E- NEW YORK LA	GUARDI NY
						(CONTIN	UED)
Exterior Wall 157	0.441	120.00	0.104	177.70	0.240	297.70	SOUTH-EAST
in space: FL4 Classroom F							
Exterior Wall 161	0.000	0.00	0.104	0.65	0.104	0.65	SOUTH-EAST
in space: FL4 Classroom F							
Exterior Wall 162	0.000	0.00	0.104	0.65	0.104	0.65	SOUTH-EAST
in space: FL4 Classroom F							
FL5 SE Wall (G.SSW1.E3)	0.441	120.00	0.104	207.00	0.228	327.00	SOUTH-EAST
in space: FL5 Classroom A							
FL2 SE Wall (G.S3.E7)	0.441	180.00	0.104	213.90	0.258	393.90	SOUTH-EAST
in space: FL2 Classroom C							
FL5 SE Wall (G.N2.E8)	0.000	0.00	0.104	47.25	0.104	47.25	SOUTH-EAST
in space: FL5 Classroom B							
FL5 SE Wall (G.W9.E21)	0.000	0.00	0.104	38.25	0.104	38.25	SOUTH-EAST
in space: FL5 Library							
FL1 SE Wall (G.E22.E25)	0.000	0.00	0.104	132.60	0.104	132.60	SOUTH-EAST
in space: FL1 Can Wash							
FL2 SE Wall (G.N6.E11)	0.000	0.00	0.104	40.95	0.104	40.95	SOUTH-EAST
in space: FL2 Classroom D							
FL5 SE Wall (G.SE13.E29)	0.441	240.00	0.104	517.50	0.211	757.50	SOUTH-EAST
in space: FL5 Classroom D							
FL2 SE Wall (G.W15.E18)	0.000	0.00	0.104	33.15	0.104	33.15	SOUTH-EAST
in space: FL2 Classroom E							
FL5 SE Wall (G.E14.E33)	0.441	240.00	0.104	471.75	0.218	711.75	SOUTH-EAST
in space: FL5 Boiler Room							
R SE Wall (G.E1.E1)	0.000	0.00	0.104	355.80	0.104	355.80	SOUTH-EAST
in space: R Elevator Machine Room							
FL1 SE Wall (G.WSW12.E17)	0.000	0.00	0.104	33.15	0.104	33.15	SOUTH-EAST
in space: FL1 Supervisory Office							
R SE Wall (G.SSE3.E9)	0.000	0.00	0.104	140.40	0.104	140.40	SOUTH-EAST

					1		
in space: R Corridor							
FL1 SE Wall (G.SSE15.E21)	0.441	277.50	0.104	626.00	0.208	903.50	SOUTH-EAST
in space: FL1 Cafeteria							
FL2 SE Wall (G.E1.E3)	0.441	180.00	0.104	206.75	0.261	386.75	SOUTH-EAST
in space: FL2 Classroom A							
FL3 SE Wall (G.E1.E3)	0.441	180.00	0.104	206.75	0.261	386.75	SOUTH-EAST
in space: FL3 Classroom A							
FL4 SE Wall (G.E1.E3)	0.441	120.00	0.104	201.10	0.230	321.10	SOUTH-EAST
in space: FL4 Classroom A							
R SW Wall (G.W4.E13)	0.000	0.00	0.104	309.01	0.104	309.01	SOUTH
in space: R Stairs A							
FL1 SW Wall (G.WSW14.E20)	0.000	0.00	0.104	139.13	0.104	139.13	SOUTH
in space: FL1 Boys							
FL4 SW Wall (G.NE16.E20)	0.441	30.00	0.104	74.00	0.202	104.00	SOUTH-WEST
in space: FL4 Corridor							
FL1 SW Wall (G.C28.E30)	0.000	0.00	0.104	12.35	0.104	12.35	SOUTH-WEST
in space: FL1 Corridor							
FL1 SW Wall (G.SW13.E18)	0.000	0.00	0.104	104.00	0.104	104.00	SOUTH-WEST
in space: FL1 Vestibule B							
FL1 SW Wall (G.W11.E13)	0.000	0.00	0.104	150.15	0.104	150.15	SOUTH-WEST
in space: FL1 Vestibule A							
FL5 SW Wall (G.SSW1.E2)	0.441	30.00	0.104	503.25	0.123	533.25	SOUTH-WEST
in space: FL5 Classroom A							
FL3 SW Wall (G.S3.E6)	0.441	30.00	0.104	432.15	0.126	462.15	SOUTH-WEST
in space: FL3 Classroom C							
FL2 SW Wall (G.C18.E21)	0.441	30.00	0.104	74.00	0.202	104.00	SOUTH-WEST
in space: FL2 Corridor							
FL5 SW Wall (G.N2.E7)	0.000	0.00	0.104	131.25	0.104	131.25	SOUTH-WEST
in space: FL5 Classroom B							

PS 33X Jerome Ave 3

REPORT- LV-I	Details of Exterior Surface	25				WEATHER FILE	- NEW YORK LA	GUARDI NY
FL2 SW Wall	(G.S3.E6)	0.441	30.00	0.104	432.15	0.126	462.15	SOUTH-WEST
in space: FL5 SW Wall	FL2 Classroom C (G.W9.E20)	0.441	90.00	0.104	463.50	0.159	553.50	SOUTH-WEST
in space:	FL5 Library		20000			00200		
FL3 SW Wall	(G.N6.E10)	0.000	0.00	0.104	113.75	0.104	113.75	SOUTH-WEST
in space:	FL3 Classroom D	0 441	90.00	0 104	156 25	0 227	246 25	COUTU-WEGT
in space:	FL1 Supervisory Office	0.111	90.00	0.104	150.55	0.227	240.33	SOUTH-WEST
FL4 SW Wall	(G.S3.E6)	0.441	30.00	0.104	432.15	0.126	462.15	SOUTH-WEST
in space:	FL4 Classroom C	0 441	20.00	0 104	00.00	0 1 9 0	120 00	COLITEL WEAT
in space:	(G.NEIZ.EZ/) FL5 Corridor	0.441	30.00	0.104	90.00	0.189	120.00	SOUTH-WEST
FL3 SW Wall	(G.W13.E16)	0.441	60.00	0.104	419.70	0.147	479.70	SOUTH-WEST
in space:	FL3 Classroom E							
in space:	(G.SSE15.E22) FL1 Cafeteria	0.441	52.50	0.104	271.20	0.159	323.70	SOUTH-WEST
FL4 SW Wall	(G.N6.E10)	0.000	0.00	0.104	113.75	0.104	113.75	SOUTH-WEST
in space:	FL4 Classroom D							
FL2 SW Wall	(G.N6.E10)	0.000	0.00	0.104	113.75	0.104	113.75	SOUTH-WEST

in space: FL2 Classroom D	0 441	60.00	0 104	410 70	0 1 4 7	470 70	
in apage. EIA Clagaroom E	0.441	60.00	0.104	419.70	0.14/	4/9./0	SOUTH-WEST
R SW Wall (G.EL.E4)	0.000	0.00	0.104	55.80	0.104	55.80	SOUTH-WEST
in space: R Elevator Machine Room	0.000	0.00	0.101	55.00	0.101	55.00	booin Mibi
FL1 SW Wall (G.W2.E5)	0.000	0.00	0.104	113.10	0.104	113.10	SOUTH-WEST
in space: FL1 Stairs B							
FL3 SW Wall (G.C16.E20)	0.441	30.00	0.104	74.00	0.202	104.00	SOUTH-WEST
in space: FL3 Corridor							
FL2 SW Wall (G.W15.E17)	0.441	90.00	0.104	389.70	0.168	479.70	SOUTH-WEST
in space: FL2 Classroom E							
R SW Wall (G.SSE3.E8)	0.000	0.00	0.104	67.84	0.104	67.84	SOUTH-WEST
in space: R Corridor							
FL3 NW Wall (G.N6.E9)	0.441	150.00	0.104	231.55	0.237	381.55	NORTH-WEST
in space: FL3 Classroom D							
FL4 NW Wall (G.NW7.E12)	0.441	36.00	0.104	128.45	0.178	164.45	NORTH-WEST
in space: FL4 Stairs B							
FL4 NW Wall (G.NW10.E13)	0.441	120.00	0.104	355.80	0.189	475.80	NORTH-WEST
in space: FL4 Staff Lunch / Conf							
FL4 NW Wall (G.NW12.E14)	0.441	36.00	0.104	116.10	0.184	152.10	NORTH-WEST
in space: FL4 Stairs A							
FL4 NW Wall (G.W13.E15)	0.441	150.00	0.104	232.85	0.236	382.85	NORTH-WEST
in space: FL4 Classroom E							
FL2 NW Wall (G.W15.E16)	0.441	150.00	0.104	232.85	0.236	382.85	NORTH-WEST
in space: FL2 Classroom E	0 000	0.00	0 104	40.05	0 1 0 4	40.05	
FL2 NW WAIL (G.EL.E2)	0.000	0.00	0.104	40.95	0.104	40.95	NORTH-WEST
IN Space: FLZ CLASSFOOM A	0 441	26 00	0 104	100 /5	0 170	164 45	NODELL WEGE
in space: FL3 Stairs B	0.441	30.00	0.104	120.45	0.178	104.43	NORTH-WEST
FIS NW Wall (C NW10 F13)	0 441	60 00	0 104	201 95	0 182	261 95	NODTU_WEST
in space: FL3 MDF	0.111	00.00	0.104	201.95	0.102	201.95	NOKIII-WEDI
FL3 NW Wall (G.NW12.E14)	0.441	36.00	0.104	116.10	0.184	152.10	NORTH-WEST
in space: FL3 Stairs A							
FL3 NW Wall (G.W13.E15)	0.441	150.00	0.104	232.85	0.236	382.85	NORTH-WEST
in space: FL3 Classroom E							
FL1 NW Wall (G.W11.E14)	0.441	50.00	0.104	83.25	0.231	133.25	NORTH-WEST
in space: FL1 Vestibule A							
FL1 NW Wall (G.WSW12.E15)	0.000	0.00	0.104	139.75	0.104	139.75	NORTH-WEST
in space: FL1 Supervisory Office							

PS 33X Jerome Ave 3

REPORT- LV-D	EPORT- LV-D Details of Exterior Surfaces WEATHER FILE- NEW YORK LAGUARDI NY										
FL5 NW Wall	(G.SSW1.E1)	0.000	0.00	0.104	38.25	0.104	38.25	NORTH-WEST			
in space: FL1 NW Wall	FL5 Classroom A (G.NW4.E7)	0.441	30.00	0.104	195.55	0.149	225.55	NORTH-WEST			
in space:	FL1 Parents/Community	0.000	0.00	0 104	105 05	0 104	105 05				
in space:	FL1 Toilet A	0.000	0.00	0.104	103.95	0.104	103.95	NORTH-WEST			
FL1 NW Wall	(G.NNE25.E28) FL1 Toilet B	0.000	0.00	0.104	40.95	0.104	40.95	NORTH-WEST			
FL5 NW Wall	(G.N2.E6)	0.441	150.00	0.104	290.25	0.219	440.25	NORTH-WEST			

in space	: FL5 Classroom B	0 441	90 00	0 104	123 85	0 246	213 85	NODTU-WEST
in space	• FL3 Supervisory	0.111	50.00	0.104	123.03	0.210	213.05	MORIH-WEDI
FT.2 NW Wal	$(C \leq 3 = 5)$	0 000	0 00	0 104	33 15	0 104	33 15	NORTH-WEST
in space	: FL2 Classroom C	0.000	0.00	0.101	55.15	0.101	55.15	NORTH MEDI
FI.5 NW Wal	(G NW3 E10)	0 441	36 00	0 104	153 75	0 168	189 75	NORTH-WEST
in space	: FL5 Stairs B	0.111	50.00	0.101	100.70	0.100	105.75	NORTH MEDI
FL5 NW Wal	$(G_{\rm NW6}, E14)$	0.441	180.00	0.104	369.00	0.215	549.00	NORTH-WEST
in space	: FL5 Classroom C						01000	
FL5 NW Wal	(G.NW8.E17)	0.441	36.00	0.104	139.50	0.173	175.50	NORTH-WEST
in space	: FL5 Stairs A							
FL5 NW Wal	l (G.W9.E19)	0.441	150.00	0.104	291.75	0.219	441.75	NORTH-WEST
in space	: FL5 Library							
FL1 NW Wal	1 (G.NW6.E9)	0.441	60.00	0.104	77.80	0.251	137.80	NORTH-WEST
in space	: FL1 Exam Room							
FL1 NW Wal	l (G.NW7.E10)	0.000	0.00	0.104	169.65	0.104	169.65	NORTH-WEST
in space	: FL1 Stairs A							
FL3 NW Wal	l (G.E1.E2)	0.000	0.00	0.104	40.95	0.104	40.95	NORTH-WEST
in space	: FL3 Classroom A							
FL4 NW Wal	l (G.E1.E2)	0.000	0.00	0.104	40.95	0.104	40.95	NORTH-WEST
in space	: FL4 Classroom A							
FL1 NW Wal	l (G.NNE1.E1)	0.441	180.00	0.104	200.90	0.264	380.90	NORTH-WEST
in space	: FL1 Exercise Room							
FL2 NW Wal	l (G.N6.E9)	0.441	150.00	0.104	231.55	0.237	381.55	NORTH-WEST
in space	: FL2 Classroom D							
FL1 NW Wal	l (G.NNW10.E12)	0.000	0.00	0.104	109.85	0.104	109.85	NORTH-WEST
in space	: FL1 Bike Storage							
FL5 NW Wal	l (G.E14.E32)	0.000	0.00	0.104	47.25	0.104	47.25	NORTH-WEST
in space	: FL5 Boiler Room							
FL1 NW Wal	1 (G.W2.E6)	0.000	0.00	0.104	154.05	0.104	154.05	NORTH-WEST
in space	: FL1 Stairs B							
FL2 NW Wal	1 (G.NW7.E12)	0.441	18.00	0.104	146.45	0.141	164.45	NORTH-WEST
in space	: FL2 Stairs B				~~		~~ 4 -	
FL4 NW Wal	I (G.S3.E5)	0.000	0.00	0.104	33.15	0.104	33.15	NORTH-WEST
in space	: FL4 Classroom C		0.00	0 104	100 00	0 104	100 00	
R NW Wall	(G.EI.E3)	0.000	0.00	0.104	126.00	0.104	126.00	NORTH-WEST
in space	: R Elevator Machine Room	0 000	0.00	0 104	22.15	0 104	22.15	
FL3 NW Wal	L (G.SJ.EJ)	0.000	0.00	0.104	33.15	0.104	33.15	NORTH-WEST
D NW Wall	(C M 2 E)	0 000	0 00	0 104	220 80	0 104	220 80	
in space	(G.NWZ.ED) • P Flevetors	0.000	0.00	0.104	229.00	0.104	229.80	NORTH-WEST
FT.2 NW Wal	(C MW11 F13)	0 441	37 50	0 104	60 65	0 233	98 15	NODTU_WEGT
in space	· EL2 Toilet D	0.441	37.50	0.104	00.05	0.233	90.15	NORTH-WEST
FI.2 NW Wal	(G.NW12.E14)	0.441	142.50	0.104	235.15	0.231	377.65	NORTH-WEST
in space	: FL2 Reading / Speech Resource		112.00	~	100.10		5.7.05	
FL4 NW Wal	1 (G.N6.E9)	0.441	150.00	0.104	231.55	0.237	381.55	NORTH-WEST
in space	: FL4 Classroom D						302.00	
R NW Wall	(G.W4.E12)	0.000	0.00	0.104	140.40	0.104	140.40	NORTH-WEST
in space	: R Stairs A		*					

PS 33X Jerome Ave 3

REPORT- LV-D Details of Exterior Surfaces

DOE-2.2-48y 7/24/2018 17:17:21 BDL RUN 1

WEATHER FILE- NEW YORK LAGUARDI NY

						(CONTIN	UED)
FL2 NW Wall (G.NW14.E15)	0.441	36.00	0.104	116.10	0.184	152.10	NORTH-WEST
in space: FL2 Stairs A							
FL1 NW Wall (G.WSW14.E19)	0.000	0.00	0.104	33.15	0.104	33.15	NORTH-WEST
in space: FL1 Boys							
Exterior Wall 175	0.000	0.00	0.055	94.35	0.055	94.35	FLOOR
in space: FL1 Can Wash							
Exterior Wall 168	0.000	0.00	0.055	153.25	0.055	153.25	FLOOR
in space: FL1 Boys							
Exterior Wall 176	0.000	0.00	0.055	75.67	0.055	75.67	FLOOR
in space: FLI Distition's Office							
Exterior Wall 166	0.000	0.00	0.055	203.71	0.055	203.71	FLOOR
In space: FLI Supervisory Office	0 000	0.00	0 055	164.66	0 055	164.66	
Exterior Wall 1//	0.000	0.00	0.055	104.00	0.055	104.00	FLOOR
In space: FLI Locker Rooms	0 000	0 00	0 055	1000 FC	0 055	1000 50	HI OOD
in appage. El Exempide Deem	0.000	0.00	0.055	1283.50	0.055	1283.50	FLOOR
Exterior Mall 160	0 000	0 00	0 055	1001 EC	0 0 5 5	1001 EC	ET OOD
in grade. EI1 Cafetoria	0.000	0.00	0.055	1901.50	0.055	1901.30	FLOOR
Exterior Wall 178	0 000	0 00	0 055	74 24	0 055	74 24	FT.OOP
in space. EL1 Toilet B	0.000	0.00	0.055	/1.21	0.055	/1.21	FLOOR
Exterior Wall 179	0.000	0.00	0.055	168.42	0.055	168.42	FLOOR
in space: FL1 Pot Wash	0.000	0.00	0.055	100012	0.055	100012	1 2001
Exterior Wall 180	0.000	0.00	0.055	541.24	0.055	541.24	ROOT
in space: FL1 Prep/Warming							
Exterior Wall 170	0.000	0.00	0.055	125.43	0.055	125.43	FLOOR
in space: FL1 Girls							
Exterior Wall 181	0.000	0.00	0.055	1182.98	0.055	1182.98	FLOOR
in space: FL1 Corridor							
Exterior Wall 171	0.000	0.00	0.055	64.16	0.055	64.16	FLOOR
in space: FL1 Students							
Exterior Wall 182	0.000	0.00	0.055	124.88	0.055	124.88	FLOOR
in space: FL1 Storage							
Exterior Wall 172	0.000	0.00	0.055	66.73	0.055	66.73	FLOOR
in space: FL1 Electrical							
Exterior Wall 183	0.000	0.00	0.055	78.62	0.055	78.62	FLOOR
in space: FL1 Receiving							
Exterior Wall 173	0.000	0.00	0.055	284.78	0.055	284.78	FLOOR
in space: FLI Servery	0 000	0.00	0 055	CE 40	0 055	CE 40	
Exterior Wall 16/	0.000	0.00	0.055	65.40	0.055	65.40	FLOOR
The space: FLI vestibule B	0 000	0 00	0 055	145 02	0 0 5 5	145 02	ET OOD
in appage. EI1 Pofuge Pogualing	0.000	0.00	0.055	145.02	0.055	145.02	FLOOR
Exterior Wall 164	0 000	0 00	0 055	97 60	0 055	97 60	FT.OOP
in space. FL1 Bike Storage	0.000	0.00	0.055	57.00	0.055	57.00	FLOOR
Exterior Wall 165	0.000	0.00	0.055	118.39	0.055	118.39	ROOT
in space: FL1 Vestibule A	0.000	0.00	0.055	110.00	0.055	110.00	1 2001
Exterior Wall 142	0.000	0.00	0.032	103.10	0.032	103.10	ROOF
in space: FL1 Stairs B							
FL5 Roof (G.NW3.E11)	0.000	0.00	0.032	349.14	0.032	349.14	ROOF
in space: FL5 Stairs B							
FL5 Roof (G.C4.E12)	0.000	0.00	0.032	119.15	0.032	119.15	ROOF
in space: FL5 Toilet A							
FL5 Roof (G.E14.E34)	0.000	0.00	0.032	1339.73	0.032	1339.73	ROOF
in space: FL5 Boiler Room							

New York City Public School PS 33X Energy Model Report

New York City Public School PS 33X Energy Model Report									
FL5 Roof (G.C15.E35) in space: FL5 Closets	0.000	0.00	0.032	347.11	0.032	347.11	ROOF		
FL5 Roof (G.C5.E13) in space: FL5 Toilet B	0.000	0.00	0.032	79.60	0.032	79.60	ROOF		

REPORT- LV-D Details of Exterior Surfa	ces				WEATHER FIL	E- NEW YORK LA	GUARDI NY
FI.5 Roof (G.W9.E23)	0.000	0.00	0.032	901.06	0.032	(CONTIN 901.06	ROOF
in space: FL5 Library				202000		202000	
FL5 Roof (G.C10.E24)	0.000	0.00	0.032	107.72	0.032	107.72	ROOF
in space: FL5 Toilet C							
FL5 Roof (G.C11.E25)	0.000	0.00	0.032	61.79	0.032	61.79	ROOF
in space: FL5 Elec							
R Roof (G.E1.E5)	0.000	0.00	0.032	403.05	0.032	403.05	ROOF
in space: R Elevator Machine Room							
FL5 Roof (G.SSW1.E4)	0.000	0.00	0.032	774.99	0.032	774.99	ROOF
in space: FL5 Classroom A							
R Roof (G.NW2.E7)	0.000	0.00	0.032	178.10	0.032	178.10	ROOF
in space: R Elevators							
FL5 Roof (G.NW6.E15)	0.000	0.00	0.032	679.47	0.032	679.47	ROOF
in space: FL5 Classroom C							
FL5 Roof (G.NE12.E28)	0.000	0.00	0.032	430.18	0.032	430.18	ROOF
in space: FL5 Corridor							
R Roof (G.SSE3.E10)	0.000	0.00	0.032	65.54	0.032	65.54	ROOF
in space: R Corridor							
Exterior Wall 141	0.000	0.00	0.032	298.98	0.032	298.98	ROOF
in space: FL5 Corridor							
FL5 Roof (G.N2.E9)	0.000	0.00	0.032	949.20	0.032	949.20	ROOF
in space: FL5 Classroom B							
FL5 Roof (G.SE13.E30)	0.000	0.00	0.032	1795.27	0.032	1795.27	ROOF
in space: FL5 Classroom D							
R Roof (G.W4.E14)	0.000	0.00	0.032	298.70	0.032	298.70	ROOF
in space: R Stairs A							
C Flr (B.NNE1.U1)	0.000	0.00	0.010	414.75	0.010	414.75	UNDERGRND
in space: C Gas Meter Room							
C NW Wall (B.NNE1.U2)	0.000	0.00	0.077	142.20	0.077	142.20	UNDERGRND
in space: C Gas Meter Room							
C NE Wall (B.NNE1.U3)	0.000	0.00	0.077	420.00	0.077	420.00	UNDERGRND
in space: C Gas Meter Room							
C Flr (B.W2.U4)	0.000	0.00	0.010	281.18	0.010	281.18	UNDERGRND
in space: C Mech Equipment Room							
C SW Wall (B.W2.U5)	0.000	0.00	0.077	104.40	0.077	104.40	UNDERGRND
in space: C Mech Equipment Room							
C NW Wall (B.W2.U6)	0.000	0.00	0.077	127.80	0.077	127.80	UNDERGRND
in space: C Mech Equipment Room							
C Flr (B.C3.U7)	0.000	0.00	0.010	130.72	0.010	130.72	UNDERGRND
in space: C Stairs B							
C Flr (B.NW4.U8)	0.000	0.00	0.010	333.40	0.010	333.40	UNDERGRND
in space: C Electrical Room							
C NW Wall (B.NW4.U9)	0.000	0.00	0.077	200.40	0.077	200.40	UNDERGRND
in space: C Electrical Room							

	N	ew York City Public	: Schoo	I PS 33X Energy	Model Repo	ort					
C Flr (B.NW5.U10)		0.000	0.00	0.010	336.67	0.010	336.67	UNDERGRND			
C NW Wall (B.NW5.U11)	sivice/ Sewage		0.00	0.077	238.80	0.077	238.80	UNDERGRND			
C Flr (B.C6.U12)	ervice/Sewage	ejector 0.000	0.00	0.010	186.71	0.010	186.71	UNDERGRND			
in space: C Elevator C Flr (B.W7.U13)	rs	0.000	0.00	0.010	316.82	0.010	316.82	UNDERGRND			
C SW Wall (B.W7.U14)	4	0.000	0.00	0.077	117.60	0.077	117.60	UNDERGRND			
C NW Wall (B.W7.U15)	<u>,</u>	0.000	0.00	0.077	138.00	0.077	138.00	UNDERGRND			
C Flr (B.SW8.U16)	r Booster Dum	0.000	0.00	0.010	347.15	0.010	347.15	UNDERGRND			
C SE Wall (B.SW8.U17) in space: C Sprinkle	er Booster Pum	0.000 0.000	0.00	0.077	157.20	0.077	157.20	UNDERGRND			
	si boostei rum	£.									
PS 33X Jerome Ave 3					DOE-2.2-48y	7/24/2018	17:17:21	BDL RUN 1			
REPORT- LV-D Details (EPORT- LV-D Details of Exterior Surfaces WEATHER FILE- NEW YORK LAGUARDI NY										
							•	- •			
SURFACE		W I N D O W S U-VALUE (BTU/HR-SQFT-F)	AREA (SQFT)	W A L L U-VALUE (BTU/HR-SQFT-F)		ALL+WIN U-VALUE TU/HR-SQFT-F)	DOWS- AREA (SQFT)	AZIMUTH			
C NW Wall (B.SW8.U18)		0.000	0.00	0.077	157.20	0.077	157.20	UNDERGRND			
in space: C Sprinkle C SW Wall (B.SW8.U19)	er Booster Pum	0.000	0.00	0.077	318.00	0.077	318.00	UNDERGRND			
C Flr (B.SE9.U20)	er Booster Pum	0.000	0.00	0.010	758.28	0.010	758.28	UNDERGRND			
C NE Wall (B.SE9.U21)	-	0.000	0.00	0.077	120.00	0.077	120.00	UNDERGRND			
C SE Wall (B.SE9.U22) in space: C Corridor	- -	0.000	0.00	0.077	847.20	0.077	847.20	UNDERGRND			
PS 33X Jerome Ave 3					DOE-2.2-48y	7/24/2018	17:17:21	BDL RUN 1			
REPORT- LV-D Details o	of Exterior Su	rfaces				WEATHER FILE-	NEW YORK LA	GUARDI NY JED)			
ט. (ז	AVERAGE -VALUE/WINDOWS 3TU/HR-SQFT-F)	AVERAGE U-VALUE/WALLS (BTU/HR-SQFT-F)	AV W (B	ERAGE U-VALUE ALLS+WINDOWS TU/HR-SQFT-F)	WINDOW AREA (SQFT)	WALL AREA (SQFT)	WIN A)	DOW+WALL REA SQFT)			

	<u>Ne</u>	w York City Public Sc.	hool PS 33X Ener	rgy Model Repor	<u>t</u>	
NORTH-EAST	0.441	0.104	0.116	225.00	6113.15	6338.15
SOUTH-EAST	0.441	0.104	0.216	2959.50	5947.05	8906.55
SOUTH	0.000	0.104	0.104	0.00	448.14	448.14
SOUTH-WEST	0.441	0.104	0.143	682.50	5207.59	5890.09
NORTH-WEST	0.441	0.104	0.196	2420.00	6481.35	8901.35
FLOOR	0.000	0.055	0.055	0.00	7094.64	7094.64
ROOF	0.000	0.032	0.032	0.00	9281.85	9281.85
ALL WALLS	0.441	0.104	0.174	6287.00	24197.28	30484.29
WALLS+ROOFS	0.441	0.084	0.141	6287.00	33479.14	39766.14
UNDERGRND	0.000	0.043	0.043	0.00	6194.48	6194.48
BUILDING	0.441	0.074	0.118	6287.00	46768.24	53055.24

DOE-2.2-48y 7/24/2018 17:17:21 BDL RUN 1

REPORT- LV-H Details of Windows WEATHER FILE- NEW YORK LAGUARDI NY

NUMBER OF WINDOWS 123

					LOCATION O	F ORIGIN				
		GLASS	GLASS	GLASS	IN	SURFACE	FRAME	CURB	FRAME	CURB
WINDOW		AREA	HEIGHT	WIDTH	COO	RDINATES	AR	EA	U-VA	LUE
NAME	MULTIPLIER	(SQFT)	(FT)	(FT)	X (FT)	Y (FT)	(SQF	т)	(BTU/HR-	SQFT-F)
Window 1	1.0	90.00	7.50	12.00	2.50	2.50	0.00	0.00	0.384	0.000
Window 2	1.0	90.00	7.50	12.00	17.30	2.50	0.00	0.00	0.384	0.000
Window 121	1.0	45.00	7.50	6.00	1.00	2.50	0.00	0.00	0.384	0.000
Window 5	1.0	30.00	7.50	4.00	11.00	2.50	0.00	0.00	0.384	0.000
Window 3	1.0	60.00	7.50	8.00	0.00	2.50	0.00	0.00	0.384	0.000
Window 7	1.0	50.00	8.00	6.25	0.00	0.00	0.00	0.00	0.384	0.000
Window 75	1.0	90.00	7.50	12.00	2.50	2.50	0.00	0.00	0.384	0.000
Window 77	1.0	52.50	7.50	7.00	3.75	2.50	0.00	0.00	0.384	0.000
Window 78	1.0	52.50	7.50	7.00	17.75	2.50	0.00	0.00	0.384	0.000
Window 79	1.0	52.50	7.50	7.00	32.75	2.50	0.00	0.00	0.384	0.000
Window 80	1.0	52.50	7.50	7.00	46.75	2.50	0.00	0.00	0.384	0.000
Window 81	1.0	67.50	7.50	9.00	58.75	2.50	0.00	0.00	0.384	0.000
Window 76	1.0	52.50	7.50	7.00	1.00	2.50	0.00	0.00	0.384	0.000
Window 82	1.0	21.00	7.00	3.00	14.00	0.00	0.00	0.00	0.384	0.000
Window 126	1.0	21.00	7.00	3.00	1.00	0.00	0.00	0.00	0.384	0.000
Window 90	1.0	90.00	7.50	12.00	2.00	2.50	0.00	0.00	0.384	0.000

		<u>rtew ronk en</u>	y i done b		10 5571	Lifeigy wie	der reepe				
Window	91	1.0	90.00	7.50	12.00	17.00	2.50	0.00	0.00	0.384	0.000
Window	131	1.0	90.00	7.50	12.00	2.75	2.50	0.00	0.00	0.384	0.000
Window	132	1.0	90.00	7.50	12.00	16.75	2.50	0.00	0.00	0.384	0.000
Window	74	1.0	30.00	7.50	4.00	2.50	2.50	0.00	0.00	0.384	0.000
Window	84	1.0	90.00	7.50	12.00	3.75	2.50	0.00	0.00	0.384	0.000
Window	85	1.0	90.00	7.50	12.00	17.75	2.50	0.00	0.00	0.384	0.000
Window	8	1.0	30.00	7.50	4.00	2.50	2.50	0.00	0.00	0.384	0.000
Window	9	1.0	60.00	7.50	8.00	10.50	2.50	0.00	0.00	0.384	0.000
Window	10	1.0	60.00	7.50	8.00	21.35	2.50	0.00	0.00	0.384	0.000
Window	44	1.0	18.00	3.00	6.00	3.00	10.00	0.00	0.00	0.384	0.000
Window	11	1.0	37.50	7.50	5.00	2.55	2.50	0.00	0.00	0.384	0.000
Window	12	1.0	52.50	7.50	7.00	0.00	2.50	0.00	0.00	0.384	0.000
Window	13	1.0	90.00	7.50	12.00	11.00	2.50	0.00	0.00	0.384	0.000
Window	51	1.0	18.00	3.00	6.00	3.00	0.00	0.00	0.00	0.384	0.000
Window	58	1.0	18.00	3.00	6.00	3.00	10.00	0.00	0.00	0.384	0.000
Window	14	1.0	60.00	7.50	8.00	0.00	2.50	0.00	0.00	0.384	0.000
Window	15	1.0	60.00	7.50	8.00	12.50	2.50	0.00	0.00	0.384	0.000
Window	16	1.0	30.00	7.50	4.00	24.50	2.50	0.00	0.00	0.384	0.000
Window	62	1.0	60.00	7.50	8.00	0.00	2.50	0.00	0.00	0.384	0.000
Window	66	1.0	30.00	7.50	4.00	30.00	2.50	0.00	0.00	0.384	0.000
Window	122	1.0	45.00	7.50	6.00	1.00	2.50	0.00	0.00	0.384	0.000
Window	70	1.0	30.00	7.50	4.00	2.00	2.50	0.00	0.00	0.384	0.000
Window	127	1.0	90.00	7.50	12.00	2.75	2.50	0.00	0.00	0.384	0.000
Window	128	1.0	90.00	7.50	12.00	16.75	2.50	0.00	0.00	0.384	0.000
Window	98	1.0	90.00	7.50	12.00	2.00	2.50	0.00	0.00	0.384	0.000
Window	99	1.0	90.00	7.50	12.00	17.00	2.50	0.00	0.00	0.384	0.000
Window	94	1.0	90.00	7.50	12.00	2.75	2.50	0.00	0.00	0.384	0.000
Window	95	1.0	90.00	7.50	12.00	16.75	2.50	0.00	0.00	0.384	0.000
Window	73	1.0	30.00	7.50	4.00	2.50	2.50	0.00	0.00	0.384	0.000
Window	92	1.0	90.00	7.50	12.00	3.75	2.50	0.00	0.00	0.384	0.000
Window	93	1.0	90.00	7.50	12.00	17.75	2.50	0.00	0.00	0.384	0.000
Window	17	1.0	60.00	7.50	8.00	2.50	2.50	0.00	0.00	0.384	0.000
Window	18	1.0	60.00	7.50	8.00	14.50	2.50	0.00	0.00	0.384	0.000

PS 33X Jerome Ave 3

DOE-2.2-48y 7/24/2018 17:17:21 BDL RUN 1

REPORT- LV-H Details of Windows

WEATHER FILE- NEW YORK LAGUARDI NY

```
(CONTINUED)------
```

					LOCATION OF	ORIGIN				
		GLASS	GLASS	GLASS	IN	SURFACE	FRAME	CURB	FRAME	CURB
WINDOW		AREA	HEIGHT	WIDTH	COOR	DINATES	ARE	A	U-VAI	JUE
NAME	MULTIPLIER	(SQFT)	(FT)	(FT)	X (FT)	Y (FT)	(SQFI)	(BTU/HR-S	SQFT-F)
Window 19	1.0	30.00	7.50	4.00	24.50	2.50	0.00	0.00	0.384	0.000
Window 45	1.0	18.00	3.00	6.00	3.00	10.00	0.00	0.00	0.384	0.000
Window 49	1.0	18.00	3.00	6.00	3.00	0.00	0.00	0.00	0.384	0.000
Window 27	1.0	30.00	7.50	4.00	2.50	2.50	0.00	0.00	0.384	0.000
Window 28	1.0	30.00	7.50	4.00	10.50	2.50	0.00	0.00	0.384	0.000
Window 52	1.0	18.00	3.00	6.00	3.00	0.00	0.00	0.00	0.384	0.000
Window 57	1.0	18.00	3.00	6.00	3.00	10.00	0.00	0.00	0.384	0.000

		ty I uone o		15 557	Lifergy Mo	uer Repo				
Window 29	1.0	60.00	7.50	8.00	0.00	2.50	0.00	0.00	0.384	0.000
Window 30	1.0	30.00	7.50	4.00	12.50	2.50	0.00	0.00	0.384	0.000
Window 31	1.0	60.00	7.50	8.00	20.50	2.50	0.00	0.00	0.384	0.000
Window 61	1.0	30.00	7.50	4.00	0.00	2.50	0.00	0.00	0.384	0.000
Window 65	1.0	30.00	7.50	4.00	30.00	2.50	0.00	0.00	0.384	0.000
Window 123	1.0	45.00	7.50	6.00	1.00	2.50	0.00	0.00	0.384	0.000
Window 69	1.0	30.00	7.50	4.00	2.00	2.50	0.00	0.00	0.384	0.000
Window 26	1.0	90.00	7.50	12.00	2.50	2.50	0.00	0.00	0.384	0.000
Window 129	1.0	90.00	7.50	12.00	2.75	2.50	0.00	0.00	0.384	0.000
Window 130	1.0	90.00	7.50	12.00	16.75	2.50	0.00	0.00	0.384	0.000
Window 109	1.0	60.00	7.50	8.00	2.00	2.50	0.00	0.00	0.384	0.000
Window 110	1.0	60.00	7.50	8.00	14.00	2.50	0.00	0.00	0.384	0.000
Window 103	1.0	30.00	7.50	4.00	0.00	2.50	0.00	0.00	0.384	0.000
Window 104	1.0	60.00	7.50	8.00	6.00	2.50	0.00	0.00	0.384	0.000
Window 105	1.0	60.00	7.50	8.00	19.00	2.50	0.00	0.00	0.384	0.000
Window 135	1.0	60.00	7.50	8.00	30.00	2.50	0.00	0.00	0.384	0.000
Window 72	1.0	30.00	7.50	4.00	2.50	2.50	0.00	0.00	0.384	0.000
Window 100	1.0	60.00	7.50	8.00	3.80	2.50	0.00	0.00	0.384	0.000
Window 101	1.0	60.00	7.50	8.00	13.80	2.50	0.00	0.00	0.384	0.000
Window 102	1.0	30.00	7.50	4.00	26.30	2.50	0.00	0.00	0.384	0.000
Window 20	1.0	60.00	7.50	8.00	2.50	2.50	0.00	0.00	0.384	0.000
Window 21	1.0	60.00	7.50	8.00	14.50	2.50	0.00	0.00	0.384	0.000
Window 22	1.0	30.00	7.50	4.00	24.50	2.50	0.00	0.00	0.384	0.000
Window 46	1.0	18.00	3.00	6.00	3.00	10.00	0.00	0.00	0.384	0.000
Window 50	1.0	18.00	3.00	6.00	3.00	0.00	0.00	0.00	0.384	0.000
Window 38	1.0	30.00	7.50	4.00	2.50	2.50	0.00	0.00	0.384	0.000
Window 39	1.0	30.00	7.50	4.00	10.50	2.50	0.00	0.00	0.384	0.000
Window 40	1.0	30.00	7.50	4.00	18.50	2.50	0.00	0.00	0.384	0.000
Window 41	1.0	30.00	7.50	4.00	26.50	2.50	0.00	0.00	0.384	0.000
Window 53	1.0	18.00	3.00	6.00	3.00	0.00	0.00	0.00	0.384	0.000
Window 56	1.0	18.00	3.00	6.00	3.00	10.00	0.00	0.00	0.384	0.000
Window 32	1.0	30.00	7.50	4.00	0.00	2.50	0.00	0.00	0.384	0.000
Window 33	1.0	60.00	7.50	8.00	8.50	2.50	0.00	0.00	0.384	0.000
Window 34	1.0	60.00	7.50	8.00	20.50	2.50	0.00	0.00	0.384	0.000
Window 60	1.0	30.00	7.50	4.00	0.00	2.50	0.00	0.00	0.384	0.000
Window 64	1.0	30.00	7.50	4.00	30.00	2.50	0.00	0.00	0.384	0.000
Window 124	1.0	45.00	7.50	6.00	1.00	2.50	0.00	0.00	0.384	0.000
Window 68	1.0	30.00	7.50	4.00	2.00	2.50	0.00	0.00	0.384	0.000
Window 133	1.0	60.00	7.50	8.00	1.00	2.50	0.00	0.00	0.384	0.000
Window 134	1.0	60.00	7.50	8.00	11.00	2.50	0.00	0.00	0.384	0.000
Window 71	1.0	30.00	7.50	4.00	2.50	2.50	0.00	0.00	0.384	0.000
Window 111	1.0	60.00	7.50	8.00	3.80	2.50	0.00	0.00	0.384	0.000
Window 112	1.0	60.00	7.50	8.00	13.80	2.50	0.00	0.00	0.384	0.000
Window 23	1.0	30.00	7.50	4.00	2.50	2.50	0.00	0.00	0.384	0.000
Window 24	1.0	60.00	7.50	8.00	10.50	2.50	0.00	0.00	0.384	0.000

New York City Public School PS 33X Energy Model Report

DOE-2.2-48y 7/24/2018 17:17:21 BDL RUN 1

REPORT- LV-H Details of Windows WEATHER FILE- NEW YORK LAGUARDI NY

(CONTINUED)-----

					LOCATION OF	F ORIGIN				
		GLASS	GLASS	GLASS	IN	SURFACE	FRAME	CURB	FRAME	CURB
WINDOW		AREA	HEIGHT	WIDTH	COOL	RDINATES	AR	EA	U-VA	LUE
NAME	MULTIPLIER	(SQFT)	(FT)	(FT)	X (FT)	Y (FT)	(SQF	'T)	(BTU/HR-	SQFT-F)
Window 25	1.0	60.00	7.50	8.00	21.35	2.50	0.00	0.00	0.384	0.000
Window 47	1.0	18.00	3.00	6.00	3.00	10.00	0.00	0.00	0.384	0.000
Window 48	1.0	18.00	3.00	6.00	3.00	0.00	0.00	0.00	0.384	0.000
Window 42	1.0	90.00	7.50	12.00	2.50	2.50	0.00	0.00	0.384	0.000
Window 43	1.0	90.00	7.50	12.00	18.50	2.50	0.00	0.00	0.384	0.000
Window 54	1.0	18.00	3.00	6.00	3.00	0.00	0.00	0.00	0.384	0.000
Window 55	1.0	18.00	3.00	6.00	3.00	10.00	0.00	0.00	0.384	0.000
Window 35	1.0	60.00	7.50	8.00	0.00	2.50	0.00	0.00	0.384	0.000
Window 36	1.0	60.00	7.50	8.00	12.50	2.50	0.00	0.00	0.384	0.000
Window 37	1.0	30.00	7.50	4.00	24.50	2.50	0.00	0.00	0.384	0.000
Window 59	1.0	60.00	7.50	8.00	0.00	2.50	0.00	0.00	0.384	0.000
Window 63	1.0	30.00	7.50	4.00	30.00	2.50	0.00	0.00	0.384	0.000
Window 125	1.0	45.00	7.50	6.00	1.00	2.50	0.00	0.00	0.384	0.000
Window 67	1.0	30.00	7.50	4.00	2.00	2.50	0.00	0.00	0.384	0.000
Window 113	1.0	60.00	7.50	8.00	4.50	2.50	0.00	0.00	0.384	0.000
Window 114	1.0	60.00	7.50	8.00	14.50	2.50	0.00	0.00	0.384	0.000
Window 115	1.0	60.00	7.50	8.00	26.50	2.50	0.00	0.00	0.384	0.000
Window 116	1.0	60.00	7.50	8.00	36.50	2.50	0.00	0.00	0.384	0.000
Window 117	1.0	60.00	7.50	8.00	0.00	2.50	0.00	0.00	0.384	0.000
Window 118	1.0	60.00	7.50	8.00	10.00	2.50	0.00	0.00	0.384	0.000
Window 119	1.0	60.00	7.50	8.00	24.00	2.50	0.00	0.00	0.384	0.000
Window 120	1.0	60.00	7.50	8.00	36.00	2.50	0.00	0.00	0.384	0.000

		GLASS	NUMBER	CENTER-OF-	GLASS	GLASS	SURFACE TO
WINDOW	SETBACK	SHADING	OF	GLASS U-VALUE	VISIBLE	SOLAR	ROUGH OPEN
NAME	(FT)	COEFF	PANES	(BTU/HR-SQFT-F)	TRANS	TRANS	AREA RATIO
Window 1	0.00	0.46	1	0.441	0.440	0.878	1.000
Window 2	0.00	0.46	1	0.441	0.440	0.878	1.000
Window 121	0.00	0.46	1	0.441	0.440	0.878	1.000
Window 5	0.00	0.46	1	0.441	0.440	0.878	1.000
Window 3	0.00	0.46	1	0.441	0.440	0.878	1.000
Window 7	0.00	0.46	1	0.441	0.440	0.878	1.000
Window 75	0.00	0.46	1	0.441	0.440	0.878	1.000
Window 77	0.00	0.46	1	0.441	0.440	0.878	1.000
Window 78	0.00	0.46	1	0.441	0.440	0.878	1.000
Window 79	0.00	0.46	1	0.441	0.440	0.878	1.000
Window 80	0.00	0.46	1	0.441	0.440	0.878	1.000
Window 81	0.00	0.46	1	0.441	0.440	0.878	1.000
Window 76	0.00	0.46	1	0.441	0.440	0.878	1.000
Window 82	0.00	0.46	1	0.441	0.440	0.878	1.000
Window 126	0.00	0.46	1	0.441	0.440	0.878	1.000
Window 90	0.00	0.46	1	0.441	0.440	0.878	1.000
Window 91	0.00	0.46	1	0.441	0.440	0.878	1.000
Window 131	0.00	0.46	1	0.441	0.440	0.878	1.000
Window 132	0.00	0.46	1	0.441	0.440	0.878	1.000
Window 74	0.00	0.46	1	0.441	0.440	0.878	1.000
Window 84	0.00	0.46	1	0.441	0.440	0.878	1.000
Window 85	0.00	0.46	1	0.441	0.440	0.878	1.000

	<u>New York Ci</u>	New York City Public School PS 33X Energy Model Report								
Window 8	0.00	0.46	1	0.441	0.440	0.878	1.000			
Window 9	0.00	0.46	1	0.441	0.440	0.878	1.000			

DOE-2.2-48y 7/24/2018 17:17:21 BDL RUN 1

REPORT- LV-H Details of Windows

WEATHER FILE- NEW YORK LAGUARDI NY

				-(CONTINUED)
NUMBER	CENTER-OF-	GLASS	GLASS	SURFACE TO

		GLASS	NUMBER	CENTER-OF-	GLASS	GLASS	SURFACE TO
WINDOW	SETBACK	SHADING	OF	GLASS U-VALUE	VISIBLE	SOLAR	ROUGH OPEN
NAME	(FT)	COEFF	PANES	(BTU/HR-SQFT-F)	TRANS	TRANS	AREA RATIO
Window 10	0.00	0.46	1	0.441	0.440	0.878	1.000
Window 44	0.00	0.46	1	0.441	0.440	0.878	1.000
Window 11	0.00	0.46	1	0.441	0.440	0.878	1.000
Window 12	0.00	0.46	1	0.441	0.440	0.878	1.000
Window 13	0.00	0.46	1	0.441	0.440	0.878	1.000
Window 51	0.00	0.46	1	0.441	0.440	0.878	1.000
Window 58	0.00	0.46	1	0.441	0.440	0.878	1.000
Window 14	0.00	0.46	1	0.441	0.440	0.878	1.000
Window 15	0.00	0.46	1	0.441	0.440	0.878	1.000
Window 16	0.00	0.46	1	0.441	0.440	0.878	1.000
Window 62	0.00	0.46	1	0.441	0.440	0.878	1.000
Window 66	0.00	0.46	1	0.441	0.440	0.878	1.000
Window 122	0.00	0.46	1	0.441	0.440	0.878	1.000
Window 70	0.00	0.46	1	0.441	0.440	0.878	1.000
Window 127	0.00	0.46	1	0.441	0.440	0.878	1.000
Window 128	0.00	0.46	1	0.441	0.440	0.878	1.000
Window 98	0.00	0.46	1	0.441	0.440	0.878	1.000
Window 99	0.00	0.46	1	0.441	0.440	0.878	1.000
Window 94	0.00	0.46	1	0.441	0.440	0.878	1.000
Window 95	0.00	0.46	1	0.441	0.440	0.878	1.000
Window 73	0.00	0.46	1	0.441	0.440	0.878	1.000
Window 92	0.00	0.46	1	0.441	0.440	0.878	1.000
Window 93	0.00	0.46	1	0.441	0.440	0.878	1.000
Window 17	0.00	0.46	1	0.441	0.440	0.878	1.000
Window 18	0.00	0.46	1	0.441	0.440	0.878	1.000
Window 19	0.00	0.46	1	0.441	0.440	0.878	1.000
Window 45	0.00	0.46	1	0.441	0.440	0.878	1.000
Window 49	0.00	0.46	1	0.441	0.440	0.878	1.000
Window 27	0.00	0.46	1	0.441	0.440	0.878	1.000
Window 28	0.00	0.46	1	0.441	0.440	0.878	1.000
Window 52	0.00	0.46	1	0.441	0.440	0.878	1.000
Window 57	0.00	0.46	1	0.441	0.440	0.878	1.000
Window 29	0.00	0.46	1	0.441	0.440	0.878	1.000
Window 30	0.00	0.46	1	0.441	0.440	0.878	1.000
Window 31	0.00	0.46	1	0.441	0.440	0.878	1.000
Window 61	0.00	0.46	1	0.441	0.440	0.878	1.000
Window 65	0.00	0.46	1	0.441	0.440	0.878	1.000
Window 123	0.00	0.46	1	0.441	0.440	0.878	1.000
Window 69	0.00	0.46	1	0.441	0.440	0.878	1.000
Window 26	0.00	0.46	1	0.441	0.440	0.878	1.000

	New York	City Public	School PS 3	3X Energy Model	<u>Report</u>		
Window 129	0.00	0.46	1	0.441	0.440	0.878	1.000
Window 130	0.00	0.46	1	0.441	0.440	0.878	1.000
Window 109	0.00	0.46	1	0.441	0.440	0.878	1.000
Window 110	0.00	0.46	1	0.441	0.440	0.878	1.000
Window 103	0.00	0.46	1	0.441	0.440	0.878	1.000
Window 104	0.00	0.46	1	0.441	0.440	0.878	1.000
Window 105	0.00	0.46	1	0.441	0.440	0.878	1.000
Window 135	0.00	0.46	1	0.441	0.440	0.878	1.000
Window 72	0.00	0.46	1	0.441	0.440	0.878	1.000
Window 100	0.00	0.46	1	0.441	0.440	0.878	1.000
Window 101	0.00	0.46	1	0.441	0.440	0.878	1.000
Window 102	0.00	0.46	1	0.441	0.440	0.878	1.000
Window 20	0.00	0.46	1	0.441	0.440	0.878	1.000
Window 21	0.00	0.46	1	0.441	0.440	0.878	1.000

DOE-2.2-48y 7/24/2018 17:17:21 BDL RUN 1

REPORT- LV-H Details of Windows

WEATHER FILE- NEW YORK LAGUARDI NY ------(CONTINUED)------

		GLASS	NUMBER	CENTER-OF-	GLASS	GLASS	SURFACE TO
WINDOW	SETBACK	SHADING	OF	GLASS U-VALUE	VISIBLE	SOLAR	ROUGH OPEN
NAME	(FT)	COEFF	PANES	(BTU/HR-SQFT-F)	TRANS	TRANS	AREA RATIO
Window 22	0.00	0.46	1	0.441	0.440	0.878	1.000
Window 46	0.00	0.46	1	0.441	0.440	0.878	1.000
Window 50	0.00	0.46	1	0.441	0.440	0.878	1.000
Window 38	0.00	0.46	1	0.441	0.440	0.878	1.000
Window 39	0.00	0.46	1	0.441	0.440	0.878	1.000
Window 40	0.00	0.46	1	0.441	0.440	0.878	1.000
Window 41	0.00	0.46	1	0.441	0.440	0.878	1.000
Window 53	0.00	0.46	1	0.441	0.440	0.878	1.000
Window 56	0.00	0.46	1	0.441	0.440	0.878	1.000
Window 32	0.00	0.46	1	0.441	0.440	0.878	1.000
Window 33	0.00	0.46	1	0.441	0.440	0.878	1.000
Window 34	0.00	0.46	1	0.441	0.440	0.878	1.000
Window 60	0.00	0.46	1	0.441	0.440	0.878	1.000
Window 64	0.00	0.46	1	0.441	0.440	0.878	1.000
Window 124	0.00	0.46	1	0.441	0.440	0.878	1.000
Window 68	0.00	0.46	1	0.441	0.440	0.878	1.000
Window 133	0.00	0.46	1	0.441	0.440	0.878	1.000
Window 134	0.00	0.46	1	0.441	0.440	0.878	1.000
Window 71	0.00	0.46	1	0.441	0.440	0.878	1.000
Window 111	0.00	0.46	1	0.441	0.440	0.878	1.000
Window 112	0.00	0.46	1	0.441	0.440	0.878	1.000
Window 23	0.00	0.46	1	0.441	0.440	0.878	1.000
Window 24	0.00	0.46	1	0.441	0.440	0.878	1.000
Window 25	0.00	0.46	1	0.441	0.440	0.878	1.000
Window 47	0.00	0.46	1	0.441	0.440	0.878	1.000
Window 48	0.00	0.46	1	0.441	0.440	0.878	1.000
Window 42	0.00	0.46	1	0.441	0.440	0.878	1.000
Window 43	0.00	0.46	1	0.441	0.440	0.878	1.000

		New York Ci	ty Public Scl	hool PS 33X	Energy Model Re	eport		
Window	54	0.00	0.46	1	0.441	0.440	0.878	1.000
Window	55	0.00	0.46	1	0.441	0.440	0.878	1.000
Window	35	0.00	0.46	1	0.441	0.440	0.878	1.000
Window	36	0.00	0.46	1	0.441	0.440	0.878	1.000
Window	37	0.00	0.46	1	0.441	0.440	0.878	1.000
Window	59	0.00	0.46	1	0.441	0.440	0.878	1.000
Window	63	0.00	0.46	1	0.441	0.440	0.878	1.000
Window	125	0.00	0.46	1	0.441	0.440	0.878	1.000
Window	67	0.00	0.46	1	0.441	0.440	0.878	1.000
Window	113	0.00	0.46	1	0.441	0.440	0.878	1.000
Window	114	0.00	0.46	1	0.441	0.440	0.878	1.000
Window	115	0.00	0.46	1	0.441	0.440	0.878	1.000
Window	116	0.00	0.46	1	0.441	0.440	0.878	1.000
Window	117	0.00	0.46	1	0.441	0.440	0.878	1.000
Window	118	0.00	0.46	1	0.441	0.440	0.878	1.000
Window	119	0.00	0.46	1	0.441	0.440	0.878	1.000
Window	120	0.00	0.46	1	0.441	0.440	0.878	1.000

PS 33X Jerome Ave 3

DOE-2.2-48y 7/24/2018 17:17:21 BDL RUN 1

WEATHER FILE- NEW YORK LAGUARDI NY

REPORT- LV-I Details of Constructions

NUMBER OF CONSTRUCTIONS 10 DELAYED 8

DELAYED 8 QUICK 2

	U-VALUE		SURFACE		NUMBER OF
CONSTRUCTION		SURFACE	ROUGHNESS	SURFACE	RESPONSE
NAME	(BTU/HR-SQFT-F)	ABSORPTANCE	INDEX	TYPE	FACTORS
C EWall Construction	0.109	0.70	3	QUICK	0
C Ceilg Construction	0.141	0.70	3	DELAYED	4
C IWall Construction	0.141	0.70	3	DELAYED	4
C IFlr Construction	0.813	0.70	3	DELAYED	5
C IFLSP Construction	0.813	0.70	3	DELAYED	5
FL1 GFlr Construction	0.056	0.70	3	DELAYED	23
FL1 GF1SP Construction	0.056	0.70	3	DELAYED	23
FL5 Roof Construction	0.032	0.60	1	QUICK	0
C UFCons (B.NNE1.U2)	0.010	0.70	3	DELAYED	52
C UWCons (B.NNE1.U2)	0.077	0.70	3	DELAYED	40

PROPOSED DESIGN:

PS 33X Jerom	e Ave 3							DOE-	2.2-48r	8/17/20	18 11:	11:54 BD	LRUN 1
REPORT- BEPS	Building	Energy Pe	rformance	e 					WE	ATHER FIL	E- NEW YO	RK LAGUAR	DI NY
	LIGHTS	TASK LIGHTS	MISC EQUIP	SPACE HEATING	SPACE COOLING	HEAT REJECT	PUMPS & AUX	VENT FANS	REFRIG DISPLAY	HT PUMP SUPPLEM	DOMEST HOT WTR	EXT USAGE	TOTAL
EM1 ELECTRI MBTU	CITY 150.9	0.0	264.2	15.7	284.9	0.0	46.5	195.6	0.0	0.0	0.0	10.7	968.6
FM1 NATURAL	-GAS												
MBTU	0.0	0.0	44.9 ======	473.9	0.0	0.0	0.0	0.0	0.0	0.0	44.8 ======	0.0	563.6
MBTU	150.9	0.0	309.1	489.7	284.9	0.0	46.5	195.6	0.0	0.0	44.8	10.7	1532.2
	TOT. TOT.	AL SITE E AL SOURCE	NERGY ENERGY	1532.21 3469.46	MBTU MBTU	31.3 KBT 71.0 KBT	U/SQFT-YR U/SQFT-YR	GROSS-AR GROSS-AR	EA 31 EA 71	.3 KBTU/S .0 KBTU/S	QFT-YR NE QFT-YR NE	T-AREA T-AREA	
	PER PER HOU HOU	CENT OF H CENT OF H RS ANY ZO RS ANY ZO	OURS ANY OURS ANY NE ABOVE NE BELOW	SYSTEM ZO PLANT LOA COOLING T HEATING T	NE OUTSIE D NOT SAI HROTTLING HROTTLING	DE OF THRO DISFIED RANGE RANGE	TTLING RA	NGE = 0. = 0. = =	02 00 0 1				

NOTE: ENERGY IS APPORTIONED HOURLY TO ALL END-USE CATEGORIES.

PS 33X Je	erome Ave 3							DOE-	2.2-48r	8/17/20	11:	11:54 BD	L RUN 1
REPORT- 1	BEPU Building (Jtility P	erforman	ce					WE	ATHER FII	LE- NEW YO	RK LAGUAR	DI NY
	LIGHTS	TASK LIGHTS	MISC EQUIP	SPACE HEATING	SPACE COOLING	HEAT REJECT	PUMPS & AUX	VENT FANS	REFRIG DISPLAY	HT PUMP SUPPLEM	DOMEST HOT WTR	EXT USAGE	TOTAL
EM1 ELEC KWH	CTRICITY 44216.	0.	77411.	4612.	83475.	0.	13633.	57323.	0.	0.	0.	3136.	283806.
FM1 NATU THERI	URAL-GAS M 0.	0.	449.	4739.	0.	0.	0.	0.	0.	0.	448.	0.	5636.
	TOTAL ELECTI TOTAL NATUR?	RICITY AL-GAS	283806. 5636.	KWH THERM	5.805 0.115	KWH . THERM .	/SQFT-YR G /SQFT-YR G	ROSS-AREA ROSS-AREA	5.805 0.115	KWH THERM	/SQFT-YR : /SQFT-YR :	NET-AREA NET-AREA	
	PERCENT OF H PERCENT OF H HOURS ANY ZO HOURS ANY ZO NOTE: ENERC	HOURS ANY HOURS ANY DNE ABOVE DNE BELOW GY IS APP	SYSTEM 2 PLANT LC COOLING HEATING	ZONE OUTSI DAD NOT SA THROTTLIN THROTTLIN HOURLY TO	DE OF THR TISFIED G RANGE G RANGE G RANGE	OTTLING 1 USE CATE	RANGE = 0 = 0 = GORIES.	.02 .00 0 1					
PS 33X Je	erome Ave 3							DOE-	2.2-48r	8/17/20)18 11:	11:54 BD	LRUN 1
REPORT- I	ES-D Energy Cos	st Summar	у						WE	ATHER FII	LE- NEW YO	RK LAGUAR	DI NY
UTILITY-J	RATE		RESO	JRCE	METE	RS	M UN	ETERED ENERGY ITS/YR		TOTAL CHARGE (\$)	VIRTUA RAT (\$/UNIT	L E RATE) ALL Y 	USED EAR?
ConEd Sm(Gen SC-2 Non-TO	OU Elec	ELEC:	TRICITY	EM1		28380	6. KWH		58464.	0.206	0 YE	S
ConEd Ger	n SC-2 Heating	Gas	NATU	RAL-GAS	FM1		563	6. THERM		6547.	1.161	7 YE	S
										===== 65012.			
						ENERG	Y COST/GRO RGY COST/N	SS BLDG A	REA: REA:	1.33 1.33			

PS 33X Jerome Ave 3							DOE-2.2-4	8r	8/17/2018	11:11:54 BDL	RUN 1
REPORT- LV-B Summary of Space	es							WEAT	THER FILE- NE	W YORK LAGUARD	I NY
NUMBER OF SPACES 112	EXTERIOR	77	INTER	RIOR 3	5						
				LIGHTS		EQUIP					
	SPACE*FLOOR	SPACE		(WATT /		(WATT /	INFILTRATION		AREA	VOLUME	
SPACE	MULTIPLIER	TYPE	AZIM	SQFT)	PEOPLE	SQFT)	METHOD	ACH	(SQFT)	(CUFT)	
Spaces on floor: C Below-Grad	de Flr										
C Gas Meter Room	1.0	INT	0.0	0.49	0.0	0.00	NO-INFILT.	0.00	414.8	4977.0	
C Mech Equipment Room	1.0	INT	-90.0	0.49	0.0	0.00	NO-INFILT.	0.00	281.2	3374.1	
C Stairs B	1.0	INT	0.0	0.23	0.0	0.00	NO-INFILT.	0.00	130.7	1568.6	
C Electrical Room	1.0	INT	0.0	0.49	0.0	0.00	NO-INFILT.	0.00	333.4	4000.8	
C Water Service/Sewage Ejecto	or 1.0	TNL	0.0	0.49	0.0	0.00	NO-INFILT.	0.00	336.7	4040.0	
C Elevators	1.0	TNL	0.0	0.00	0.0	0.00	NO-INFILT.	0.00	186.7	2240.5	
C Stairs A	1.0	INT	-90.0	0.23	0.0	0.00	NO-INFILT.	0.00	310.8	3801.9 4165 9	
C Corridor	1.0		100.0	0.49	0.0	0.00	NO-INFILI.	0.00	34/.Z 750 2	4105.0	
C COTTIGOT	1.0	TNT	90.0	0.49	0.0	0.00	NO-INFILI.	0.00	/50.5	9099.5	
Spaces on floor: FL1 Ground 1	Flr										
FL1 Exercise Room	1.0	EXT	0.0	0.31	74.4	0.25	AIR-CHANGE	0.31	1283.6	16686.3	
FL1 Stairs B	1.0	EXT	-90.0	0.23	0.0	0.00	AIR-CHANGE	0.31	432.5	5622.8	
FL1 Toilet/Shower/Lockers	1.0	INT	0.0	0.57	0.0	0.00	NO-INFILT.	0.00	188.3	2448.4	
FL1 Parents/Community	1.0	EXT	0.0	1.14	2.2	0.50	AIR-CHANGE	0.31	217.7	2830.7	
FL1 Toilet A	1.0	EXT	0.0	0.57	0.0	0.00	AIR-CHANGE	0.31	70.1	911.2	
FL1 Exam Room	1.0	EXT	0.0	0.90	4.0	0.00	AIR-CHANGE	0.31	91.2	1185.1	
FL1 Stairs A	1.0	EXT	0.0	0.23	0.0	0.00	AIR-CHANGE	0.31	362.8	4716.3	
FL1 Nurse's Office	1.0	INT	0.0	0.90	1.7	1.25	NO-INFILT.	0.00	166.9	2169.4	
FL1 Elevators	1.0	INT	0.0	0.00	0.0	0.00	NO-INFILT.	0.00	193.1	2510.6	
FL1 Bike Storage	1.0	EXT	90.0	0.99	0.0	0.00	AIR-CHANGE	0.31	97.6	1268.8	
FLI Vestibule A	1.0	EXT	-90.0	0.49	0.0	0.00	AIR-CHANGE	0.31	118.4	1539.0	
FLI Supervisory Office	1.0	EXT	0.0	0.90	2.0	1.25	AIR-CHANGE	0.31	203.7	2648.3	
FLI Vestibule B	1.0	EXT	-90.0	0.49	0.0	0.00	AIR-CHANGE	0.31	65.4	850.1	
FLI Boys	1.0	EXT	1.00 0	0.57	0.0	0.00	AIR-CHANGE	0.31	153.2	1992.2	
FLI Careteria	1.0	EXT	180.0	0.51	110.1	0.00	AIR-CHANGE	0.31	1981.6	25760.2	
FLI GITIS FII Students	1.0	EAT	0.0	0.57	0.0	0.00	NO-INFILT.	0.00	125.4	1030.5	
FLI Students	1.0	EA1 EVT	0.0	0.57	0.0	0.00	NO-INFILI.	0.00	64.2	034.1 967 5	
	1.0	EAI	0.0	0.49	15 0	0.00	NO-INFILI.	0.00	204.0	2702 1	
FLI Janitoria Closet	1.0	EXT EXT	0.0	0.51	12.0	0.00	NO-INFILT.	0.00	48 7	633 4	
FL1 Refuse Recycling	1 0	EXT	180 0	0.70	0.0	0.00	ATR-CHANGE	0.31	145 0	1885 2	
FL1 Can Wash	1 0	EXT	90.0	0.78	0.5	3.00	ATR-CHANCE	0.31	94 3	1226.5	
FL1 Dietition's Office	1 0	EXT	90.0	0.90	0.8	1.25	ATR-CHANCE	0.31	75 7	983.7	
FL1 Locker Rooms	1.0	EXT	90.0	0.57	0.0	0.00	ATR-CHANGE	0.31	164.7	2140.6	
FL1 Toilet B	1.0	EXT	0.0	0.57	0.0	0.00	ATR-CHANGE	0.31	74.2	965.1	
FL1 Pot Wash	1.0	EXT	0.0	0.78	0.8	3.00	NO-INFILT.	0.00	168.4	2189.4	

	<u>New Yo</u>	rk Cit	ty Publi	c Schoo	1 PS 33	X Energ	gy Model Re	port		
FL1 Prep/Warming	1.0	EXT	0.0	0.78	2.7	3.00	NO-INFILT.	0.00	541.2	7036.1
FL1 Corridor	1.0	EXT	-90.0	0.49	0.0	0.00	NO-INFILT.	0.00	1183.0	15378.8
FL1 Storage	1.0	EXT	180.0	0.99	0.0	0.00	AIR-CHANGE	0.31	124.9	1623.4
FL1 Receiving	1.0	EXT	180.0	0.99	0.0	0.00	AIR-CHANGE	0.31	78.6	1022.1
Spaces on floor: FL2 Ground Flr										
FL2 Classroom A	1.0	EXT	90.0	0.59	43.3	0.25	AIR-CHANGE	0.31	994.9	12933.2
PS 33X Jerome Ave 3							DOE-2.2-4	8r	8/17/2018	11:11:54 BDL RUN 1
REPORT- LV-B Summary of Spaces								WEA	THER FILE- NE	EW YORK LAGUARDI NY
	1 0				42 7			0 21		(CONTINUED)
FL2 CLASSICOM B	1.0	EAT	90.0	0.59	42./	0.25	ALK-CHANGE	0.31	903.0	12169 0
FL2 CLASSIOOM C	1.0	EAT TNT	0.0	0.59	44.0	0.25	ALK-CHANGE	0.31	1013.0	1726 2
FLZ TOILETS A	1.0	TNL	0.0	0.57	0.0	0.00	NO-INFILT.	0.00	133.6	1620 2
FL2 TOILETS B	1.0	TNL	0.0	0.57	0.0	0.00	NO-INFILT.	0.00	125.3	1629.3
FL2 Classroom D	1.0	EXT	90.0	0.59	41.3	0.25	AIR-CHANGE	0.31	949.2	12339.5
FL2 Stairs B	1.0	EAT	0.0	0.23	0.0	0.00	AIR-CHANGE	0.31	349.1 110 1	4538.8
FL2 Toffets C	1.0	TNL	0.0	0.57	0.0	0.00	NO-INFILT.	0.00	119.1	1002 0
FL2 Staff	1.0	TNL	0.0	0.57	0.0	0.00	NO-INFILT.	0.00	84.1	1093.0
FL2 Comp / AV	1.0	TNL	0.0	0.49	0.0	7.50	NO-INFILT.	0.00	86.6	1126.2
FL2 Toilet D	1.0	EXT	0.0	0.57	0.0	0.00	AIR-CHANGE	0.31	61.2	795.0
FL2 Reading / Speech Resource	1.0	EXT	0.0	0.54	8.1	0.50	AIR-CHANGE	0.31	469.0	6097.4
FL2 Elevators	1.0	TNL	0.0	0.00	0.0	0.00	NO-INFILT.	0.00	196.5	2554.0
FL2 Stairs A	1.0	EXT	0.0	0.23	0.0	0.00	AIR-CHANGE	0.31	322.3	4190.4
FLZ Classroom E	1.0	EXT	0.0	0.59	41.1	0.25	AIR-CHANGE	0.31	946.1	12299.9
FL2 Toilet E	1.0	INT	0.0	0.57	0.0	0.00	NO-INFILT.	0.00	62.6	814.1
FLZ Elec	1.0	TNL	0.0	0.49	0.0	0.00	NO-INFILT.	0.00	61.8	803.3
FL2 Corridor	1.0	EXT	90.0	0.49	0.0	0.00	AIR-CHANGE	0.31	1089.6	14165.3
FL2 Classroom F	1.0	EXT	90.0	0.59	43.7	0.25	AIR-CHANGE	0.31	1005.6	13073.0
Spaces on floor: FL3 Ground Flr										
FL3 Classroom A	1.0	EXT	90.0	0.59	43.3	0.25	AIR-CHANGE	0.31	994.9	12933.2
FL3 Classroom B	1.0	EXT	90.0	0.59	42.7	0.25	AIR-CHANGE	0.31	983.0	12778.4
FL3 Classroom C	1.0	EXT	0.0	0.59	44.0	0.25	AIR-CHANGE	0.31	1013.0	13168.9
FL3 Toilets A	1.0	INT	0.0	0.57	0.0	0.00	NO-INFILT.	0.00	133.6	1736.3
FL3 Toilets B	1.0	INT	0.0	0.57	0.0	0.00	NO-INFILT.	0.00	125.3	1629.3
FL3 Classroom D	1.0	EXT	90.0	0.59	41.3	0.25	AIR-CHANGE	0.31	949.2	12339.5
FL3 Stairs B	1.0	EXT	0.0	0.23	0.0	0.00	AIR-CHANGE	0.31	349.1	4538.8
FL3 Toilet C	1.0	INT	0.0	0.57	0.0	0.00	NO-INFILT.	0.00	119.1	1548.9
FL3 Toilet D	1.0	INT	0.0	0.57	0.0	0.00	NO-INFILT.	0.00	84.1	1093.0
FL3 MDF	1.0	EXT	0.0	0.49	0.0	7.50	AIR-CHANGE	0.31	358.7	4662.7
FL3 Elevators	1.0	INT	0.0	0.00	0.0	0.00	AIR-CHANGE	0.31	196.5	2554.0
FL3 Stairs A	1.0	EXT	0.0	0.23	0.0	0.00	AIR-CHANGE	0.31	322.3	4190.4
FL3 Classroom E	1.0	EXT	0.0	0.59	41.1	0.25	AIR-CHANGE	0.31	946.1	12299.9
FL3 Toilet E	1.0	INT	0.0	0.57	0.0	0.00	NO-INFILT.	0.00	62.6	814.1
FL3 Elec	1.0	INT	0.0	0.49	0.0	0.00	NO-INFILT.	0.00	61.8	803.3
FL3 Corridor	1.0	EXT	90.0	0.49	0.0	0.00	AIR-CHANGE	0.31	1093.1	14209.7
FL3 Comp / AV	1.0	INT	0.0	0.49	0.0	7.50	NO-INFILT.	0.00	59.2	769.6
FL3 Supervisory	1.0	EXT	0.0	0.90	2.0	1.25	AIR-CHANGE	0.31	195.8	2544.8
FL3 Classroom F	1.0	EXT	90.0	0.59	43.7	0.25	AIR-CHANGE	0.31	1005.6	13073.0

Spaces on floor: FL4 Ground Flr

FL4	Classroom A	1.0	EXT	90.0	0.59	38.2	0.25	AIR-CHANGE	0.31	877.5	11407.1
FL4	Classroom B	1.0	EXT	90.0	0.59	64.4	0.25	AIR-CHANGE	0.31	1480.3	19244.5
FL4	Classroom C	1.0	EXT	0.0	0.59	46.8	0.25	AIR-CHANGE	0.31	1077.2	14003.1
FL4	Classroom D	1.0	EXT	90.0	0.59	41.3	0.25	AIR-CHANGE	0.31	949.2	12339.5
FL4	Stairs B	1.0	EXT	0.0	0.23	0.0	0.00	AIR-CHANGE	0.31	349.1	4538.8
FL4	Toilet C	1.0	INT	0.0	0.57	0.0	0.00	NO-INFILT.	0.00	119.1	1548.9
FL4	Comp / AV	1.0	INT	0.0	0.49	0.0	7.50	NO-INFILT.	0.00	67.2	873.1
FL4	Staff Lunch / Conf	1.0	EXT	-90.0	0.51	34.2	0.00	AIR-CHANGE	0.31	615.8	8005.2
FL4	Elevators	1.0	INT	0.0	0.00	0.0	0.00	NO-INFILT.	0.00	196.5	2554.0
FL4	Stairs A	1.0	EXT	0.0	0.23	0.0	0.00	AIR-CHANGE	0.31	322.3	4190.4
FL4	Classroom E	1.0	EXT	0.0	0.59	39.2	0.25	AIR-CHANGE	0.31	901.1	11713.8
FL4	Toilet D	1.0	INT	0.0	0.57	0.0	0.00	NO-INFILT.	0.00	107.7	1400.3
FL4	Elec	1.0	INT	0.0	0.49	0.0	0.00	NO-INFILT.	0.00	61.8	803.3
FL4	Corridor	1.0	EXT	90.0	0.49	0.0	0.00	AIR-CHANGE	0.31	1032.4	13421.4

PS 33X Jerome Ave 3

DOE-2.2-48r 8/17/2018 11:11:54 BDL RUN 1

REPORT- LV-B Summary of Spaces								WEATH	ER FILE- NEW	YORK LAGUARDI	NY
										-(CONTINUED)	
FL4 Staff	1.0	INT	0.0	0.57	0.0	0.00	NO-INFILT.	0.00	76.1	989.5	
FL4 Classroom F	1.0	EXT	90.0	0.59	35.5	0.25	AIR-CHANGE	0.31	817.3	10624.6	
Spaces on floor: FL5 Ground Flr											
FL5 Classroom A	1.0	EXT	0.0	0.59	33.7	0.25	AIR-CHANGE	0.27	775.0	11624.8	
FL5 Classroom B	1.0	EXT	90.0	0.59	41.3	0.25	AIR-CHANGE	0.27	949.2	14237.9	
FL5 Stairs B	1.0	EXT	0.0	0.23	0.0	0.00	AIR-CHANGE	0.27	349.1	5237.1	
FL5 Toilet A	1.0	EXT	0.0	0.57	0.0	0.00	NO-INFILT.	0.00	119.1	1787.2	
FL5 Toilet B	1.0	EXT	0.0	0.57	0.0	0.00	NO-INFILT.	0.00	79.6	1194.0	
FL5 Classroom C	1.0	EXT	-90.0	0.59	29.5	0.25	AIR-CHANGE	0.27	679.5	10192.0	
FL5 Elevators	1.0	INT	0.0	0.00	0.0	0.00	NO-INFILT.	0.00	196.5	2946.9	
FL5 Stairs A	1.0	EXT	0.0	0.23	0.0	0.00	AIR-CHANGE	0.27	322.3	4835.0	
FL5 Library	1.0	EXT	0.0	0.54	15.5	0.50	AIR-CHANGE	0.27	901.1	13515.9	
FL5 Toilet C	1.0	EXT	0.0	0.57	0.0	0.00	NO-INFILT.	0.00	107.7	1615.7	
FL5 Elec	1.0	EXT	0.0	0.49	0.0	0.00	NO-INFILT.	0.00	61.8	926.9	
FL5 Corridor	1.0	EXT	90.0	0.49	0.0	0.00	AIR-CHANGE	0.27	1032.4	15486.3	
FL5 Classroom D	1.0	EXT	180.0	0.59	78.1	0.25	AIR-CHANGE	0.27	1795.3	26929.1	
FL5 Boiler Room	1.0	EXT	90.0	0.49	0.0	0.00	AIR-CHANGE	0.27	1339.7	20096.0	
FL5 Closets	1.0	EXT	0.0	0.99	0.0	0.00	NO-INFILT.	0.00	347.1	5206.7	
Spaces on floor: R Ground Flr											
R Elevator Machine Room	1.0	EXT	180.0	0.49	0.0	0.00	AIR-CHANGE	0.34	403.0	4836.5	
R Elevators	1.0	EXT	0.0	0.00	0.0	0.00	AIR-CHANGE	0.34	178.1	2137.1	
R Corridor	1.0	EXT	90.0	0.49	0.0	0.00	AIR-CHANGE	0.34	65.5	786.5	
R Stairs A	1.0	EXT	90.0	0.23	0.0	0.00	AIR-CHANGE	0.34	298.7	3584.4	
BUILDING TOTALS					 1234.9				49128.7	652732.6	

DOE-2.2-48r 8/17/2018 11:11:54 BDL RUN 1

REPORT- LV-D Details of Exterior Surfaces

WEATHER FILE- NEW YORK LAGUARDI NY

NUMBER OF EXTERIOR SURFACES 183

(U-VALUE INCLUDES OUTSIDE FILM; WINDOW INCLUDES FRAME AND CURB, IF DEFINED)

	W I N D O W	s	W A L L		-WALL+WIN	DOWS-	
SURFACE	U-VALUE	AREA	U-VALUE	AREA	U-VALUE	AREA	AZIMUTH
	(BTU/HR-SQFT-F)	(SQFT)	(BTU/HR-SQFT-F)	(SQFT)	(BTU/HR-SQFT-F)	(SQFT)	
FL1 NE Wall (G.NNE1.E2)	0.450	45.00	0.060	62.90	0.223	107.90	NORTH-EAST
in space: FL1 Exercise Room							
FL1 NE Wall (G.NNE1.E4)	0.000	0.00	0.060	473.20	0.060	473.20	NORTH-EAST
in space: FL1 Exercise Room							
FL1 NE Wall (G.NNW10.E11)	0.000	0.00	0.060	42.90	0.060	42.90	NORTH-EAST
in space: FL1 Bike Storage							
FL1 NE Wall (G.E22.E24)	0.000	0.00	0.060	120.25	0.060	120.25	NORTH-EAST
in space: FL1 Can Wash							
FL1 NE Wall (G.NE23.E26)	0.000	0.00	0.060	68.90	0.060	68.90	NORTH-EAST
in space: FL1 Dietition's Office	9						
FL1 NE Wall (G.NE24.E27)	0.000	0.00	0.060	180.05	0.060	180.05	NORTH-EAST
in space: FL1 Locker Rooms							
FL1 NE Wall (G.NNE25.E29)	0.000	0.00	0.060	95.55	0.060	95.55	NORTH-EAST
in space: FL1 Toilet B							
FL2 NE Wall (G.E1.E1)	0.000	0.00	0.060	462.15	0.060	462.15	NORTH-EAST
in space: FL2 Classroom A							
FL2 NE Wall (G.N6.E8)	0.000	0.00	0.060	473.20	0.060	473.20	NORTH-EAST
in space: FL2 Classroom D							
FL2 NE Wall (G.W15.E19)	0.000	0.00	0.060	113.75	0.060	113.75	NORTH-EAST
in space: FL2 Classroom E							
FL2 NE Wall (G.C18.E20)	0.450	45.00	0.060	65.50	0.219	110.50	NORTH-EAST
in space: FL2 Corridor							
FL3 NE Wall (G.E1.E1)	0.000	0.00	0.060	462.15	0.060	462.15	NORTH-EAST
in space: FL3 Classroom A							
FL3 NE Wall (G.N6.E8)	0.000	0.00	0.060	473.20	0.060	473.20	NORTH-EAST
in space: FL3 Classroom D							
FL3 NE Wall (G.W13.E18)	0.000	0.00	0.060	113.75	0.060	113.75	NORTH-EAST
in space: FL3 Classroom E	0.450	45 00	0.050	65 50	0 010	110 50	
FL3 NE Wall (G.CI6.E19)	0.450	45.00	0.060	65.50	0.219	110.50	NORTH-EAST
IN Space: FL3 Corridor	0.000	0 00	0 060	462 15	0 060	460 15	
FL4 NE Wall (G.EI.EI)	0.000	0.00	0.080	462.15	0.060	402.15	NORTH-EAST
IN SPACE: FL4 CLASSFOOM A	0.000	0 00	0.000	472 20	0.000	472 20	
in appage. EIA (leastroom D	0.000	0.00	0.080	4/3.20	0.080	4/3.20	NORIH-LASI
III SPACE: FL4 CLASSIOOM D FL4 NF Wall (C W13 F18)	0 000	0 00	0 060	113 75	0 060	113 75	N∩DTU_E3CT
in space. FL4 Classroom F	0.000	0.00	0.000	113.75	0.000	113.15	NOKIN-PADI
FLA NE Wall (C NE16 E19)	0 450	45 00	0 060	65 50	0 219	110 50	NORTH-FACT
in space. FL4 Corridor	0.100	-3.00	0.000	03.50	0.213	110.50	TOWIN-PROT
FL5 NE Wall (C N2 E5)	0 000	0 00	0 060	546 00	0 060	546 00	NORTH-FACT
103 ND NGIT (G.M2.03)	0.000	0.00	0.000	540.00	0.000	540.00	WOLUTH-RUDI

in space:	FL5 Classroom B							
FL5 NE Wall	(G.W9.E22)	0.000	0.00	0.060	131.25	0.060	131.25	NORTH-EAST
in space:	FL5 Library							
FL5 NE Wall	(G.NE12.E26)	0.450	45.00	0.060	82.50	0.198	127.50	NORTH-EAST
in space:	FL5 Corridor							
FL5 NE Wall	(G.E14.E31)	0.000	0.00	0.060	533.25	0.060	533.25	NORTH-EAST
in space:	FL5 Boiler Room							
R NE Wall (G.E1.E2)	0.000	0.00	0.060	235.20	0.060	235.20	NORTH-EAST
in space:	R Elevator Machine Room							

PS 33X Jerome Ave 3

DOE-2.2-48r 8/17/2018 11:11:54 BDL RUN 1

REPORT- LV-D Details of Exterior Sur	faces				WEATHER FI	LE- NEW YORK LA	GUARDI NY
R NE Wall (G.W4.E11)	0.000	0.00	0.060	197.40	0.060	(CONTIN 197.40	NORTH-EAST
in space: R Stairs A							
Exterior Wall 145	0.450	180.00	0.060	212.60	0.239	392.60	SOUTH-EAST
in space: FL2 Classroom F							
Exterior Wall 149	0.000	0.00	0.060	0.65	0.060	0.65	SOUTH-EAST
in space: FL2 Classroom F							
Exterior Wall 150	0.000	0.00	0.060	0.65	0.060	0.65	SOUTH-EAST
in space: FL2 Classroom F							
FL1 SE Wall (G.SE21.E23)	0.450	21.00	0.060	219.50	0.095	240.50	SOUTH-EAST
in space: FL1 Refuse Recycling							
FL3 SE Wall (G.SE2.E4)	0.450	180.00	0.060	200.25	0.245	380.25	SOUTH-EAST
in space: FL3 Classroom B							
Exterior Wall 152	0.000	0.00	0.060	0.65	0.060	0.65	SOUTH-EAST
in space: FL3 Classroom B							
Exterior Wall 153	0.000	0.00	0.060	0.65	0.060	0.65	SOUTH-EAST
in space: FL3 Classroom B							
Exterior Wall 154	0.000	0.00	0.060	0.65	0.060	0.65	SOUTH-EAST
in space: FL3 Classroom B							
FL3 SE Wall (G.S3.E7)	0.450	180.00	0.060	213.90	0.239	393.90	SOUTH-EAST
in space: FL3 Classroom C							
Exterior Wall 143	0.000	0.00	0.060	175.50	0.060	175.50	SOUTH-EAST
in space: FL1 Storage							
FL3 SE Wall (G.N6.E11)	0.000	0.00	0.060	40.95	0.060	40.95	SOUTH-EAST
in space: FL3 Classroom D							
FL3 SE Wall (G.W13.E17)	0.000	0.00	0.060	33.15	0.060	33.15	SOUTH-EAST
in space: FL3 Classroom E							
Exterior Wall 144	0.450	21.00	0.060	89.50	0.135	110.50	SOUTH-EAST
in space: FL1 Receiving				40.05		40.05	
FLI SE Wall (G.NNEL.E3)	0.000	0.00	0.060	40.95	0.060	40.95	SOUTH-EAST
in space: FLI Exercise Room	0 450	100.00	0.000	010 60	0 0 0 0	200 60	
Exterior Wall 151	0.450	180.00	0.060	212.60	0.239	392.60	SOUTH-EAST
In space: FL3 Classroom F	0 000	0 00	0.000	0.65	0.000	0.65	
Exterior Wall 155	0.000	0.00	0.060	0.65	0.060	0.65	SOUTH-EAST
In space: FL3 Classroom F	0 000	0 00	0 060	0 65	0 060	0 65	
in apage. EL2 Claggroom E	0.000	0.00	0.080	0.05	0.000	0.05	SOUTH-EAST
III Space: FLS Classioom F	0 000	0 00	0 060	0 65	0 060	0 65	
in grade: EL2 Classroom P	0.000	0.00	0.000	0.05	0.000	0.05	SOOTH-BASI
TH SPACE; FUZ CLASSIOOM B FLA CF Wall (C CF2 F4)	0 450	210 00	0 060	330 15	0 212	540 15	2∩IITU_E3.CT
THE DE MAIL (G.DEA.ET)	0.100	210.00	0.000	330.13	0.212	210.12	POOLU-PUPI

	New York City	Public School	PS 33X En	ergy Model Re	eport		
in space: FL4 Classroom B Exterior Wall 158	0.000	0.00	0.060	0.65	0.060	0.65	SOUTH-EAST
in space: FL4 Classroom B Exterior Wall 159 in space: FL4 Classroom B	0.000	0.00	0.060	0.65	0.060	0.65	SOUTH-EAST
Exterior Wall 160	0.000	0.00	0.060	0.65	0.060	0.65	SOUTH-EAST
FL4 SE Wall (G.S3.E7)	0.450	150.00	0.060	243.90	0.209	393.90	SOUTH-EAST
In space: FL4 Classroom C Exterior Wall 146	0.450	180.00	0.060	200.25	0.245	380.25	SOUTH-EAST
in space: FL2 Classroom B FL4 SE Wall (G.N6.E11)	0.000	0.00	0.060	40.95	0.060	40.95	SOUTH-EAST
in space: FL4 Classroom D FL4 SE Wall (G.W13.E17)	0.000	0.00	0.060	33.15	0.060	33.15	SOUTH-EAST
in space: FL4 Classroom E Exterior Wall 147	0.000	0.00	0.060	0.65	0.060	0.65	SOUTH-EAST
in space: FL2 Classroom B Exterior Wall 148	0.000	0.00	0.060	0.65	0.060	0.65	SOUTH-EAST
in space: FL2 Classroom B							

DOE-2.2-48r 8/17/2018 11:11:54 BDL RUN 1

REPORT- LV-D Details of Exterior Surfa	aces				WEATHER FIL	E- NEW YORK LA	GUARDI NY
Exterior Wall 157	0.450	120.00	0.060	177.70	0.218	297.70	SOUTH-EAST
in space: FL4 Classroom F							
Exterior Wall 161	0.000	0.00	0.060	0.65	0.060	0.65	SOUTH-EAST
in space: FL4 Classroom F							
Exterior Wall 162	0.000	0.00	0.060	0.65	0.060	0.65	SOUTH-EAST
in space: FL4 Classroom F							
FL5 SE Wall (G.SSW1.E3)	0.450	120.00	0.060	207.00	0.203	327.00	SOUTH-EAST
in space: FL5 Classroom A							
FL2 SE Wall (G.S3.E7)	0.450	180.00	0.060	213.90	0.239	393.90	SOUTH-EAST
in space: FL2 Classroom C							
FL5 SE Wall (G.N2.E8)	0.000	0.00	0.060	47.25	0.060	47.25	SOUTH-EAST
in space: FL5 Classroom B							
FL5 SE Wall (G.W9.E21)	0.000	0.00	0.060	38.25	0.060	38.25	SOUTH-EAST
in space: FL5 Library							
FL1 SE Wall (G.E22.E25)	0.000	0.00	0.060	132.60	0.060	132.60	SOUTH-EAST
in space: FL1 Can Wash							
FL2 SE Wall (G.N6.E11)	0.000	0.00	0.060	40.95	0.060	40.95	SOUTH-EAST
in space: FL2 Classroom D							
FL5 SE Wall (G.SE13.E29)	0.450	240.00	0.060	517.50	0.184	757.50	SOUTH-EAST
in space: FL5 Classroom D							
FL2 SE Wall (G.W15.E18)	0.000	0.00	0.060	33.15	0.060	33.15	SOUTH-EAST
in space: FL2 Classroom E							
FL5 SE Wall (G.E14.E33)	0.450	240.00	0.060	471.75	0.192	711.75	SOUTH-EAST
in space: FL5 Boiler Room							
R SE Wall (G.El.El)	0.000	0.00	0.060	355.80	0.060	355.80	SOUTH-EAST
in space: R Elevator Machine Room				~~ 45		~~	
FLI SE WAII (G.WSWIZ.EI7)	0.000	0.00	0.060	33.15	0.060	33.15	SOUTH-EAST
in space: FLI Supervisory Office	0 000	0 00	0.000	140.40	0.000	140.40	
R SE WALL (G.SSE3.E9)	0.000	0.00	0.060	140.40	0.060	140.40	SOUTH-EAST

	<u>item i oik eity</u>	I done beneo	110 3311 Lii	engy model ne	epone		
in space: R Corridor							
FL1 SE Wall (G.SSE15.E21)	0.510	277.50	0.060	626.00	0.199	903.50	SOUTH-EAST
in space: FL1 Cafeteria							
FL2 SE Wall (G.E1.E3)	0.450	180.00	0.060	206.75	0.242	386.75	SOUTH-EAST
in space: FL2 Classroom A							
FL3 SE Wall (G.E1.E3)	0.450	180.00	0.060	206.75	0.242	386.75	SOUTH-EAST
in space: FL3 Classroom A							
FL4 SE Wall (G.E1.E3)	0.450	120.00	0.060	201.10	0.206	321.10	SOUTH-EAST
in space: FL4 Classroom A							
R SW Wall (G.W4.E13)	0.000	0.00	0.060	309.01	0.060	309.01	SOUTH
in space: R Stairs A							
FL1 SW Wall (G.WSW14.E20)	0.000	0.00	0.060	139.13	0.060	139.13	SOUTH
in space: FL1 Boys							
FL4 SW Wall (G.NE16.E20)	0.450	30.00	0.060	74.00	0.173	104.00	SOUTH-WEST
in space: FL4 Corridor							
FL1 SW Wall (G.C28.E30)	0.000	0.00	0.060	12.35	0.060	12.35	SOUTH-WEST
in space: FL1 Corridor							
FL1 SW Wall (G.SW13.E18)	0.000	0.00	0.060	104.00	0.060	104.00	SOUTH-WEST
in space: FL1 Vestibule B							
FL1 SW Wall (G.W11.E13)	0.000	0.00	0.060	150.15	0.060	150.15	SOUTH-WEST
in space: FL1 Vestibule A							
FL5 SW Wall (G.SSW1.E2)	0.450	30.00	0.060	503.25	0.082	533.25	SOUTH-WEST
in space: FL5 Classroom A							
FL3 SW Wall (G.S3.E6)	0.450	30.00	0.060	432.15	0.086	462.15	SOUTH-WEST
in space: FL3 Classroom C							
FL2 SW Wall (G.C18.E21)	0.450	30.00	0.060	74.00	0.173	104.00	SOUTH-WEST
in space: FL2 Corridor							
FL5 SW Wall (G.N2.E7)	0.000	0.00	0.060	131.25	0.060	131.25	SOUTH-WEST
in space: FL5 Classroom B							

DOE-2.2-48r 8/17/2018 11:11:54 BDL RUN 1

REPORT- LV-D Details of Exterior Surf.	aces				WEATHER FILE	- NEW YORK LA	GUARDI NY
FL2 SW Wall (G.S3.E6)	0.450	30.00	0.060	432.15	0.086	462.15	SOUTH-WEST
in space: FL2 Classroom C FL5 SW Wall (G.W9.E20)	0.450	90.00	0.060	463.50	0.124	553.50	SOUTH-WEST
in space: FL5 Library					0.050		
in space: FL3 Classroom D	0.000	0.00	0.060	113.75	0.060	113.75	SOUTH-WEST
FL1 SW Wall (G.WSW12.E16)	0.450	90.00	0.060	156.35	0.203	246.35	SOUTH-WEST
In space: FLI Supervisory Office FL4 SW Wall (G.S3.E6)	0.450	30.00	0.060	432.15	0.086	462.15	SOUTH-WEST
in space: FL4 Classroom C	0 450	30 00	0 060	90.00	0 159	120 00	COUTU-WECT
in space: FL5 Corridor	0.450	30.00	0.000	30.00	0.138	120.00	SOUTH-WEST
FL3 SW Wall (G.W13.E16)	0.450	60.00	0.060	419.70	0.109	479.70	SOUTH-WEST
FL1 SW Wall (G.SSE15.E22)	0.510	52.50	0.060	271.20	0.133	323.70	SOUTH-WEST
in space: FL1 Cafeteria FL4 SW Wall (G.N6.E10)	0.000	0.00	0.060	113.75	0.060	113.75	SOUTH-WEST
in space: FL4 Classroom D							
FL2 SW Wall (G.N6.E10)	0.000	0.00	0.060	113.75	0.060	113.75	SOUTH-WEST

New York City Public School PS 33X Energy Model Report

in space:	FL2 Classroom D	0 450	60.00	0.000	410 50	0 1 0 0	480.80	
FL4 SW Wall	(G.WI3.EI6) EI4 Glaggmoom E	0.450	60.00	0.060	419.70	0.109	4/9./0	SOUTH-WEST
D GW Wall (0 000	0 00	0 060	55 90	0 060	55 90	COUTU WEOT
K SW Wall (G.BI.BT) D. Elevator Maghine Deem	0.000	0.00	0.080	55.60	0.080	55.60	SOUTH-WEST
IN Space:	(C W2 FE)	0 000	0 00	0 060	112 10	0 060	112 10	
FLI SW Wall	(G.WZ.ES) EI1 Chaima B	0.000	0.00	0.080	113.10	0.080	113.10	SOUTH-WEST
III Space:	FLI SLAIIS B	0 450	20.00	0 060	74 00	0 172	104 00	
in anado.	(G.CIO.E20) FI 2 Corridor	0.450	30.00	0.080	74.00	0.175	104.00	SOUTH-WEST
FT.2 GW Wall	(C W15 F17)	0 450	90 00	0 060	389 70	0 134	479 70	SUILTR-MEST
in grade.	(G.WIJ.EI/) FL2 Classroom F	0.450	90.00	0.000	369.70	0.134	1/3./0	SOOIH-WEST
D CW Wall (0 000	0 00	0 060	67 91	0 060	67 94	COUTU_WECT
in angeo.	B. Corridor	0.000	0.00	0.000	07.01	0.000	07.01	SOOIH-WESI
FIS NW Wall	(G NE F9)	0 450	150 00	0 060	231 55	0 214	381 55	NODTU_WEST
in grade.	(G.NO.ES) FL3 Classroom D	0.450	130.00	0.000	231.35	0.214	301.33	NORTH-WEST
FT.4 NW Wall	(C NW7 F12)	0 450	36 00	0 060	128 45	0 146	164 45	NORTH-WEST
in gnace.	FL4 Stairs B	0.150	50.00	0.000	120.15	0.110	101.15	NORTH WEDT
FI.4 NW Wall	(G NW10 F13)	0 450	120 00	0 060	355 80	0 159	475 80	NORTH-WEST
in space:	FL4 Staff Lunch / Conf	0.150	120.00	0.000	555.00	0.135	1/5:00	NORTH MEDI
FL4 NW Wall	(G_NW12_E14)	0.450	36.00	0.060	116.10	0.153	152.10	NORTH-WEST
in space:	FL4 Stairs A					01200		
FL4 NW Wall	(G.W13.E15)	0.450	150.00	0.060	232.85	0.213	382.85	NORTH-WEST
in space:	FL4 Classroom E							
FL2 NW Wall	(G.W15.E16)	0.450	150.00	0.060	232.85	0.213	382.85	NORTH-WEST
in space:	FL2 Classroom E							
FL2 NW Wall	(G.E1.E2)	0.000	0.00	0.060	40.95	0.060	40.95	NORTH-WEST
in space:	FL2 Classroom A							
FL3 NW Wall	(G.NW7.E12)	0.450	36.00	0.060	128.45	0.146	164.45	NORTH-WEST
in space:	FL3 Stairs B							
FL3 NW Wall	(G.NW10.E13)	0.450	60.00	0.060	201.95	0.150	261.95	NORTH-WEST
in space:	FL3 MDF							
FL3 NW Wall	(G.NW12.E14)	0.450	36.00	0.060	116.10	0.153	152.10	NORTH-WEST
in space:	FL3 Stairs A							
FL3 NW Wall	(G.W13.E15)	0.450	150.00	0.060	232.85	0.213	382.85	NORTH-WEST
in space:	FL3 Classroom E							
FL1 NW Wall	(G.W11.E14)	0.450	50.00	0.060	83.25	0.207	133.25	NORTH-WEST
in space:	FL1 Vestibule A							
FL1 NW Wall	(G.WSW12.E15)	0.000	0.00	0.060	139.75	0.060	139.75	NORTH-WEST
in space:	FL1 Supervisory Office							

PS 33X Jerome Ave 3

DOE-2.2-48r 8/17/2018 11:11:54 BDL RUN 1

REPORT- LV-I	D Details of Exterior Surfaces				۲	VEATHER FILE- NEW	YORK LAC	JUARDI NY
FL5 NW Wall	(G.SSW1.E1)	0.000	0.00	0.060	38.25	0.060	38.25	NORTH-WEST
in space:	FL5 Classroom A							
FL1 NW Wall	(G.NW4.E7)	0.450	30.00	0.060	195.55	0.112	225.55	NORTH-WEST
in space:	FL1 Parents/Community							
FL1 NW Wall	(G.NW5.E8)	0.000	0.00	0.060	105.95	0.060	105.95	NORTH-WEST
in space:	FL1 Toilet A							
FL1 NW Wall	(G.NNE25.E28)	0.000	0.00	0.060	40.95	0.060	40.95	NORTH-WEST
in space:	FL1 Toilet B							
FL5 NW Wall	(G.N2.E6)	0.450	150.00	0.060	290.25	0.193	440.25	NORTH-WEST

					-			
in space:	FL5 Classroom B	0 450	00.00	0.000	100.05	0.004	212 05	
FL3 NW Wall	(G.NWI8.E21) EL 2 Cuperni gerry	0.450	90.00	0.060	123.85	0.224	213.85	NORTH-WEST
TH Space:	(C C C E)	0 000	0 00	0 060	22 15	0 060	22 15	
in space.	FL2 Classroom C	0.000	0.00	0.000	33.13	0.000	55.15	MORITI-WEDI
FL5 NW Wall	(C NW3 E10)	0 450	36 00	0 060	153 75	0 134	189 75	NORTH-WEST
in space:	FL5 Stairs B	0.150	50.00	0.000	100.70	0.131	105.75	NORTH MEDI
FL5 NW Wall	(G.NW6.E14)	0.450	180.00	0.060	369.00	0.188	549.00	NORTH-WEST
in space:	FL5 Classroom C						0 - 20 - 0 - 0 - 0	
FL5 NW Wall	(G.NW8.E17)	0.450	36.00	0.060	139.50	0.140	175.50	NORTH-WEST
in space:	FL5 Stairs A							
FL5 NW Wall	(G.W9.E19)	0.450	150.00	0.060	291.75	0.193	441.75	NORTH-WEST
in space:	FL5 Library							
FL1 NW Wall	(G.NW6.E9)	0.450	60.00	0.060	77.80	0.230	137.80	NORTH-WEST
in space:	FL1 Exam Room							
FL1 NW Wall	(G.NW7.E10)	0.000	0.00	0.060	169.65	0.060	169.65	NORTH-WEST
in space:	FL1 Stairs A							
FL3 NW Wall	(G.E1.E2)	0.000	0.00	0.060	40.95	0.060	40.95	NORTH-WEST
in space:	FL3 Classroom A							
FL4 NW Wall	(G.E1.E2)	0.000	0.00	0.060	40.95	0.060	40.95	NORTH-WEST
in space:	FL4 Classroom A							
FL1 NW Wall	(G.NNE1.E1)	0.450	180.00	0.060	200.90	0.245	380.90	NORTH-WEST
in space:	FL1 Exercise Room							
FL2 NW Wall	(G.N6.E9)	0.450	150.00	0.060	231.55	0.214	381.55	NORTH-WEST
in space:	FL2 Classroom D							
FLI NW Wall	(G.NNW10.E12)	0.000	0.00	0.060	109.85	0.060	109.85	NORTH-WEST
in space:	FLI Bike Storage		0.00	0.000	48.05	0.000	48.05	
FL5 NW Wall	(G.E14.E32)	0.000	0.00	0.060	47.25	0.060	47.25	NORTH-WEST
in space:	FLS BOILER ROOM	0 000	0.00	0.000	164 05	0.000	154 05	
FLI NW Wall	(G.WZ.EO) Ell Staing P	0.000	0.00	0.080	154.05	0.060	154.05	NORTH-WEST
TH Space:	(C NW7 E12)	0 450	19 00	0 060	146 45	0 102	164 45	
in space.	FL2 Stairs B	0.450	10.00	0.000	140.43	0.103	101.13	MORITI-WEDI
FL4 NW Wall	(G, S3, E5)	0.000	0.00	0.060	33,15	0.060	33,15	NORTH-WEST
in space:	FL4 Classroom C	0.000	0.00	0.000	55115		55115	NORTH ADDI
R NW Wall ((G.E1.E3)	0.000	0.00	0.060	126.00	0.060	126.00	NORTH-WEST
in space:	R Elevator Machine Room							
FL3 NW Wall	(G.S3.E5)	0.000	0.00	0.060	33.15	0.060	33.15	NORTH-WEST
in space:	FL3 Classroom C							
R NW Wall ((G.NW2.E6)	0.000	0.00	0.060	229.80	0.060	229.80	NORTH-WEST
in space:	R Elevators							
FL2 NW Wall	(G.NW11.E13)	0.450	37.50	0.060	60.65	0.209	98.15	NORTH-WEST
in space:	FL2 Toilet D							
FL2 NW Wall	(G.NW12.E14)	0.450	142.50	0.060	235.15	0.208	377.65	NORTH-WEST
in space:	FL2 Reading / Speech Resource							
FL4 NW Wall	(G.N6.E9)	0.450	150.00	0.060	231.55	0.214	381.55	NORTH-WEST
in space:	FL4 Classroom D							
R NW Wall (C	G.W4.E12)	0.000	0.00	0.060	140.40	0.060	140.40	NORTH-WEST
in space:	R Stairs A							

PS 33X Jerome Ave 3

REPORT- LV-D Details of Exterior Surfaces

DOE-2.2-48r 8/17/2018 11:11:54 BDL RUN 1

WEATHER FILE- NEW YORK LAGUARDI NY

						(CONTIN	UED)
FL2 NW Wall (G.NW14.E15)	0.450	36.00	0.060	116.10	0.153	152.10	NORTH-WEST
in space: FL2 Stairs A							
FLI NW Wall (G.WSW14.E19)	0.000	0.00	0.060	33.15	0.060	33.15	NORTH-WEST
in space: FLI Boys							
Exterior Wall 173	0.000	0.00	0.055	284.78	0.055	284.78	FLOOR
in space: FLI Servery				40.50		40.50	
Exterior Wall 1/4	0.000	0.00	0.055	48.72	0.055	48.72	FLOOR
in space: FLI Janitor's Closet				<u> </u>		CE 10	
Exterior Wall 167	0.000	0.00	0.055	65.40	0.055	65.40	FLOOR
in space: FLI vestibule B				145 00		145 00	
Exterior Wall 1/5	0.000	0.00	0.055	145.02	0.055	145.02	FLOOR
in space: FLI Refuse Recycling				07 60		0	
Exterior Wall 164	0.000	0.00	0.055	97.60	0.055	97.60	FLOOR
in space: FLI Bike Storage				110.00			
Exterior Wall 165	0.000	0.00	0.055	118.39	0.055	118.39	FLOOR
in space: FLI Vestibule A							
Exterior Wall 176	0.000	0.00	0.055	94.35	0.055	94.35	FLOOR
in space: FLI Can Wash				150.05		453.05	
Exterior Wall 168	0.000	0.00	0.055	153.25	0.055	153.25	FLOOR
in space: FLI Boys							
Exterior Wall 177	0.000	0.00	0.055	75.67	0.055	75.67	FLOOR
in space: FLI Dietition's Office							
Exterior Wall 166	0.000	0.00	0.055	203.71	0.055	203.71	FLOOR
in space: FLI Supervisory Office				1.5.4.5.5			
Exterior Wall 1/8	0.000	0.00	0.055	164.66	0.055	164.66	FLOOR
in space: FLI Locker Rooms				1000 56		1000 54	
Exterior Wall 163	0.000	0.00	0.055	1283.56	0.055	1283.56	FLOOR
in space: FLI Exercise Room				1001 56		1001 54	
Exterior Wall 169	0.000	0.00	0.055	1981.56	0.055	1981.56	FLOOR
in space: FLI Cafeteria							
Exterior Wall 1/9	0.000	0.00	0.055	74.24	0.055	74.24	FLOOR
In space: FLI TOILET B	0 000	0.00	0 055	1 60 40	0 055	1.00 4.0	
Exterior Wall 180	0.000	0.00	0.055	168.42	0.055	168.42	FLOOR
In space: FLI Pot wash	0 000	0 00	0 055	E 41 0 4	0 055	E 41 04	
Exterior Wall 181	0.000	0.00	0.055	541.24	0.055	541.24	FLOOR
in space: FLI Prep/warming	0 000	0.00	0 055	105 43	0 055	105 40	
Exterior wall 1/0	0.000	0.00	0.055	125.43	0.055	125.43	FLOOR
In space: FLI GITIS	0 000	0 00	0 055	1100 00	0 055	1100 00	HI OOD
in grade. EL1 Corridor	0.000	0.00	0.055	1102.90	0.055	1102.90	FLOOR
Futorier Mall 171	0 000	0 00	0 055	64 16	0 055	64 16	FT OOD
in apage. Ell Studenta	0.000	0.00	0.055	04.10	0.055	04.10	FLOOR
Exterior Wall 192	0 000	0 00	0 055	12/ 99	0 055	12/ 99	ET OOD
in grade: EL1 Storage	0.000	0.00	0.055	124.00	0.055	124.00	FLOOR
France: FLI Scorage	0 000	0 00	0 055	66 77	0 055	66 72	ET OOD
in apage. FI1 Fleatrical	0.000	0.00	0.055	00.75	0.055	00.75	FLOOR
Exterior Wall 194	0 000	0 00	0 055	79 62	0 055	79 62	ET OOD
in grace; FL1 Peceiving	0.000	0.00	0.055	70.02	0.055	78.02	FLOOR
Exterior Wall 142	0 000	0 00	0 032	103 10	0 032	103 10	ROOF
in space. FL1 Stairs B	0.000	0.00	0.052	103.10	0.034	103.10	ROOP
FL5 Roof (G NW3 F11)	0 000	0 00	0 032	349 14	0 032	349 14	ROOF
in space: FL5 Stairs B	0.000	0.00	0.002	5-29-1-7	0.032	319.11	NOOF
FL5 Roof (G.C4.E12)	0.000	0.00	0.032	119 15	0.032	110 15	ROOF
in space: FL5 Toilet A	0.000	0.00	0.002		0.054	110.13	

New York City Public School PS 33X Energy Model Report

FL5 Roof (G.E14.E34) in space: FL5 Boiler Room	0.000	0.00	0.032	1339.73	0.032	1339.73	ROOF
FL5 Roof (G.C15.E35) in space: FL5 Closets	0.000	0.00	0.032	347.11	0.032	347.11	ROOF
-							
					0 /1 = /0010		
PS 33X Jerome Ave 3				DOE-2.2-48r	8/17/2018	11:11:54	BDL RUN I
REPORT- LV-D Details of Exterior Surfa	ices			ъ ъ	VEATHER FILE-	NEW YORK LA	GUARDI NY UED)
FL5 Roof (G.C5.E13)	0.000	0.00	0.032	79.60	0.032	79.60	ROOF
FL5 Roof (G.W9.E23)	0.000	0.00	0.032	901.06	0.032	901.06	ROOF
FL5 Roof (G.C10.E24)	0.000	0.00	0.032	107.72	0.032	107.72	ROOF
IN Space: FLS TOILET C FLS Roof (G.C11.E25)	0.000	0.00	0.032	61.79	0.032	61.79	ROOF
in space: FL5 Elec R Roof (G.E1.E5)	0.000	0.00	0.032	403.05	0.032	403.05	ROOF
in space: R Elevator Machine Room FL5 Roof (G.SSW1.E4)	0.000	0.00	0.032	774.99	0.032	774.99	ROOF
in space: FL5 Classroom A R Roof (G.NW2.E7)	0.000	0.00	0.032	178.10	0.032	178.10	ROOF
in space: R Elevators FL5 Roof (G.NW6.E15)	0.000	0.00	0.032	679.47	0.032	679.47	ROOF
in space: FL5 Classroom C FL5 Roof (G.NE12.E28)	0.000	0.00	0.032	430.18	0.032	430.18	ROOF
in space: FL5 Corridor R Roof (G.SSE3.E10)	0.000	0.00	0.032	65.54	0.032	65.54	ROOF
in space: R Corridor Exterior Wall 141	0.000	0.00	0.032	298.98	0.032	298.98	ROOF
in space: FL5 Corridor FL5 Roof (G.N2.E9)	0.000	0.00	0.032	949.20	0.032	949.20	ROOF
in space: FL5 Classroom B FL5 Roof (G.SE13.E30)	0.000	0.00	0.032	1795.27	0.032	1795.27	ROOF
in space: FL5 Classroom D R Roof (G.W4.E14)	0.000	0.00	0.032	298.70	0.032	298.70	ROOF
in space: R Stairs A C Flr (B.NNE1.U1)	0.000	0.00	0.010	414.75	0.010	414.75	UNDERGRND
in space: C Gas Meter Room C NW Wall (B.NNE1.U2)	0.000	0.00	0.060	142.20	0.060	142.20	UNDERGRND
in space: C Gas Meter Room C NE Wall (B.NNE1.U3)	0.000	0.00	0.060	420.00	0.060	420.00	UNDERGRND
in space: C Gas Meter Room C Flr (B.W2.U4)	0.000	0.00	0.010	281.18	0.010	281.18	UNDERGRND
in space: C Mech Equipment Room C SW Wall (B.W2.U5)	0.000	0.00	0.060	104.40	0.060	104.40	UNDERGRND
in space: C Mech Equipment Room C NW Wall (B.W2.U6)	0.000	0.00	0.060	127.80	0.060	127.80	UNDERGRND
in space: C Mech Equipment Room C Flr (B.C3.U7)	0.000	0.00	0.010	130.72	0.010	130.72	UNDERGRND
in space: C Stairs B C Flr (B.NW4.U8)	0.000	0.00	0.010	333.40	0.010	333.40	UNDERGRND
in space: C Electrical Room							

Page 210 of 310

	1	New York City Public	Schoo	ol PS 33X Energy	Model Rep	ort			
C NW Wall (B.NW4.U9)	_	0.000	0.00	0.060	200.40	0.060	200.40	UNDERGRND	
in space: C Electrica	l Room								
C Flr (B.NW5.U10)		0.000	0.00	0.010	336.67	0.010	336.67	UNDERGRND	
C NW Wall (B.NW5.1111)	vice/sewage		0.00	0.060	238.80	0.060	238.80	UNDERGRND	
in space: C Water Ser	vice/Sewage	e Ejector	0.00	01000	200100		200.00	onplatonap	
C Flr (B.C6.U12)		0.000	0.00	0.010	186.71	0.010	186.71	UNDERGRND	
in space: C Elevators	1			0.010			21 6 00		
C FIr (B.W7.UI3)		0.000	0.00	0.010	316.82	0.010	316.82	UNDERGRND	
C SW Wall (B.W7.U14)		0.000	0.00	0.060	117.60	0.060	117.60	UNDERGRND	
in space: C Stairs A									
C NW Wall (B.W7.U15)		0.000	0.00	0.060	138.00	0.060	138.00	UNDERGRND	
in space: C Stairs A		0.000	0 00	0 010	247 15	0 010	247 15		
in space: C Sprinkler	Booster Pi	0.000	0.00	0.010	347.15	0.010	347.15	UNDERGRIND	
PS 33X Jerome Ave 3					DOE-2.2-48	r 8/17/2018	11:11:54	BDL RUN	1
REPORT- LV-D Details of	Exterior 9	urfaces				WEATHER FILE-	NEW YORK LA	TIARDT NY	
							(CONTIN	UED)	
SURFACE		W I N D O W S · U-VALUE (BTU/HR-SQFT-F)	AREA (SQFT)	W A L L U-VALUE (BTU/HR-SQFT-F)	 AREA (SQFT) (W A L L + W I N U-VALUE BTU/HR-SQFT-F)	D O W S- Area (SQFT)	AZIMUTH	
C SE Wall (B.SW8.U17)		0.000	0.00	0.060	157.20	0.060	157.20	UNDERGRND	
in space: C Sprinkler	Booster Pu	mp 0.000	0 00	0.060	157 20	0 060	157 20		
in space: C Sprinkler	Booster Pu		0.00	0.060	157.20	0.080	157.20	UNDERGRIND	
C SW Wall (B.SW8.U19)		0.000	0.00	0.060	318.00	0.060	318.00	UNDERGRND	
in space: C Sprinkler	Booster Pu	mp							
C Flr (B.SE9.U20)		0.000	0.00	0.010	758.28	0.010	758.28	UNDERGRND	
C NE Wall (B.SE9.U21)		0.000	0.00	0.060	120.00	0.060	120.00	UNDERGRND	
in space: C Corridor									
C SE Wall (B.SE9.U22)		0.000	0.00	0.060	847.20	0.060	847.20	UNDERGRND	
in space: C Corridor									
PS 33X Jerome Ave 3					DOE-2.2-48	r 8/17/2018	11:11:54	BDL RUN	1
REPORT- LV-D Details of	Exterior &	Surfaces				WEATHER FILE-	NEW YORK LA	GUARDI NY	
							(CONTIN	UED)	
	AVERAGE	AVERAGE	AV	VERAGE U-VALUE	WINDOW	WALL	WIN	DOW+WALL	
U-V	ALUE/WINDOW	IS U-VALUE/WALLS	й	ALLS+WINDOWS	AREA	AREA	Al	REA	
(BI	U/HR-SQFT-H) (BTU/HR-SQFT-F)	(E	BTU/HR-SQFT-F)	(SQFT)	(SQFT)	()	SQFT)	

REPORT- LV-H Details of	Windows			WE2	ATHER FILE- NE	W YORK LAGUARDI NY	
PS 33X Jerome Ave 3				DOE-2.2-48r	8/17/2018	11:11:54 BDL RUN	1
BUILDING	0.453	0.051	0.098	6287.00	46816.96	53103.97	
UNDERGRND	0.000	0.035	0.035	0.00	6194.48	6194.48	
WALLS+ROOFS	0.453	0.052	0.116	6287.00	33479.14	39766.14	
ALL WALLS	0.453	0.060	0.141	6287.00	24197.28	30484.29	
ROOF	0.000	0.032	0.032	0.00	9281.85	9281.85	
FLOOR	0.000	0.055	0.055	0.00	7143.36	7143.36	
NORTH-WEST	0.450	0.060	0.166	2420.00	6481.35	8901.35	
SOUTH-WEST	0.455	0.060	0.106	682.50	5207.59	5890.09	
SOUTH	0.000	0.060	0.060	0.00	448.14	448.14	
SOUTH-EAST	0.456	0.060	0.192	2959.50	5947.05	8906.55	
NORTH-EAST	0.450	0.060	0.074	225.00	6113.15	6338.15	

NUMBER OF WINDOWS 123

					LOCATION OF	ORIGIN				
		GLASS	GLASS	GLASS	IN	SURFACE	FRAME	CURB	FRAME	CURB
WINDOW		AREA	HEIGHT	WIDTH	COOF	DINATES	AR	EA	U-VA	LUE
NAME	MULTIPLIER	(SQFT)	(FT)	(FT)	X (FT)	Y (FT)	(SQF	г)	(BTU/HR-	SQFT-F)
Window 1	1.0	90.00	7.50	12.00	2.50	2.50	0.00	0.00	0.384	0.000
Window 2	1.0	90.00	7.50	12.00	17.30	2.50	0.00	0.00	0.384	0.000
Window 121	1.0	45.00	7.50	6.00	1.00	2.50	0.00	0.00	0.384	0.000
Window 5	1.0	30.00	7.50	4.00	11.00	2.50	0.00	0.00	0.384	0.000
Window 3	1.0	60.00	7.50	8.00	0.00	2.50	0.00	0.00	0.384	0.000
Window 7	1.0	50.00	8.00	6.25	0.00	0.00	0.00	0.00	0.384	0.000
Window 75	1.0	90.00	7.50	12.00	2.50	2.50	0.00	0.00	0.384	0.000
Window 77	1.0	52.50	7.50	7.00	3.75	2.50	0.00	0.00	0.384	0.000
Window 78	1.0	52.50	7.50	7.00	17.75	2.50	0.00	0.00	0.384	0.000
Window 79	1.0	52.50	7.50	7.00	32.75	2.50	0.00	0.00	0.384	0.000
Window 80	1.0	52.50	7.50	7.00	46.75	2.50	0.00	0.00	0.384	0.000
Window 81	1.0	67.50	7.50	9.00	58.75	2.50	0.00	0.00	0.384	0.000
Window 76	1.0	52.50	7.50	7.00	1.00	2.50	0.00	0.00	0.384	0.000
Window 82	1.0	21.00	7.00	3.00	14.00	0.00	0.00	0.00	0.384	0.000

	<u>New York Ci</u>	ty Public S	School]	PS 33X	Energy Mo	del Repo	<u>rt</u>			
Window 126	1.0	21.00	7.00	3.00	1.00	0.00	0.00	0.00	0.384	0.000
Window 90	1.0	90.00	7.50	12.00	2.00	2.50	0.00	0.00	0.384	0.000
Window 91	1.0	90.00	7.50	12.00	17.00	2.50	0.00	0.00	0.384	0.000
Window 131	1.0	90.00	7.50	12.00	2.75	2.50	0.00	0.00	0.384	0.000
Window 132	1.0	90.00	7.50	12.00	16.75	2.50	0.00	0.00	0.384	0.000
Window 74	1.0	30.00	7.50	4.00	2.50	2.50	0.00	0.00	0.384	0.000
Window 84	1.0	90.00	7.50	12.00	3.75	2.50	0.00	0.00	0.384	0.000
Window 85	1.0	90.00	7.50	12.00	17.75	2.50	0.00	0.00	0.384	0.000
Window 8	1.0	30.00	7.50	4.00	2.50	2.50	0.00	0.00	0.384	0.000
Window 9	1.0	60.00	7.50	8.00	10.50	2.50	0.00	0.00	0.384	0.000
Window 10	1.0	60.00	7.50	8.00	21.35	2.50	0.00	0.00	0.384	0.000
Window 44	1.0	18.00	3.00	6.00	3.00	10.00	0.00	0.00	0.384	0.000
Window 11	1.0	37.50	7.50	5.00	2.55	2.50	0.00	0.00	0.384	0.000
Window 12	1.0	52.50	7.50	7.00	0.00	2.50	0.00	0.00	0.384	0.000
Window 13	1.0	90.00	7.50	12.00	11.00	2.50	0.00	0.00	0.384	0.000
Window 51	1.0	18.00	3.00	6.00	3.00	0.00	0.00	0.00	0.384	0.000
Window 58	1.0	18.00	3.00	6.00	3.00	10.00	0.00	0.00	0.384	0.000
Window 14	1.0	60.00	7.50	8.00	0.00	2.50	0.00	0.00	0.384	0.000
Window 15	1.0	60.00	7.50	8.00	12.50	2.50	0.00	0.00	0.384	0.000
Window 16	1.0	30.00	7.50	4.00	24.50	2.50	0.00	0.00	0.384	0.000
Window 62	1.0	60.00	7.50	8.00	0.00	2.50	0.00	0.00	0.384	0.000
Window 66	1.0	30.00	7.50	4.00	30.00	2.50	0.00	0.00	0.384	0.000
Window 122	1.0	45.00	7.50	6.00	1.00	2.50	0.00	0.00	0.384	0.000
Window 70	1.0	30.00	7.50	4.00	2.00	2.50	0.00	0.00	0.384	0.000
Window 127	1.0	90.00	7.50	12.00	2.75	2.50	0.00	0.00	0.384	0.000
Window 128	1.0	90.00	7.50	12.00	16.75	2.50	0.00	0.00	0.384	0.000
Window 98	1.0	90.00	7.50	12.00	2.00	2.50	0.00	0.00	0.384	0.000
Window 99	1.0	90.00	7.50	12.00	17.00	2.50	0.00	0.00	0.384	0.000
Window 94	1.0	90.00	7.50	12.00	2.75	2.50	0.00	0.00	0.384	0.000
Window 95	1.0	90.00	7.50	12.00	16.75	2.50	0.00	0.00	0.384	0.000
Window 73	1.0	30.00	7.50	4.00	2.50	2.50	0.00	0.00	0.384	0.000
Window 92	1.0	90.00	7.50	12.00	3.75	2.50	0.00	0.00	0.384	0.000
Window 93	1.0	90.00	7.50	12.00	17.75	2.50	0.00	0.00	0.384	0.000
Window 17	1.0	60.00	7.50	8.00	2.50	2.50	0.00	0.00	0.384	0.000
Window 18	1.0	60.00	7.50	8.00	14.50	2.50	0.00	0.00	0.384	0.000

PS 33X Jerome Ave 3

DOE-2.2-48r 8/17/2018 11:11:54 BDL RUN 1

```
REPORT- LV-H Details of Windows
```

WEATHER FILE- NEW YORK LAGUARDI NY

------ (CONTINUED)------

					LOCATION OF	F ORIGIN				
		GLASS	GLASS	GLASS	IN	SURFACE	FRAME	CURB	FRAME	CURB
WINDOW		AREA	HEIGHT	WIDTH	COOF	RDINATES	AR	EA	U-VA	LUE
NAME	MULTIPLIER	(SQFT)	(FT)	(FT)	X (FT)	Y (FT)	(SQF	т)	(BTU/HR-	SQFT-F)
Window 19	1.0	30.00	7.50	4.00	24.50	2.50	0.00	0.00	0.384	0.000
Window 45	1.0	18.00	3.00	6.00	3.00	10.00	0.00	0.00	0.384	0.000
Window 49	1.0	18.00	3.00	6.00	3.00	0.00	0.00	0.00	0.384	0.000
Window 27	1.0	30.00	7.50	4.00	2.50	2.50	0.00	0.00	0.384	0.000
Window 28	1.0	30.00	7.50	4.00	10.50	2.50	0.00	0.00	0.384	0.000

	New York Cit	y Public S	chool l	PS 33X	Energy Mo	del Repo	<u>ort</u>			
Window 52	1.0	18.00	3.00	6.00	3.00	0.00	0.00	0.00	0.384	0.000
Window 57	1.0	18.00	3.00	6.00	3.00	10.00	0.00	0.00	0.384	0.000
Window 29	1.0	60.00	7.50	8.00	0.00	2.50	0.00	0.00	0.384	0.000
Window 30	1.0	30.00	7.50	4.00	12.50	2.50	0.00	0.00	0.384	0.000
Window 31	1.0	60.00	7.50	8.00	20.50	2.50	0.00	0.00	0.384	0.000
Window 61	1.0	30.00	7.50	4.00	0.00	2.50	0.00	0.00	0.384	0.000
Window 65	1.0	30.00	7.50	4.00	30.00	2.50	0.00	0.00	0.384	0.000
Window 123	1.0	45.00	7.50	6.00	1.00	2.50	0.00	0.00	0.384	0.000
Window 69	1.0	30.00	7.50	4.00	2.00	2.50	0.00	0.00	0.384	0.000
Window 26	1.0	90.00	7.50	12.00	2.50	2.50	0.00	0.00	0.384	0.000
Window 129	1.0	90.00	7.50	12.00	2.75	2.50	0.00	0.00	0.384	0.000
Window 130	1.0	90.00	7.50	12.00	16.75	2.50	0.00	0.00	0.384	0.000
Window 109	1.0	60.00	7.50	8.00	2.00	2.50	0.00	0.00	0.384	0.000
Window 110	1.0	60.00	7.50	8.00	14.00	2.50	0.00	0.00	0.384	0.000
Window 103	1.0	30.00	7.50	4.00	0.00	2.50	0.00	0.00	0.384	0.000
Window 104	1.0	60.00	7.50	8.00	6.00	2.50	0.00	0.00	0.384	0.000
Window 105	1.0	60.00	7.50	8.00	19.00	2.50	0.00	0.00	0.384	0.000
Window 135	1.0	60.00	7.50	8.00	30.00	2.50	0.00	0.00	0.384	0.000
Window 72	1.0	30.00	7.50	4.00	2.50	2.50	0.00	0.00	0.384	0.000
Window 100	1.0	60.00	7.50	8.00	3.80	2.50	0.00	0.00	0.384	0.000
Window 101	1.0	60.00	7.50	8.00	13.80	2.50	0.00	0.00	0.384	0.000
Window 102	1.0	30.00	7.50	4.00	26.30	2.50	0.00	0.00	0.384	0.000
Window 20	1.0	60.00	7.50	8.00	2.50	2.50	0.00	0.00	0.384	0.000
Window 21	1.0	60.00	7.50	8.00	14.50	2.50	0.00	0.00	0.384	0.000
Window 22	1.0	30.00	7.50	4.00	24.50	2.50	0.00	0.00	0.384	0.000
Window 46	1.0	18.00	3.00	6.00	3.00	10.00	0.00	0.00	0.384	0.000
Window 50	1.0	18.00	3.00	6.00	3.00	0.00	0.00	0.00	0.384	0.000
Window 38	1.0	30.00	7.50	4.00	2.50	2.50	0.00	0.00	0.384	0.000
Window 39	1.0	30.00	7.50	4.00	10.50	2.50	0.00	0.00	0.304	0.000
Window 40	1.0	30.00	7.50	4.00	26.50	2.50	0.00	0.00	0.304	0.000
Window 53	1.0	18 00	3 00	4.00 6.00	20.30	2.50	0.00	0.00	0.384	0.000
Window 55	1.0	18.00	3.00	6.00	3.00	10.00	0.00	0.00	0.384	0.000
Window 32	1.0	30.00	7.50	4.00	0.00	2.50	0.00	0.00	0.384	0.000
Window 33	1.0	60.00	7.50	8.00	8.50	2.50	0.00	0.00	0.384	0.000
Window 34	1.0	60.00	7.50	8.00	20.50	2.50	0.00	0.00	0.384	0.000
Window 60	1.0	30.00	7.50	4.00	0.00	2.50	0.00	0.00	0.384	0.000
Window 64	1.0	30.00	7.50	4.00	30.00	2.50	0.00	0.00	0.384	0.000
Window 124	1.0	45.00	7.50	6.00	1.00	2.50	0.00	0.00	0.384	0.000
Window 68	1.0	30.00	7.50	4.00	2.00	2.50	0.00	0.00	0.384	0.000
Window 133	1.0	60.00	7.50	8.00	1.00	2.50	0.00	0.00	0.384	0.000
Window 134	1.0	60.00	7.50	8.00	11.00	2.50	0.00	0.00	0.384	0.000
Window 71	1.0	30.00	7.50	4.00	2.50	2.50	0.00	0.00	0.384	0.000
Window 111	1.0	60.00	7.50	8.00	3.80	2.50	0.00	0.00	0.384	0.000
Window 112	1.0	60.00	7.50	8.00	13.80	2.50	0.00	0.00	0.384	0.000
Window 23	1.0	30.00	7.50	4.00	2.50	2.50	0.00	0.00	0.384	0.000
Window 24	1.0	60.00	7.50	8.00	10.50	2.50	0.00	0.00	0.384	0.000

PS 33X Jerome Ave 3	DOE-2.2-48r	8/17/2018	11:11:54	BDL RUN	1
REPORT- LV-H Details of Windows	WE.	ATHER FILE- 1	NEW YORK LAG	UARDI NY	
				IED)	
			(CONTINO		

					LOCATION OF	ORIGIN				
		GLASS	GLASS	GLASS	IN	SURFACE	FRAME	CURB	FRAME	CURB
WINDOW		AREA	HEIGHT	WIDTH	COOR	DINATES	AI	REA	U-VA	LUE
NAME	MULTIPLIER	(SQFT)	(FT)	(FT)	X (FT)	Y (FT)	(SQI	7T)	(BTU/HR-	SQFT-F)
	1.0	~ ~ ~			04 05					
Window 25	1.0	60.00	7.50	8.00	21.35	2.50	0.00	0.00	0.384	0.000
Window 47	1.0	18.00	3.00	6.00	3.00	10.00	0.00	0.00	0.384	0.000
Window 48	1.0	18.00	3.00	6.00	3.00	0.00	0.00	0.00	0.384	0.000
Window 42	1.0	90.00	7.50	12.00	2.50	2.50	0.00	0.00	0.384	0.000
Window 43	1.0	90.00	7.50	12.00	18.50	2.50	0.00	0.00	0.384	0.000
Window 54	1.0	18.00	3.00	6.00	3.00	0.00	0.00	0.00	0.384	0.000
Window 55	1.0	18.00	3.00	6.00	3.00	10.00	0.00	0.00	0.384	0.000
Window 35	1.0	60.00	7.50	8.00	0.00	2.50	0.00	0.00	0.384	0.000
Window 36	1.0	60.00	7.50	8.00	12.50	2.50	0.00	0.00	0.384	0.000
Window 37	1.0	30.00	7.50	4.00	24.50	2.50	0.00	0.00	0.384	0.000
Window 59	1.0	60.00	7.50	8.00	0.00	2.50	0.00	0.00	0.384	0.000
Window 63	1.0	30.00	7.50	4.00	30.00	2.50	0.00	0.00	0.384	0.000
Window 125	1.0	45.00	7.50	6.00	1.00	2.50	0.00	0.00	0.384	0.000
Window 67	1.0	30.00	7.50	4.00	2.00	2.50	0.00	0.00	0.384	0.000
Window 113	1.0	60.00	7.50	8.00	4.50	2.50	0.00	0.00	0.384	0.000
Window 114	1.0	60.00	7.50	8.00	14.50	2.50	0.00	0.00	0.384	0.000
Window 115	1.0	60.00	7.50	8.00	26.50	2.50	0.00	0.00	0.384	0.000
Window 116	1.0	60.00	7.50	8.00	36.50	2.50	0.00	0.00	0.384	0.000
Window 117	1.0	60.00	7.50	8.00	0.00	2.50	0.00	0.00	0.384	0.000
Window 118	1.0	60.00	7.50	8.00	10.00	2.50	0.00	0.00	0.384	0.000
Window 119	1.0	60.00	7.50	8.00	24.00	2.50	0.00	0.00	0.384	0.000
Window 120	1.0	60.00	7.50	8.00	36.00	2.50	0.00	0.00	0.384	0.000
		GLASS	NUMBE	R	CENTER-O	7-	GLASS	GLASS	SURFAC	е то
WINDOW	SETBACK	SHADING	c)F	GLASS U-VAL	JE V	ISIBLE	SOLAR	ROUGH	OPEN
NAME	(FT)	COEFF	PANE	s ((BTU/HR-SQFT-	· ?)	TRANS	TRANS	AREA R	ATIO
Window 1	0.00	0.39		1	0.4	50	0.680	0.878	1.00	0
Window 2	0.00	0.39		1	0.4	50	0.680	0.878	1.00	0
Window 121	0.00	0.39		1	0.4	50	0.680	0.878	1.00	0
Window 5	0.00	0.39		1	0.4	50	0.680	0.878	1.00	0
Window 3	0.00	0.39		1	0.4	50	0.680	0.878	1.00	0
Window 7	0.00	0.39		1	0.4	50	0.680	0.878	1.00	0
Window 75	0.00	0.39		1	0.4	50	0.680	0.878	1.00	0
Window 77	0.00	0.39		1	0.5	LO	0.680	0.878	1.00	0
Window 78	0.00	0.39		1	0.5	LO	0.680	0.878	1.00	0
Window 79	0.00	0.39		1	0.5	LO	0.680	0.878	1.00	0
Window 80	0.00	0.39		1	0.5	LO	0.680	0.878	1.00	0
Window 81	0.00	0.39		1	0.5	LO	0.680	0.878	1.00	0
Window 76	0.00	0.39		1	0.5	LO	0.680	0.878	1.00	0
Window 82	0.00	0.39		1	0.4	50	0.680	0.878	1.00	0
Window 126	0.00	0.39		1	0.4	50	0.680	0.878	1.00	0
Window 90	0.00	0.39		1	0.4	50	0.680	0.878	1.00	0
Window 91	0.00	0.39		1	0.4	50	0.680	0.878	1.00	0
Window 131	0.00	0.39		1	0.4	50	0.680	0.878	1.00	0
Window 132	0.00	0.39		1	0.4	50	0.680	0.878	1.00	0
Window 74	0.00	0.39		1	0.4	50	0.680	0.878	1.00	0
······································	5.00	~ ~ ~ ~ ~ ~ ~ ~ ~ ~ ~ ~ ~ ~ ~ ~ ~ ~ ~ ~		_	U • 1					-

		<u>New York Ci</u>	ty Public Scl	hool PS 33X	Energy Model R	eport		
Window 8	84	0.00	0.39	1	0.450	0.680	0.878	1.000
Window 8	85	0.00	0.39	1	0.450	0.680	0.878	1.000
Window 8	8	0.00	0.39	1	0.450	0.680	0.878	1.000
Window S	9	0.00	0.39	1	0.450	0.680	0.878	1.000

Window 61

Window 65

Window 123

11:11:54 BDL RUN 1 DOE-2.2-48r 8/17/2018

REPORT- LV-H Details of N	Windows				WEATHER	FILE- NE	NEW YORK LAGUARDI NY		
		GLASS	NUMBER	CENTER-OF-	GLASS	GLASS	SURFACE TO		
WINDOW	SETBACK	SHADING	OF	GLASS U-VALUE	VISIBLE	SOLAR	ROUGH OPEN		
NAME	(FT)	COEFF	PANES	(BTU/HR-SQFT-F)	TRANS	TRANS	AREA RATIO		
Window 10	0.00	0.39	1	0.450	0.680	0.878	1.000		
Window 44	0.00	0.39	1	0.450	0.680	0.878	1.000		
Window 11	0.00	0.39	1	0.450	0.680	0.878	1.000		
Window 12	0.00	0.39	1	0.450	0.680	0.878	1.000		
Window 13	0.00	0.39	1	0.450	0.680	0.878	1.000		
Window 51	0.00	0.39	1	0.450	0.680	0.878	1.000		
Window 58	0.00	0.39	1	0.450	0.680	0.878	1.000		
Window 14	0.00	0.39	1	0.450	0.680	0.878	1.000		
Window 15	0.00	0.39	1	0.450	0.680	0.878	1.000		
Window 16	0.00	0.39	1	0.450	0.680	0.878	1.000		
Window 62	0.00	0.39	1	0.450	0.680	0.878	1.000		
Window 66	0.00	0.39	1	0.450	0.680	0.878	1.000		
Window 122	0.00	0.39	1	0.450	0.680	0.878	1.000		
Window 70	0.00	0.39	1	0.450	0.680	0.878	1.000		
Window 127	0.00	0.39	1	0.450	0.680	0.878	1.000		
Window 128	0.00	0.39	1	0.450	0.680	0.878	1.000		
Window 98	0.00	0.39	1	0.450	0.680	0.878	1.000		
Window 99	0.00	0.39	1	0.450	0.680	0.878	1.000		
Window 94	0.00	0.39	1	0.450	0.680	0.878	1.000		
Window 95	0.00	0.39	1	0.450	0.680	0.878	1.000		
Window 73	0.00	0.39	1	0.450	0.680	0.878	1.000		
Window 92	0.00	0.39	1	0.450	0.680	0.878	1.000		
Window 93	0.00	0.39	1	0.450	0.680	0.878	1.000		
Window 17	0.00	0.39	1	0.450	0.680	0.878	1.000		
Window 18	0.00	0.39	1	0.450	0.680	0.878	1.000		
Window 19	0.00	0.39	1	0.450	0.680	0.878	1.000		
Window 45	0.00	0.39	1	0.450	0.680	0.878	1.000		
Window 49	0.00	0.39	1	0.450	0.680	0.878	1.000		
Window 27	0.00	0.39	1	0.450	0.680	0.878	1.000		
Window 28	0.00	0.39	1	0.450	0.680	0.878	1.000		
Window 52	0.00	0.39	1	0.450	0.680	0.878	1.000		
Window 57	0.00	0.39	1	0.450	0.680	0.878	1.000		
Window 29	0.00	0.39	1	0.450	0.680	0.878	1.000		
Window 30	0.00	0.39	1	0.450	0.680	0.878	1.000		
Window 31	0.00	0.39	1	0.450	0.680	0.878	1 000		

0.00

0.00

0.00

0.39

0.39

0.39

1

1

1

0.680

0.680

0.680

0.878

0.878

0.878

1.000

1.000

1.000

0.450

0.450

0.450
	New York C	ity Public Sc	hool PS 33X	Energy Model R	eport		
Window 69	0.00	0.39	1	0.450	0.680	0.878	1.000
Window 26	0.00	0.39	1	0.450	0.680	0.878	1.000
Window 129	0.00	0.39	1	0.450	0.680	0.878	1.000
Window 130	0.00	0.39	1	0.450	0.680	0.878	1.000
Window 109	0.00	0.39	1	0.450	0.680	0.878	1.000
Window 110	0.00	0.39	1	0.450	0.680	0.878	1.000
Window 103	0.00	0.39	1	0.450	0.680	0.878	1.000
Window 104	0.00	0.39	1	0.450	0.680	0.878	1.000
Window 105	0.00	0.39	1	0.450	0.680	0.878	1.000
Window 135	0.00	0.39	1	0.450	0.680	0.878	1.000
Window 72	0.00	0.39	1	0.450	0.680	0.878	1.000
Window 100	0.00	0.39	1	0.450	0.680	0.878	1.000
Window 101	0.00	0.39	1	0.450	0.680	0.878	1.000
Window 102	0.00	0.39	1	0.450	0.680	0.878	1.000
Window 20	0.00	0.39	1	0.450	0.680	0.878	1.000
Window 21	0.00	0.39	1	0.450	0.680	0.878	1.000

PS 33X Jerome Ave 3

DOE-2.2-48r 8/17/2018 11:11:54 BDL RUN 1

REPORT- LV-H Details of Windows

------ (CONTINUED)------

WEATHER FILE- NEW YORK LAGUARDI NY

		GLASS	NUMBER	CENTER-OF-	GLASS	GLASS	SURFACE TO
WINDOW	SETBACK	SHADING	OF	GLASS U-VALUE	VISIBLE	SOLAR	ROUGH OPEN
NAME	(FT)	COEFF	PANES	(BTU/HR-SQFT-F)	TRANS	TRANS	AREA RATIO
Window 22	0.00	0.39	1	0.450	0.680	0.878	1.000
Window 46	0.00	0.39	1	0.450	0.680	0.878	1.000
Window 50	0.00	0.39	1	0.450	0.680	0.878	1.000
Window 38	0.00	0.39	1	0.450	0.680	0.878	1.000
Window 39	0.00	0.39	1	0.450	0.680	0.878	1.000
Window 40	0.00	0.39	1	0.450	0.680	0.878	1.000
Window 41	0.00	0.39	1	0.450	0.680	0.878	1.000
Window 53	0.00	0.39	1	0.450	0.680	0.878	1.000
Window 56	0.00	0.39	1	0.450	0.680	0.878	1.000
Window 32	0.00	0.39	1	0.450	0.680	0.878	1.000
Window 33	0.00	0.39	1	0.450	0.680	0.878	1.000
Window 34	0.00	0.39	1	0.450	0.680	0.878	1.000
Window 60	0.00	0.39	1	0.450	0.680	0.878	1.000
Window 64	0.00	0.39	1	0.450	0.680	0.878	1.000
Window 124	0.00	0.39	1	0.450	0.680	0.878	1.000
Window 68	0.00	0.39	1	0.450	0.680	0.878	1.000
Window 133	0.00	0.39	1	0.450	0.680	0.878	1.000
Window 134	0.00	0.39	1	0.450	0.680	0.878	1.000
Window 71	0.00	0.39	1	0.450	0.680	0.878	1.000
Window 111	0.00	0.39	1	0.450	0.680	0.878	1.000
Window 112	0.00	0.39	1	0.450	0.680	0.878	1.000
Window 23	0.00	0.39	1	0.450	0.680	0.878	1.000
Window 24	0.00	0.39	1	0.450	0.680	0.878	1.000
Window 25	0.00	0.39	1	0.450	0.680	0.878	1.000
Window 47	0.00	0.39	1	0.450	0.680	0.878	1.000
Window 48	0.00	0.39	1	0.450	0.680	0.878	1.000

	New York City Public School PS 33X Energy Model Report											
Window	42	0.00	0.39	1	0.450	0.680	0.878	1.000				
Window	43	0.00	0.39	1	0.450	0.680	0.878	1.000				
Window	54	0.00	0.39	1	0.450	0.680	0.878	1.000				
Window	55	0.00	0.39	1	0.450	0.680	0.878	1.000				
Window	35	0.00	0.39	1	0.450	0.680	0.878	1.000				
Window	36	0.00	0.39	1	0.450	0.680	0.878	1.000				
Window	37	0.00	0.39	1	0.450	0.680	0.878	1.000				
Window	59	0.00	0.39	1	0.450	0.680	0.878	1.000				
Window	63	0.00	0.39	1	0.450	0.680	0.878	1.000				
Window	125	0.00	0.39	1	0.450	0.680	0.878	1.000				
Window	67	0.00	0.39	1	0.450	0.680	0.878	1.000				
Window	113	0.00	0.39	1	0.450	0.680	0.878	1.000				
Window	114	0.00	0.39	1	0.450	0.680	0.878	1.000				
Window	115	0.00	0.39	1	0.450	0.680	0.878	1.000				
Window	116	0.00	0.39	1	0.450	0.680	0.878	1.000				
Window	117	0.00	0.39	1	0.450	0.680	0.878	1.000				
Window	118	0.00	0.39	1	0.450	0.680	0.878	1.000				
Window	119	0.00	0.39	1	0.450	0.680	0.878	1.000				
Window	120	0.00	0.39	1	0.450	0.680	0.878	1.000				

PS 33X Jerome Ave 3

DOE-2.2-48r 8/17/2018 11:11:54 BDL RUN 1

REPORT- LV-I Details of Constructions

WEATHER FILE- NEW YORK LAGUARDI NY

NUMBER OF CONSTRUCTIONS 10 DELAYED 8 QUICK 2

CONSTRUCTION	U-VALUE	SURFACE	SURFACE ROUGHNESS	SURFACE	NUMBER OF RESPONSE
NAME	(BTU/HR-SQFT-F)	ABSORPTANCE	INDEX	TYPE	FACTORS
C EWall Construction	0.062	0.70	3	QUICK	0
C Ceilg Construction	0.141	0.70	3	DELAYED	4
C IWall Construction	0.141	0.70	3	DELAYED	4
C IFlr Construction	0.813	0.70	3	DELAYED	5
C IF1SP Construction	0.813	0.70	3	DELAYED	5
FL1 GFlr Construction	0.056	0.70	3	DELAYED	23
FL1 GF1SP Construction	0.056	0.70	3	DELAYED	23
FL5 Roof Construction	0.032	0.60	1	QUICK	0
C UFCons (B.NNE1.U2)	0.010	0.70	3	DELAYED	52
C UWCons (B.NNE1.U2)	0.060	0.70	3	DELAYED	27

Credit E4-2: Cooling and Heating Load Calculations

PS-347X SCHOOL

COOLING AND HEATING LOAD CALCULATIONS

60% DESIGN SUBMISSION

Prepared By:

DVL consulting Engineer, Inc 375 Main Street Hackensack, NJ 07601

DVL#756

4/26/2018

DESIGN PARAMETERS

INDOOR AMBIENT DESIGN PARAMETERS FOR ASSEMBLY SPACES:

- Summer: 78°F (DB) / 50% RH
- Winter: 72°F (DB)

INDOOR AMBIENT DESIGN PARAMETERS FOR CLASSROOMS AND

OFFICES:

Summer: 78°F (DB) / 50% RH

Winter: 72°F (DB)

OUTDOOR DESIGN PARAMETERS FOR AIR HANDLERS (AHU):

- Summer: 89°F (DB) / 73°F (WB)
- Winter: 11°F (DB)

THERMAL TRANSMITTANCE U-FACTORS:

U-FACTOR (WINDOW)	0.42
U-FACTOR (WALL)	0.056
U-FACTOR (ROOF)	0.031

SOLAR HEAT GAIN COEFFICIENT: shgc 0.38

2400 Jerome Avenue Bronx, NY 10468 Heating Calculation for the Size of Boilers

DVL#: 756.00

Date:

3/14/2018

New Building: 1. Instantaneous Block Heating Load and Conductive Heat Load

A. Conductive Heat Load:

(Total Glass A 5,422	vrea) X X	(Glass "U" 0.42) X X	61 61	=	138,912	BTU/HR
(Total Exterioo 22,408	r Wall Ar X	ea) X (\ 0.056	Vall "U X	") X 61	61 =	76,546	BTU/HR
(Total Roof An 9,674	ea) X X	(Roof "U") 0.031	x	61 61	-	18,294	BTU/HR
(Ventilation Air 13,620	, cfm) X	K 1.085 x 1.085	61 °F X	61	=	901,440	BTU/HR

B. Total Block Heating Load				1,135,191 BTU/HR
C. Total Building Heating Load				1,135,191 BTU/HR
2. Heating Safety Fac 25%				
3. Total Heating Load 1,135,191 BTU/HR	х	1.25	=	1,418,988 BTU/HR

4. As per SCA HVAC Design Standard No. 6.2.13 - Two (2) Boilers, each sized for 75% of building total heating load shall be provided for the school.

One (1) Boiler Minimum						
Net Capacity:	1,418,988	х	0.75	=	1,064,241	BTU/HR

LWT = 155 °F EWT = 125°F

Heating Calculation for the Size of Boilers

1. The "U" values considered in this calculations are: Glass 0.42, Wall 0.056, Roof 0.031. Notes:

The boiler sizing is in compliance with SCA standards Section: 6.2.13 Sizing of Equipment.

PS 347X-Bronx Standalone Annex Load Calculations for the Chiller

DVL#: 756

Date:

3/13/2018

SYSTEM	TOTAL COO	LING LOAD
AHU-1 (O.A = 5500 CFM)	389 MBH*	32 TONS*
AHU-2 (O.A = 5800 CFM)	433 MBH*	36 TONS*
AHU-3 (O.A = 2000 CFM)	218 MBH*	18 TONS*
Total	1040 MBH	87 TONS

Cooling Safety Factor (considering reduction of cooling capacity after several years of service): add 10%

Total Cooling Load: 87 x1.10 95 TONS

Actual Capacity = 133.9 TONS (Based on Air Stack Modular Air Cooled Chiller)

*BASED ON PERFORMANCE DATA SHEET OF SELECTED EQUIPMENT.

**BASED ON COOLING LOAD CALCULATIONS.

System Checksums By DVL

AHU-1

VAV w/Baseboard Heating

	COOLING COIL PEAK				CLG SPAC	E PEAK	(HEATING	COIL PEAK		TEMPERATURES			
Peake	ed at Time: Outside Air:	Me OADB/WB	o/Hr: 7 / 16 /HR: 89 / 73 /	97	Mo/Hr OADB	r: 8 / 10 I: 79			Mo/Hr: OADB:	Heating Desig	n .	SADB Plenum	Cooling 56.3 75.9	Heatin 72 71	ng 2.0 1.6
	Space Sens. + Lat. Btu/h	Plenum Sens. + Lat Btu/h	Net Total Btu/h	Percent Of Total (%)	Space Sensible Btu/h	Percent Of Total (%)			Space Peak Space Sens Btu/h	Coil Peak Tot Sens Btu/f	Of Total	Return Ret/OA Fn MtrTD	76.9 82.7 0.1	71 34 0	1.6 1.2 0.0
Envelope Loads Skylite Solar Skylite Cond Roof Cond	9 0 0	0 0 0	0000	0000	0		Envelope Skylite Skylite Roof Co	Loads Solar Cond ond	0 0		0.00	Fn BlatD Fn Frict	0.9	Ċ	0.0
Glass Solar Glass Cond Wall Cond Partition	61,434 14,083 7,479	0 0 3,929	61,434 14,083 11,409	12 3 2 0	101,951 3,398 4,872 0	40 1 2 0	Glass S Glass C Wall Co Partition	Solar Cond ond n	0 -65,056 -10,691 0	-65,056 -16,445	0 0.00 12.78 3.23 0 0.00	All	RFLOWS	Heati	na
Exposed Floor Infiltration	0 0 82 996	3 020	0 0 86 925	0 0 17	0 0 110.221	0 0 43	Expose Infiltration	d Floor on tal ==>	0 -3 -75,749	-81.504	0.00 0.00 16.01	Vent Infil Supply	5,406 0 12,295	5,4	06
Internal Loads	02,990	5,525			110,221		Internal L	.oads			0.00	MinStop/Rh Return	8,766 12,295 5,406	8,7 8,7 5,4	66 66 06
Lights People Misc	42,349 131,950 16,200	10,587	52,936 131,950 16,200	10 25 3	42,349 79,170 16,200	17 31 6	People Misc		0		0.00	Rm Exh Auxiliary	0	0,1	0
Sub Total ==>	190,499	10,587	201,086	39	137,719	54	Sub Tot	ta/ ==>	1 026		0.00				
Ceiling Load Ventilation Load Dehumid. Ov Si	4,182 1 0 zing	-4,182 0	210,689 0	41 0	3,5/4	0	Ventilatio	oad on Load Sizing Hoat	-1,920 0 0	-367,587	72.23	ENGIN	Cooling 44.0	CKS Heatir	ng 0.0
Exhaust Heat Sup. Fan Heat	2,348	-11,535 12 940	-11,535 16,175 12 940	-2 3 2	4,000	. 2	OA Prehe RA Prehe Additiona	at Diff. at Diff.		-62,213	0.00	cfm/ft ² cfm/ton ft ² /ton	0.79 284.48 358.87	0.	57
Duct Heat Pkup Reheat at Desig	n	0	0	0								Btu/hr-ft ² No. People	33.44 377	-32.8	81
Grand Total ==>	280,025	11,740	518,629	100.00	255,899	100.00	Grand To	otal ==>	-77,675	-508,943	100.00				
•	Total Capacity ton MBh	COOLING Sens Cap. MBh	Coil Airflow	ECTIO Enter I °F	N DB/WB/HR °F gr/lb	Leave DI °F	°F gr/lb		AREAS Gross Total	Glass ft ^z (%)	HEA	TING COIL Capacity C MBh	SELECTI coil Airflow	ON Ent °F	Lvg °F
Main Clg 4 Aux Clg	3.2 518.6 0.0 0.0	337.1 0.0	10,918.3 0	82.7 0	68.1 79.9 0 0	55.0 5 0	2.9 56.5	Floor Part	15,510 0		Main Htg Aux Htg Prebeat	-243.8 0.0 -265.1	0.0 0 5.406	0.0 0 11	0.0 0 55
Total 4	3.2 518.6	0.0	0	0.0	0.0 0.0	0.0	0.0 0.0	Roof Wall	0 7,347	0 0 2,522 34	Humidif Opt Vent	0.0	0	0.0	0.0 0.0
											Total	-508.9			

Project Name: PS-347X Dataset Name: G:\756 - PS-33X\M\Heating & Cooling Calculations\PS-347X AHU-1 Classroom.trc TRACE® 700 v6.0 calculated at 02:12 PM on 04/26/2018 Alternative - 1 System Checksums Report Page 1 of 1

PEAK COOLING LOADS

MAIN SYSTEM

By DVL

				SPACE							COIL							
					0	A	Room	Supply	Space	Space	Space		0	A			Coil	Coil
			Floor	Peak	Cond	dition	Dry	Dry	Air	Sensible	Latent	Peak	Conc	lition	Supply	Coil	Sensible	Latent
			Area	Time	DB	WB	Bulb	Bulb	Flow	Load	Load	Time	DB	wв	Dry Bulb	Airflow	Load	Load
System Zone	Room		ft²	Mo/Hr	۴F	°F	°F	°F	cfm	Btu/h	Btu/h	Mo/Hr	°F	°F	۴F	cfm	Btu/h	Btu/h
	508 Grade 2 E	Peak	773	7/9	79	67	75.0	56.3	824	17,160	3,640	7 /10	81	68	56.3	797	20,796	7,280
	506 Grade 2 E	Peak	756	7/9	79	67	75.0	56.3	822	17,110	3,640	7 /10	81	68	56.3	795	20,727	7,269
	504 Grade 2 SE	Peak	804	9/11	78	63	75.0	56.3	902	18,777	3,920	7 /12	86	70	56.3	823	23,358	9,745
	503 Library SW	Peak	864	9/16	84	66	75.0	56.3	1,162	24,176	3,220	7/17	88	72	56.3	1,124	32,332	12,895
	408 Grade 1 E	Peak	792	7/9	79	67	75.0	56.3	827	17,216	3,640	7/10	81	68	56.3	800	20,873	7,292
	406 Grade 1 E	Peak	761	7/9	79	67	75.0	56.3	823	17,125	3,640	7/10	81	68	56.3	795	20,748	7,272
	404 Grade 1 SE	Peak	804	9/11	78	63	75.0	56.3	862	17,937	3,360	7 /12	86	70	56.3	783	22,261	8,925
	403 Grade 1 SW	Peak	838	9/16	84	66	75.0	56.3	1,043	21,698	3,220	7/17	88	72	56.3	1,005	28,997	11,903
	3 Floor Corridor	Peak	997	11/13	62	49	75.0	56.3	412	8,573	980	7/14	89	72	56.3	329	10,225	3,943
	306 Kindergarten E	Peak	917	7/9	79	67	75.0	56.3	918	19,108	3,220	7/9	79	67	56.3	918	24,214	7,110
	304 Kindergarten SE	Peak	954	8/9	77	64	75.0	56.3	987	20,548	3,360	7/9	79	67	56.3	982	24,851	7,543
	303 Project Room	Peak	930	9/16	84	66	75.0	56.3	979	20,374	3,220	7/17	88	72	56.3	941	27,259	11,373
	2 FLoor Corridor	Peak	997	11/13	62	49	75.0	56.3	412	8,573	980	7/14	89	72	56.3	329	10,225	3,943
	206 Pre-K E	Peak	917	7/9	79	67	75.0	56.3	918	19,108	3,220	7 /9	79	67	56.3	918	24,214	7,110
	204 Pre-K SE	Peak	954	8/9	77	64	75.0	56.3	987	20,548	3,360	7/9	79	67	56.3	982	24,851	7,543
	203 Kindergarten SW	Peak	930	9/16	84	66	75.0	56.3	979	20,374	3,220	7/17	88	72	56.3	941	27,259	11,373
	1 Floor Corridor	Peak	1,102	9/18	81	66	75.0	56.3	230	4,791	980	7/15	89	73	56.3	230	6,999	2,982
	103C Exam Room W	Peak	117	7/18	86	72	75.0	56.3	227	4,717	280	7/18	86	72	56.3	227	6,346	2,212
	103A Nurse Office	Peak	89	7/18	86	72	75.0	56.3	90	1,871	280	7 /16	89	73	56.3	88	2,577	1,079
	105 Parent Community W	Peak	214	6/18	83	66	75.0	56.3	207	4,303	1,400	7/15	89	73	56.3	203	5,943	3,197
AHU-1	•	Peak	15,510		79	64	75.0	56.3	14,610	304,086	52,780		89	73	56.3	14,008	454,321	141,989
AHU-1		Block	15,510	8/10	79	64	75.0	56.3	12,295	255,899	52,780	7 /16	89	73	56.3	10,918	337,623	182,605

Project Name: PS-347X Dataset Name: G:\756 - PS-33X\M\Heating & Cooling Calculations\PS-347X AHU-1 Classroom.trc TRACE® 700 v6.0 calculated at 02:30 PM on 04/26/2018 Alternative - 1 Peak Clg Loads Main System Report Page 1 of 1

PEAK HEATING LOADS

MAIN SYSTEM

By DVL

	OA Condition DB WB					SPAC	E		COIL		
System	Peak Time °F °F Htg Design 11 7	Block or Peak	Floor Area ft²	Room Dry Bulb °F	Supply Dry Bulb °F	Space Air Flow cfm	Space Sensible Load Btu/h	Supply Dry Bulb °F	Coil Air Flow cfm	Coil Sensible Load Btu/h	
oyatem	500 Crade 2 E	Peak	773	72.0	72.0	0	-3.028	72.0	0	-12,403	
	508 Grade 2 E	Peak	756	72.0	72.0	0	-3,026	72.0	0	-12,373	
	506 Grade 2 E	Peak	804	72.0	72.0	0	-5,273	72.0	0	-15,531	
	504 Grade 2 SE	Peak	864	72.0	72.0	0	-6,510	72.0	0	-19,717	
	408 Grade 1 E	Peak	792	72.0	72.0	0	-3,030	72.0	0	-12,436	
	406 Grade 1 E	Peak	761	72.0	72.0	0	-3,026	72.0	0	-12,382	
	400 Grade 1 SE	Peak	804	72.0	72.0	0	-5,273	72.0	0	-15,072	
	404 Glade 1 SE	Peak	838	72.0	72.0	0	-6,507	72.0	0	-18,360	
	3 Eleer Cerrider	Peak	997	72.0	72.0	0	-1,708	72.0	0	-6,392	
	306 Kindergarten F	Peak	917	72.0	72.0	0	-4,341	72.0	0	-14,780	
	304 Kindergarten SE	Peak	954	72.0	72.0	0	-6,455	72.0	0	-17,681	
	303 Project Room	Peak	930	72.0	72.0	0	-6,518	72.0	0	-17,648	
	2 El oor Corridor	Peak	997	72.0	72.0	0	-1,708	72.0	0	-6,392	
	206 Pre-K F	Peak	917	72.0	72.0	0	-4,341	72.0	0	-14,780	
	204 Pre-K SE	Peak	954	72.0	72.0	0	-6,455	72.0	0	-17,681	
	203 Kindergarten SW	Peak	930	72.0	72.0	0	-6,518	72.0	0	-17,648	
	1 Eloor Corridor	Peak	1,102	72.0	72.0	0	-137	72.0	0	-2,754	
	103C Exam Boom W	Peak	117	72.0	72.0	0	-1,488	72.0	0	-4,066	
	103A Nurse Office	Peak	89	72.0	72.0	0	-166	72.0	0	-1,189	
	105 Parent Community W	Peak	214	72.0	72.0	0	-2,166	72.0	0	-4,517	
AHIL-1	.cor area commany r	Peak	15,510	72.0	72.0	0	-77,675	72.0	0	-243,798	
AHU-1		Block	15,510	72.0	72.0	0	-77,672	72.0	0	-243,795	

Project Name: PS-347X Dataset Name: G:\756 - PS-33X\M\Heating & Cooling Calculations\PS-347X AHU-1 Classroom.trc TRACE® 700 v6.0 calculated at 02:30 PM on 04/26/2018 Alternative - 1 Peak Htg Loads Main System Report Page 1 of 1

System Checksums By DVL

AHU-2

VAV w/Baseboard Heating

COOLING COIL PEA	к	CLG SPACE PE	AK	HEATING	COIL PEAK	TEMPERAT	JRES
Peaked at Time: N Outside Air: OADB/Wi	lo/Hr: 7 / 16 3/HR: 89 / 73 / 97	Mo/Hr: 7 / 17 OADB: 88	7	Mo/Hr: OADB:	Heating Design 11	Cooli SADB 50 Plenum 7	ng Heating 3.3 72.0 9.3 71.6
Space Plenum Sens. + Lat. Sens. + La Btu/h Btu/i	Net Percent t Total Of Tota Btu/h (%	t Space Perc I Sensible Of To) Btu/h	ent otal (%)	Space Peak Space Sens Btu/h	Coil Peak Percent Tot Sens Of Total Btu/h (%)	Return 8 Ret/OA 8 Fn MtrTD	0.4 71.6 4.4 30.2 0.1 0.0
Envelope Loads Skylite Solar 0 00 Skylite Cond 0 00 Roof Cond 0 0			0 Skylite Solar 0 Skylite Cond 0 Roof Cond	ds 0 0 0	0 0.00 0 0.00 0 0.00	Fn BldTD Fn Frict	0.3 0.0 0.9 0.0
Glass Solar 86,499 0 Glass Cond 9,168 0 Wall Cond 6,963 3,17	0 86,499 16 0 9,168 2 5 10,138 2	5 91,955 2 8,499 2 7,403	32 Glass Solar 3 Glass Cond 3 Wall Cond	0 -54,325 -12,763	0 0.00 -54,325 10.64 -18,709 3.66	AIRFLOV	vs
Partition 0 Exposed Floor 0 Infiltration 0			0 Partition 0 Exposed Floo 0 Infiltration	or 0 -2	0 0.00 0 0.00 -2 0.00	Cooli Vent 5,7 Infil	ng Heating 51 5,751 0 0
Sub Total ==> 102,630 3,175	5 105,805 19	107,857	38 Sub Total ==	> -67,091	-73,037 14.30	Supply 11,8 MinStop/Rh 8,4 Return 11,8	62 8,417 17 8,417 62 8,417
Lights 79,597 19,899 People 131,600 Misc 13,200 0	99,496 18 131,600 24 13,200 2	3 79,597 4 78,960 2 13,200	28 Lights 28 People 5 Misc	0	0 0.00 0 0.00 0 0.00	Rm Exh Auxiliary	0 0 0 0
Sub Total ==> 224,397 19,899	244,296 44	171,757	60 Sub Total ==	> 0	0 0.00		
Ceiling Load 6,087 -6,087 Ventilation Load 0 0 Dehumid, Ov Sizing	0 0 191,451 34 0 0	6,061 4 0	2 Ceiling Load 0 Ventilation Loa 0v/Undr Sizing	ad 0 g 0	-391,082 76.59 0 0.00	ENGINEERIN Cooli	G CKS
Ov/Undr Sizing 223 Exhaust Heat -15,266 Sup. Fan Heat 13,771 Duct Heat Pkup	223 0 -15,266 -3 17,214 3 13,771 2	883	0 Exhaust Heat OA Preheat Din RA Preheat Din Additional Reh	ff. ff. heat	2,723 -0.53 0 0.00 -49,246 9.64 0 0.00	% OA 44 cfm/ft ² 0. cfm/ton 255. ft ² /ton 313. Btu/hr-ft ² 38.	3.5 0.0 81 0.58 33 75 25 -35.03
Reheat at Design	0 0	286 557 100	00 Grand Total	-69.052	-510.642 100.00	No. People 3	76
Grand Total ==> 333,337 13,492		200,007 100			HE	ATING COIL SELE	TION
Total Capacity Sens Cap ton MBh MBh	Coll Airflow Enter	DB/WB/HR Leav °F gr/lb °F	e DB/WB/HR * °F gr/lb	Gross Total	Glass ft ² (%)	Capacity Coil Airfl MBh cfr	n °F °F
Main Clg 46.5 557.5 381.3 Aux Clg 0.0 0.0 0.0 Opt Vent 0.0 0.0 0.0	11,619.5 84.4 0 0	69.0 81.6 55.0 0 0 0	53.9 60.3 F 0 0 0 P 0 0.0 0.0 E	loor 14,576 art 0 xFir 0	Main Htg Aux Htg Preheat	-228.6 0. 0.0 -282.1 5,75	0 0.0 0.0 0 0 0 1 11 55
Total 46.5 557.5			R	oof 0 Vall 7,595	0 0 2,106 28 Humidif Opt Vent Total	0.0 0.0 -510.6	0 0.0 0.0 0 0.0 0.0

Project Name: PS-347X Dataset Name: G:\756 - PS-33X\M\Heating & Cooling Calculations\PS-347X AHU-2 Classroom.trc TRACE® 700 v6.0 calculated at 03:06 PM on 04/26/2018 Alternative - 1 System Checksums Report Page 1 of 1

PEAK COOLING LOADS

MAIN SYSTEM

By DVL

				SPACE						COIL								
					C	A	Room	Supply	Space	Space	Space		0	A			Coil	Coil
			Floor	Peak	Cond	dition	Dry	Dry	Air	Sensible	Latent	Peak	Cond	lition	Supply	Coil	Sensible	Latent
			Area	Time	DB	WB	Bulb	Bulb	Flow	Load	Load	Time	DB	WB	Dry Bulb	Airflow	Load	Load
System Zone	Room		ft²	Mo/Hr	°F	°F	°F	°F	cfm	Btu/h	Btu/h	Mo/Hr	°F	°F	°F	cfm	Btu/h	Btu/h
	5 Floor Corridor	Peak	997	11/13	62	49	78.0	56.3	471	11,388	980	7/13	88	71	56.3	404	13,324	4,162
	505 CSD Spec Education W	Peak	637	7/17	88	72	78.0	56.3	969	23,404	2,940	7 /16	89	73	56.3	952	30,051	11,474
	507 Grade 2 NW	Peak	843	7/18	86	72	78.0	56.3	891	21,521	3,220	7 /18	86	72	56.3	891	27,316	10,714
	4 Floor Corridor	Peak	997	11/13	62	49	78.0	56.3	471	11,388	980	7/13	88	71	56.3	404	13,324	4,162
	410 Grade 1 E	Peak	788	7/9	79	67	78.0	56.3	802	19,369	3,640	7 /10	81	68	56.3	778	22,126	6,762
	412 Grade 1 NE	Peak	796	7/10	81	68	78.0	56.3	817	19,741	3,920	7 /12	86	70	56.3	709	21,924	8,936
	405 Staff Lunch/Conference W	Peak	588	7/17	88	72	78.0	56.3	863	20,844	5,880	7 /16	89	73	56.3	850	26,857	13,480
	407 Grade 1 NW	Peak	843	7/18	86	72	78.0	56.3	891	21,521	3,220	7 /18	86	72	56.3	891	27,316	10,714
	305 Supervisory Office W	Peak	180	7/17	88	72	78.0	56.3	347	8,375	140	7 /16	89	73	56.3	339	10,675	3,194
	307 Kindergarten NW	Peak	921	7/18	86	72	78.0	56.3	844	20,380	3,220	7 /18	86	72	56.3	844	26,000	10,316
	310 Kindergarten NE	Peak	936	7/10	81	68	78.0	56.3	896	21,649	3,360	7 /10	81	68	56.3	896	25,489	6,849
	308 Kindergarten E	Peak	917	7/9	79	67	78.0	56.3	894	21,588	3,220	7 /10	81	68	56.3	857	24,562	6,699
	210 Pre-K NE	Peak	936	7/10	81	68	78.0	56.3	896	21,649	3,360	7/10	81	68	56.3	896	25,489	6,849
	208 Pre-K E	Peak	923	7/9	79	67	78.0	56.3	895	21,623	3,220	7/10	81	68	56.3	859	24,594	6,705
	205 Reading/Speech Resorce V	/ Peak	540	7/17	88	72	78.0	56.3	1,006	24,304	3,920	7 /16	89	73	56.3	990	31,098	12,782
	207 Kindergarten NW	Peak	921	7/18	86	72	78.0	56.3	843	20,375	3,220	7/18	86	72	56.3	843	25,993	10,315
	109 Exersize Rm NW	Peak	1,268	7/17	88	72	78.0	56.3	1,080	26,083	3,920	7 /16	89	73	56.3	1,064	34,098	13,430
	Basement Corridor	Peak	545	6/20	79	64	78.0	56.3	152	3,668	280	7/15	89	73	56.3	150	5,137	1,585
AHU-2		Peak	14,576		88	72	78.0	56.3	14,028	338,870	52,640		89	73	56.3	13,615	462,491	149,127
AHU-2		Block	14,576	7/17	88	72	78.0	56.3	11,862	286,557	52,640	7 /16	89	73	56.3	11,620	381,297	176,197

Project Name: PS-347X Dataset Name: G:\756 - PS-33X\M\Heating & Cooling Calculations\PS-347X AHU-2 Classroom.trc TRACE® 700 v6.0 calculated at 03:06 PM on 04/26/2018 Alternative - 1 Peak Clg Loads Main System Report Page 1 of 1

PEAK HEATING LOADS

MAIN SYSTEM

By DVL

ĺ	OA Condition DB WB					SPAC	CE		COIL	
System	Peak Time 'F 'F Htg Design 11 7	Block or Peak	Floor Àrea ft²	Room Dry Bulb °F	Supply Dry Bulb °F	Space Air Flow cfm	Space Sensible Load Btu/h	Supply Dry Bulb °F	Coil Air Flow cfm	Coil Sensible Load Btu/h
-,	5 Electr Certifor	Peak	997	72.0	72.0	0	-1,718	72.0	0	-7,079
	505 CSD Spec Education W	Peak	637	72.0	72.0	0	-4,484	72.0	0	-15,499
	507 Grade 2 NW	Peak	843	72.0	72.0	0	-4,783	72.0	0	-14,913
	4 Floor Corridor	Peak	997	72.0	72.0	0	-1,718	72.0	0	-7,079
	410 Grade 1 E	Peak	788	72.0	72.0	0	-3,038	72.0	0	-12,154
	412 Grade 1 NE	Peak	796	72.0	72.0	0	-3,985	72.0	0	-13,277
	405 Staff Lunch/Conference W	Peak	588	72.0	72.0	0	-3,300	72.0	0	-13,111
	407 Grade 1 NW	Peak	843	72.0	72.0	0	-4,783	72.0	0	-14,913
	305 Supervisory Office W	Peak	180	72.0	72.0	0	-2,164	72.0	0	-6,106
	307 Kindergarten NW	Peak	921	72.0	72.0	0	-4,794	72.0	0	-14,386
	310 Kindergarten NE	Peak	936	72.0	72.0	0	-5,299	72.0	0	-15,489
	308 Kindergarten E	Peak	917	72.0	72.0	0	-4,350	72.0	0	-14,511
	210 Pre-K NE	Peak	936	72.0	72.0	0	-5,299	72.0	0	-15,489
	208 Pre-K E	Peak	923	72.0	72.0	0.0	-4,351	72.0	0	-14,529
	205 Reading/Speech Resorce W	Peak	540	72.0	72.0	0	-4,471	72.0	0	-15,910
	207 Kindergarten NW	Peak	921	72.0	72.0	0	-4,781	72.0	0	-14,371
	109 Exersize Rm NW	Peak	1,268	72.0	72.0	0	-5,659	72.0	0	-17,935
	Basement Corridor	Peak	545	72.0	72.0	0	-74	72.0	0	-1,800
AHU-2		Peak	14,576	72.0	72.0	0	-69,052	72.0	0	-228,550
AHU-2		Block	14,576	72.0	72.0	0	-69,050	72.0	0	-228,548

Project Name: PS-347X Dataset Name: G:\756 - PS-33X\M\Heating & Cooling Calculations\PS-347X AHU-2 Classroom.trc

TRACE® 700 v6.0 calculated at 03:06 PM on 04/26/2018 Alternative - 1 Peak Htg Loads Main System Report Page 1 of 1

System Checksums By DVL

AHU-3

VAV w/Baseboard Heating

	COOLING	COIL PEAK	ĸ		CLG SPAC	E PEAK	C		HEATING C	OIL PEAK		TEMP	ERATUR	ES	
Peaked	d at Time: utside Air:	M OADB/WB	o/Hr: 7 / 15 //HR: 89 / 73 /	96	Mo/H OADE	n:8/9 1:77			Mo/Hr: OADB:	Heating Desig 11	n	SADB Plenum	Cooling 56.3 75.5	Heati 7 7	ing 2.0 1.2
	Space Sens. + Lat. Btu/h	Plenum Sens. + Lat Btu/h	Net Total Btu/h	Percent Of Total (%)	Space Sensible Btu/f	Percent Of Total (%)			Space Peak Space Sens Btu/h	Coil Peal Tot Sens Btu/t	c Percent s Of Total n (%)	Return Ret/OA Fn MtrTD	76.5 82.9 0.1	7	1.2 1.0 0.0
Envelope Loads Skylite Solar Skylite Cond Roof Cond	000	0 0 0	0 0 0	0 0 0			Skylite Skylite Roof C	Solar Cond ond	0		0.00	Fn Frict	0.9		0.0
Glass Solar Glass Cond Wall Cond Partition	7,200 2,677 526	0 0 429	7,200 2,677 955 0	· 1 1 0	27,962 342 605	2 28 2 0 5 1 0 0	Glass 6 Glass 0 Wall Co Partitio	Solar Cond ond n	0 -12,072 -911 0	-12,072 -1,654	0 0.00 2 10.80 4 1.48 0 0.00	All	RFLOWS	Heati	ina
Exposed Floor Infiltration	0 0 10 403	429	0 0 10 832	0	28.909) 0) 0	Expose Infiltrati Sub To	d Floor ion tal ==>	0 0 -12,983	((-13,72)	0 0.00 0 0.00 7 12.28	Vent Infil Supply	2,000 0 4,793	nouu	0
Internal Loads	0,400		10,002		0.200		Internal L	_oads	0			MinStop/Rh Return Exhaust	0 4,793 2,000		0
Lights People Misc	8,380 55,370 31,200	2,095	10,475 55,370 31,200	29 16	30,870 31,200	31	People Misc	to/>	000		0.00	Rm Exh Auxiliary	0		0
Sub Total ==> Ceiling Load	94,950	-461	97,045 0 75.997	0 40	399		Ceiling L	oad	-743	(0.00	ENGIN	EERING	скѕ	
Ventilation Load Dehumid. Ov Siz Ov/Undr Sizing Exhaust Heat Sup. Fan Heat Ret. Fan Heat Duct Heat Pkup	cing 0	-3,427 4,630 0	75,997 0 -3,427 5,788 4,630 0	40 0 -2 3 2	c	0 0	Ov/Undr Exhaust I OA Prehe RA Prehe Additiona	Sizing Heat eat Diff. eat Diff. al Reheat	ŏ	-98,097 (0 (0	0 0.00 0 0.00 7 87.72 0 0.00 0 0.00	% OA cfm/ft² cfm/ton ft²/ton Btu/hr·ft²	Cooling 41.7 1.56 301.34 192.95 62.19	Heati 0. -36.	0.0 .00
Reheat at Desigr Grand Total ==>	105,813	3,267	0 190,865	0 100.00	99,758	100.00	Grand To	otal ==>	-13,727	-111,823	3 100.00	No. People	147		
Tr t	otal Capacity on MBh	COOLING Sens Cap. MBh	Coil Airflow	ECTIO Enter I	N DB/WB/HR °F gr/lb	Leave D	B/WB/HR °F gr/lb		AREAS Gross Total	Glass ft² (%)	HEA	Capacity C MBh	SELECTI coil Airflow	ON Ent °F	Lvg °F
Main Clg 15 Aux Clg 0 Opt Vent 0	5.9 190.9 0.0 0.0 0.0 0.0	121.6 0.0 0.0	3,906.8 0 0	82.9 0 0.0	68.3 80.7 0 0 0.0 0.0	55.0 5 0 0.0	2.7 55.8 0 0 0.0 0.0	Floor Part ExFlr	3,069 0 0		Main Htg Aux Htg Preheat	-13.7 0.0 -98.1	0.0 0 2,000	0.0 0 11	0.0 0 55
Total 15	5.9 190.9							Roof Wall	0 955	0 0 468 49	Humidif Opt Vent <i>Total</i>	0.0 0.0 -111.8	0	0.0 0.0	0.0 0.0

Project Name: PS-347X Dataset Name: G:\756 - PS-33X\M\Heating & Cooling Calculations\PS-347X AHU-3 Dining.trc TRACE® 700 v6.0 calculated at 03:15 PM on 04/26/2018 Alternative - 1 System Checksums Report Page 1 of 1

PEAK COOLING LOADS

MAIN SYSTEM

By DVL

				SPACE					COIL								
				0	A	Room	Supply	Space	Space	Space		C	A			Coil	Coil
		Floor	Peak	Cond	dition	Dry	Dry	Air	Sensible	Latent	Peak	Cond	lition	Supply	Coil	Sensible	Latent
		Area	Time	DB	WB	Bulb	Bulb	Flow	Load	Load	Time	DB	WB	Dry Bulb	Airflow	Load	Load
System Zone Room		ft²	Mo/Hr	°F	°F	°F	°F	cfm	Btu/h	Btu/h	Mo/Hr	°F	°F	۴F	cfm	Btu/h	Btu/h
102 Dining Area SE	Peak	1,960	8/9	77	64	75.0	56.3	3,071	63,915	19,600	7 /15	89	73	56.3	2,184	73,583	53,189
Kitchen	Peak	1,109	7/12	86	70	75.0	56.3	2,000	41,626	4,900	7 /16	89	73	56.3	2,000	48,506	16,352
AHU-3	Peak	3,069		77	64	75.0	56.3	5,071	105,542	24,500		89	73	56.3	4,184	122,062	69,541
AHU-3	Block	3,069	8/9	77	64	75.0	56.3	4,793	99,758	24,500	7 /15	89	73	56.3	3,907	121,580	69,285

Project Name: PS-347X Dataset Name: G:\756 - PS-33X\M\Heating & Cooling Calculations\PS-347X AHU-3 Dining.trc TRACE® 700 v6.0 calculated at 03:15 PM on 04/26/2018 Alternative - 1 Peak Clg Loads Main System Report Page 1 of 1

PEAK HEATING LOADS

MAIN SYSTEM

By DVL

OA Condition DB WB					SPAC	E		COIL	
Htg Design 11 7	Block or Peak	Floor Area ft²	Room Dry Bulb °F	Supply Dry Bulb °F	Space Air Flow cfm	Space Sensible Load Btu/h	Supply Dry Bulb °F	Coil Air Flow cfm	Coil Sensible Load Btu/h
102 Dining Area SE Kitchen	Peak Peak	1,960 1,109	72.0 72.0	72.0 72.0	0	-13,458 -269	72.0 72.0	0	-13,458 -269
AHU-3 AHU-3	Peak Block	3,069 3,069	72.0 72.0	72.0 72.0	0 0	-13,727 -13,727	72.0 72.0	0	-13,727 -13,727

Project Name: PS-347X Dataset Name: G:\756 - PS-33X\M\Heating & Cooling Calculations\PS-347X AHU-3 Dining.trc TRACE® 700 v6.0 calculated at 03:15 PM on 04/26/2018 Alternative - 1 Peak Htg Loads Main System Report Page 1 of 1 Credit Q1.1P: ASHRAE Outdoor Air Assessment



AKRF Engineering, P.C. Environmental and Engineering Consultants 440 Park Avenue South 7th Floor New York, NY 10016 tel: 212 696-0670 www.akrf.com

May 10, 2018

Mr. Bob Kanaparthi Industrial Hygienist, IEH Division New York City School Construction Authority 30-30 Thomson Avenue Long Island City, NY 11101

Re: ASHRAE Outdoor Air Assessment Proposed P.S. 33X Annex (X347) 2424 Jerome Avenue, Bronx, NY 10468 NYCSCA LLW # 107340; Service ID 68562 AKRF Project No. 80619.46

Dear Mr. Kanaparthi:

At the request of the New York City School Construction Authority (NYCSCA), AKRF Engineering, P.C. (AKRF) conducted an American Society of Heating, Refrigeration, and Air Conditioning Engineers (ASHRAE) outdoor air assessment for the site of the proposed new annex (X347) to P.S. 33X, located at 2424 Jerome Avenue in the Fordham neighborhood of the Bronx (the "Site"). The assessment was conducted in accordance with the ASHRAE Standard 62.1-2016 (Standard) Section 4.0: Outdoor Air Quality. The assessment was conducted to satisfy the New York City Department of Education/NYCSCA Green Schools Guide Credit Q1.1 R: Minimum IAQ Performance/Increased Ventilation. The assessment consisted of a qualitative evaluation of regional and local air quality, and did not include air sampling, modeling, or other detailed analysis.

Regional Air Quality Compliance Status

Criteria Air Pollutants are those substances for which a National Ambient Air Quality Standard (NAAQS) has been established, as provided in the Clean Air Act. The following table contains a summary of criteria pollutant information for Bronx County provided by the U.S. Environmental Protection Agency's (USEPA) Green Book Non-attainment Areas for Criteria Pollutants website.

			Regional Outdoor	Air Quality Po	llutants		
	Particulates (PM2.5)	Particulates (PM10)	Carbon Monoxide – 1 hour/8 hours	Ozone 8-hour	Nitrogen Dioxide	Lead	Sulfur Dioxide
Attainment Status	Attainment	Attainment	Attainment	Non- attainment	Attainment	Attainment	Attainment

In April 2016, as requested by New York State, USEPA reclassified New York City as a moderate nonattainment area for ozone. Areas classified as moderate non-attainment have 8-hour ozone design value concentrations ranging from 0.086 to 0.100 parts per million (ppm).

New York City • Hudson Valley Region • Long Island

Local Survey

Date and Time of Observation

Visual inspection of the Site and adjacent areas was performed on April 4, 2018 by Jacob Menken of AKRF at approximately 10:30 AM.

2

Site Description

The Site is an approximately 12,300-square foot (SF) asphalt-paved play yard with a track and playground equipment. The Site is being redeveloped by the NYCSCA as an annex for the north-adjacent P.S. 33X. At the time of the inspection, there were no visibility impairments, with weather conditions consisting of overcast skies, 45°F and light winds out of the southeast. AKRF conducted a visual survey of the properties within an approximately 500-foot radius the Site perimeter to inspect for potential point sources of air emissions.

Description of Nearby Facilities

The surrounding properties are a mix of commercial, educational, and residential uses. The Site is bounded to the north by the main P.S. 33X school building, to the south by the existing P.S. 33X annex building (X939), to the east by Walton Avenue, residential properties and a church, and to the west by Jerome Avenue and elevated subway tracks, followed by residential and commercial properties, including a surface parking lot and auto repair shop. A gas station was noted on the south-adjacent block, approximately 500 feet to the south.

Observation of Odors, Irritants, Visible Plumes or Air Contaminants

No odors, irritants, visible plumes or air contaminants were noted during the survey.

Description of Nearby Sources of Vehicle Exhaust

Jerome Avenue, which is a minor arterial roadway with moderate traffic flow, runs north-south, adjacent to the western Site boundary. West Fordham Road, a principal arterial roadway located approximately 450 feet north of the Site, is the nearest roadway with heavy traffic flow.

Description of Nearby Point Sources

Based on a review of USEPA Envirofacts Air Facility System (AFS) database (<u>https://www.epa.gov/enviro/icis-air-search</u>) the following facilities, located within approximately 1,000 feet of the Site, are potential point sources of air emissions:

		Distance		
Site Name	Address	Site	Air Program Information	Notes
Fordham Auto Plus Inc.	2409 Jerome Avenue Bronx, NY 10468	~180 feet	CAASIP ⁱ (Operating)	Minor Emissions
2400 Walton Avenue Building	2400 Walton Avenue Bronx, NY 10468	~220 feet	CAASIP ² (Operating) Title V Permits (Permanently Closed)	Minor Emissions
NYC-HPD 2410 Davidson Ave	2410 Davidson Avenue Bronx, NY 10468	~240 feet	CAASIP ⁱ (Operating)	Minor Emissions
2400 Davidson Avenue Building	2400 Davidson Avenue Bronx, NY 10468	~280 feet	CAASIP ⁱ (Operating)	Minor Emissions
Amoco 65425671005	2350 Jerome Avenue Bronx, NY 10468	~500 feet	CAASIP ⁱ (Operating)	Minor Emissions
2386 Morris Avenue Building	2386 Morris Avenue Broux, NY 10468	~530 feet	CAASIP ⁱ (Operating)	Minor Emissions
Kleener King	2439 Creston Avenue Bronx, NY 10468	~640 feet	CAASIP ¹ (Operating) CAAMACT (Operating-Perchloroethene)	Minor Emissions
Gaseteria-North Street	2318 Jerome Avenue Bronx, NY 10468	~700 feet	CAASIP ¹ (Operating)	Minor Emissions

¹CAASIP = Clean Air Act State Implementation Plan for National Primary and Secondary Ambient Air Quality Standards ²CAAMACT = MACT Standards (40 CFR Part 63)

Discussion and Conclusions

In order to determine the acceptability of outdoor air, the nearby facilities identified during the assessment were evaluated against the following screening criteria¹:

3

- Large parking facilities or parking garage exhaust vents adjacent to the Site;
- An atypical (e.g., not at-grade) source of vehicular pollutants, such as a highway or bridge, within 200 feet of the Site;
- A major or large emission source within 1,000 feet of the Site;
- A medical, chemical, or research lab within 400 feet of the Site;
- Manufacturing or processing facilities within 400 feet of the Site; and
- A facility with a New York State Department of Environmental Conservation (NYSDEC) air facility registration within 200 feet the site.

Based on this evaluation and the findings of the local survey, the following source may affect the acceptability of the outdoor air quality at the Site:

 Fordham Auto Plus, an auto repair shop and NYSDEC air registration facility located approximately 180 feet (across Jerome Avenue) from the Site.

Therefore, AKRF recommends conducting further evaluation of emissions from this source to determine whether additional design measures beyond the standard NYCSCA requirements should be incorporated into the HVAC system design for the new annex. Please feel free to contact me at (914) 922-2362 with any questions or concerns.

Sincerely,

Rebecca A. Kinal, P.E Vice President/Project Manager

¹ Based on guidance for evaluation of air quality in the City Environmental Quality Review Technical Manual (New York City Mayor's Office of Environmental Coordination, March 2014).

Credit Q1.1P: CFD modeling



PS 347X – Outdoor Air Intake Quality for GSG Prerequisite Q1.1P and LEED v4 EQp1

September 24, 2018

Prepared for: New York City School Construction Authority Prepared by: Vidaris, Inc.

Vidaris, Inc. 360 Park Avenue South, 15th Floor New York, New York 10010 T: 212.689.5389 F: 212.689.6449

www.vidaris.com

TABLE OF CONTENTS

Introduction	1
EPA Non-Attainment Areas and Impact on HVAC Design	2
Local Pollutant Review	2
CFD Analysis	4
Purpose of study	4
Model information	4
Domain	4
Boundary Conditions	6
Results	7
Summary	7
Parametric Runs	10
QUALIFICATION OF RESULTS	11
APPENDIX A: ASHRAE OUTDOOR AIR ASSESSMENT REPORT	12
APPENDIX B: SOURCE OF POLLUTANTS – AUTO BODY SHOP	15
APPENDIX C: SOURCE OF POLLUTANTS - TRAFFIC	18
APPENDIX D: MODEL CONVERGENCE	21

TABLE OF FIGURES

Figure 1 Map showing PS347X and a circle of radius 0.3 miles4
Figure 2 347X and neighboring structures in the CFD model5
Figure 3 Close-up of the school and HVAC units5
Figure 4 Wind Speed profile for areas exposed to wind flowing over water per chapter 24, ASHRAE
Fundamentals 2017. Referenced wind speed is measured 33 feet above the ground: 2 mph, 7.5mph, 22.5 mph.
Figure 5 Plot of VOCs at 500 μg/m³ concentration colored by speed, High Risk Conditions8
Figure 6 Vertical section at school; Plot of VOC concentration, High Risk Conditions
Figure 7 Horizontal section at inlet of AHUs-1,2,3; Plot of VOC concentration, High Risk Conditions
Figure 8 Plot of Residuals of pollutant concentration vs Iteration

Introduction

PS 33X is an existing public school located at 2424 Jerome Avenue, Bronx, New York. A new addition to the adjacent to the existing building is being designed for the New York City School Construction Authority (NYC SCA). The purpose of this analysis is to show that the outdoor air being delivered to the new building occupants meets the minimum requirements of

- a) Section 4 of ASHRAE 62.1-2007, as required by 2016 Green Schools Guide (GSG) Prerequisite Q1.1P, "Minimum IAQ Performance", and
- b) Section 4 of ASHRAE 62.1-2010, as required by LEED Building Design and Construction v4 (LEED) Prerequisite EQp1, "Minimum IAQ Performance".

Other requirements of the prerequisite are not part of this scope.

Per the prerequisite requirements, the SCA Indoor and Environmental Health (IEH) Unit conducted a site investigation and research during Design Development. For this project, NYC SCA retained AKRF Engineering to prepare an ASHRAE Outdoor Air Assessment Report. The assessment consisted of a qualitative evaluation of regional and local air quality, and did not include air sampling, modeling, or other detailed analysis.

Based on the ASHRAE Outdoor Air Assessment dated May 10, 2018¹, the SCA is concerned that emissions from an auto body shop located nearby can affect the air quality in the school. A copy of the assessment is included in Appendix A.

Vidaris was retained by NYC SCA to conduct computational fluid dynamic (CFD) modeling to estimate the concentrations of pollutants at the outdoor air intake of the school based on this source to determine compliance with GSG and LEED criteria². The concentrations are compared to the EPA criteria pollutants, per ASHRAE 62.1-2007.

Since fluid flow behavior is difficult to predict over a varied topography, Vidaris analyzed different wind speeds and directions. Based on the CFD modeling, no special filters are required to meet the outdoor air quality requirements of ASHRAE 62.1-2007.

¹ ASHRAE Outdoor Air Assessment for Proposed PS 33X Annex (X347) by AKRF Engineering, P.C.

² The NYC SCA Green Schools Guide 2016 specifies that the SCA/IEH Unit conducts site investigation and research during Design Development. It is the responsibility of the architect of record or the engineer of record to submit an IEH outdoor air analysis report, and a narrative summarizing the design approach for credit compliance and identifying applicable SCA standards to be incorporated into the design documents. The proposed ventilation system design is to be described, noting any special considerations relating to compliance.

EPA Non-Attainment Areas and Impact on HVAC Design

The first step in considering the effect of site conditions is to check for the status under the Clean Air Act, as determined by the EPA.

The project is located in the Bronx, New York City. On 5/14/16, New York City was defined as a "Moderate ozone non-attainment" area with a 2012-2014 design value of 0.085 ppm and a 2014 4th highest daily maximum 8-hour average of 0.081 ppm. This is less than the 0.107 ppm level where LEED currently recommends employment of air filtration/cleaning to address ozone. Thus, for LEED v4 purposes, special carbon/sorbent filters are not required for ozone mitigation.

According to the ASHRAE Outdoor Air Assessment dated May 10, 2018, the project is not located in an area classified by the EPA as Non-Attainment for Particulate Matter (PM₁₀) and the project is not in a non-attainment area for nitrogen dioxide, sulfur dioxide and lead.

Based on the EPA status for this project region, which does not consider local pollutant sources, no special filtration is required to meet the requirements of ASHRAE 62.1-2007.

Local Pollutant Review

The proposed annex will be located approximately 180 feet from Fordham Auto Plus, an auto body shop. Auto body shops emit volatile organic compounds (VOCs) that are present in the paint solvents and thinners. Emissions from the auto body shop were calculated based on reviewing the materials used to paint vehicles.

Vidaris selected a combination of typical primer, basecoat and clear coat by Nexa Auto Color and reviewed their technical specification document to find out the amount of VOCs present in the paints. An average car requires 3 quarts of primer, 3 quarts of basecoat and 2 quarts of clearcoat. Vidaris assumed that all three coats are applied in an hour. This assumption is conservative since, in reality, this process takes several hours. Please see Appendix B for detailed technical specifications of the paints and calculations for VOCs. Vidaris also assumed that all 7 paint stations in the auto body shop are being used continuously during the peak hour.

New York State Department of Environmental Conservation requires that filters achieving 98% capture efficiency be installed on the exhaust of all spray operations³. This analysis assumes that the filers are only 90% efficient.

The proposed site for the annex is also located on Jerome Avenue. Emissions from vehicles were calculated using California's Emissions Factor Inventory (EMFAC2014)⁴ and NYSERDA's Inventory of Light Vehicles on New York Roads in 2015. The rate of emissions increases with a decrease in vehicle speed. Moreover, at higher speed the car density is lower because the vehicles must keep a greater distance.

³ Environmental Compliance Guide for Auto Body Shops by NYSDEC; December 2009

⁴ EMFAC2014 gives data on emissions factors (ROG, TOG, CO, NOX, CO2, PM10, PM2.5) based on vehicle speed and type.

To find the average low speed for vehicles, data from NYC DOT was used. The speed limit on Jerome Avenue is 25 mph³. The NYC DOT Mobility Report of October 2016 shows that the average bus speed on Jerome Avenue near the proposed site during evening rush hours (4PM-6PM) is 2-8 mph⁶. Hence 5 mph as the low speed for all vehicles is a reasonable average over a year. An aggregated data for emissions from all vehicle types running at 5 mph was used.

Based on the road length, number of lanes and vehicle distance at 5 mph in the region, a total vehicle population of 136 was estimated. Using the NYSERDA inventory, the Vehicle Miles Travelled was obtained for a total population of 136 vehicles. This was combined with the EMFAC2014 data to get the rate of pollution. Additional information about the pollutant sources and calculations is given in Appendix C.

The average pollution rate by pollutant type is summarized below.

Emissions from	Emissions from	Total Emissions (g/hr)
Jerome Avenue	Fordham Auto	
(g/hr)	Plus (g/hr)	
251	2754	3005
342	0	342
2812	0	2812
267	0	267
800396	0	800396
10	0	10
9	0	9
	Emissions from Jerome Avenue (g/hr) 251 342 2812 267 800396 10 9	Emissions from Jerome Avenue (g/hr)Emissions from Fordham Auto Plus (g/hr)25127543420281202670800396010090

Table 1 Rate of Emissions

The pollution in the ambient air was modeled as below, using data from NYSDEC and NOAA (see footnotes).

Table 2 Pollution III Ambient Air								
Pollutant								
ROG/VOC ⁷	12.94	ppb						
CO ⁸	1.86	ppm						
PM10 ⁸	32	μg/m³						
PM2.58	10.3	μg/m³						
CO2 ⁹	404	ppm						

Table 2 Pollution in Ambient Air

Target chemicals such as formaldehyde and others listed in CDPH Standard Methodv1.1, Table 1-4 were not modeled individually.

⁵ http://www.nyc.gov/html/dot/downloads/pdf/current-pre-vision-zero-speed-limit-maps.pdf

⁶ http://www.nyc.gov/html/dot/downloads/pdf/mobility-report-2016-screen-optimized.pdf

⁷ https://www.dec.ny.gov/chemical/23781.html

⁸ http://www.dec.ny.gov/docs/air_pdf/2016airqualreport.pdf

⁹ ftp://aftp.cmdl.noaa.gov/products/trends/co2/co2_annmean_gl.txt

CFD Analysis

Purpose of study

The computational fluid dynamic (CFD) analyses performed to ascertain the possibility of pollution contamination in and around the outside air intake caused by emissions from Fordham Auto Plus and traffic on Jerome Avenue.

Model information

<u>Domain</u>



Figure 1 Map showing PS347X and a circle of radius 0.3 miles

Vidaris modeled the building and surrounding topography and neighboring structures within radius of 0.3 miles. The neighboring structures were modeled with a simplified geometry, created by extracting data from Google Earth. The school has 3 air handling units (AHUs) located on the roof. All the units have an outside air intake louver.



Figure 2 347X and neighboring structures in the CFD model



Figure 3 Close-up of the school and HVAC units

Vidaris, Inc.

Boundary Conditions

The following boundary conditions were used:

- Outdoor air temperature: 15 °F, 89F
- Wind speeds at standard reference point: 2 mph, 7.5mph and 22.5 mph
- Wind orientations: North, South, West, East
- Emissions at steady rate as described in Table 1

The model does not account for infiltration /exfiltration through the building envelope. It focuses on pollutant levels at the OA intakes.

The outdoor air temperature was based on the heating design temperature for NYC from Table D-1 of ASHRAE 90.1.

The standard reference point for wind speed measurements is of 33 ft (10 m) above the ground. The wind speed profile with respect to distance above ground as shown on following figure.



Figure 4 Wind Speed profile for areas exposed to wind flowing over water per chapter 24, ASHRAE Fundamentals 2017. Referenced wind speed is measured 33 feet above the ground: 2 mph, 7.5mph, 22.5 mph.

Results

Summary

The model shows that the pollution levels at the AHU inlets are below the maximum allowed threshold.

Vidaris performed preliminary modeling runs to determine the combination factors which result in the highest risk for contaminants at the inlet of the RTU's. Based on the parametric runs, the risk of contaminants is highest under the following conditions:

- Outdoor air temperature: 89 °F
- Wind speeds at standard reference point: 7.5 mph
- Wind orientation: 65 degrees

Additional information on the parametric runs is provided later in this section. The contaminant levels at the inlet to the AHUs for this condition are summarized in Table 3.

	Concentration at				
Pollutant	Inlet of	Inlet of	Inlet of		
	AHU-1	AHU-2	AHU-3		
CO (ppm)	2.0	1.9	1.9		
PM10	33.2	33.0	32.7		
(µg/m³)					
PM2.5	10.7	10.6	10.5		
(µg/m³)					
VOC	432.3	417.7	244.5		
(µg/m³)					
CO2	419.1	416.3	413.4		
(ppm)					

Table 3 Concentration of Pollutants at RTU inlets for Highest Risk Case, 7.5 mph wind, Summer

The concentrations of individual pollutants were compared against the LEED maximum levels for Indoor Air Quality Assessment.

Pollutant	At inlet of MAU-3	LEED maximum
VOC	432.3 μg/m³	500 μg/m³
со	2.0 ppm	9 ppm
PM10	33.2 μg/m³	50 μg/m³
PM2.5	10.7 μg/m³	15 μg/m³

Table 4 Breakdown of pollutants for Highest Risk Case, 7.5 mph wind, Summer

The CFD analysis indicates that based on the assumed pollution emissions, the surrounding air meets the air quality requirements of Section 4 of ASHRAE 62.1-2007 and ASHRAE 62.1-2010, necessary for GSG and LEED compliance.



Figure 5 Plot of VOCs at 500 μ g/m³ concentration colored by speed, High Risk Conditions



Figure 6 Vertical section at school; Plot of VOC concentration, High Risk Conditions 0.4 PPM equals to 500 $\mu\text{g/m3}$



Figure 7 Horizontal section at inlet of AHUs-1,2,3; Plot of VOC concentration, High Risk Conditions 0.4 PPM equals to 500 μ g/m³

Parametric Runs

Wind Direction

Initially, all four wind orientations (North, South, West, East) were considered. Wind blowing at 65 degrees (straight line from the auto body shop to the school addition) should carry the maximum amount of pollutants to the school. This can also be seen when the map of the area is visually inspected – Fordham Auto plus lies to the north-east of the school addition and that is where most of the pollutants originate. Wind direction was not studied beyond the preliminary stage.

Wind Speed

Three wind speeds (2 mph, 7.5 mph and 22.5 mph) were modeled. Based on the results obtained, it was observed that wind speeds of 7.5 mph lead to much higher concentration of pollutants at one or more of the AHU inlets. The following results were observed:

- Wind speed of 2 mph does not have enough energy to reach over the taller building behind the auto body shop -- and then to pull with much force the pollutants towards to school
- Wind speed of 7.5 mph leads to the highest concentration of pollutants, which was observed at the inlet to AHU-1.
- The 22.5 mph wind speed dissipates the pollutants.

	Concentration of VOC in Summer conditions (PPM)			
Wind Speed	Inlet of AHU-1	Inlet of AHU-2	Inlet of AHU-3	
2 mph	135.2	198.5	209.8	
7.5 mph	432.3	417.7	244.5	
22.5 mph	183.1	181.2	85.8	

Table 5 Results for different wind speed (wind blowing at 65 degrees)

Vidaris, Inc.

Page 11

QUALIFICATION OF RESULTS

In general, CFD analyses are a simplified representation of reality. There are limitations regarding how close a computer model can predict reality. These limitations stem from the capabilities of the software, the simplifications in the model, and the fact that real-life construction and operation is imperfect.

- "Computational fluid dynamics (CFD) models attempt to resolve airflow around buildings by solving the Navier-Stokes equations at finite grid locations.
- CFD models are currently used to model internal flows, but are insufficient to accurately model atmospheric turbulence. (24.10 2009 ASHRAE Handbook—Fundamentals)"
- "Based on the current state of the art, CFD models should be used with extreme caution when modeling exhaust plumes from laboratory pollutant sources. Currently, CFD models can both over- and under predict concentration levels by orders of magnitude, leading to potentially unsafe designs. If a CFD study is conducted for such an application, supporting full-scale or wind tunnel validation studies should be carried out. (45.10 2011 ASHRAE Handbook—HVAC Applications)"
- "Measurements on small-scale models in wind tunnels or water channels can provide information for design before construction. These measurements can also be used as an economical method of performance evaluation for existing facilities. (24.10 2009 ASHRAE Handbook—Fundamentals)"

APPENDIX A: ASHRAE OUTDOOR AIR ASSESSMENT REPORT

New York City Public School PS 33X Energy Model Report

Credit Q1.1P: ASHRAE Outdoor Air Assessment



May 10, 2018

Re:

Mr. Bob Kanaparthi Industrial Hygnenist, IEH Division New York City School Construction Authority 30-30 Thomson Avenue Long Island City, NY 11101

> ASHRAE Outdoor Air Assessment Proposed P.S. 33X Annex (X347) 2424 Jerome Avenue, Bronx, NY 10468 NYCSCA LLW # 107340; Service ID 68562 AKRF Project No. 80619.46

Dear Mr. Kanaparthi:

At the request of the New York City School Construction Authority (NYCSCA), AKRF Engineering, P.C. (AKRF) conducted an American Society of Heating, Refrigeration, and Air Conditioning Engineers (ASHRAE) outdoor air assessment for the site of the proposed new annex (X347) to P.S. 33X, located at 2424 Jerome Avenue in the Fordham neighborhood of the Broax (the "Site"). The assessment was conducted in accordance with the ASHRAE Standard 62.1-2016 (Standard) Section 4.0: Outdoor Air Quality. The assessment was conducted to satisfy the New York City Department of Education/NYCSCA Green Schools Guide Credit Q1.1 R: Minimum IAQ Performance/Increased Ventilation. The assessment consisted of a qualitative evaluation of regional and local air quality, and did not include air sampling, modeling, or other detailed analysis.

Regional Air Quality Compliance Status

Criteria Air Pollutants are those substances for which a National Ambient Air Quality Standard (NAAQS) has been established, as provided in the Clean Air Act. The following table contains a summary of criteria pollutant information for Bronx County provided by the U.S. Environmental Protection Agency's (USEPA) Green Book Non-attainment Areas for Criteria Pollutants website.

	Regional Outdoor Air Quality Pollutants						
	Particulates (PM2.5)	Particulates (PMI0)	Carbon Monozide - 1 hour:8 hours	Ozone 8-hour	Nitrogen Diszide	Lead	Sulfur Dioxide
Attainment Status	Attainment	Attainment	Attainment	Non- attainment	Attainment	Attainment	Amainment

In April 2016, as requested by New York State, USEPA reclassified New York City as a moderate nonattainment area for ozone. Areas classified as moderate non-attainment have 8-hour ozone design value concentrations ranging from 0.086 to 0.100 parts per million (ppm).

New York City . Hudson Valley Region . Long Island

Page 317 of 371

new FOR City rubbe school rs 55A Energy bloder Report

Proposed P.S. 33X Annex (X347) 2 May 10, 2018

Local Survey

Date and Time of Observation

Visual inspection of the Site and adjacent areas was performed on April 4, 2018 by Jacob Menken of AKRF at approximately 10:30 AM.

Site Description

The Site is an approximately 12,300-square foot (SF) asphalt-paved play yard with a track and playground equipment. The Site is being redeveloped by the NYCSCA as an annex for the north-adjacent P.S. 33X. At the time of the inspection, there were no visibility impairments, with weather conditions consisting of overcast skies, 45°F and light winds out of the southeast. AKRF conducted a visual survey of the properties within an approximately 500-foot radius the Site perimeter to inspect for potential point sources of air emissions.

Description of Nearby Facilities

The surrounding properties are a mix of commercial, educational, and residential uses. The Site is bounded to the north by the main P.S. 33X school building, to the south by the existing P.S. 33X annex building (X939), to the east by Walton Avenue, residential properties and a church, and to the west by Jerome Avenue and elevated subway tracks, followed by residential and commercial properties, including a surface parking lot and auto repair shop. A gas station was noted on the south-adjacent block, approximately 500 feet to the south.

Observation of Odors, Irritants, Visible Plumes or Air Contaminants

No odors, irritants, visible plumes or air contaminants were noted during the survey.

Description of Nearby Sources of Vehicle Exhaust

Jerome Avenue, which is a minor arterial roadway with moderate traffic flow, runs north-south, adjacent to the western Site boundary. West Fordham Road, a principal arterial roadway located approximately 450 feet north of the Site, is the nearest roadway with heavy traffic flow.

Description of Nearby Point Sources

Based on a review of USEPA Envirofacts Air Facility System (AFS) database (https://www.epa.gov/enviro/icis-air-search) the following facilities, located within approximately 1,000 feet of the Site, are potential point sources of air emissions:

Site Name	Address	Distance from Site	Air Program Information	Notes
Fordham Auto Plus Inc.	2409 Jerome Avenue Broux, NY 10468	~190 feet	CAASIP ⁱ (Operating)	Minor Emissions
2400 Walton Avenue Building	2400 Walton Avenue Broux, NY 10468	~220 feet	CAASIP' (Operating) Title V Permits (Permanently Closed)	Minor Emissions
NYC-HPD 2410 Davidson Ave	2410 Davidson Avenue Broux, NY 10468	~240 feet	CAASIP ⁱ (Operating)	Minor Emissions
2400 Davidson Avenue Building	2400 Davidson Avenue Broux, NY 10468	~280 feet	CAASIP ⁱ (Operating)	Minor Emissions
Amoce 65425671005	2350 Jerome Avenue Broux, NY 10468	~500 feet	CAASIP ¹ (Operating)	Minor Emissions
2386 Morris Avenue Building	2386 Morris Avenue Broux, NY 10468	~530 feet	CAASIP ⁱ (Operating)	Minor Emissions
Kleener King	3439 Creston Avenue Broux, NY 10468	~.540 feet	CAASIP ⁱ (Operating) CAAMACT (Operating-Perchloroethene)	Minor Emissions
Gaseteria-North Street	2318 Jerome Avenue Broux, NY 10468	~700 feet	CAASIP ¹ (Operating)	Minor Emissions

¹CAASIP = Clean Air Act State Implementation Plan for National Primary and Secondary Ambient Air Quality Standards ²CAAMACT = MACT Standards (40 CFR Part 63)

Vidaris, Inc.

New TORK City Public School PS 35A Energy Model Report

Propoted P.S. 33X Annex (X347) 3 May 10, 2018

Discussion and Conclusions

In order to determine the acceptability of outdoor air, the nearby facilities identified during the assessment were evaluated against the following screening criteria¹:

- · Large parking facilities or parking garage exhaust vents adjacent to the Site;
- An atypical (e.g., not at-grade) source of vehicular pollutants, such as a highway or bridge, within 200 feet of the Site;
- A major or large emission source within 1,000 feet of the Site;
- A medical, chemical, or research lab within 400 feet of the Site;
- Manufacturing or processing facilities within 400 feet of the Site; and
- A facility with a New York State Department of Environmental Conservation (NYSDEC) air facility registration within 200 feet the site.

Based on this evaluation and the findings of the local survey, the following source may affect the acceptability of the outdoor air quality at the Site:

 Fordham Auto Plus, an auto repair shop and NYSDEC air registration facility located approximately 180 feet (across Jerome Avenue) from the Site.

Therefore, AKRF recommends conducting further evaluation of emissions from this source to determine whether additional design measures beyond the standard NYCSCA requirements should be incorporated into the HVAC system design for the new annex. Please feel free to contact me at (914) 922-2362 with any questions or concerns.

Sincerely,

Rebecca A. Kinal, P.E. Vice President/Project Manager

Page 14

¹ Based on guidance for evaluation of air quality in the City Environmental Quality Review Technical Manual (New York City Mayor's Office of Environmental Coordination, March 2014).

APPENDIX B: SOURCE OF POLLUTANTS - AUTO BODY SHOP

NEXA autocolor 2K Clear coat mix – 2 parts P190-6490 clearcoat, 1 part P210-8490 hardener			
	VOC	1.39	lb/gal
Clearcoat			
Ingredient	percent by volume	CAS number	
4-chloro-a,a,a-trifluorotoluene	20%	98-56-6	
Acetone	20%	67-64-1	
5-methylhexan-2-one	10%	110-12-3	
2-ethylhexyl acetate	10%	103-09-3	
Pentyl propionate	05%	624-54-4	
Heptan-2-one	01%	110-43-0	
Propionic acid	01%	79-09-4	
Bis(1,2,2,6,6-pentamethyl-4-piperdyl) sebacate	0.1%	41556-26-7	
H20	33%		
Hardener			
Ingredient	percent by volume	CAS number	
Hexamethylene Diisocynaate, oligomers	50%	28182-81-2	
4-chloro-a,a,a-trifluorotoluene	49%	98-56-6	
Hexamethylene-di-isocyanate	1%	822-06-0	

	VOC	5.93	lb/ga
Basecoat			
Ingredient	percent by volume	CAS number	
n-butyl acetate	90%	123-86-4	
xylene	50%	1330-20-7	
2-methoxy-1-methylethyl acetate	20%	108-65-6	
5-methylhexan-2-one	10%	110-12-3	
Solvent naphtha	10%	64742-95-6	
Titanium dioxide	10%	13463-67-7	
ethylbenzene	5%	100-41-4	
butan-1-ol	5%	71-36-3	
1,2,40trimethylbenzene	5%	95-63-6	
Aluminium oxide	5%	1344-28-1	
Azacyclotridecan-2-onee, homopolymer	5%	25038-74-8	
Diiron trioxide	5%	1309-37-1	
Mica-group minerals	1%	12001-26-2	
Magnesium fluoride	1%	7783-40-6	
Ligroine	1%	8032-32-4	
Carbon black, respirable powder	1%	1333-86-4	
Toluene	1%	108-88-3	
Mesitylene	1%	108-67-8	
Naphtha(petroleum)	1%	64741-65-7	
n-butyl propionate	1%	590-01-2	
cumene	1%	98-82-8	
Rosin, oligomers	1%	65997-05-9	
2-methoxypropyl acetate	1%	70657-70-4	
2,3-epoxypropyl neodecanoate	1%	26761-45-5	
Thinner			
Density – 6.84 lbs / gal			
Ingredient	percent by volume	CAS number	
5-methylhexan-2-one	40%	110-12-3	
4-methylpentan-2-one	40%	108-10-1	
xylene	5%	1330-20-7	
2-ethylhexyl acetate	5%	103-09-3	
Solvent naphtha	5%	64742-95-6	
1,2,40trimethylbenzene	3%	95-63-6	
ethylbenzene	1.7%	100-41-4	
cumene	1%	98-82-8	

NEXA autocolor P565-2910 Primer-Surfacer – 6 parts P565, 1 part P210-85 hardener, 2 parts P850-16				
	VOC	4.71	lb/gal	
Primer-Surfacer				
Ingredient	percent by volume	CAS number		
b3rium sulfate	30.0%	7727-43-7		
n-butyl acetate	30.0%	123-86-4		
xylene	13.0%	1330-20-7		
titanium dioxide	10.0%	13463-67-7		
Talc , not containing asbestiform fibres	7.0%	14807-96-6		
ethylbenzene	5.0%	100-41-4		
aluminium orthophosphate	5.0%	7784-30-7		
2-methoxy-1-methylethyl acetate	1.5%	108-65-6		
crystalline silica, respirable powder (<10 microns)	1.0%	14808-60-7		
crystalline silica, respirable powder (>10 microns)	1.0%	14808-60-7		
Hardener				
Ingredient	percent by volume	CAS number		
Vexamethylene diisocyanate, oligomers	50.0%	28182-81-2		
2-butoxyethyl acetate	20.0%	112-07-2		
3-lsocyanatomethyl-3,5,5-trimethylcyclohexyl isocyanate, oligo	20.0%	53880-05-0		
Solvent naphtha (petroleum), light aromatic	10.0%	64742-95-6		
heptan-2-one	5.0%	110-43-0		
n-butyl acetate	4.5%	123-86-4		
5-methylhexan-2-one	2.5%	110-12-3		
1,2,4-trimethylbenzene	2.5%	95-63-6		
Solvent naphtha (petroleum), heavy arom.	2.7%	64742-94-5		
xylene	1.6%	1330-20-7		
4-isocyanatosulphonyltoluene	1.0%	4083-64-1		
ethylbenzene	1.0%	100-41-4		
naphthalene	1.0%	91-20-3		
Thinner				
Ingredient	percent by volume	CAS number		
Igmethylhexan-2-one	50.0%	110-12-3		
4-methylpentan-2-one	48.0%	108-10-1		
n-butyl acetate	20.0%	123-86-4		
xylene	13.0%	1330-20-7		
ethylbenzene	2.4%	100-41-4		
APPENDIX C: SOURCE OF POLLUTANTS - TRAFFIC

EMFAC2014	(v1.0.7) En	nission Rat	es										
Region Type	e: Statewid	le											
Region: Cali	ifornia												
Calendar Ye	ar: 2017												
Season: Ani	nual												
Vehicle Cla	ssification:	EMFAC20	11 Categories										
Units: miles	/day for V	MT, g/mile	for RUNEX, I	MBW and Pl	MTW								
						mi/day	gram/veh-mile						
Region	CalYr	VehClass	MdlYr	Speed	Fuel	VMT	ROG_RUNEX	TOG_RUNEX	CO_RUNEX	NOx_RUNEX	CO2_RUNEX	PM10_RUNEX	PM2_5_RUNEX
Statewide	2017	LDA	Aggregated	5	GAS	938511.5105	0.151294323	0.214483287	1.987134089	0.175315144	988.3009307	0.01175757	0.010817573
Statewide	2017	LDT1	Aggregated	5	GAS	82697.11122	0.480374648	0.661387953	7.153270782	0.580357296	1161.846787	0.022692751	0.020908989
Statewide	2017	LDT2	Aggregated	5	GAS	354766.0727	0.21432272	0.305434127	2.923718393	0.357613675	1334.68687	0.012036352	0.011075101
Statewide	2017	LHD1	Aggregated	5	GAS	195140.4523	0.450227091	0.64819599	5.328907219	0.790280624	1404.594266	0.010906922	0.010036924
Statewide	2017	LHD2	Aggregated	5	GAS	31447.60501	0.249570681	0.361706671	2.730893965	0.542571114	1492.416129	0.007725231	0.00710547
Statewide	2017	MCY	Aggregated	5	GAS	10298.30336	13.21347885	15.98631029	60.28676158	1.484627033	543.3475889	0.009350837	0.008796928
Statewide	2017	MDV	Aggregated	5	GAS	239543.3436	0.401263099	0.560835886	4.932856388	0.609014299	1760.932895	0.012639272	0.011641149
Statewide	2017	MH	Aggregated	5	GAS	4915.761191	1.342870477	1.789930984	23.90687092	1.399260875	3932.873375	0.01675651	0.015514648
Statewide	2017	OBUS	Aggregated	5	GAS	5050.916969	0.553200011	0.79993857	4.642460368	1.112950075	3891.618334	0.005176993	0.004764552
Statewide	2017	SBUS	Aggregated	5	GAS	2003.889652	0.90494844	1.320498639	6.941540811	1.630983769	1848.851173	0.009681113	0.008901426
Statewide	2017	T6TS	Aggregated	5	GAS	9897.336003	1.163558017	1.662318994	11.56320754	1.946463404	3898.616723	0.009264781	0.00854121
Statewide	2017	T7IS	Aggregated	5	GAS	670.7077748	4.644059008	6.582505951	77.05037312	6.988114251	4273.272306	0.006481312	0.006011949
Statewide	2017	UBUS	Aggregated	5	GAS	9393.869964	2.310287533	3.288070205	17.31417285	2.523543244	3909.452156	0.008504881	0.007862002

Vidaris, Inc.

Page 19

Taken from "	Assessment	of Carbonace	ous PM2.5	for New York and	the Region", TA	BLE 3-9		CALCUL	ATIONS	
				Gasoline LDV						
	population	Percent of		VMT in CY 2002	Percent Total	Per Capita Gasoline	Gasoline	Gasoline	VMT/	VMT/
	(2000	Total NYS	County In	(1,000,000	NYS Gasoline	LDV/VMT (1000 mi	LDV VMT	LDV VMT	person /	person /
county	Census)	Population	NYMA	mi/yr)	LDV VMT	/ person / yr)	per day	per hour	day	hour
Albany	294,565	1.6	No	3,280.1	2.5	11.1	8986575	374440.6	30.41096	1.267123
Bronx	1,332,650	7	Yes	4,327.8	3.3	3.2	11856986	494041.1	8.767123	0.365297
Erie	950,265	5	No	8,132.8	6.3	8.6	22281644	928401.8	23.56164	0.981735
Kings	2,465,326	13	Yes	4,487.6	3.5	1.8	12294795	512283.1	4.931507	0.205479
Monroe	735,343	3.9	No	6,752.8	5.2	9.2	18500822	770867.6	25.20548	1.050228
Nassau	1,334,544	7	Yes	10,610.0	8.2	8	29068493	1211187	21.91781	0.913242
New York	1,537,195	8.1	Yes	3,987.3	3.1	2.6	10924110	455171.2	7.123288	0.296804
Onondaga	458,336	2.4	No	4,307.4	3.3	9.4	11801096	491712.3	25.75342	1.073059
Orange	341,367	1.8	No	4,038.3	3.1	11.8	11063836	460993.2	32.32877	1.347032
Putnam	95,745	0.5	No	2,749.5	2.1	28.7	7532877	313869.9	78.63014	3.276256
Queens	2,229,379	11.7	Yes	7,160.7	5.5	3.2	19618356	817431.5	8.767123	0.365297
Richmond	443,728	2.3	Yes	1,827.7	1.4	4.1	5007397	208641.6	11.23288	0.468037
Rockland	286,753	1.5	Yes	2,405.1	1.9	8.4	6589315	274554.8	23.0137	0.958904
Suffolk	1,419,369	7.5	Yes	17,886.0	13.8	12.6	49002740	2041781	34.52055	1.438356
Westchester	923,459	4.9	Yes	8,012.9	6.2	8.7	21953151	914714.6	23.83562	0.993151
TOTAL		78.2		89,966	69.4					

Vidaris, Inc.

Taken From "New York S Inventory and Fore	tate Gree ecst", Tal	enhouse ble 3-1	Gas	VehClass			CALCULATION			
Vehicle Type	1990	2000	2007			VehClass		1990	2000	2007
Heavy Duty Diesel Vehicle	4,056	4,538	8,022	LHD1	LHD2	LDA	Passenger Cars	84,398	64,440	60,836
						LDT1	Light-Duty Trucks (GVWR<6000 lbs and ETW <3750)	9067	31579	32789
Heavy Duty Gasoline Vehicle	206	320	1,414	LHD1	LHD2	LDT2	Light-Duty Trucks (GVWR<6000 lbs and ETW 3750-5750)	9067	31579	32789
						LHD1	Light-Heavy-Duty Trucks (GVWR 8501-10000 lbs)	2131	2429	4718
Light Duty Diesel Truck	582	1,890	1,459	LDT1	LDT2	LHD2	Light-Heavy-Duty Trucks (GVWR 10000-14000 lbs)	2,131	2,429	4,718
						MCY	Motorcycles	107	603	887
Light Duty Diesel Vehicle	26	20	19	LDA		MDV	Medium-Duty Trucks (GVWR 6000-8500 lbs)			
						MH	Motor Homes			
Light Duty Gasoline Truck	17,552	61,268	64,119	LDT1	LDT2	OBUS	Motor Coach			
						SBUS	School Bus	206	320	1,414
Light Duty Gasoline Vehicle	84,372	64,420	60,817	LDA		T6TS	Medium-Heavy Duty Gasoline Truck			
						T7IS	Heavy-Heavy Duty Gasoline Truck			
Motorcycle	107	603	887	MCY		UBUS	Urban Buses	206	320	1,414
Total	106,901	133,059	136,737				Total	107,313	133,699	136,737
(1,000,000 mi/yr)							(1,000,000 mi/yr)			

Vidaris, Inc.

Page 21

APPENDIX D: MODEL CONVERGENCE

Mesh

The fine grid meshing was used next to the school building with focus on the OA intake inlet, based on the information provided by the design team. The total numbers of grids cells in the VFD model is 2,238,273. The shape of the mesh is rectangular cuboid. The maximum aspect ratio in the region around the school is 5.0.

Residuals

The run with 2 mph wind speed did not achieve optimal convergence due to turbulence. However, the trends pertaining to VOCs are valid.

The CFD models for 7.5 mph and 22.5 mph wind speed were allowed to run until steady state convergence was achieved. The maximum residual for the pollutant concentration was in the order of e-5; and in the order of e-7 for VOCs.

Vidaris, Inc.



Figure 8 Plot of Residuals of pollutant concentration vs Iteration, High Risk Conditions

Page 22

Credit Q7.5R: Point-by-point lighting level (photometric) and LPD calculations for typical and non-typical areas



Luminaire Schedul	le														
Symbol	Qty	Label		Arrangement	Total Lamp	Lumens	LLF	Description	n		Lum. Watts	Lum. Lu	mens	[MANUFA	•C]
+	6	T2		SINGLE	N.A.		0.900	LAW4-351	ML-EU		42.7	4904		COLUMB	IA LIGHTING
Calculation Summa	ary									LPD Area Summary					
Label			CalcType	Units	Avg	Max	Min	Avg/Min	Max/Min	Label		Area	Total Wa	tts	LPD
Room_C03_Work	plane		Illuminance	Fc	33.64	60.3	17.1	1.97	3.53	Room_C03_LPD		334.38	128.1		0.383
Room_C07_Work	plane		Illuminance	Fc	33.85	63.0	6.2	5.46	10.16	Room_C07_LPD		310.13	128.1		0.413

TING





Area = 1938 Sq.ft Total Watts = 806.9999

LPD = 0.416 Watts/Sq.ft

					Ζ1	\square													Ζ	1	1									
=	-						h		h		-			-		h		-												_
Ĭ	21.5	25.6	26.8	24.8	18.9	16.4	22.4	26.9	30.6	29.2	26.7	25.6	27.0	29.6	30.7	29.1	26.3	23.1	16.9	1	23.8	28.2	26.2	25.3	26.8	29.4	30.7	29.1	26.3	•
Ц	26.2	D ₃ 3E	36.0	34.1	30.4	28.9	31.4	D.3	38.3	35.9	31.7	29.9	32.2	D,3 E	38.4	35.8	31.3	29.2	30.8	34.3	37.7	35.5	31.6	29.9	32.2	D,3E	38.4	35.7	31.3	•
	29.1	36.6	40.5	38.3	33.9	32.1	34.9	40.3	42.9	40.1	35.0	33.0	35.6	10.7	43.1	40.0	34.9	\$2.7	D	3	43.3	40.1	35.1	33.0	35.7	ŧ0.6	43.1	39.8	34.6	•
1	1 10 3	1 77 1	\$ 0.5	100	1 45 1	1 1 6	\$6.2	31.0	114	40.5	16.2	14.4	1 6.7	1 41.4	43.6	20.8	16.2	34.4	36.0	\$1.7	43.8	31.0	9 6 A	1 4 A	16.0	5 1 3	13.6	30.6	1 .5 0	•
μ		•	•0.8	39.0	•	•	•	•1.0	•	•0.0	50.2		\$0.7	•1.4	43.0	40.0	\$0.2	54.4	3 0.9	•1.7	43.8	•1.0	±	34.4 •	•	•1.5	43.0	40.0	•	•
	30.5	37.2 D.Z	40.7	39.2	35.6	34.2	36.7	41.3 D.7 I	43.7	41.2	36.8	35.0	37.3	41.6	43.7	41.2	36.9	35.2	37.5	41.9 D.Z.E	44.0	41.4	36.9	35.1	37.4	41.7 D.Z	43.7	41.0	36.5	3
	31.5	5.0	42.8	41.0	36.8	35.1	38.0	Lai	46.3	43.2	37.9	35.8	38.5	tes E	46.5	43.2	38.0	35.9	38.7	LADE	46.7	43.3	38.0	35.8	38.5	13.2	46.4	43.0	37.6	3
	32.0	39.9	44.0	41.9	37.2	35.3	38.4	44.5	47.6	44.1	38.3	36.0	38.9	14.9	47.8	44.2	38.5	36.2	39.2	15.0	48.0	44.2	38.4	36.1	38.9	64.8	47.7	44.0	38.0	3
	31.1	38.3	42.0	40.2	36.2	34.6	37.4	42.6	45.4	42.4	37.4	35.4	38.0	43.1	45.6	42.6	37.7	35.7	38.3	43.4	45.8	42.6	37.6	35.5	38.0	43.0	45.4	42.2	37.1	\$
	29.9	36.5	39.9	38.5	35.0	33.6	36.1	40.6	42.9	40.5	36.2	34.5	36.8	41.2	43.3	40.8	36.6	34.9	37.2	41.5	43.6	40.9	36.4	34.6	\$ 6.8	41.1	43.1	40.3	35.8	5
	29,4	D,3E	40.2	38.3	34.1	32.5	35.4	D.3	42.9	40.2	35.4	33.4	36.1	D,3E	43.4	40.8	36.1	34.1	36.7	D,3	4 3.8	40.7	\$5.7	33.5	36.0	D.3 E	43.0	40.0	35.1	3
	28.0	35.4	38.9	36.6	32.5	30.8	33.5	38.6	41.1	38.3	33.3	31.4	34.1	39.3	42.0	39.2	34.4	32.4	35.0	ŧ0.0	42.2	39.0	34.1	31.8	34.2	39.1	41.6	38.2	33.1	•
	27.7	35.4	38.3	36.6	33.8	32.1	31.8	33.5	34.8	32.7	29.0	27.5	29.6	33.6	36.1	34.2	30.5	29.0	30.9	34.9	36.5	36.1	34.5	33.7	35.4	39.1	40.5	36.0	29.8	•
	32.1	40.8	44.9	44.9	42.6	39.0	30	25.6	26.7	25.7	23.8	22.9	23.8	25.5	41-3	22.7	20.6	Ж	20.8	22.8	24.0	55.3	40.1	43.2	45.7	47.0	44,7		23.4	•
	38.2	<u>م</u>	53.8	\$6.6	ڈ ¹	F ^{45.6}	5.1												-	$\overline{}$	•	29.3	4519	5 f ².6	\$8.4	567	5 [#]	40.0		5
	38.3	- P	53.3	58.5	-,©	41.2	3.:	Ę			5			T2E	٦L	<u> </u>	3	П	fe	:3		31.8	42.9	3. 31.2	60.6	55.6	3 .	ون ا		Ò
	30.5	38.5	44.6	47.1	43.5	36.5	2.1		2	-								$\left \right\rangle$				25.6	36.4	43.8	48.8	46.6	40.2	Υ Ω		
$\left \right $	1 9:1	24.3	F				⊒	C	2							L		1]]	22.8			25.4	22.0	<u></u>		
		-1-			Д				OC				_ _		」┖ ╼┨╶┖				F		à	16.3	16.0		19.5	24.1	23.6		F	_
1						$\overline{\ }$	L L	1	4	1			-5	<u> </u>	J	·,												JL		Ē



102





Luminaire Sc	hedule															
Symbol	Qty	Label		Arrangement	Total Lan	np Lumens	s LLF	Descrip	ion					Total Watts	Lum. Lumens	[MANUFAC]
•	28	D3		SINGLE	N.A.		0.900	2CAG4	2L835-4-DS-	UNV				1122.8	4406	PHILIPS DAY-BRITE - PHILIPS CFI
\odot	6	H5		SINGLE	N.A.		0.900	C6RN+	C6L25835W	Z10U+C6	RDLCL			127.8	2307	PHILIPS LIGHTOLIER
•	14	K1		SINGLE	N.A.		0.900	CSEDO	-24-45L35K	DCC-DV	-2F-2H-SYM			686	5462	Kenall Manufacturing
•	6	A2		SINGLE	N.A.		0.900	2CAG5	5L835-4-DS-	UNV				307.8	5553	PHILIPS DAY-BRITE - PHILIPS CFI
÷	1 7	Y		SINGLE	N.A.		0.900	3901LB	GRS447VOI	LTSE 3 I	NCH X 4FT LINEAR RECESSED LI	ED		470.9	2203	PHILIPS LEDALITE
Calculation S	ummary]	LPD Area Summary					
Label			CalcType	Units	Avg	Max	Min	Avg/Min	Max/Min	1	Label	Area	Total Watts	LPD		
CalcPts_101 (a) 18 INCHES	Fc	32.40	37.4	27.8	1.17	1.35		Room_100_LPD	503.19	332.4	0.661				
Room_100_F	loor		Illuminance	Fc	32.33	45.9	15.7	2.06	2.92		Room_100A_LPD	205.31	138.5	0.675		
Room_100A	Floor		Illuminance	Fc	24.73	30.7	15.9	1.56	1.93	1	Room_101_LPD	63.13	42.6	0.675		
Room_102_V	Vorkplane		Illuminance	Fc	36.46	60.6	16.4	2.22	3.70	1	Room_102_LPD	1938	806.9999	0.416		
Room_103_V	/orkplane		Illuminance	Fc	50.26	64.8	34.5	1.46	1.88		Room_103_LPD	178.69	153.9	0.861		
Room_109_V	/orkplane		Illuminance	Fc	30.67	44.5	11.8	2.60	3.77	1	Room_109_LPD	1248	401	0.321		
Room_111_V	Vorkplane		Illuminance	Fc	54.72	66.5	36.6	1.50	1.82	1	Room_111_LPD	152.63	153.9	1.008		
Room_112B	Workplane		Illuminance	Fc	50.73	70.4	18.3	2.77	3.85	1	Room_112B_LPD	702.31	490	0.698		
Room_112K	Workplane		Illuminance	Fc	57.32	69.9	37.4	1.53	1.87	1	Room_112K_LPD	266.06	196	0.737		

	Area = 915.50 Sq.ft Total Watts = 452.7999 LPD = 0.495 Watts/Sq.ft	Area = 898.50 Sq.ft Total Watts = 452.7999 LPD = 0.504 Watts/Sq.ft
	210 PRE-KINDERGARTEN 931 SF	208 PRE-KINDERGARTEN 912 SF
	J1 J1 J1	25.8 32.9 39.2 43.5 460 47.4 48.0 48.1 47.5 46.2 43.8 39.5 33.2 262 J1 J1 J1 J1 J1
	5	
	35.6 43.0 49.1 52.8 35.2 36.3 36.7 36.2 35.0 52.5 48.4 42.2 34.7	28.1 35.0 41.4 45.9 48.6 30.2 30.9 31.0 30.4 48.9 46.2 41.6 35.1 27.9
	52.9 59.4 44.5 47.8 49.9 50.9 51.3 50.8 49.5 47.2 43.6 38.3 31.5	25.5 31.8 37.2 41.0 43.4 44.9 45.6 45.6 45.0 43.7 41.4 37.5 32.0 25.5
	29.7 34.5 38.6 41.5 43.5 44.5 44.8 44.3 43.0 40.9 37.7 33.3 28.3	23.0 27.6 31.7 34.9 37.1 38.5 39.2 39.3 38.8 37.5 35.4 32.2 28.0 23.3
	29.5 34.2 38.2 41.1 42.9 43.9 44.2 43.6 42.3 40.2 37.0 32.8 27.9	22.8 27.1 31.1 34.2 36.4 37.8 38.6 38.7 38.2 37.0 34.9 31.8 27.8 23.3
	33.0 39.2 43.9 47.1 49.1 30.1 30.3 49.7 48.3 46.0 42.4 37.2 30.9	25.1 30.9 36.1 39.8 42.2 43.8 44.6 44.8 44.3 43.0 40.7 37.1 31.8 25.8
	36.8 44.2 30.0 33.7 35.9 36.8 37.0 36.3 34.8 32.1 47.9 41.6 34.0 J1 J1 J1 J1	27.9 34.6 40.9 45.5 48.4 50.1 51.0 51.3 50.8 49.5 46.9 42.5 36.1 29.0 J1 J1 J1
	37.6 45.1 51.1 34.9 57.0 57.8 57.6 56.5 34.5 51.4 46.8 40.1 32.3	26.7 33.3 39.7 44.5 47.8 49.9 51.3 51.9 51.8 50.6 48.1 43.4 36.9 29.6
	34.8 41.6 46.9 50.1 51.9 52.5 51.9 50.5 48.0 44.8 40.1 33.7 27.2	2 2.6 2 8.3 3 3.8 3 8.1 4 1.3 4 3.8 4 5.6 4 6.7 4 6.7 4 5.8 4 3.7 3 9.8 3 4.0 2 7.5
	31.8 37.5 42.0 45.0 46.5 46.7 45.7 43.5 40.2	17.5 214 25.4 29.5 33.3 36.6 39.2 40.8 41.3 40.6 38.7 35.3 30.6 25.3
	33.0 39.8 44.7 47.7 49.1 48.9 47.2 43.6 38.4	161 20.3 25.4 30.7 35.9 40.1 42.6 43.7 43.2 41.3 37.7 32.3 26.1
	36.1 ⁴ 3.9 ⁴ 9.5 ⁵ 2.7 ⁵ 4.0 ⁵ 3.6 ⁵ 1.0 ⁴ 6.0 ³ 8.8 1	a b b b c b c c c c c c c c c c
		19.5 <u>салинийны уналинийнэ салинийнэ ула</u> 37.2
48 SF	34.4 41.2 46.3 49.0 49.9 49.6 46.6 41.1 34.0	
		LP2-3
Corridor_LPD	$\begin{array}{ c c c c c c c c c c c c c c c c c c c$	9 516 522 519 511 516 521 515 516 524 521
Area = 904.00 Sq.ft Total Watts = 393.5999 LPD = 0.435 Watts/Sq.ft	$\begin{array}{c c c c c c c c c c c c c c c c c c c $	$\begin{array}{c ccccccccccccccccccccccccccccccccccc$
	Páge zoz or 310	

Room_210_LPD

Area = 899.75 Sq.ft Total Watts = 452.7999 LPD = 0.503 Watts/Sq.ft



PRE-KINDERGARTEN 949 SF

Room_204_LPD

Area = 935.31 Sq.ft Total Watts = 452.7999 LPD = 0.484 Watts/Sq.ft





Luminaire Schedul	e								
Symbol	Qty	Label	Arrangement	Total Lamp Lumens	LLF	Description	Lum. Watts	Total Watts	[MANUFAC]
•	99	J ALT 2	SINGLE	N.A.	0.900	7406LBEQN-RUN-7-VOLTS-E-FINISH	28.3	2801.7	PHILIPS LEDALITE
•	12	D2	SINGLE	N.A.	0.900	2CAG36L8354-DS-UNV	32.8	393.6	PHILIPS DAY-BRITE - PHILIPS CFI

Calculation Summary								LPD Area Summary
Label	CalcType	Units	Avg	Max	Min	Avg/Min	Max/Min	Label
CalcPts_Corr at 18 inches	Illuminance	Fc	22.78	26.9	18.1	1.26	1.49	Corridor_LPD
Room_203_Workplane	Illuminance	Fc	43.65	56.6	22.6	1.93	2.50	Room_203_LPD
Room_204_Workplane	Illuminance	Fc	47.27	59.8	25.6	1.85	2.34	Room_204_LPD
Room_205_Workplane	Illuminance	Fc	44.28	58.6	23.6	1.88	2.48	Room_205_LPD
Room_206_Workplane	Illuminance	Fc	48.14	60.4	31.0	1.55	1.95	Room_206_LPD
Room_207_Workplane	Illuminance	Fc	42.72	55.3	18.5	2.31	2.99	Room_207_LPD
Room_208_Workplane	Illuminance	Fc	38.34	52.1	16.4	2.34	3.18	Room_208_LPD
Room_210_Workplane	Illuminance	Fc	45.28	57.9	27.2	1.66	2.13	Room_210_LPD

Area	Total Watts	LPD
904	393.5999	0.435
904	396.2	0.438
935.31	452.7999	0.484
403.13	198.1	0.491
899.75	452.7999	0.503
877.5	396.2	0.452
898.5	452.7999	0.504
915.5	452.7999	0.495

ע ד ו	Area = 931.2 Total Watts LPD = 0.486	38 Sq.f = 452. 5 Watts	ît 7999 s/Sq.ft												
3.4	L)			(4		R A Te L	oom 30 rea = 5 otal Wa PD = 0	06A_LF 0.75 Sc atts = 4 .849 W	PD q.ft 3.1 atts/Sq.	ft		(•	4.8	
306A -	TOILET 48 SF		Т												
306	KINDEF	RGA	RTE	N	5										
	915 SF														
		U		Q			P		ղե		ղր				
													+	╉┼╊	
┕┧╢┛	34.9	41.6	47.0	30.4	32.4	53.4	53.7	53.3	32.3	50.4	47.1	41.9	3.3		
	"J ₇ 1	44.7	30.7	34.6	J1	38.1	58.5	58.1	<u>_</u> ,j_1	54.6	50.7	44.9	31.2		
	38.9	4 6.2	P'3←	- \$ 6.5	38.8		P3-	- 4 9.9	3 8.7	⁵6.3LF	o ' 33₂	- 4 6.2	31.9	Ħ	
	38.5	45.8	51.6	55.3	\$7.6	58.7	\$9.0	58.6	57.3	\$5.0	51.2	45.4	31.0		
	36.0	42.0	47.0	5 0.4	5 2.4	\$3.6	\$1.8	5 3 3	\$2.1	49.9	46.3	41.4	3-4		
	•	1 2.7	1.10	\$ 1.2	t	\$ 4.3	1 .1.6	\$40	\$ 21.7	\$ 0.4	46.7	1 1 8	•		
	•	•	•	•	•	•	•	•	•	•	•	•1.5			
	^{39.8}	47.4	\$3.3	37.2	59.4	60.5	60.7	60.0	58.6	56.1	51.9	45.9	31.4		
	10.7	48.1	54.4	58.5		61.8	62.0	61.2	₽	56.7	52.3	45.9	31.7		
	40.5	47.9	54.1	58.2	60.4	61.3	61.2	60.3	58.5	55.5	50.9	44.4	31.2		
	39.2	46.5	52.3	55.9	57.8	58.5	58.0	56.8	54.7	51.6	4 6.7	40.5	3:.6		
	35.8	41.8	46.5	49.6	\$1.1	51.5	50.7	48.8	46.0	42,4	35.9	- 5 1.5	21.9		
I	35.6	41.6	46.3	49.3	\$0.7	50.7	49.3	46.4	42.2		<u> </u>	_			
	38.1	45.4	\$1.0	54.3	\$5.7	55.4	53.2	48.8	42.0		_	\geq	\times		
	J1	45.3	51.0	54.5	.J.1	55.2	52.5	47.5	40.7	17.5	20.	4 20	.3 17		
	•		1 9.4	* 2-7	ॻऻ •ः	*	3 0.4	1 6.2		20.5	24.	Ç2	.2 26		
			•.	~~		٦.	-50.4 •	+J.2 ●	50./~	20.8	4	+ 4 04	5 5		
	33.8	40.5	45.4	< 4 8 ,1 `	49.0	48.3	46.0	41.4	34.9	20.0	242		- 1		
	/]║║+	•				



-]	<u>─────</u>			╫┓┎───			
	* _0 °	21.7	51.7	1 20.9	t 21.5	* 10	t al 2	t 21.2	22.1	* 1.4	t	<u>+</u>	• 16	22.1	+	• >> >	22.3	
	1 23.5	* 24.6	24.6	23.7	1 24.4	*	• 24.1	4 24.1	+ 25.1	24.5	•23.9	1 21.9 1 25.1	1 24.3	25.3	+ 26.8	26.6	2:.7	•22.2
			<u>D</u> 2			-1 ⁻¹ ⁻¹ ⁻¹				2F1					- <u>2</u>	1	12T	

Luminaire Sche	edule										
Symbol	Qty	Label	Arrangement	Total Lamp Lumens	LLF	Description	Lum. Watts	Total Watts	Lumens/Lamp	Lum. Lumens	[MANUFAC]
· · · · · · · · · · · · · · · · · · ·	16	J	SINGLE	N.A.	0.900	7406LBEQN-RUN-7-VOLTS-E-FINISH	28.3	452.8	N.A.	3513	PHILIPS LEDALITE
•	12	D2	SINGLE	N.A.	0.900	2CAG36L835-4-DS-UNV-DIM-DAYOCC 2X4 RECESSED SOFT LIGHT	32.8	393.6	N.A.	3617	PHILIPS DAY-BRITE - PHILIPS CFI
•	1	C2	SINGLE	N.A.	0.900	2TF43L835-4-FS-02F-UNV	43.1	43.1	N.A.	4180	PHILIPS DAY-BRITE - PHILIPS CFI

Calculation Summary			LPD Area Summary								
Label	CalcType	Units	Avg	Max	Min	Avg/Min	Max/Min	Label	Area	Total Watts	LPD
CalcPts_@ 18 INCHES AFF	Illuminance	Fc	22.50	26.8	16.8	1.34	1.60	Corridor_LPD	915.88	393.5999	0.430
Room 306A_Floor	Illuminance	Fc	20.84	24.5	17.5	1.19	1.40	Room 306A_LPD	50.75	43.1	0.849
Room_306_Workplane	Illuminance	Fc	49.31	62.0	26.9	1.83	2.30	Room_306_LPD	931.38	452.7999	0.486





Area = 748.56 Sq.ft Total Watts = 339.6 LPD = 0.454 Watts/Sq.ft



Page 269 of 310



Room_417_LPD



Luminaire Schedu	le								
Symbol	Qty	Label	Arrangement	Total Lamp Lumens	LLF	Description	Lum. Watts	Total Watts	[MANUFAC]
•	2	C3	SINGLE	N.A.	0.900	2CAF36L835-4-DS-UNV 2X4 FLANGED FOR HARD	32.8	65.6	PHILIPS DAY-BRITE - PHILIPS CFI
+	12	JALT 2	SINGLE	N.A.	0.900	7406LBEQN-RUN-7-VOLTS-E-FINISH	28.3	339.6	PHILIPS LEDALITE

Calculation Summary								[LPD Area Summary			
Label	CalcType	Units	Avg	Max	Min	Avg/Min	Max/Min		Label	Area	Total Watts	LPD
Room_404_Workplane	Illuminance	Fc	42.99	55.8	23.1	1.86	2.42		Room_404_LPD	748.56	339.6	0.454
Room_417_Floor	Illuminance	Fc	21.51	24.3	17.8	1.21	1.37		Room_417_LPD	123.25	65.6	0.532

Credit Q8.1P & Q8.2: Acoustical 60% review.



440 Park Avenue South 7th Floor New York, NY 10016 tel: 212 696-0670 fax: 212 213-3191 www.akrf.com

June 4, 2018

John Doherty, AIA Mitchell | Giurgola Architects, LLP 630 Ninth Avenue, Suite 711 New York, NY 10036

Re: PS 347X Standalone Annex – Bronx, New York 60% Construction Documents Drawing Submission – Acoustical Review Report

Dear Mr. Doherty:

AKRF has completed a review of the PS 347X project 4/30/18 60% Construction Design architectural, structural and mechanical drawings package. Acoustical comments related to architectural, structural and MEP issues for the project are outlined below.

Action Item Ref	Description	Drawings / Ref	Issue	Action Required					
	ARCHITECTURAL								
A-1	Reading/Speech Resource Room (205) Partition Type K0.2	A102	Elevator Shaft Wall and Structure-borne	Consider a free-standing stud (i.e., no bracing back to elevator shear wall) with a minimum 1/2-to-1-inch air gap separating the elevator shaft wall from the metal stud.					
A-2	CSD Special Education (505) Partition Type K0.2	A105	Noise	Refer to Action Item A-1					
A-3	Classroom Entry Doors Minimum STC-35 Rating Required	A910 and A911	Door Schedule/ STC Rating Coordination	Include "Min. STC 35" note in the Door Schedule "Remarks."					
A-4	Classroom Entry Doors Head/Jamb/Door Bottom Sound Seals Required	A912 Detail 3	Door Details/ Acoustic Sound Seal Coordination	Details should include sound seals at the head, jamb, and door bottom locations.					
A-5	Classroom Entry Doors Thresholds Required	A912	Maintain Acoustical Integrity	Flat, ungrooved thresholds are needed to maintain acoustical integrity. Door details should include thresholds.					
A-6	Classroom Entry Doors Hollow Metal Frames	A912 Detail 3	Limit Noise Flanking from Corridor to Classrooms	Loosely pack hollow metal door frames with insulation (fiberglass or mineral wool) and fully seal to perimeter wall constructions with non-hardening acoustic caulk. Details should include insulation and caulking notes as appropriate.					
A -7	Classroom Entry Door/Frame Side-lite Design	A912 Detail 6	DR 1.3.1.9 Glazing Minimum STC-35 Rating Required	Design to include minimum 1/4-inch thick laminated glass.					
A-8	Cafeteria 102 Below Classrooms 204, 206, & 208	A801 and A900	DR 5.4.1, B.6 Acoustical Ceiling	2'x4' ceiling tile should be specified with the following minimum acoustic ratings: NRC 0.90 and CAC 40. Consider the following vendors/products:					

Action Item Ref	Description	Drawings / Ref	Issue Tile Requirements	Action Required • Armstrong "Lyra High CAC" (model #8732). • CertainTeed "Adagio" (model #1660-IOF-1). • Rockfon "Sonar dB". Throughout the footprint of the Cafeteria, provide minimum 3-inch thick, 2.5 pcf density mineral wool loose laid over the top of the ceiling tile. Architect to review weight limit requirements of acoustic ceiling tile and grid system and modify as necessary to account for the added weight. Design to include minimum 3-inch thick 2.5 pcf.
A-9	Boiler Room 510 Above Classrooms 410 & 412	A804	DR 1.3.1.9 Floor/Ceiling Assembly Airborne STC-60 Rating Required	density mineral wool batt insulation above acoustic ceiling tile (ACT). Architect to review weight limit requirements of acoustic ceiling tile and grid system and modify as necessary to account for the added weight.
			STRUCTURAL	
S-1	5th Floor Boiler Room Equipment Boilers, Pumps, Heat Exchangers, Hot Water Heaters, etc.	S105	Housekeeping Pads not Shown on Drawings	Structural drawings to include the location of housekeeping pads as coordinated with architectural and mechanical drawings.
			MECHANICAL	
M-1	VAV Boxes Discharge Air Silencer Selection/Dynamic Insertion Loss (DIL) Values	M101-M105	DR 6.2.25 Meeting Background HVAC Design Goals in Classrooms/Library/ CSD Rooms	The following octave band DIL's are required: Freq. 63 125 250 500 1k 2k 4k 8k DIL 10 11 13 17 24 31 18 10 DIL values are based on Vibro-Acoustics ultra-low velocity rectangular film lined silencer (Model: RFL-ULV-AC4). Silencer length = 3-ft and pressure drop = 0.11 inch w.g. See attached Markup of the Duct Silencer Schedule on M002.00.
М-2	AHU-1 Return Air Noise	M105	DR 6.2.25 Meeting Background HVAC Design Goals in Classrooms	Add 1-inch thick acoustical lining* for minimum 20 feet downstream of AHU return duct opening. *Note: Lining shall adhere to SCA criteria including: (1) meeting ASTM C1338, G21, and G22 properties and (2) coated with an acrylic polymer. Liners that meet these criteria include Johns Manville "Linacoustic R-300", CertainTeed "ToughGard T Textile Liner", or similar.
M-3	Volume Damper Design Classrooms, Reading/Speech Room, Library, Exercise Room, Offices, and Cafeteria	M101-M105	DR 6.2.25 Limit Aerodynamically Generated Noise	Locate volume dampers (and other balancing/control dampers) a minimum of four (4) duct diameters up- stream of all supply/return air terminal grilles, registers, and diffusers. Subsequent drawing set should clearly indicate volume dampers.
M-4	Classrooms, Reading/Speech Room, Library, Exercise Room, Offices, and Cafeteria	M101-M105 Ref: M501	Flexible Ducts Diffusor Noise/Poor Air Distribution Profile	Improperly designed/installed flexible duct can increase background noise levels anywhere from 12-15 decibels. Flexible duct should be no greater than 5 feet length (preferably 3 feet) and should be specified as non- metallic type (e.g., Flexmaster USA Type 6B). For coordination purposes, include attached Sketch 170293-01.
M-5	AHU-1 44"x24" Supply Air & 50"x24" Return Air Ducts	M105	DR 6.2.25 Controlling Break- Out Noise in 5th	In lieu of lighter 22/20-guage ducts, all main supply and return ducts located within the footprint of the classroom to include minimum 18-gauge sheetmetal.

Action Item Ref	Description	Drawings / Ref	Issue	Action Required
			Floor Classrooms	For coordination purposes, include a note on M105.
M-6	Exhaust Fan Ductwork		DR 6.2.25 Controlling Break- Out Noise in 5th Floor Classrooms	Refer to Action Item M-5.
М-7	Rooftop Mounted Downblast/Upblast Exhaust Fans Located Above Classroom(s)	M504 "Roof Exhaust Fan Detail"	Structureborne/ Vibration Isolation	In lieu of a pre-fabricated non-isolated curb, consider including vibration isolated curbs similar to Kinetics "KSCR" (see attached cutsheet) or equal. These curbs have been successfully used in this application by the vendor.
		5	SPECIFICATION	s
Spec-1	Wood Doors	08210	Meeting DR 1.3.1.9 STC-35 Requirement	
Spec-2	Vibration Isolation	15504	Coordination	See attached specification markups.
Spec-3	Packaged Modular Outdoor Chillers	15660	NYC Noise Code	

If you have any questions, please do not hesitate to contact me at <u>mmanis@akrf.com</u> or 646-388-9553.

Sincerely,

Matthew Marino

Matthew Manis Technical Director – Acoustics, Noise & Vibration

cc: Wai Yin / Mitchell | Giurgola Architects, LLP Yuriy Shiller, Arkady Kats, Jose Valencia / DVL Consulting Engineers Andre Brzozowski, Marco Coco / Thornton Tomasetti Lucas Johnson / AKRF, Inc.

Mark-up)S
---------	----

	DUCT SILENCER SCHEDULE																		
	Octave Band - Hz / Dynamic Insertion Loss (dB)											JCT ISIONS N.)							
						OCTAV	E BAND						1		PRESSUR	SILENCER	MAX.		
			1	2	3	4	5	6	7	8	-		UNIT		E	FACE	FACE		
UNIT NO	SERVICE	LOCATION	67	1.25	CENT	ER FRE	QUENCY	(HZ)	4000	8000	WIDTH	UFICUT	LENGTH	OFM	DROP(IN.	AREA	VELOCITY	NODEL	MANUEACTURER
ST-1R	AHU-1	504	3	4	230	12	16	18	12	5000	50	24	36	9730	0.05	8.33	1168	REL-HV-E7	VIRRO-ACOUSTICS
ST-1S	AHU-1	506	2	3	6	11	15	18	12	5	52	30	36	11000	0.04	10.83	1016	RFL-HV-F7	VIBRO-ACOUSTICS
ST-2RA	AHU-2	512	4	5	10	17	15	13	10	6	24	10	36	920	0.02	1.67	551	RFL-MHV-F4	VIBRO-ACOUSTICS
ST-2RB	AHU-2	510	3	4	9	16	19	15	11	7	24	10	36	650	0.01	1.67	389	RFL-MHV-F4	VIBRO-ACOUSTICS
ST-2RC	AHU-2	FOURTH FLOOR SHAFT	3	4	9	16	19	19	13	6	36	24	36	7550	0.10	6.00	1258	RFL-MHV-F7	VIBRO-ACOUSTICS
ST-2SA	AHU-2	516	2	4	9	16	16	15	11	6	22	14	36	2220	0.07	2.14	1037	RFL-MHV-F5	VIBRO-ACOUSTICS
ST-2SB	AHU-2	410	1	3	6	10	14	20	17	8	30	14	36	3700	0.07	2.92	1267	RFL-HV-F7	VIBRO-ACOUSTICS
ST-2SC	AHU-2	FOURTH FLOOR SHAFT	2	3	8	15	18	19	13	6	36	24	36	5730	0.06	6.00	955	RFL-MHV-F7	VIBRO-ACOUSTICS
ST-3R	AHU-3	501	3	5	11	15	14	13	12	8	28	14	36	2000	0.04	2.72	735	RFL-MHV-F2	VIBRO-ACOUSTICS
ST-3S	AHU-3	FIFTH FLOOR SHAFT	1	3	6	10	14	20	17	8	30	22	36	4800	0.05	4.58	1048	RFL-HV-F8	VIBRO-ACOUSTICS
ST-VAV-BOX	VAV BOX	MULTIPLE	2	4	-9	17	-15	-13	10	-5	24	12	36	900	0.11	2.00	450	RFL-ULV-AC4	VIBRO-ACOUSTICS
			10	11	13	17	24	31	18	10									

05/15/15

DESIGN NO.



PART 1 - GENERAL

1.01 DESCRIPTION OF WORK

A. Provide all interior flush wood doors with wood veneer, factory-finished, prefit and premachined as indicated on the Drawings and as specified herein.
 B. Reference Specification: 08730: Thresholds, Weatherstripping and Seals

1.02 SUSTAINABILITY REQUIREMENTS

- A. Sustainability requirements included in the Section are as follows:
 - Restrictions on the use of urea-formaldehyde containing materials.
- B. The Contractor shall implement practices and procedures to meet the Project's sustainable requirements. The Contractor shall ensure that the requirements related to these goals, as defined in Specification Section S01352, Sustainability Requirements, and as specified in this Section, are implemented to the fullest extent. Substitutions or other changes to the work shall not be proposed by the Contractor or their sub-contractors if such changes compromise the stated Sustainable Design Performance Criteria.

1.03 <u>REFERENCES</u>

- A. References and industry standards listed in this Section are applicable to the Work. Unless more restrictive criteria or differing requirements are explicitly stated in the Specifications, or mandated by governing codes or regulations, the recommendations, suggestions, and requirements described in the referenced standards shall be deemed mandatory and applicable to the Work.
 - Architectural Woodwork Institute's (AWI) Architectural Woodwork Standards (AWS) Section 9 Doors, Section 5 Finishing, Section 4 Sheet products.

WOOD DOORS 08210 - 1

NYCSCA

05/15/	15	DESIGN N	ю
		With the written permission of the Ar sample doors may be incorporated in finished work.	chitect, nto the
		 Perforated Metal panels - 12" by 12" sample with frame and finish. 	corner
		5. Door Louver.	
	D.	Quality Assurance Certifications (per Par. 1.05	c.)
ASTM E90 -	E	Warranty per Article 1.08	luding all scheduled
	F.	Certification and classroom entry per	rimeter sound seals, d automatic drop ttoms
	G.	STC test certificate for acoustical doors.	
	н.	1. Classroom entry doors to achieve minimum STC 35.	
		 Provide documentation for each adhesive to be used indicating that the adhesi glues comply with V.O.C. requirements as in Specification Section G01600. 	and glue .ves and s stated
	I.	Sustainability Submittals	
		 Submit manufacturer's documentation composite wood doors used withit 	that in the

weatherproofing/waterproof membrane (interior) of the building are manufactured without the use of any added urea-formaldehyde. This requirement includes binders, and laminating adhesives used in the shop. Submit manufacturer's documentation of the resin used in lieu of urea-formaldehyde.

1.05 QUALITY ASSURANCE

A. Standards

Unless otherwise specified, comply with the applicable requirements of the "Architectural Woodwork Standards (2009)" (AWS), Sections 4, 5 and 9, Premium Grade.

B. Manufacturer

Minimum 5 years successful experience in manufacturing the type of doors specified.

NYCSCA

WOOD DOORS 08210 - 3

05/15/15

D. Transom and Side Panels

Panels of identical quality and appearance as associated wood doors where panels are indicated in the same framing system as wood doors.

E. Acoustical Doors

Doors shall comply with all applicable requirements for solid core flush interior doors and in addition shall comply with requirements as hereinafter specified. including seals and

Thickness: 1³/₄".

- frame
- STC for operable leaf: 35 , tested in accordance with ASTM E90. Submit test report to the Authority.
- 3. Finish of door: as indicated on the Drawings.
- Contractor shall submit letter to the Authority indicating that the acoustical door proposed will be installed per manufacturer's recommendations to provide acoustical rating range noted above.
- Acoustical seal set

Perimeter seal provided to meet specified acoustical rating. Finish to match door hardware.

- Threshold Seal: Plunger operated, self-retracting neoprene gasket sweep. Mechanism to be completely housed in bottom of door.
- Door with vision panel
 - a) Provide factory installed lite to meet specified acoustical rating
 - or
 - b) Provide cutout for glazing to receive noise reducing glass as specified under Section 08800.

c) Classroom entry doors with vision panel to achieve minimum STC 35.

WOOD DOORS 08210 - 9

NYCSCA

04/30/18 (60% CD)

C. Vibration isolation equipment installed outdoors shall be designed and installed to resist wind loads in accordance with the NYC Building Code.

3.02 SUPPLEMENTAL INSTALLATION

- A. At each equipment location, provide the required deflection under the imposed load to produce uniform loading and deflection even when equipment weight is not evenly distributed. Jack inertia blocks and bases into position and wedge in place before spring loading; leveling bolts shall not be used as jacking screws. After equipment is in place and springs are loaded through leveling bolts, remove wedges and jacks. Isolators shall be suitable for the lowest operating speed of the equipment.
- B. Where the floor is waterproofed or finished with waterproof cement, install vibration isolation in such manner that the waterproofing is not damaged.
- C. Isolation equipment shall be in accordance with the following table:

Lowest RPM	Inches Deflection (Min.)	<pre>% Efficiency (Min.)</pre>	Туре
1750 & over	.25	95	Single neoprene- in-shear
1200-1749	.50	95	Double neoprene- in-shear
1000-1199 570-999	.75 1.25	95 90-95	Spring Spring
520-569	1.5	90	Spring
330-519	2.0	80-90	Spring
Up to 329	3.5	80	Spring
VFD	4.0	80	Spring

NYCSCA PS347X

VIBRATION ISOLATION 15504 - 5

requirement with isolators internal to the container providing the isolators meet the above minimum isolator efficiencies.

- J. Per Section MC 928.3.5, all pumps of 3 horsepower or more located on any floor other than a floor on grade shall be supported on vibration isolators having a minimum isolation efficiency of 90 percent at the lowest disturbing frequency. Each isolator shall incorporate a leveling device and a resilient pad having a minimum thickness of 1/4".
- K. Per Section MC 928.3.6, compressors and drives located on a floor other than a floor on grade shall be mounted on vibration isolators having a minimum isolation efficiency of 90 percent at the lowest disturbing frequency. Each isolator shall incorporate a leveling device and a resilient pad having a minimum thickness of 1/4".
- L. Duct Connections to Fan Equipment: As per Section MC 928.3.9, flexible connections shall be installed between fan equipment and connecting ductwork.

3.03 SCHEDULE

A. Provide vibration isolation supports for HVAC equipment as indicated in this schedule. Contractor shall submit a schedule for approval by Engineer of Record indicating the type of support for each item of Plumbing & Drainage Equipment and each item of Electrical Equipment.

Equipment	Location	Type of Support
Air Handling Unit	roof mounted	springs on elevated steel platform
Chiller	roof mounted	springs on elevated steel platform
Fans	mounted above grade	Springs on Integral Structural Steel Base
Pump, 3 H.P. or more	upper floor	inertia block
Pipe, refrigerant	equipment room	spring and D.D.* hanger
Pipe, hot and/	at pumps	spring and D.D.*

NYCSCA PS347X

VIBRATION ISOLATION 15504 - 8

or chilled	water	hanger
VAV Box	Celling Hung	spring and D.D. hanger
	*D.D. =	Double Deflecting
Heat Exchangers	Mounted	Elastomer pad isolator

3.04 FIELD QUALITY CONTROL

A. On completion of the vibration isolation system herein specified, the representative of the vibration isolation manufacturer shall inspect the completed systems and report in writing any installation error, improperly selected isolation devices, or any other faults that could affect performance. Submit report indicating steps taken to properly complete the isolation work. Both of these reports shall be reviewed by the Authority for final approval.

END OF SECTION

NYCSCA PS347X

04/30/18 (60% CD)

- G. All warranties signed by the Manufacturer specified in this Section
- H. Maintenance materials
- Start-up service reports
- J. Operation and Maintenance Data: Submittals shall include all the required refrigeration equipment including the Operation and Maintenance manuals; and the maintenance data specified in Section 15501.
- K. Certificate: Contractor's start-up and demonstration

L. Manufacturer's Octave Band Sound Pressure Level at 30-feet.

1.05 SUPPLEMENTAL QUALITY ASSURANCE

- A. Codes and Standards
 - Capacity ratings shall be in accordance with ARI 550/590 Standard.
 - Refrigeration system shall be constructed in accordance with ASHRAE 15-2010: Safety Standard for Refrigeration Systems as modified by NYC Mechanical Code Chapter 11.
 - Packaged air cooled modular chiller shall meet the minimum COP/Efficiency levels as prescribed in the 2016 New York City Energy Conservation Code and ASHRAE 90.1-2013 as modified by Appendix CA of the 2016 NYCECC at both full load and partial load (i.e. Integrated Part Load Value-IPLV).
 - All electrical components shall be UL or ETL listed and labeled. Wiring internal to the unit shall be wired to a numbered terminal strip for simplified identification and ease of trouble shooting.
 - Comply with the 1990 Clean Air Act and all other Federal, State and City Codes and Regulations.
 - 6. NFPA latest recommendations.
 - B. Permits necessary for work in connection with the installation of the refrigeration equipment and the operation thereof shall be obtained by the Contractor, free of charge to the Authority, from the Department of Buildings, Fire Department, Department of Buildings Electrical

NYCSCA PS347X

PACKAGED MODULAR OUTDOOR CHILLERS 15660 - 4

independent of other circuits from a refrigeration and electrical stand-point. The multi-circuit chiller must be able to produce chilled water even in the even of a failure of one or more refrigerant circuits.

- H. Chiller Modules shall be ETL listed or UL listed in accordance with UL Standard 1995, CSA certified per Standard C22.2#236, and bear the ASME UM stamp on all water-torefrigerant heat exchangers.
- Modules shall ship wired and charged with refrigerant. All modules shall be factory run tested prior to shipment.
- J. Compressors, heat exchangers, condenser fans, piping and controls shall be mounted on a heavy gauge steel frame. Electrical silencer, upper frame shall be m silencer, upper frame provided wi acoustic intake louvers outdoor use and acoustic corrosion r compressor wraps nish.
- K. The maximum sound pressure level in dB re 20 µPa at a distance of 30 feet from the combination of all chiller modules shall be as follows:

Center Frequency (Hz)	63	125	250	500	1000	2000	4000	8000	Overall
Band Designation	1	2	3	4	5	6	7	8	dBA
Db	63	67	65	59	52	50	46	38	61

2.02 MODULAR CHILLER COMPONENTS

- A. Chilled Water Mains: Each module shall include supply and return mains for chilled water. Grooved end connections shall be provided for interconnection to piping with Victaulic type couplings.
- B. Evaporators: Each evaporator shall be a brazed plate heat exchangers constructed of 316 stainless steel; designed, tested, and stamped in accordance with ASME code for 360 psig water-side working pressure. Evaporator heat exchanger shall not be mounted above the compressor, to prevent the effect of migration of refrigerant to the cold evaporator with consequent liquid slugging on start-up.
- C. Compressor: Each module shall contain two hermetic scroll compressors mounted to the module with rubber-in-shear

NYCSCA PS347X

PACKAGED MODULAR OUTDOOR CHILLERS 15660 - 8

04/30/18 (60% CD)

Each scroll compressor to be acoustically wrapped.

LLW No.: 107340

isolators. V Each system shall also include high discharge pressure and low suction pressure safety cut-outs. Compressor motors shall not exceed 15 Hp.

- D. Condenser Fans: Each module shall contain dual condenser fans for each refrigerant circuit. These fans shall be multi-blade vane-axial type made of plastic composite material for quiet operation. Fans shall be direct drive at maximum RPM of 1,150. Fan motors shall all be pressure controlled and suitable for outdoor use.
- E. Low Ambient to 0°F: Chiller shall incorporate appropriate refrigerant specialties for operation to 0°F.
- F. Single point power connection: Chiller shall be provided with a single point power connection. This will include pre-engineered wiring for field installation and connection to a factory mounted chiller junction box. Junction box shall include individual circuit protection for each Module Set and provide a single point of connection to building power.
- G. Condenser Coils: Air cooled condenser coils shall have aluminum fins mechanically bonded to copper tubing. Condensers shall have integral sub-cooling circuitry and be factory leak tested.
- H. Per Section MC 1101.12, refrigerant circuit access ports located outdoors shall be fitted with locking-type tamperresistant caps requiring a special tool or key to open.

2.03 I. Provide manufacturer recommended fan discharge silencers and acoustic intake louvers to achieve maximum permissible sound pressure levels at 30 feet according to section 2.01.K.

- A. Each chiller module safety controls shall be provided (minimum) as follows:
 - 1. Low evaporator refrigerant pressure
 - 2. Loss of water flow through the evaporator
 - 3. High condenser refrigerant pressure
 - 4. High compressor motor temperature
 - 5. Low suction gas temperature
 - 6. Low leaving evaporator water temperature

PACKAGED MODULAR OUTDOOR CHILLERS 15660 - 9

NYCSCA PS347X

Acoustical 100% review:



440 Park Avenue South 7th Floor New York, NY 10016 tel: 212 696-0670 fax: 212 213-3191 www.akrf.com

July 30, 2018

John Doherty, AIA Mitchell | Giurgola Architects, LLP 630 Ninth Avenue, Suite 711 New York, NY 10036

Re: PS 347X Standalone Annex – Bronx, New York 100% Construction Documents Drawing Submission – Acoustical Review Report

Dear Mr. Doherty:

AKRF has completed a review of the PS 347X project 7/09/18 100% Construction Design architectural, structural and mechanical drawings package. Acoustical comments related to architectural, structural and MEP issues for the project are outlined below.

Action Item		Drawings /			
Ref	Description	Ref	Issue	Action Required	
		A	ARCHITECTURA	L	
A-1	Reading/Speech Resource Room (205) Partition Type K0.2	A102	Elevator Shaft Wall and Structure-borne	Consider a free-standing stud (i.e., no bracing back to elevator shear wall) with a minimum 1/2-to-1-inch air gap separating the elevator shaft wall from the metal stud.	
A-2	CSD Special Education (505) Partition Type K0.2	A105	Noise	Refer to Action Item A-1	
A-3	Classroom Entry Doors Minimum STC-35 Rating Required	A910 and A911	Door Schedule/ STC Rating Coordination	Include "Min. STC 35" note in the Door Schedule "Remarks."	
A-4	Classroom Entry Doors Head/Jamb/Door Bottom Sound Seals Required	A912 Detail 3	Door Details/ Acoustic Sound Seal Coordination	Details should include sound seals at the head, jamb, and door bottom locations.	
A-5	Classroom Entry Doors Hollow Metal Frames	A912 Detail 3	Limit Noise Flanking from Corridor to Classrooms	Loosely pack hollow metal door frames with insulation (fiberglass or mineral wool) and fully seal to perimeter wall constructions with non-hardening acoustic caulk. Details should include insulation and caulking notes as appropriate.	
A-6	Classroom Entry Door/Frame Side-lite Design	A912 Detail 2	DR 1.3.1.9 Glazing Minimum STC-35 Rating Required	Design to include minimum 1/4-inch thick laminated glass.	
STRUCTURAL					
S-1	5th Floor Boiler Room Equipment Boilers, Pumps, Heat Exchangers, Hot Water	S105	Housekeeping Pads not Shown on Drawings	Structural drawings to include the location of housekeeping pads as coordinated with architectural and mechanical drawings.	

New York City • Hudson Valley Region • Long Island • Baltimore / Washington Area • New Jersey• Philadelphia

Action Item Ref	Description	Drawings / Ref	Issue	Action Required
	Heaters, etc.			
			MECHANICAL	
M-1	Classrooms 504 & 506 AHU-1 44"x24" Main Supply Air Duct Above ACT / Occupied Spaces	M105	Excessive Velocity Noise ASHRAE Noise & Vibration Control Guidelines	Calculations indicate velocities are approximately 1,600 feet / minute. Maximum duct airflow velocities should be no greater than 1,500 feet / min. for all classroom spaces with a NC 35 background design goal. DVL to explore if 44"x24" ducts can be enlarged to 48"x24".
M-2	Classrooms, Reading/Speech Room, Library, Exercise Room, Offices, and Cafeteria	M101-M105 Ref: M501	Flexible Ducts Diffusor Noise/Poor Air Distribution Profile	Flexible duct should be no greater than 5 feet length (preferably 3 feet) and should be specified as non- metallic type (e.g., Flexmaster USA Type 6B). Include Sketch 170293-01 onto the appropriate mechanical details sheet or add a general note on Sheets M101- M105.

2

If you have any questions, please do not hesitate to contact me at mmanis@akrf.com or 646-388-9553.

Sincerely,

Matthew Marins

Matthew Manis Technical Director – Acoustics, Noise & Vibration

cc: Wai Yin / Mitchell | Giurgola Architects, LLP Yuriy Shiller, Arkady Kats, Jose Valencia / DVL Consulting Engineers Andre Brzozowski, Marco Coco / Thornton Tomasetti Lucas Johnson / AKRF, Inc.

Acoustical Compliance Memo:



7th Floor New York, NY 10016 tel: 212 696-0670 fax: 212 213-3191 www.akrf.com

Memorandum

To:	Wai-Yin Leung / Mitchell Giurgola Architects LLP
From:	Lucas Johnson
Date:	September 11, 2018
Re:	SCA PS347X - Green School Guide (GSG) Compliance
cc:	John Doherty / Mitchell Giurgola Architects LLP Matthew Manis / AKRF, Inc.

ARKF has reviewed the Bid Documents set dated 8/24/18 with regard to NYC GSG Credits Q8.1p (Minimum Acoustical Performance), Q8.2 (Sound Isolation for Special Space), and Credit Q8.3 (Acoustic Windows).

The project has been designed to meet all acoustical goals with regards to reverberation times, interior/exterior sound isolation, background sound level goals (Q8.1p), sound isolation for special spaces (Q8.2) and acoustic windows (Q8.3). All previous acoustical comments/recommendations have been incorporated into the Bid Set submission.

Lucas Johnem

Lucas Johnson Acoustical Consultant

*

Q8.3: Window Acoustical Laboratory Test Report



AAMA 1801 SOUND TRANSMISSION LOSS TEST REPORT

Rendered to:

GRAHAM ARCHITECTURAL PRODUCTS INC.

SERIES/MODEL: 6800

TYPE: Fixed Over Hopper Window

Summary of Test Results						
Data File No.	Glazing (Nominal Dimensions)	*Operating Force	**Air Infiltration	STC	OITC	
D6519.01A	Primary 1" IG (5/16" laminated, 3/8" air space, 5/16" laminated), Secondary 5/16" laminated, Glass temperature 75°F	Pass	Pass	48	37	

*The maximum allowable operating force, according to AAMA/WDMA/CSA 101/1.S.2/A440, is 30.35 lbs for AW performance class, fixed over hopper windows.

**The maximum allowable air leakage rate, according to AAMA/WDMA/CSA 101/1.S.2/A440-11, is 0.10 cfm/ft² when the test pressure is 6.27 psf for AW performance class, fixed over hopper windows.

Reference should be made to Architectural Testing, Inc. Report No. D6519.01-113-11 for complete test specimen description. The complete test results are listed in Appendix B.

130 Derry Court York, PA 17406-8405 phone: 717-764-7700 fax: 717-764-4129 www.archtest.com



ACOUSTICAL PERFORMANCE TEST REPORT

Rendered to:

GRAHAM ARCHITECTURAL PRODUCTS INC. 1551 Mount Rose Avenue York, Pennsylvania 17403

Report No:	D6519.01-113-11
Test Date:	03/27/14
Report Date:	04/09/14
Record Retention End Date:	03/27/18

Test Sample Identification:

Series/Model: 6800

Type: Fixed Over Hopper Window

Performance Class: AW

Overall Size: 48" by 72"

Glazing (Nominal Dimensions):

Primary: 1" IG (5/16" Laminated, 3/8" Air Space, 5/16" Laminated)

Secondary: 5/16" Laminated

Glass Temperature: 75°F

Project Scope: Architectural Testing, Inc. was contracted by Graham Architectural Products Inc. to conduct operating force, air leakage, and sound transmission loss tests on a Series/Model 6800, fixed over hopper window. A summary of the results is listed in the Test Results section, and the complete test data is included as Appendix B of this report. The sample was provided by the client.

Test Methods: The acoustical test was conducted in accordance with the following:

AAMA 1801-11, Voluntary Specification for the Acoustical Rating of Windows, Doors, and Glazed Wall Sections. ASTM E 1425-07, Standard Practice for Determining the Acoustical Performance of Exterior Windows and Doors. ASTM E 90-09, Standard Test Method for Laboratory Measurement of Airborne Sound Transmission Loss of Building Partitions. ASTM E 413-10, Classification for Rating Sound Insulation.

Test Methods: (Continued)

ASTM E 1332-10a, Standard Classification for Rating Outdoor-Indoor Sound Attenuation. ASTM E 283-04 (Reapproved 2012), Standard Test Method for Determining Rate of Air Leakage Through Exterior Windows, Curtain Walls, and Doors Under Specified Pressure Differences Across the Specimen. ASTM E 2235-04 (Reapproved 2012), Standard Test Method for Determination of Decay Rates for Use in Sound Insulation Test Methods.

ASTM E 2068-00 (Reapproved 2008), Standard Test Method for Determination of Operating Force of Sliding Windows and Doors.

Test Equipment: The equipment used to conduct this test meets the requirements of ASTM E 90. The microphones were calibrated before conducting the sound transmission loss test. The test equipment and test chamber descriptions are listed in Appendix A.

Sample Installation: Sound transmission loss tests were initially performed on a filler wall that was designed to test window specimens. The filler wall achieved an STC rating of 69.

The specimen plug was removed from the filler wall assembly. The window was placed on an isolation pad in the test opening. Duct seal was used to seal the perimeter of the window to the test opening on both sides. The interior side of the window frame, when installed, was approximately 1/4" from being flush with the receiving room side of the filler wall. A stethoscope was used to check for any abnormal air leaks around the test specimen prior to testing. The vent was opened and closed at least five times prior to testing.

Test Procedure:

Operating Force Test - The Type B method, which utilizes a force gauge, was used to determine the breakaway and operating forces required to open and close the vent.

Air Leakage Test - The window was closed and locked for this test. A negative pressure of 6.27 psf was applied inside the chamber that was placed around the interior side of the window. The total air leakage and extraneous air leakage measurements were used to calculate the specimen air leakage. Barometric pressure corrections were applied to the air leakage calculations.

Sound Transmission Loss Test - The window was also closed and locked for this test. The sound transmission loss test was conducted in accordance with the ASTM E 90 test method using a single direction of measurement. The sound transmission loss test consisted of the following measurements: one background noise sound pressure level and five sound absorption measurements were conducted at each of the five microphone positions. Two sound pressure level measurements were made simultaneously in both rooms at each of the five microphone positions. The air temperature and relative humidity conditions were monitored and recorded during the background, absorption, source, and receive room measurements.
Sample Descriptions:

Frame Construction:

		Frame	
Size		48" by 72"	
Thickness		3-1/2"	
Co	rners	Coped	
	Fasteners	Screws	
	Seal Method	Sealant	
Ma	terial	Aluminum	
	Reinforcement	N/A	
	Thermal Break Material	Urethane	
Daylight Opening Size		43-1/8" by 37-7/16"	

Vent Construction:

		Vent
Size		48" by 72"
Thickness		3-1/2"
Co	rners	Mitered
	Fasteners	Keyed and staked
	Seal Method	Sealant
Ma	terial	Aluminum
	Reinforcement	N/A
	Thermal Break Material	Urethane
Daylight Opening Size		40-5/16" by 24-3/16"

N/A-Non Applicable

Sample Descriptions: (Continued)

Secondary Access Panel Construction:

		Panel
Size		43-1/4" by 37-7/8"
Thickness		1/2"
Co	rners	Mitered
	Fasteners	Screws
	Seal Method	None
Ma	terial	Aluminum
	Reinforcement	N/A
	Thermal Break Material	N/A
Daylight Opening Size		40-1/2" by 35-1/16"

Primary Fixed Glazing:

Measured Overall Insulation	0.931"				
Spacer Type			Aluminum		
	Exterior Sheet	Gap	Interior Sheet		
Measured Thickness	0.116", 0.058", 0.116"	0.352"	0.116", 0.057", 0.116"		
Muntin Pattern	N/A	N/A	N/A		
Material	Laminated	Air*	Laminated		
Laminate Material	PVB N/A		PVB		
Glazing Method		Interior			
Glazing Material	Glazing Material				
Glazing Bead Material	Aluminum				

* Stated per Client/Manufacturer, N/A-Non Applicable

Sample Descriptions: (Continued)

Primary Vent Glazing:

Measured Overall Insulation	1.014"			
Spacer Type		Aluminum		
	Exterior Sheet	Gap	Interior Sheet	
Measured Thickness	0.116", 0.059", 0.116"	0.432"	0.116", 0.059", 0.116"	
Muntin Pattern	N/A	N/A	N/A	
Material	Laminated	Air*	Laminated	
Laminate Material	PVB N/A		PVB	
Glazing Method		Interior		
Glazing Material		Silicone		
Glazing Bead Material	1	Aluminum		

Note: Glass-to-glass air space was 1-9/16".

Secondary Glazing:

	Exterior Sheet
Measured Thickness	0.116", 0.059", 0.116"
Muntin Pattern	N/A
Material	Laminated
Laminate Material	PVB
Glazing Method	Channel

* Stated per Client/Manufacturer, N/A-Non Applicable

Sample Descriptions: (Continued)

Components:

	TYPE	QUANTITY	LOCATION		
We	Weatherstrip				
	1/8" Hollow bulb gasket	1 Row	Jambs at secondary panel		
	1/4" Hollow bulb gasket	1 Row	Primary frame: Head, sill and intermediate at secondary panel		
	1/4" Hollow bulb gasket	2 Rows	Vent perimeter (3" cut out at stiles top corner of exterior row)		
Ha	rdware				
-	Multi-point hinge	2	Jambs at vent		
	Sweep lock	2	Vent top rail		
	Keeper	2	Intermediate at vent		
	Sweep lever	2	Secondary access panel jambs		
Dra	inage				
	Weep slot with cover	3	Sill		

Sample Weight:

Overall Semple Areas	m ²	ft ²			
Overan Sample Area:	2.23	24.00			
	Total Weight		Weight Per Unit Area		
Test Specimen	kg	1bs	kg / m ²	lbs / ft ²	
	118	260	52.91	10.84	

*- Stated per Client/Manufacturer, N/A-Non Applicable

Comments: The design drawings (included in Appendix C) supplied by the client, accurately describe the Series/Model 6800, fixed over hopper window. The dimensions on the drawings that are circled and/or checked were verified against the test specimen. The window was disassembled, and the components will be retained by Architectural Testing for four years. Photographs of the test specimen are included in Appendix D.

Test Results: The STC (Sound Transmission Class) rating was calculated in accordance with ASTM E 413. The OITC (Outdoor-Indoor Transmission Class) was calculated in accordance with ASTM E 1332. A summary of the operating force, air leakage, and sound transmission loss test results on the Series/Model 6800, fixed over hopper window is listed below.

Summary of Test Results						
Data File No.	Glazing (Nominal Dimensions)	*Operating Force	**Air Infiltration	STC	OITC	
D6519.01A	Primary 1" IG (5/16" laminated, 3/8" air space, 5/16" laminated), Secondary 5/16" laminated, Glass temperature 75°F	Pass	Pass	48	37	

*The maximum allowable operating force, according to AAMA/WDMA/CSA 101/I.S.2/A440, is 30.35 lbs for AW performance class, fixed over hopper windows.

**The maximum allowable air leakage rate, according to AAMA/WDMA/CSA 101/I.S.2/A440-11, is 0.10 cfm/ft² when the test pressure is 6.27 psf for AW performance class, fixed over hopper windows.

The complete test results are listed in Appendix B. Flanking limit tests and reference specimen tests are available upon request.

Architectural Testing will service this report for the entire test record retention period. Test records, such as detailed drawings, datasheets, representative samples of test specimens, or other pertinent project documentation, will be retained by Architectural Testing for the entire test record retention period.

This report does not constitute certification of this product nor an opinion or endorsement by this laboratory. It is the exclusive property of the client so named herein and relates only to the specimen tested. This report may not be reproduced, except in full, without the written approval of Architectural Testing.

For ARCHITECTURAL TESTING, INC:

that a. Holden

Kurt A. Golden Senior Technician - Acoustical Testing

Tork P. Kisty disc Topic Order

Todd D. Kister Laboratory Supervisor - Acoustical Testing

KAG: jmcs

Attachments (pages): This report is complete only when all attachments listed are included. Appendix-A: Equipment description (1)

Appendix-A: Equipment description (1) Appendix-B: Complete test results (4) Appendix-C: Design drawings (11) Appendix-D: Photographs (1)

Revision Log

Rev. #	Date	Page(s)	Revision(s)
0	04/09/14	N/A	Original test report

Appendix A

Instrumentation:

Manufacturer	Model	Description	ATI Number	Date of Calibration
Hewlett Packard	HP35670A	Real time analyzer	004112	06/13 *
Agilent	34970A	Data Acquisition Unit	62211	07/13
GRAS	40 AR	1/2* Microphone	Y003247	02/14
GRAS	40 AR	1/2" Microphone	Y003239	02/14
GRAS	26 AK	1/2* Preamptifier	63260	04/13
GRAS	26 A K	1/2* Preamplifier	005656	06/13
Bruel & Kjaer	Туре 4228	Pistonphone Catibrator	Y002816	02/14
Delta Electronics	SNG-1	Noise Generator	Y002181	N/A
Rane	RPE 228	Programmable Equalizer	Y002180	N/A
Crown	Xti 2000	Two, Amplifiers	005769 005770	N/A
Renkus-Heinz Inc.	Trap Jr/9	Two, Loudspeakers	Y001784 Y001785	N/A
Renkus-Heinz Inc.	Trap Jr/9	Two, Loudspeakers	Y002649 Y002650	N/A
Vaisala	HMW92	Temperature and Humidity Sensor	064286	05/13
Vaisala	HMW60Y	Temperature and Humidity Sensor	Y002653	05/13
Davis Instruments	VantagePRO 6150C	Weather Station	¥003257	06/13
Architectural Testing, Inc.	NA	Lab Pack	Y001618	02/14
Chatillon	LG-50	Force Gauge	063156	10/14
	Manufacturer Hewlett Packard Agilent GRAS GRAS GRAS GRAS GRAS Bruel & Kjaer Delta Electronics Rane Crown Renkus-Heinz Inc. Renkus-Heinz Inc. Vaisala Vaisala Davis Instruments Architectural Testing, Inc.	ManufacturerModelHewlett PackardHP35670AAgilent34970AGRAS40 ARGRAS40 ARGRAS26 A KGRAS26 A KGRAS26 A KBruel & KjaerType 4228Delta ElectronicsSNG-1RaneRPE 228CrownXti 2000Renkus-Heinz Inc.Trap Jr./9VaisalaHMW92VaisalaHMW60YDavis InstrumentsXantagePRO 6150CArchitectural Testing, Inc.NA	ManufacturerModelDescriptionHewlett PackardHP35670AReal time analyzerAgilent34970AData Acquisition UnitGRAS40 AR1/2" MicrophoneGRAS40 AR1/2" MicrophoneGRAS26 AK1/2" PreamplifierGRAS26 AK1/2" PreamplifierGRAS26 AK1/2" PreamplifierGRAS26 AK1/2" PreamplifierGRASSNG-1Noise GeneratorDelta ElectronicsSNC-1Noise GeneratorRaneRPE 228Programmable EquatizerCrownXti 2000Two, AmplifiersRenkus-Heinz Inc.Trap Jr/9Two, LoudspeakersVaisalaHMW92Temperature and Humidity SensorVaisalaKMW60YTemperature and Humidity SensorDavis InstrumentsNALab PackChatiltonLG-50Force Gauge	ManufacturerModelDescriptionATI NumberHew lett PackardHP35670AReal time analyzer004112Agilent34970AData Acquisition Unit62211Agilent34970AData Acquisition Unit62211GRAS40 A R1/2" MicrophoneY003247GRAS40 A R1/2" MicrophoneY003239GRAS26 A K1/2" Preamplifier63260GRAS26 A K1/2" Preamplifier005656Bruel & KjaerType 4228Pistonphone CalibratorY002816Delta ElectronicsSNG-1Noise GeneratorY002180CrownXti 2000Two, Amplifiers005769 005776Renkus-Heinz Inc.Trap Jr/9Two, LoudspeakersY001784 Y001785Renkus-Heinz Inc.Trap Jr/9Two, LoudspeakersY002649 Y002649VaisalaHMW60YTemperature and Humidity Sensor064286VaisalaKainage PRO Architectural Testing, Inc.NALab PackY001618ChatiltonLG-50Force Gauge063156

* Note: The calibration frequency for this equipment is every two years per the manufacturer's recommendation.

Test Chamber:

	Volume	Description
Receive Room	234 m ³ (8291.3 ft ³)	Rotating vane and stationary diffusers Temperature and humidity controlled Isotation pads under the floor
Source Room	206.6 m ³ (7296.3 ft ³)	Stationary diffusers only Temperature and humidity controlled
	Mayimum Siza	Description
	and a state	reset (prov
TI Test Openine	4.27 m (14 ft) wide by	Vibratian break between course and receive recome
TE Test Opening	3.05 m (10 ft) high	Thankin break between source and receive rooms

N/A-Non Applicable

Appendix B

Complete Test Results





SOUND TRANSMISSION LOSS ASTM E 90

-	00/07/44							
Test Date	03/2//14	03/27/14						
ATI No.	D6519.01	A	1000					
Client	Graham /	Architectura	al Products					
Specimen	Series/Me laminated	Series/Model: 6800, fixed over hopper window with Primary 1" IG (5/16" laminated, 3/8" air space, 5/16" laminated), Secondary 5/16" laminated, Glass temperature 75 °F						
Operator	Kurt Gold	len	200					
Sample Area	2.23	m ²						
Filler Area	10.77	m ²						
0	Source	Receive	Specimen					
Temp C	22	23	23					
RH %	56	51	53					

Freq	Bkgrd SPL	Absorp	Source SPL	Receive SPL	Filler	Specimen TL	95% Conf	No. of Defi-	Trans
(Hz)	(dB)	(m ²)	(dB)	(dB)	(dB)	(dB)	Limit	ciencies	Diff
80	41	5.7	93	68	33	22	2.2	0.70	5.8
100	38	6.1	99	70	39	26	3.0	22	7.9
125	39	4.8	104	68	47	33	2.3	0	7.8
160	40	4.9	105	66	48	37	1.4	0	5.7
200	34	5.1	110	73	53	34	1.1	4	11.9
250	33	5.7	110	68	57	38	0.9	3	12.0
315	29	5.6	107	62	61	41	0.8	3	13.5
400	26	5.9	106	59	66	43	0.9	4	16.4
500	22	6.1	106	58	69	44	0.6	4	18.2
630	22	6.1	110	61	72	45	0.4	4	20.2
800	18	6.2	111	59	78	47	0.4	3	23.5
1000	14	6.2	110	56	83	49	0.8	2	26.7
1250	11	6.9	110	53	86	52	0.4	0	27.9
1600	8	7.1	115	58	89	52	0.4	0	29.3
2000	6	7.6	107	50	88	52	0.2	0	29.9
2500	6	8.4	104	45	86	53	0.4	0	25.7
3150	6	9.9	105	43	86	56	0.5	0	23.8
4000	7	11.8	103	38	83	57	0.3	0	19.3
5000	7	15.1	99	32	83	59	0.6		16.9

STC Rating Deficiencies OITC Rating 48 (Sound Transmission Class)

27 (Number of deficiencies versus contour curve)

37 (Outdoor Indoor Transmission Class)

Notes:

1) Transmission loss coefficient differences less than 6 indicate the lower limit of the transmission loss for this specimen. These cells are highlighted red.

2) Transmission loss coefficient differences between 6 and 15 indicate there has been a filler wall correction applied. These cells are highlighted green.

3) Receive Room levels less than 5 dB above the background levels are highlighted in yellow.

ATI 00254 Revised 06/13/13

-								
Test Date	03/27/14	J3/27/14						
ATI No.	D6519.01	Α						
Client	Graham A	Architectura	al Products					
Specimen	Series/Mo	del: 6800,	fixed over ho	pper window with Primary 1" IG (5/16" laminated, 3/8" air space, 5/16"				
-	laminated), Seconda	uy 5/16" lamir	nated, Glass temperature 75 °F				
Operator	Kurt Gold	en						
Sample Area	2.23	m ²						
Filler Area	10.77	m ²						
	Source	Receive	Sample					
Temp C	22	23	23					
RH %	56	51	53					



Note: To obtain the Sound Transmission Class (STC), read the Sound Transmission Loss of the contour curve at 500 Hz. The sum of the deficiencies below the contour curve cannot exceed 32. The maximum deficiency at any one frequency cannot exceed 8.

ATI 00254 Revised 06/13/13

AAMA 1801 Data Sheet

ATI Job Number	D6519.01
Client Name	Graham Architectural Products Inc.
Series/Mode1	6800
Specimen Type	Fixed Over Hopper Window
Test Date	03/27/14
Tests Performed by	KAG

Air Leakage (ASTM E 283)

Specimen Area (ft ²)		24		
Test Pressure	300 pa (6.27 psf)]		
Temperature (°F)		72	1	
Barometric Pressure (ml	b)	1027]	
Air Flow (cfm)	Measured	Corrected	1	
Total	13,5	13,55	1	
Extraneous	13.25	13.30	1	
Net	0.3	0.25]	
Rate	0.01	cfm/ft2	0.1	L/s·m ²
Allowable Rate	0.10	cfm/ft ²		
Result	Pass		-	

Comments:

ATI 00010 Revised 12/17/12

ATI Job Number	D6519.01
Client Name	Graham Architectural Products Inc.
Series/Model	6800
Specimen Type	Fixed Over Hopper Window
Test Date	03/27/14
Tests Performed by	KAG

Operating Force Vent

per ASTM test method E 2068 Method B - Force Gauge

Trial No.	Opening Breakaway	Opening In-Motion	Closing Breakaway	Closing In-Motion	
1	7	7	21	19	
2	7	7	20	18	
3	7	7	21	19	
3 Trial A verage	7.00	7.00	20.67	18.67	
10% of 3 Trial Average	0.7	0.7	2.1	1.9	

Left Lever

Trial No.	Opening Breakaway	Opening In-Motion	Closing Breakaway	Closing In-Motion	
1	6	1	8	1	
2	5	1	8	1	
3	5	1	8	1	
3 Trial A verage	5.33	1.00	8.00	1.00	
10% of 3 Trial Average	0.5	0.1	0.8	0.1	

Right Lever

Trial No.	Opening Breakaway	Opening In-Motion	Closing Breakaway	Closing In-Motion	
1	7	1	10	1	
2	7	1	10	1	
3	8	1	10	1	
3 Trial A verage	7.33	1.00	10.00	1.00	
10% of 3 Trial Average	0.7	0.1	1.0	0.1	

ATI 00010 Revised 12/17/12

Appendix C

Design Drawings

				4	Architectural Testing	
Bill of	Mat	terials Per Qu	ote Item	Test samp	Deviations are noted.	•
Dill VI	wia		ole ilem	Reporta	D6519.01-113-11	_
Quote: Quote Title Customer:	-12 6800 ; GRA	7860- Ver 2 F/H Acoustic HAM	Quote Date: 1/23/201	Date 47	User.: MCOLEM	AN
Job No.:	5G88	03				
item Mark		D	escription			Quantity
	101	6 <u>(</u>	Hopper inswing	aver and the		1.00
Code: 68V1	8~1689	95490				-
Dimension:	48.000	0 x 72.0000				
Comments:						
Width Height HEAD OPTION SILL OPTION LEFT JAMB C RIGHT JAMB C RIGHT JAMB HEAD NOTCH SILL NOTCH LOCKS POLE RING LOCK TRI WI HINGE CLOS HINGE TRI WI MAGANIM LIM LIMITED OPE	N OPTION OPTION HTYPE TYPE NGS URE INGS IIT DEVI NING	CE	48.0000 72.0000 Equal Leg 2.500 Equal Leg 2.500 Universal Equal Leg 2.500 NONE NONE CAM LOCK False False False MAGNUM Falso NONE NONE			
FIXED GUARI OPERABLE G FX BLIND KN OP BLIND KN HORZ ORIEL FRAME WEIG	DIAN BUARDIA OB LOC IOB LOC	AN ATION ATION	LIFTIN LIFTIN 0.0000 (32.0000) (32.0000)			
Extrusion	Color		122/24 10	Qty.	Length Location	
650062	BL.	GUARDIAN RAIL		1.00	40.6520 guardian top	
650082	BL	GUARDIAN RAIL		1.00	40.6520 guardian bottom	
650082	BL	GUARDIAN RAIL		1.00	24.6520 guardian right	
650082	BL	GUARDIAN RAIL		1.00	24.6520 guardian left	
680008	BL	PROJECT IN SASH		1.00	45.2500 Vent Top	
80008	BL	PROJECT IN SASH		1.00	46.2500 Vent Btm	
880008	DL	PROJECT IN SASH		1.00	29.1240 Vent Right	
680010	DL BI	FROJECT IN SASH		1.00	29.1240 Vent Left	
680011	RI	FRAME IS 2 500		1.00	45.5000 HEAD	
680012	BL	IS/FX INTERMEDIATE		1.00	45 5000 EV aver 19	
680014	BL	BEAD ADAPTER		1.00	38 7510 Right Adapter	
680014	BL	BEAD ADAPTER		1.00	38,7510 Left Adapter	
680033	BL	FRAME UNV 2.500		1.00	72,0000 RIGHT JAMB	
680033	BL	FRAME UNV 2.500		1.00	72,0000 LEFT JAMB	
680037	BL	GLAZING LEG ADAPTER -	BEVELLED	1.00	38.3750 Right Adapter	
680037	BL	GLAZING LEG ADAPTER -	BEVELLED	1.00	38.3750 Left Adapter	
680057	BL	VENT LEG ADAPTER		1.00	25.8740 Right Adapter	
680057	BL.	VENT LEG ADAPTER		1.00	26.8740 Left Adapter	
680080	BL.	1 INCH BEAD HORZ FOR I	JIFTIN GUARDIAN	1.00	41.6080 Top Bead	
680080	BL	1 INCH BEAD HORZ FOR	LIFTIN GUARDIAN	1.00	41.6080 Bottom Bead	
680081	81.	1 INCH BEAD VERT FOR L	IFTIN GUARDIAN	1.00	24.2320 Right Bead	
680081	BL	1 INCH BEAD VERT FOR L	IFTIN GUARDIAN	1.00	24.2320 Left Bead	
Soft Tech V6		1/23/2014 11:09:19	Graham Archited	ctural Produc	ots Corporation	Page 3

Bill of Materials Per Quote Item

Quote: -127860- Ver 2 Quote Title: 6800 F/H Acoustic Customer: GRAHAM Job No.: 5G8803 Quote Date: 1/23/2014

User.: MCOLEMAN

Item Mark	Description				Quantity
Fil					
940935	.317 LAM (1/8 cir 060 pvb 1/8 cir)			1.00 39.0900 x 23.0900	
CG935-12-935	(Crd) 317 Lam 3/8 Sp 317 Lam (1/8 060 1/8)			1.00 41.3780 x 25.2520	
Component					
925067	VINYL SETTING TUBE 4ins	2.00	EA		
926196	Magnum Hinge 12ins 6X00	2.00	EA		
926545	(Color) HOOD WEEP COVER	3.00	EA		
926552	KEEPER INSWING - BC#210-078	2.00	EA		
926579	INSWING LOCK GASKET	2.00	ËA		
926600	STABILIZING ANGLE-PLASTIC	4.00	EΑ		
926621	HANDLE R HINGED IS - BC#158-001	1.00	EA		
926622	HANDLE L HINGED IS - BC#156-003	1.00	EA		
926842	CORNER KEY VENT (1.232 IN.)	4.00	EA		
926843	CORNER KEY VENT (.960 IN.)	4.00	EA		
929921	GUARDIAN LOCK PAWL	2.00	EA		
929922	GUARDIAN LOCK PIVOT SHAFT <650082>	2.00	EA		
930024	#10-24 X .375 PH PN TT 188	12.00	£Α	4-Bar Hinges	
930031	#8 X 1.000 TP BH TK 410	1.00	EA	Guardian Anti-lift Screw	
931920	#6-32 X .125 HX Drive Oval Point	2.00	EA	929922 Guardian Lock	
935033	#10-24 X .500 PH OV TT 188	4.00	ËA	926552 Keeper	
935033	#10-24 X .500 PH OV TT 188	4.00	EA	926621 926622 Cam Lock	
939076	#8 X 1.250 PH PN LP AB 410 (WAXED)	12.00	EA	Assembly	
939095	#6 X .750 PH PN AB 410	4.00	EA	Guardian Assembly	
939163	#10-24 KEPS NUT W/STAR 188	4.00	EA	926621 926622 Cam Lock	
939202	POP RIV 1/8D 1/4GR MF	6.00	EA	926545 Weeps	
939380	#8-32 X .500 PH PN F 410	8.00	EA	926600 Stabilizer	
939502	#10-24 X .625 SQ 8 PLN TK 3 ZP	22.00	EA	Adapter	
960335	GL CHANNEL 11/32 (FT)	10.36	FT	Guardian Channel	
960679	Rigid Back Vinyl W/ .270 Bk	28.51	FT		
962680	BULB RIGID BACK W/9-LOCK 0.187	25.24	त्त		
963451	SBLK 3/8 X 3/8 X 4	2.00	ËA		
970157	Glass Shim 1/8 x 1/8 x 1	14.00	EA		

Architectural Testing

Test sample complies with these details. Deviations are noted.

D6519.01-113-11 Report# 126. Date 4/ 8 1,4 Tech

Soft Tech V6

1/23/2014 11:09:19

Graham Architectural Products Corporation

Page 4





















D6519.01-113-11

Appendix D

Photographs



Receive Room View of Installed Specimen



Source Room View of Installed Specimen