

**Matrix of Changes to Existing RPS**

<b>Room Layout Number</b>	<b>Room Layout Name</b>	<b>Items that need to be updated</b>	<b>Change</b>	<b>Applicable specification section or detail # for GC provided item</b>
File 2-10	Art Classroom	Drinking fountain Shelving Student chair height IWB	Delete drinking fountain. Locate three 36x12x24h shelving units with epoxy resin top under interactive white board. Revise all C & D chairs to be 18" high. Modify size of IWB to 75" (71"x43") actual	Section 15440 Section 06410,11600 F & E item
File 2-20, 2-30.1, 2-32	Specialized instruction	Shelving IWB	Locate three 36x12x24h shelving units under IWB Modify size of IWB to 75" (71"x43") actual Include Dimmer switch, Daylight harvesting and switched outlets similar to that shown on classroom layout 1-17	Section 06410 F&E item Sections 16140,16145
File 4-21, 4-22, 4-24, 4-25, 4-70, 4-71, 4-90	Physical Education	Fire blanket DF/Cuspidor	Fire Blankets to be indicated as GC provided, not owner provided; similar to science room layouts that show blankets as GC provided. Cuspidors are not required. A minimum of two Drinking fountains (one with bottle filler and one without) in an alcove must be provided to meet accessibility requirements.	Section 10522 Section 15440
All Group 5 layouts	Assembly Areas	Fire blanket	Blankets to be indicated as GC provided, not owner provided; similar to science room layouts that show blankets as GC provided.	Section 10522
All Group 8, 10 and Group 12 layouts	Pupil Personnel Services Administration Plant Operations	Vertical file cabinets	Revise to lateral file cabinets in all locations. Use cabinet of approximately 30"W x 18"D in layouts.	F & E item